

Eaton UPS Flex Onsite Service Parts and Labor Coverage Scope of Work Attachment R-30

This scope of work is shared by the power quality equipment types listed in the below table. Note the applicable features vary by type of equipment being contracted and additional scopes of work may be required. All checks or processes may not be applicable to all equipment types or models.

Equipment Type	Electronics Corrective Maintenance Coverage	Battery Corrective Maintenance Coverage	Tech Support
Eaton 3 Phase UPS	Yes	No	Yes
Eaton 1 Phase UPS	Yes	Yes	Yes
Eaton DC	Yes	No	Yes
Eaton PDU/PDR/RPP/STS	Yes	No	Yes
Flywheel	Yes	No	Yes
Non Eaton equipment (MVS)	Yes	No	Yes

If optionally purchased by Customer within the first three (3) years of a Eaton® 3 Phase UPS installation date (first startup) OR,

If optionally purchased by Customer in conjunction with one or more annual on-site UPS Power Module Preventive Maintenance SOW R-2 of the same duration, Contractor will provide:

Electronics Corrective Maintenance Coverage: Inspection and repair of the electronic portion of the UPS (or other equipment type), or “Power Module” shall be performed as needed during the contracted period of maintenance at no extra charge to Purchaser. Remedial maintenance provided by Contractor shall include, and be expressly limited to, maintenance to the Power Module, travel expenses, all necessary parts replacement, adjustments and repairs. If the Purchaser maintains Eaton spare parts at the maintenance site, Contractor may, at its option, use those spare parts in the performance of Corrective Maintenance and shall replace the spare parts, which it so uses, at no cost to the Purchaser.
Exclusions: certain wear parts are excluded from electronics corrective coverage including batteries and full capacitor and full fan replacements. All Corrective Maintenance to Battery System, if any, will be in accordance with battery manufacturers’ warranty or separate agreement, if any. For Flywheel coverage: any failure due to lack of recommended bearing replacement, vacuum pump replacement (or “major maintenance” per manufacturer recommendation) will not be included under corrective maintenance coverage and will be billable at current time and material rates. Eaton 9390 and 9395 UPS models have a special policy on capacitor replacements: DC link electrolytic capacitors are eligible for inspection and repair at no extra charge (excludes AC input/output oil filled and DC oil filled battery capacitors). In the 9390 and 9395 models, only the AC input/output oil filled and DC oil filled battery capacitors will be recommended for replacement cycles (expected useful life of (7) years).



Powering Business Worldwide

1. **Battery Corrective Maintenance Coverage (Limited to 1 Phase UPS Models and BladeUPS):** Inspection and repair of the internal battery portion of the UPS (or other equipment type), or "Internal Battery" shall be performed as needed during the contracted period of maintenance at no extra charge to Purchaser. Remedial maintenance provided by Contractor shall include, and be expressly limited to, maintenance to the Internal Battery, travel expenses, all necessary parts replacement, adjustments and repairs. External battery coverage, if applicable, must be purchased separately if external batteries or battery cabinets exist.
2. **7x24 Technical Support:** technical support via telephone or email to Contractor shall be available to answer product or support questions.

The Purchaser shall, from the commencement date of the Service Agreement, maintain the UPS Power Module in accordance with the published operating specifications for the Power Module at the time of purchase. The Purchaser shall, unless otherwise specified in the Service Agreement, maintain the Battery System in strict accordance with the Battery System manufacturer's recommended maintenance guidelines.

Eaton is a trade name, trademark and/or service mark of Eaton Corporation or its subsidiaries and affiliates.