

Exhibit N

This page intentionally left blank.

PLN210202 / Abalone Creek LLC

Review comments from Monterey County Water Resources Agency

Date: November 15, 2023



This review supersedes the Agency comments dated July 10, 2023; it has been updated to reflect revised water demand estimates.

Applicant Information	
Owner Name: Abalone Creek LLC	
Well Address: 18000 Corral De Cielo, Salinas	APN: 416-441-047-000
Proposed Water Demand Information	
Pumping rate (gpm): 7.95 – average day water demand	
Proposed well depth (feet): 800	
Proposed screened interval(s) (feet): 130 to 800	


Proposed Well Impact Assessment Summary

The well impact assessment summarized below is conducted by the Water Resources Agency in fulfillment of the County's mandate to implement policies of the 2010 Monterey County General Plan and the Governor's Executive Order N-7-22.

Finding: The proposed domestic well, at its current location and with its proposed design and pumping rate, does not indicate potential for significant adverse impact to existing domestic wells, water system wells, or in-stream flows based on an assessment using regional aquifer parameters and the methodology applied to meet the criteria of PS-3.3 of the 2010 Monterey County General Plan and the requirements set forth in N-7-22.

The Water Resources Agency review of this well construction application is not an endorsement or opinion of the applicant's legal authority to use of the water extracted as a result of this application.

Reviewer: Amy Woodrow
Amy Woodrow, PG – Hydrologist



Date: November 15, 2023

This page intentionally left blank