



# DLR Group

Architecture  
Engineering  
Planning  
Interiors

---

## COUNTY OF MONTEREY NEW JUVENILE HALL

---

### Project Manual Volume 2 of 3

---

DLR Group Project No. 75-14126-00  
State Fire Marshal Reference No. 40-27-44-0011  
BSCC Reference No. 053-7346.04  
Bid Number: 10590  
Date: October 13th, 2016

ADDENDUM AND CONFORMING DOCUMENTS



**MONTEREY COUNTY**  
**RESOURCE MANAGEMENT AGENCY**

---

**PUBLIC WORKS AND FACILITIES -**  
**ARCHITECTURE**

---

**VOLUME TWO OF THREE**

**PROJECT MANUAL**

**NEW JUVENILE HALL**  
**PROJECT NO. 8811**  
**BID NO. 10590**






DOCUMENT - SEALS PAGE

1.1 DESIGN PROFESSIONALS OF RECORD

ARCHITECT **DLR Group**  
**1050 20<sup>th</sup> Street, Suite 250**  
**Sacramento, CA 95811**  
**Darrell Stelling**




CIVIL ENGINEER **Whitson Engineers**  
**9699 Blue Larkspur Lane, Suite 105**  
**Monterey, CA 93940**  
**Richard Weber**



STRUCTURAL ENGINEER **DLR Group**  
**3130 Wilshire Boulevard, 6<sup>th</sup> Floor**  
**Santa Monica, CA 90403**  
**Michael Zahn**



MECHANICAL & PLUMBING ENGINEER **DLR Group**  
**3130 Wilshire Boulevard, 6<sup>th</sup> Floor**  
**Santa Monica, CA 90403**  
**Tony Cocea**



ELECTRICAL  
ENGINEER

**DLR Group**  
**3130 Wilshire Boulevard, 6<sup>th</sup> Floor**  
**Santa Monica, CA 90403**  
**Zoheir Guemmat**



LOW VOLTAGE  
ENGINEER /  
SECURITY

**R&N System Design, LLC**  
**9053 Stone Walk Place, Suite 201**  
**Germantown, TN 38138**  
**Frank Niedzwiedz**



END OF DOCUMENT 000107

## TABLE OF CONTENTS – Volume 2 of 3 (Divisions 01-22)

### DIVISION 01 - GENERAL REQUIREMENTS

Section 01 1000	Summary
Section 01 2200	Unit Prices
Section 01 2300	Alternates
Section 01 2500	Substitution Procedures
Section 01 2600	Contract Modification Procedures
Section 01 2900	Payment Procedures
Section 01 3100	Project Management and Coordination
Section 01 3200	Construction Progress Documentation
Section 01 3233	Photographic Documentation
Section 01 3300	Submittal Procedures
Section 01 3333	Electronic Drawings
Section 01 3513.16	Special Project Procedures for Detention Facilities
Section 01 4000	Quality Requirements
Section 01 4200	References
Section 01 5000	Temporary Facilities and Controls
Section 01 4000	Quality Requirements
Section 01 5723	Temporary Storm Water Pollution Control
Section 01 6000	Product Requirements
Section 01 7123	Field Engineering
Section 01 7300	Execution
Section 017419	Construction Waste Management and Disposal
Section 01 7700	Closeout Procedures
Section 01 7823	Operation and Maintenance Data
Section 01 7839	Project Record Documents
Section 01 7900	Demonstration and Training
Section 01 8113.14	Sustainable Design Requirements – LEED v4 BD+C
Section 01 9113	General Commissioning Requirements

### DIVISION 02 - EXISTING CONDITIONS

Section 02 4116	Structure Demolition
Section 02 4119	Selective Demolition

### DIVISION 03 - CONCRETE

Section 03 3000	Cast-In-Place Concrete
-----------------	------------------------

### DIVISION 04 – MASONRY

Section 04 2200	Concrete Unit Masonry
-----------------	-----------------------

### DIVISION 05 – METALS

Section 05 1200	Structural Steel Framing
Section 05 5316	Plank Grating
Section 05 5400	Cold Formed Metal Framing
Section 05 5000	Metal Fabrications

COUNTY OF MONTEREY  
NEW JUVENILE HALL

Section 05 5213 Pipe and Tube Railings  
Section 05 5963 Detention Enclosures

DIVISION 06 - WOOD, PLASTICS AND COMPOSITES

Section 06 1000 Rough Carpentry  
Section 06 1323 Heavy Timber Construction  
Section 06 1516 Wood Roof Decking  
Section 06 1800 Glued-Laminate Construction  
Section 06 4023 Interior Architectural Woodwork

DIVISION 07 - THERMAL AND MOISTURE PROTECTION

Section 07 2100 Thermal Insulation  
Section 07 2600 Vapor Barrier  
Section 07 5400 Thermoplastic Membrane Roofing  
Section 07 7100 Roof Specialties  
Section 07 7200 Roof Accessories  
Section 07 8120 Intumescent Fire Proofing  
Section 07 8413 Penetration Firestopping  
Section 07 8446 Fire Resistive Joint Systems  
Section 07 9200 Joint Sealants

DIVISION 08 – OPENINGS

Section 08 1113 Hollow Metal Doors and Frames  
Section 08 1416 Flush Wood Doors  
Section 08 3113 Access Doors and Frames  
Section 08 3323 Overhead Coiling Doors  
Section 08 3463 Detention Doors and Frames  
Section 08 4113 Aluminum-Framed Entrances and Storefronts  
Section 08 5123.13 Hot-Rolled Steel Windows  
Section 08 6200 Unit Skylights  
Section 08 7100 Door Hardware  
Section 08 7163 Detention Door Hardware  
Section 08 8000 Glazing  
Section 08 8700 Glazing Surface Film  
Section 08 8853 Security Glazing

DIVISION 09 – FINISHES

Section 09 2116.23 Gypsum Board Shaft Wall Assemblies  
Section 09 2216 Non-Structural Metal Framing  
Section 09 2900 Gypsum Board  
Section 09 5113 Acoustical Panel Ceilings  
Section 09 6513 Resilient Base and Accessories  
Section 09 6723 Resinous Flooring  
Section 09 6813 Tile Carpeting  
Section 09 9113 Exterior Painting  
Section 09 9123 Interior Painting  
Section 09 9601 High Performance Coatings for Interiors  
Section 09 9603 Special Coatings



COUNTY OF MONTEREY  
NEW JUVENILE HALL

DIVISION 10 – SPECIALTIES

Section 10 1100	Visual Display Surfaces
Section 10 1400	Signage
Section 101419	Dimensional Letter Signage
Section 10 2113	Toilet Compartments
Section 10 2123	Cubicles
Section 10 2213	Wire Mesh Partitions
Section 10 2600	Wall Protection
Section 10 2800	Toilet Bath and Laundry Accessories
Section 10 2813.63	Detention Toilet Accessories
Section 10 4413	Fire Extinguishers Cabinets
Section 10 4416	Fire Extinguishers
Section 10 5113	Metal Lockers
Section 105613	Metal Storage Shelving
Section 10 5620	Mobile Storage Shelving Units
Section 10 7500	Flagpoles

DIVISION 11 – EQUIPMENT

Section 11 1100	Commercial Laundry Equipment
Section 11 1100.1	Liquid Laundry Detergent Material Safety Data Sheet
Section 11 4000	Foodservice Equipment
Section 11 6623	Basketball Hoops

DIVISION 12 – FURNISHINGS

Section 12 2113	Horizontal Louver Blinds
Section 12 4813	Entrance Floor Mats and Frames
Section 12 5500	Detention Furniture
Section 12 9300	Site Furnishings
Section 12 9313	Bicycle Racks

DIVISION 21 - FIRE SUPPRESSION

Section 21 0517	Sleeves and Sleeve Seals for Fire Suppression Piping
Section 21 0518	Escutcheons for Fire-Suppression Piping
Section 21 0523	General-Duty Valves for Water-Based Fire-Suppression Piping
Section 21 0548	Vibration and Seismic Controls for Fire Sprinkler Piping and Equipment
Section 21 0548.13	Vibration Controls for Fire-Suppression Piping and Equipment
Section 21 0553	Identification for Fire-Suppression Piping and Equipment
Section 21 1100	Facility Fire-Suppression Water-Service Piping
Section 21 1116	Facility Fire Hydrants
Section 21 1119	Fire-Department Connections
Section 21 1213	Fire-Suppression Hoses and Nozzles
Section 21 1313	Wet-Pipe Sprinkler Systems
Section 21 1316	Dry-Pipe Sprinkler Systems

DIVISION 22 – PLUMBING

Section 22 0513	Common Motor Requirements for Plumbing Equipment
-----------------	--

COUNTY OF MONTEREY  
NEW JUVENILE HALL

Section 22 0517	Sleeves and Sleeve Seals for Plumbing Piping
Section 22 0518	Escutcheons for Plumbing Piping
Section 22 0519	Meters and Gages for Plumbing Piping
Section 22 0523.12	Ball Valves for Plumbing Piping
Section 22 0523.14	Check Valves for Plumbing Piping
Section 22 0523.15	Gate Valves for Plumbing Piping
Section 22 0529	Hangers and Supports for Plumbing Piping and Equipment
Section 22 0719	Plumbing Piping Insulation
Section 22 1113	Facility Water Distribution Piping
Section 22 1116	Domestic Water Piping
Section 22 1119	Domestic Water Piping Specialties
Section 22 1123	Domestic Water Pumps
Section 22 1316	Sanitary Waste and Vent Piping
Section 22 1319	Sanitary Waste Piping Specialties
Section 22 1423	Storm Drainage Piping Specialties
Section 22 3100	Domestic Water Softeners
Section 22 3400	Fuel-Fired, Domestic-Water Heaters
Section 22 4213.16	Commercial Urinals
Section 22 4216.13	Commercial Lavatories
Section 22 4216.16	Commercial Sinks
Section 22 4223	Commercial Showers
Section 22 4500	Emergency Plumbing Fixtures
Section 22 4600	Security Plumbing Fixtures
Section 22 4713	Drinking Fountains

(Please Note Divisions 23 – 33 in Volume 3 of 3)  
END OF TABLE OF CONTENTS Volume 2 of 3

**DIVISION 01 – GENERAL REQUIREMENTS**



SECTION 01 11 00 – SUMMARY

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Work Includes:

1. Project information.
2. Work covered by Contract Documents.
3. **Work by Owner. None.**
4. Work under separate contracts.
5. Future work.
6. Purchase contracts.
7. Owner-furnished products.
8. Contractor-furnished, Owner-installed products.
9. Access to site-
10. Coordination with occupants.
11. Work restrictions.
12. Specification and drawing conventions.
13. Miscellaneous provisions.

B. Related Requirements:

1. Section 015000 "Temporary Facilities and Controls" for limitations and procedures governing temporary use of Owner's facilities.

1.3.....PROJECT INFORMATION

A. Project Identification: Monterey Jail Housing Addition, New Construction.

1. Owner's Project No. 8819.
2. Project Location: 1420 Natividad Road, Salinas, CA 93906.

B. Owner: County of Monterey.

1. Owner's Representative:

Don Searle, Architectural Services Manager.  
County of Monterey, Department of Public Works  
168 W. Alisal Street, Second Floor  
Salinas, CA 93901  
Phone: 831-755-4800  
Email: [searledd@co.monterey.ca.us](mailto:searledd@co.monterey.ca.us)

2. Owner's Project Manager:

Peter Andreu, Architectural Services/Kitchell CEM  
168 W. Alisal Street, Second Floor  
Salinas, CA 93901  
Phone: 831-755-4806  
Email: [andreupp@co.monterey.ca.us](mailto:andreupp@co.monterey.ca.us)

C. Architect:

Darrell Stelling, Senior Project Manager  
DLR Group  
1050 20<sup>th</sup> Street  
Suite 250  
Sacramento, CA 95811  
Phone: 916-446-0206  
Email: [dstelling@dlrgroup.com](mailto:dstelling@dlrgroup.com)

D. Architect's Consultants: The Architect has retained the following design professionals who have prepared designated portions of the Contract Documents:

1. Structural Engineer: DLR Group  
3130 Wilshire Blvd., 6<sup>th</sup> Flr., Santa Monica, CA 90403  
310-828-0040  
Michael Zahn: [mzahn@dlrgroup.com](mailto:mzahn@dlrgroup.com)
2. Civil Engineer: Whitson Engineers  
9699 Blue Larkspur Lane, Suite 105, Monterey, CA 93940  
831-373-5065  
Richard Weber: [rweber@whitsonengineers.com](mailto:rweber@whitsonengineers.com)
3. Mechanical/Plumbing DLR Group  
3130 Wilshire Blvd., 6<sup>th</sup> Flr., Santa Monica, CA 90403  
310-828-0040  
Mechanical: Diarmuid Hartley: [dhartley@dlrgroup.com](mailto:dhartley@dlrgroup.com)  
Plumbing: Kimya Azadmard: [kazadmard@dlrgroup.com](mailto:kazadmard@dlrgroup.com)
4. Electrical Engineer: DLR Group  
3130 Wilshire Blvd., 6<sup>th</sup> Flr., Santa Monica, CA 90403  
310-828-0040  
Zoheir Gueumat: [zgueumat@dlrgroup.com](mailto:zgueumat@dlrgroup.com)
5. Security & Low Voltage: R&N Systems Design, L.L.C.  
615 Oakleaf Office Lane, Memphis, TN 38117  
901-309-0115  
Frank Niedzwiedz Jr.: [frankn@rnsystemsdesign.com](mailto:frankn@rnsystemsdesign.com)
6. Fire Protection: R&N Systems Design, L.L.C.  
615 Oakleaf Office Lane, Memphis, TN 38117  
901-309-0115

Frank Niedzwiedz Jr.: [frankn@rnsystemsdesign.com](mailto:frankn@rnsystemsdesign.com)

7. Landscape Architect: SSA Landscape Architects, Inc...  
303 Trero Street, Suite 40-C, Santa Cruz, CA 95060  
931-459-0455  
Christian Harris: [Christian@ssala.com](mailto:Christian@ssala.com)
8. Geotechnical Engineer: Butano Geotechnical Engineering, Inc.  
231 Green Valley Road, Suite E, Freedom, CA 95019  
831-724-2612  
Greg Bloom: [greg@butanogeotech.com](mailto:greg@butanogeotech.com)
9. Corrosion Engineer: Butano Geotechnical Engineering, Inc.  
231 Green Valley Road, Suite E, Freedom, CA 95019  
831-724-2612  
Greg Bloom: [greg@butanogeotech.com](mailto:greg@butanogeotech.com)

E. Contractor: To be determined.

F. Construction Manager:

APSI Sixth Dimension  
717 K Street, Suite 534  
Sacramento, CA  
916-284-5187  
Contact: Mani Subramanian

#### 1.4 WORK COVERED BY CONTRACT DOCUMENTS

The Work of Project is defined by the Contract Documents and consists of the following:

The Work of Project is defined by the Contract Documents and consists of the following:

This Type II New Juvenile Hall Project will replace the original late 1950's facility. The new facility will be constructed in phases with existing buildings being demolished to make way for the new recreation yard and support buildings. Upon completion, the facility will provide approximately 63,438 square feet (sf) of total building area and approximately 100,108 sf of site improvements on 9.217± acres of the greater 38.407± acres of county owned land in Salinas.

The completed 120-bed facility will be laid out in a campus style design with a central 1-1/4 acre recreation yard surrounded by four housing buildings and support buildings. Two new 30-bed medium-security housing buildings will be approximately 7,176 sf with single and double rooms, and the new 30-bed high-security housing building will be approximately 9,715 sf with single and double rooms. Each new housing building will have three 10-bed housing units with connecting dayroom and showers surrounding a central multi-purpose room, staff-support spaces, and an outdoor recreation area. Additionally, the high-security housing building will provide on-unit classrooms and a satellite medical exam room. The base project includes the renovation of the existing 4,775 sf medium-security dormitory

housing building; the renovation includes the remodel two existing housing units, one with 10 beds and one with 20 beds, with existing day room and programming space retained.

Program services space will be provided at each housing building for education; religious services; counseling; substance abuse classes; group counseling; mental health evaluations; and, other programs to reduce recidivism. The new administration building provides spaces for contact and non-contact visitation; central control; medical facilities; staff offices; intake processing; release; staff training; staff locker rooms; staff break room; equipment storage; and, maintenance shop with direct access to the new juvenile hall campus. The project provides a new central kitchen, dining, laundry and warehouse building, and a school/gymnasium building with a teacher resource room, educational offices and staff support areas directly off a large recreational yard.

Primary security and visual supervision for the new facility will be provided by the new central control room, which will utilize closed circuit television to provide visual control and assist in the control of the security perimeter fence line. Central control will have visual supervision of the housing units, attached outdoor exercise areas, and program spaces. Each new and existing housing unit will also be monitored by a smaller unit security station, located off the multi-purpose room.

A. Type of Contract:

1. Project will be constructed under a single prime contract.

1.5 PHASED CONSTRUCTION

Before commencing Work of each phase, submit an updated copy of Contractor's construction schedule showing the sequence, commencement and completion dates, **and move-out and -in dates of Owner's personnel** for all phases of the Work. LINES AND GRADES

- A. The Work shall be conducted in two phases each with two sub-phases, with each phase substantially complete as indicated. CONTRACTOR shall commence the work on the starting date established in the Notice to Proceed. The CONTRACTOR shall achieve Final Completion of the entire Work no later than Eight Hundred and One, **(801) calendar** days from the date of commencement. Phase 1 of the Work as described in the Specifications shall be completed within the first Four Hundred and Forty-four (444) calendar days. Time is of the essence because this is an occupied facility.
- B. All Work shall be done to the lines, grades, and elevations indicated on the Drawings.
- C. County shall provide basic horizontal and vertical control points to be used as datum's for the Work. All additional survey, layout, and measurement work shall be performed by Contractor as a part of the Work.
- D. Contractor shall keep County informed, a reasonable time in advance, of the times and places at which it wishes to do Work, so that any checking deemed necessary by County may be done with minimum inconvenience to County and minimum delay to Contractor.
- E. Contractor shall remove and reconstruct Work which is improperly located.



## 1.6 OWNER-FURNISHED PRODUCTS

- A. Owner will furnish products indicated. The Work includes receiving, unloading, handling, storing, protecting, and installing Owner-furnished products and making building services connections.

## 1.7 ACCESS TO SITE

- A. General: Contractor shall have full use of Project site for construction operations during construction period. Contractor's use of Project site is limited only by Owner's right to perform work or to retain other contractors on portions of Project.
- B. General: Contractor shall have limited use of Project site for construction operations as indicated on Drawings by the Contract limits and as indicated by requirements of this Section.
- C. Use of Site: Limit use of Project site to work in areas indicated. Do not disturb portions of Project site beyond areas in which the Work is indicated.
  - 1. Limits: Confine construction operations to "Limit of Construction" as indicated within construction documents.
  - 2. Driveways, Walkways and Entrances: Keep driveways and entrances serving premises clear and available to Owner, Owner's employees, and emergency vehicles at all times. Do not use these areas for parking or storage of materials.
    - a. Schedule deliveries to minimize use of driveways and entrances by construction operations.
    - b. Schedule deliveries to minimize space and time requirements for storage of materials and equipment on-site.
- D. Condition of Existing Building: Maintain portions of existing building affected by construction operations in a weather tight condition throughout construction period. Repair damage caused by construction operations.

## 1.8 COORDINATION WITH OCCUPANTS

- A. Full Owner Occupancy: Owner will occupy site and existing adjacent building(s) during entire construction period. Cooperate with Owner during construction operations to minimize conflicts and facilitate Owner usage. Perform the Work so as not to interfere with Owner's day-to-day operations. Maintain existing exits unless otherwise indicated.
  - 1. Maintain access to existing walkways, corridors, and other adjacent occupied or used facilities. Do not close or obstruct walkways, corridors, or other occupied or used facilities without written permission from Owner and approval of authorities having jurisdiction.

2. Notify Owner not less than **72** hours in advance of activities that will affect Owner's operations.
3. Prisoners are present on site and every effort should be made to separate prisoners from construction workers audibly, physically and visually.

#### 1.9 WORK RESTRICTIONS

- A. Work Restrictions, General: Comply with restrictions on construction operations.
  1. Comply with limitations on use of public streets and with other requirements of authorities having jurisdiction.
  2. Security backgrounds for all contractor staff required. On-Site Work Hours: Limit work in the existing building to normal business working hours of 7 a.m. to 5 p.m., Monday through Saturday, unless otherwise indicated.
- B. Existing Utility Interruptions: Do not interrupt utilities serving facilities occupied by Owner or others unless permitted under the following conditions and then only after providing temporary utility services according to requirements indicated:
  1. Notify **Owner** not less than **two** days in advance of proposed utility interruptions.
  2. Obtain owners written permission before proceeding with utility interruptions.
- C. Noise, Vibration, and Odors: Coordinate operations that may result in high levels of noise and vibration, odors, or other disruption to Owner occupancy with Owner.
- D. Controlled Substances: Use of tobacco products and other controlled substances on Project site is not permitted.
- E. Employee Identification: Owner will provide identification tags for Contractor personnel working on Project site. Require personnel to use identification tags at all times.
- F. Employee Screening: Contractor required to provide drug and background screening of Contractor personnel working on Project site. Contractor must submit and maintain list of approved screened personnel with Owner's representative.
- G. This is a Nonsmoking Building: Smoking is not permitted within the building or on site.

#### 1.10 SPECIFICATION AND DRAWING CONVENTIONS

- A. Specification Content: The Specifications use certain conventions for the style of language and the intended meaning of certain terms, words, and phrases when used in particular situations. These conventions are as follows:
  1. Imperative mood and streamlined language are generally used in the Specifications. The words "shall," "shall be," or "shall comply with," depending on the context, are implied where a colon (:) is used within a sentence or phrase.

2. Specification requirements are to be performed by Contractor unless specifically stated otherwise.
- B. Division 01 General Requirements: Requirements of Sections in Division 01 apply to the Work of all Sections in the Specifications.
- C. Drawing Coordination: Requirements for materials and products identified on Drawings are described in detail in the Specifications. One or more of the following are used on Drawings to identify materials and products:
1. Terminology: Materials and products are identified by the typical generic terms used in the individual Specifications Sections.
  2. Abbreviations: Materials and products are identified by abbreviations.
  3. Keynoting: Materials and products are identified by reference keynotes referencing Specification Section numbers found in this Project Manual.

#### 1.11 CEQA MITIGATIONS

Contractor shall be responsible to implement and assist the County in compliance with the environmental conditions which apply to this Project. Contractor shall assist in compliance with the 'Notice of Determination', filed with the Monterey County Clerk Recorder, which is available at County Offices. The mitigation regulations are included in the document 'Mitigation Monitoring Plan', which is available at County Offices.

#### 1.12 COUNTY BOARD OF STATE AND COMMUNITY CORRECTIONS AGREEMENT WITH STATE OF CALIFORNIA

Contractor shall be responsible for complying with County's construction-related obligations pursuant to the Local Youthful Offender Rehabilitative Facility Board of State and Community Corrections Agreement between County and the State of California ("BSCC") that is made available to Contractor in Volume One of Three (Appendix D) to the Project Manual. Such obligations include but are not limited to the following:

- A. Contractor shall not substantively alter the scope, cost or schedule of the Project without the prior written approval of BSCC and State Public Works Board (SPWB).
- B. Contractor agrees to construct the Project in accordance with the BSCC.
- C. Contractor agrees to comply with all federal, state or local laws, regulations, rules, ordinances and guidelines applicable to the construction of the Project, including without limitation the following (collectively "**Applicable Laws**"):
  1. The 2007 Local Youthful Offender Rehabilitative Facility Construction Financing regulations and the Minimum Standards for Juvenile Facilities contained in Title 15, California Code of Regulations ("**CCR**").

2. The Minimum Standards for Local Detention Facilities contained in Title 24, California Code of Regulations (“**CCR**”).
3. California Public Contract Code.
4. California Environmental Quality Act (CEQA) contained in California Public Resources Code Section 2100 *et seq.* and California Code of Regulations, Title 14, Division 6, Chapter 3, Sections 15000 *et seq.*
5. Accounting Standards and Procedures for Counties, California State Controller, Division of Local Fiscal Affairs.
6. Construction Financing Agreement Administration and Audit Guide.

D. Valley Fever. California is one of several states in the country with soils that may contain spores known to cause the disease Coccidioidomycosis (sometimes called “Valley Fever”), which spores may be transmitted through contact with dirt and fugitive dust associated with construction activities. Contractor acknowledges receipt of notice from County of this information prior to execution of its Agreement with County. Contractor and any lower-tier subcontractors shall take appropriate precautionary measures designed to minimize the exposure of their respective employees and other workers, County employees, State employees, and other individuals or personnel who may be present during construction activities.

E. Record Keeping and Audit Requirements. Contractor shall keep such full and detailed accounting records as are necessary for proper financial management of the Project. Contractor shall maintain a complete and current set of all books and records relating to the construction of the Project. County shall be entitled, upon forty-eight (48) hour written notice, to inspect all books, records, and accounts kept by Contractor relating to the work contemplated by this Contract. Within 90 calendar days after Final Completion, Contractor shall deliver to County those records necessary for County to perform a financial audit of the Project (“**Final Audit**”).

F. Invoice and progress/final reports and all required audit reports shall be submitted to County in a timely manner.

G. Contractor shall:

1. Books and Records. Maintain adequate fiscal and Project books, records, documents, and other evidence pertinent to Contractor’s work on the Project in accordance with generally accepted accounting principles. Adequate supporting documentation shall be maintained in such detail so as to permit tracing transactions from the invoices, to the financial statement, to the accounting records, and to the supporting documentation. These records shall be maintained for a period of three years after Final Completion of the Project, and shall be subject to examination and/or audit by County or designees, state government auditors or designees.
2. Access to Books and Records. Make such books, records, supporting documen-

tations, and other evidence available to County or designees, their designated representatives, during the course of the Project and for a period of three years after Final Completion of the Project, and provide suitable facilities for access, monitoring, inspection, and copying thereof. Further, Contractor agrees to include a similar right of County to audit records and interview staff in any subcontract related to the performance of this Contract.

3. Contractor Advisement. Be advised that a partial source of financing for the agreement between County and Contractor for construction of the Project is State Financing, and that County may not have funds to finance the Agreement for Construction independently of the State Financing. Contractor shall in all ways cooperate with County and BSCC in maintaining a good working relationship. Contractor shall cooperate as instructed by the County Construction Manager in resolving any disputes arising under the CSA or the Contract.

#### 1.13 COUNTY PROJECT DELIVERY AND CONSTRUCTION AGREEMENT WITH STATE OF CALIFORNIA

Contractor shall be responsible for complying with County's construction-related obligations pursuant to the Project Delivery and Construction Agreement between County and the State of California ("PDCA") that is made available to Contractor as Appendix "C" to the Project Manual. Such obligations include but are not limited to the following:

- A. Establishment of Official Project File. Contractor shall establish an official file for the Project (the "Official Project File"). The file shall contain adequate documentation of all actions that have been taken with respect to the Project, in accordance with generally accepted government accounting principles and the requirements for record retention for capital projects constructed with the proceeds of tax exempt bonds. Contractor will provide a copy of such file to County upon termination of this Contract. The documents to be retained shall include, but are not limited to contracts, payment of invoices, transfer of funds and other related accounting records.
- B. Preservation of Records. Contractor agrees to protect records adequately from fire or other damage. When records are stored away from Contractor's principal office, a written index of the location of records stored must be on hand and ready access must be assured. All Contractor records contained in the Official Project File must be preserved a minimum of three years after Final Completion of the Project. These records shall be subject at all reasonable times to inspection, examination, monitoring, copying, excerpting, transcribing, and audit by the County or designees. If any litigation, claim, negotiation, audit, or other action involving the records has been started before the expiration of the relevant time period set forth in the second sentence of this paragraph, the related records must be retained until the completion of the action and resolution of all issues which arise from it if such date is later than the end of the afore-mentioned three-year period.

SECTION 2. - PRODUCTS (Not Used)

SECTION 3. - EXECUTION (Not Used)

END OF SECTION 011000

## SECTION 012200 - UNIT PRICES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for unit prices.
- B. Related Requirements:
  - 1. Section 012600 "Contract Modification Procedures" for procedures for submitting and handling Change Orders.
  - 2. Section 014000 "Quality Requirements" for general testing and inspecting requirements.

#### 1.3 DEFINITIONS

- A. Unit price is **an amount incorporated in the Agreement, applicable during the duration of the Work as** a price per unit of measurement for materials, equipment, or services, or a portion of the Work, added to or deducted from the Contract Sum by appropriate modification, if the scope of Work or estimated quantities of Work required by the Contract Documents are increased or decreased.

#### 1.4 PROCEDURES

- A. Unit prices include all necessary material, plus cost for delivery, installation, insurance, **applicable taxes**, overhead, and profit.
- B. Measurement and Payment: See individual Specification Sections for work that requires establishment of unit prices. Methods of measurement and payment for unit prices are specified in those Sections.
- C. Owner reserves the right to reject Contractor's measurement of work-in-place that involves use of established unit prices and to have this work measured, at Owner's expense, by an independent surveyor acceptable to Contractor.
- D. List of Unit Prices: A schedule of unit prices is included in Part 3. Specification Sections referenced in the schedule contain requirements for materials described under each unit price.

PART 3 - EXECUTION

3.1 SCHEDULE OF UNIT PRICES

A. Unit Price 1: Removal of unsatisfactory soil and replacement with satisfactory soil material.

1. Description: Unsatisfactory soil excavation and disposal off site and replacement with satisfactory fill material or engineered fill from off site, as required, according to Section 312000 "Earth Moving."
2. Unit of Measurement: Cubic yard (Cubic meter) of soil excavated, based on survey of volume removed.

END OF SECTION 012200



## SECTION 012300 - ALTERNATES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for alternates.

#### 1.3 DEFINITIONS

- A. Alternate: An amount proposed by bidders and stated on the Bid Form for certain work defined in the bidding requirements that may be added to or deducted from the base bid amount if Owner decides to accept a corresponding change either in the amount of construction to be completed or in the products, materials, equipment, systems, or installation methods described in the Contract Documents.
  - 1. Alternates described in this Section are part of the Work only if enumerated in the Agreement.
  - 2. The cost or credit for each alternate is the net addition to or deduction from the Contract Sum to incorporate alternate into the Work. No other adjustments are made to the Contract Sum.

PART 2 - Include as part of each alternate, miscellaneous devices, accessory objects, and similar items incidental to or required for a complete installation whether or not indicated as part of alternate.

- A. Notification: Immediately following award of the Contract, notify each party involved, in writing, of the status of each alternate. Indicate if alternates have been accepted, rejected, or deferred for later consideration. Include a complete description of negotiated revisions to alternates.
- B. Execute accepted alternates under the same conditions as other work of the Contract.
- C. Schedule: A schedule of alternates is included at the end of this Section. Specification Sections referenced in schedule contain requirements for materials necessary to achieve the work described under each alternate.

PART 3 - PRODUCTS (Not Used)

PART 4 - EXECUTION

4.1 SCHEDULE OF ALTERNATES

A. Alternate No. 1: Canopy at Staff Entry.

1. Base Bid: Provide Canopy at Staff Entry at Level 1- Area A in its entirety bounded by Grid Lines M and 2.1, including, but not limited to foundations, walls, framing, sheet metal, roofing, lighting and all materials shown in related details as described and shown in the following drawings:
  - a. S-111 FOUNDATION PLAN - LEVEL 1 – OVERALL.
  - b. S-111A FOUNDATION PLAN - LEVEL 1 - AREA A.
  - c. S-130 FRAMING PLAN - ROOF OVERALL.
  - d. S-130A FRAMING PLAN - ROOF - AREA A.
  - e. S-442 FOUNDATION AND FRAMING PLANS - STAFF ENTRY CANOPY.
  - f. A-111 FLOOR PLAN - LEVEL 1 – OVERALL.
  - g. A-111A FLOOR PLAN - LEVEL 1 - AREA A.
  - h. A-121A REFLECTED CEILING PLAN - LEVEL 1 - AREA 'A'.
  - i. A-141A ROOF PLAN - AREA A.
  - j. AS-113 DETAILS - EXTERIOR CANOPY, DETAILS 20 and related details 10, 15 and 16.
  - k. E-121A LIGHTING PLAN - LEVEL 1 - AREA 'A'.
  - l. Related references, elevations, sections, details, general notes, key notes, legends and annotations noted on the above drawings.
2. Alternate Bid: Delete the Canopy at Staff Entry at Level 1- Area A in its entirety, as described in the drawings noted under Base Bid.

END OF SECTION 012300

## SECTION 012500 - SUBSTITUTION PROCEDURES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for substitutions.
- B. Related Requirements:
  - 1. Section 016000 "Product Requirements" for requirements for submitting comparable product submittals for products by listed manufacturers.

#### 1.3 DEFINITIONS

- A. Substitutions: Changes in products, materials, equipment, and methods of construction from those required by the Contract Documents and proposed by Contractor.
  - 1. Substitutions for Cause: Changes proposed by Contractor that are required due to changed Project conditions, such as unavailability of product, regulatory changes, or unavailability of required warranty terms.
  - 2. Substitutions for Convenience: Changes proposed by Contractor or Owner that are not required in order to meet other Project requirements but may offer advantage to Contractor or Owner.

#### 1.4 ACTION SUBMITTALS

- A. Substitution Requests: Submit three copies of each request for consideration. Identify product or fabrication or installation method to be replaced. Include Specification Section number and title and Drawing numbers and titles.
  - 1. Substitution Request Form: Use form provided in Project Manual.
  - 2. Documentation: Show compliance with requirements for substitutions and the following, as applicable:
    - a. Statement indicating why specified product or fabrication or installation cannot be provided, if applicable.
    - b. Coordination information, including a list of changes or revisions needed to other parts of the Work and to construction performed by Owner and separate contractors, that will be necessary to accommodate proposed substitution.
    - c. Detailed comparison of significant qualities of proposed substitution with those of the Work specified. Include annotated copy of applicable Specification Section. Significant qualities may include attributes such as performance, weight, size, durability, visual effect,

- sustainable design characteristics, warranties, and specific features and requirements indicated. Indicate deviations, if any, from the Work specified.
- d. Product Data, including drawings and descriptions of products and fabrication and installation procedures.
  - e. Samples, where applicable or requested.
  - f. Certificates and qualification data, where applicable or requested.
  - g. List of similar installations for completed projects with project names and addresses and names and addresses of architects and owners.
  - h. Material test reports from a qualified testing agency indicating and interpreting test results for compliance with requirements indicated.
  - i. Research reports evidencing compliance with building code in effect for Project, from ICC-ES, or other organization acceptable to Authority Having Jurisdiction.
  - j. Detailed comparison of Contractor's construction schedule using proposed substitution with products specified for the Work, including effect on the overall Contract Time. If specified product or method of construction cannot be provided within the Contract Time, include letter from manufacturer, on manufacturer's letterhead, stating date of receipt of purchase order, lack of availability, or delays in delivery.
  - k. Cost information, including a proposal of change, if any, in the Contract Sum.
  - l. Contractor's certification that proposed substitution complies with requirements in the Contract Documents except as indicated in substitution request, is compatible with related materials, and is appropriate for applications indicated.
  - m. Contractor's waiver of rights to additional payment or time that may subsequently become necessary because of failure of proposed substitution to produce indicated results.
3. Architect's Action: If necessary, Architect will request additional information or documentation for evaluation within 7 (seven) days of receipt of a request for substitution. Architect will notify Contractor through Construction Manager of acceptance or rejection of proposed substitution within 15 (fifteen) days of receipt of request, or 7 (seven) days of receipt of additional information or documentation, whichever is later.
- a. Forms of Acceptance: Change Order, Construction Change Directive, or Architect's Supplemental Instructions for minor changes in the Work.
  - b. Use product specified if Architect does not issue a decision on use of a proposed substitution within time allocated.

## 1.5 QUALITY ASSURANCE

- A. Compatibility of Substitutions: Investigate and document compatibility of proposed substitution with related products and materials. Engage a qualified testing agency to perform compatibility tests recommended by manufacturers.

## 1.6 PROCEDURES

- A. Coordination: Revise or adjust affected work as necessary to integrate work of the approved substitutions.

## PART 2 - PRODUCTS

### 2.1 SUBSTITUTIONS

- A. Substitutions for Cause: Submit requests for substitution immediately on discovery of need for change, but not later than 15 (fifteen) days prior to time required for preparation and review of related submittals.
1. Conditions: Architect will consider Contractor's request for substitution when the following conditions are satisfied. If the following conditions are not satisfied, Architect will return requests without action, except to record noncompliance with these requirements:
    - a. Requested substitution is consistent with the Contract Documents and will produce indicated results.
    - b. Requested substitution provides sustainable design characteristics that specified product provided.
    - c. Substitution request is fully documented and properly submitted.
    - d. Requested substitution will not adversely affect Contractor's construction schedule.
    - e. Requested substitution has received necessary approvals of authorities having jurisdiction.
    - f. Requested substitution is compatible with other portions of the Work.
    - g. Requested substitution has been coordinated with other portions of the Work.
    - h. Requested substitution provides specified warranty.
    - i. If requested substitution involves more than one contractor, requested substitution has been coordinated with other portions of the Work, is uniform and consistent, is compatible with other products, and is acceptable to all contractors involved.
- B. Substitutions for Convenience: Not allowed unless otherwise indicated.
- C. Substitutions for Convenience: Architect will consider requests for substitution if received within 60 (sixty) days after the Notice to Proceed. Requests received after that time may be considered or rejected at discretion of Architect.
1. Conditions: Architect will consider Contractor's request for substitution when the following conditions are satisfied. If the following conditions are not satisfied, Architect will return requests without action, except to record noncompliance with these requirements:
    - a. Requested substitution offers Owner a substantial advantage in cost, time, energy conservation, or other considerations, after deducting additional responsibilities Owner must assume. Owner's additional responsibilities may include compensation to Architect for redesign and evaluation services, increased cost of other construction by Owner, and similar considerations.
    - b. Requested substitution does not require extensive revisions to the Contract Documents.
    - c. Requested substitution is consistent with the Contract Documents and will produce indicated results.
    - d. Requested substitution provides sustainable design characteristics that specified product provided.
    - e. Substitution request is fully documented and properly submitted.
    - f. Requested substitution will not adversely affect Contractor's construction schedule.
    - g. Requested substitution has received necessary approvals of authorities having jurisdiction.
    - h. Requested substitution is compatible with other portions of the Work.
    - i. Requested substitution has been coordinated with other portions of the Work.
    - j. Requested substitution provides specified warranty.

- k. If requested substitution involves more than one contractor, requested substitution has been coordinated with other portions of the Work, is uniform and consistent, is compatible with other products, and is acceptable to all contractors involved.

PART 3 - EXECUTION (Not Used)

END OF SECTION 012500

## SECTION 012600 - CONTRACT MODIFICATION PROCEDURES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for handling and processing Contract modifications.
- B. Related Requirements:
  - 1. Section 012500 "Substitution Procedures" for administrative procedures for handling requests for substitutions made after the Contract award.

#### 1.3 MINOR CHANGES IN THE WORK

- A. Architect will issue through Construction Manager supplemental instructions authorizing minor changes in the Work, not involving adjustment to the Contract Sum or the Contract Time, on AIA Document G710, "Architect's Supplemental Instructions."

#### 1.4 Change order REQUESTS

- A. Owner-Initiated Change Order Requests: Architect will issue a detailed description of proposed changes in the Work that may require adjustment to the Contract Sum or the Contract Time. If necessary, the description will include supplemental or revised Drawings and Specifications.
  - 1. Change Order Requests issued by Architect are not instructions either to stop work in progress or to execute the proposed change.
    - a. The Contractor shall follow the provisions in General Conditions Article 18 related to the timeliness and content of Change Order Proposals. They will follow Section 01 32 00 for requirements related to any changes to the contract time related to the Change Order Request.
    - b. Include a list of quantities of products required or eliminated and unit costs, with total amount of purchases and credits to be made. If requested, furnish survey data to substantiate quantities.
    - c. Indicate applicable taxes, delivery charges, equipment rental, and amounts of trade discounts.
    - d. Include costs of labor and supervision directly attributable to the change.
    - e. Include an updated Contractor's construction schedule that indicates the effect of the change, including, but not limited to, changes in activity duration, start and finish times,

and activity relationship. Use available total float before requesting an extension of the Contract Time.

- B. Contractor-Initiated Change Order Request: If latent or changed conditions require modifications to the Contract, Contractor may initiate a claim by submitting a Contractor Initiated Change Order to the Construction Manager.
  - 1. Contractor shall include a statement outlining reasons for the change and the effect of the change on the Work. Provide a complete description of the proposed change. They shall indicate the effect of the proposed change on the Contract Sum and the Contract Time.
  - 2. Contractor shall include a list of quantities of products required or eliminated and unit costs, with total amount of purchases and credits to be made. If requested, furnish survey data to substantiate quantities.
  - 3. Contractor shall comply with requirements in Section 012500 "Substitution Procedures" if the proposed change requires substitution of one product or system for product or system specified.

#### 1.5 CHANGE ORDER PROCEDURES

- A. On Owner's approval of a Work Changes Proposal Request, Construction Manager will issue a Change Order for signatures of Owner and Contractor on AIA Document G701.

#### 1.6 CONSTRUCTION CHANGE DIRECTIVE

- A. Change Directive: Construction Manager may issue a Change Directive on AIA Document G714. Change Directive instructs Contractor to proceed with a change for subsequent inclusion in a Change Order.
  - 1. Change Directive contains a complete description of change in the Work. It also designates method to be followed to determine change in the Contract Sum or the Contract Time.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 012600



## SECTION 012900 - PAYMENT PROCEDURES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements necessary to prepare and process Applications for Payment.
- B. Related Requirements:
  - 1. Section 012600 "Contract Modification Procedures" for administrative procedures for handling changes to the Contract.
  - 2. Section 013200 "Construction Progress Documentation" for administrative requirements governing the preparation and submittal of the Contractor's construction schedule.

#### 1.3 DEFINITIONS

- A. Schedule of Values: Schedule of Values" means the detailed breakdown of cost necessary to accomplish the Work as described in the Contract Documents.

#### 1.4 SCHEDULE OF VALUES

- A. Coordination: Coordinate preparation of the schedule of values with preparation of Contractor's construction schedule. Cost-loaded Critical Path Method Schedule consistent with the requirements of Section 01-32-00 will be considered to satisfy requirements for the schedule of values and used to review progress payments.
  - 1. Coordinate line items in the schedule of values with other required administrative forms and schedules, including the following:
    - a. Application for Payment forms with continuation sheets.
    - b. Submittal schedule.
    - c. Items required to be indicated as separate activities in Contractor's construction schedule.
  - 2. Submit the schedule of values to Construction Manager consistent with the requirements of Section 01-32-00 to allow sufficient time for the review and acceptance in advance of the initial Application for Payment.
- B. Format and Content: Follow the requirements of Section 01 32 00 in developing the Schedule of Values. In addition, follow the requirements below.
  - 1. Identification: Include the following Project identification on the schedule of values:

- a. Project name and location.
  - b. Name of Architect.
  - c. Architect's project number.
  - d. Contractor's name and address.
  - e. Date of submittal.
2. Arrange the schedule of values in tabular form with separate columns to indicate the following for each item listed:
- a. Related Specification Section or Division.
  - b. Description of the Work.
  - c. Name of subcontractor.
  - d. Name of manufacturer or fabricator.
  - e. Name of supplier.
  - f. Change Orders (numbers) that affect value.
  - g. Dollar value of the following, as a percentage of the Contract Sum to nearest one-hundredth percent, adjusted to total 100 percent.
    - 1) Labor.
    - 2) Materials.
    - 3) Equipment.
3. Provide a breakdown of the Contract Sum in enough detail to facilitate continued evaluation of Applications for Payment and progress reports. Coordinate with Project Manual table of contents. Provide multiple line items for principal subcontract amounts in excess of five percent of the Contract Sum.
4. Round amounts to nearest whole dollar; total shall equal the Contract Sum.
5. Provide a separate line item in the schedule of values for each part of the Work where Applications for Payment may include materials or equipment purchased or fabricated and stored, but not yet installed.
- a. Differentiate between items stored on-site and items stored off-site. If required, include evidence of insurance.
6. Provide separate line items in the schedule of values for initial cost of materials, for each subsequent stage of completion, and for total installed value of that part of the Work.
7. Each item in the schedule of values and Applications for Payment shall be complete. Include total cost and proportionate share of general overhead and profit for each item.
- a. Temporary facilities and other major cost items that are not direct cost of actual work-in-place may be shown either as separate line items in the schedule of values or distributed as general overhead expense, at Contractor's option.
8. Schedule Updating: Follow the requirements of Section 01 32 00 related to updating of the Schedule.

## 1.5 APPLICATIONS FOR PAYMENT

- A. Each Application for Payment following the initial Application for Payment shall be consistent with previous applications and payments as certified by Architect and paid for by Owner.
  - 1. Initial Application for Payment, Application for Payment at time of Substantial Completion, and final Application for Payment involve additional requirements.
- B. Payment Application Times: The date for each progress payment is indicated in the Agreement between Owner and Contractor. The period of construction work covered by each Application for Payment is the period indicated in the Agreement.
- C. Payment Application Times: Submit Application for Payment to Construction Manager by the last day of the month. The period covered by each Application for Payment is one month, ending on the last day of the month.
  - 1. Submit draft copy of Application for Payment five days prior to due date.
- D. Application for Payment Forms: Use AIA Document G702 and AIA Document G703 as form for Applications for Payment.
- E. Application Preparation: Complete every entry on form. Execute by a person authorized to sign legal documents on behalf of Contractor. Construction Manager will return incomplete applications without action.
  - 1. Entries shall match data on the schedule of values and Contractor's construction schedule. Use updated schedules and when revisions were made.
  - 2. Include amounts for work completed following previous Application for Payment, whether or not payment has been received. Include only amounts for work completed at time of Application for Payment.
  - 3. Include amounts of Change Orders and Construction Change Directives issued before last day of construction period covered by application.
- F. Stored Materials: Include in Application for Payment amounts applied for materials or equipment purchased or fabricated and stored, but not yet installed. Differentiate between items stored on-site and items stored off-site.
  - 1. Provide certificate of insurance, evidence of transfer of title to Owner, and consent of surety to payment, for stored materials.
  - 2. Provide supporting documentation that verifies amount requested, such as paid invoices. Match amount requested with amounts indicated on documentation; do not include overhead and profit on stored materials.
  - 3. Provide summary documentation for stored materials indicating the following:
    - a. Value of materials previously stored and remaining stored as of date of previous Applications for Payment.
    - b. Value of previously stored materials put in place after date of previous Application for Payment and on or before date of current Application for Payment.
    - c. Value of materials stored since date of previous Application for Payment and remaining stored as of date of current Application for Payment.

- G. Transmittal: Submit four signed and notarized original copies of each Application for Payment to Construction Manager by a method ensuring receipt. One copy shall include waivers of lien and similar attachments if required.
1. Transmit each copy with a transmittal form listing attachments and recording appropriate information about application.
- H. Waivers of Mechanic's Lien: With each Application for Payment, submit waivers of mechanic's lien from entities lawfully entitled to file a mechanic's lien arising out of the Contract and related to the Work covered by the payment.
1. Submit partial waivers on each item for amount requested in previous application, after deduction for retainage, on each item.
  2. When an application shows completion of an item, submit conditional final or full waivers.
  3. Owner reserves the right to designate which entities involved in the Work must submit waivers.
  4. Waiver Forms: Submit executed waivers of lien on forms acceptable to Owner.
- I. Waivers of Mechanic's Lien: With each Application for Payment, submit waivers of mechanic's liens from subcontractors, sub-subcontractors, and suppliers for construction period covered by the previous application.
1. Submit partial waivers on each item for amount requested in previous application, after deduction for retainage, on each item.
  2. When an application shows completion of an item, submit conditional final or full waivers.
  3. Owner reserves the right to designate which entities involved in the Work must submit waivers.
  4. Submit final Application for Payment with or preceded by conditional final waivers from every entity involved with performance of the Work covered by the application who is lawfully entitled to a lien.
  5. Waiver Forms: Submit executed waivers of lien on forms, acceptable to Owner.
- J. Initial Application for Payment: Administrative actions and submittals that must precede or coincide with submittal of first Application for Payment include the following:
1. List of subcontractors.
  2. Schedule of values.
  3. Contractor's construction schedule (preliminary if not final).
  4. Products list (preliminary if not final).
  5. Schedule of unit prices.
  6. Submittal schedule (preliminary if not final).
  7. List of Contractor's staff assignments.
  8. List of Contractor's principal consultants.
  9. Copies of authorizations and licenses from authorities having jurisdiction for performance of the Work.
  10. Initial progress report.
- K. Application for Payment at Substantial Completion: After Architect issues the Certificate of Substantial Completion, submit an Application for Payment showing 100 percent completion for portion of the Work claimed as substantially complete.
1. Include documentation supporting claim that the Work is substantially complete and a statement showing an accounting of changes to the Contract Sum.

2. This application shall reflect Certificate(s) of Substantial Completion issued previously for Owner occupancy of designated portions of the Work.
- L. Final Payment Application: After completing Project closeout requirements, submit final Application for Payment with releases and supporting documentation not previously submitted and accepted, including, but not limited, to the following:
1. Evidence of completion of Project closeout requirements.
  2. Insurance certificates for products and completed operations where required and proof that taxes, fees, and similar obligations were paid.
  3. Updated final statement, accounting for final changes to the Contract Sum.
  4. Evidence that claims have been settled.
  5. Final meter readings for utilities, a measured record of stored fuel, and similar data as of date of Substantial Completion or when Owner took possession of and assumed responsibility for corresponding elements of the Work.
  6. Final liquidated damages settlement statement.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 012900

## SECTION 013100 - PROJECT MANAGEMENT AND COORDINATION

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative provisions for coordinating construction operations on Project including, but not limited to, the following:
  - 1. General coordination procedures.
  - 2. Coordination drawings.
  - 3. Requests for Information (RFIs).
  - 4. Project Web site.
  - 5. Project meetings.
  - 6. Section 013200 "Construction Progress Documentation" for preparing and submitting Contractor's construction schedule.
  - 7. Section 017300 "Execution" for procedures for coordinating general installation and field-engineering services, including establishment of benchmarks and control points.
  - 8. Section 017700 "Closeout Procedures" for coordinating closeout of the Contract.
  - 9. Section 019113 "General Commissioning Requirements" for coordinating the Work with Owner's Commissioning Authority.

#### 1.3 DEFINITIONS

- A. RFI: Request from Contractor seeking information clarifications of the Contract Documents.
- B. Commissioning Agent: Owners Commissioning Representative Kitchell CEM.

#### 1.4 INFORMATIONAL SUBMITTALS

- A. Subcontract List: Prepare a written summary identifying individuals or firms proposed for each portion of the Work, including those who are to furnish products or equipment fabricated to a special design. **Use CSI Form 1.5A.** Include the following information in tabular form:
  - 1. Name, address, and telephone number of entity performing subcontract or supplying products.
  - 2. Number and title of related Specification Section(s) covered by subcontract.
  - 3. Drawing number and detail references, as appropriate, covered by subcontract.

- B. Key Personnel Names: Within **14** days of starting construction operations, submit a list of key personnel assignments, including superintendent and other personnel in attendance at Project site. Identify individuals and their duties and responsibilities; list addresses and telephone numbers, including home, office, and cellular telephone numbers and e-mail addresses. Provide names, addresses, and telephone numbers of individuals assigned as alternates in the absence of individuals assigned to Project.
  - 1. Post copies of list in project meeting room, in temporary field office. Keep list current at all times.

#### 1.5 GENERAL COORDINATION PROCEDURES

- A. Coordination: Coordinate construction operations included in different Sections of the Specifications to ensure efficient and orderly installation of each part of the Work. Coordinate construction operations, included in different Sections that depend on each other for proper installation, connection, and operation.
  - 1. Schedule construction operations in sequence required to obtain the best results where installation of one part of the Work depends on installation of other components, before or after its own installation.
  - 2. Coordinate installation of different components to ensure maximum performance and accessibility for required maintenance, service, and repair.
  - 3. Make adequate provisions to accommodate items scheduled for later installation.
- B. Administrative Procedures: Coordinate scheduling and timing of required administrative procedures with construction activities to avoid conflicts and to ensure orderly progress of the Work. Such administrative activities include, but are not limited to, the following:
  - 1. Preparation of Contractor's construction schedule.
  - 2. Installation and removal of temporary facilities and controls.
  - 3. Delivery and processing of submittals.
  - 4. Progress meetings.
  - 5. Pre-installation conferences.
  - 6. Project closeout activities.
  - 7. Startup and adjustment of systems.
- C. Conservation: Coordinate construction activities to ensure that operations are carried out with consideration given to conservation of energy, water, and materials. Coordinate use of temporary utilities to minimize waste.
  - 1. Salvage materials and equipment involved in performance of, but not actually incorporated into, the Work. See other Sections for disposition of salvaged materials that are designated as Owner's property.

#### 1.6 COORDINATION DRAWINGS

- A. Coordination Drawings, General: Prepare coordination drawings according to requirements in individual Sections, and additionally where installation is not completely shown on Shop

Drawings, where limited space availability necessitates coordination, or if coordination is required to facilitate integration of products and materials fabricated or installed by more than one entity.

1. Content: Project-specific information, drawn accurately to a scale large enough to indicate and resolve conflicts. Do not base coordination drawings on standard printed data. Include the following information, as applicable:
  - a. Use applicable Drawings as a basis for preparation of coordination drawings. Prepare sections, elevations, and details as needed to describe relationship of various systems and components.
  - b. Coordinate the addition of trade-specific information to the coordination drawings by multiple contractors in a sequence that best provides for coordination of the information and resolution of conflicts between installed components before submitting for review.
  - c. Indicate functional and spatial relationships of components of architectural, structural, civil, mechanical, and electrical systems.
  - d. Indicate space requirements for routine maintenance and for anticipated replacement of components during the life of the installation.
  - e. Show location and size of access doors required for access to concealed dampers, valves, and other controls.
  - f. Indicate required installation sequences.
  - g. Indicate dimensions shown on the Drawings. Specifically note dimensions that appear to be in conflict with submitted equipment and minimum clearance requirements. Provide alternate sketches to Architect indicating proposed resolution of such conflicts. Minor dimension changes and difficult installations will not be considered changes to the Contract.

B. Coordination Drawing Organization: Organize coordination drawings as follows:

1. Floor Plans and Reflected Ceiling Plans: Show architectural and structural elements, and mechanical, plumbing, fire-protection, fire-alarm, and electrical Work. Show locations of visible ceiling-mounted devices relative to acoustical ceiling grid. Supplement plan drawings with section drawings where required to adequately represent the Work.
2. Plenum Space: Indicate subframing for support of ceiling and wall systems, mechanical and electrical equipment, and related Work. Locate components within ceiling plenum to accommodate layout of light fixtures indicated on Drawings. Indicate areas of conflict between light fixtures and other components.
3. Mechanical Rooms: Provide coordination drawings for mechanical rooms showing plans and elevations of mechanical, plumbing, fire-protection, fire-alarm, and electrical equipment.
4. Structural Penetrations: Indicate penetrations and openings required for all disciplines.
5. Slab Edge and Embedded Items: Indicate slab edge locations and sizes and locations of embedded items for metal fabrications, sleeves, anchor bolts, bearing plates, angles, door floor closers, slab depressions for floor finishes, curbs and housekeeping pads, and similar items.
6. Mechanical and Plumbing Work: Show the following:
  - a. Sizes and bottom elevations of ductwork, piping, and conduit runs, including insulation, bracing, flanges, and support systems.



- b. Dimensions of major components, such as dampers, valves, diffusers, access doors, cleanouts and electrical distribution equipment.
  - c. Fire-rated enclosures around ductwork.
7. Electrical Work: Show the following:
- a. Runs of vertical and horizontal conduit 1-1/4 inches (32 mm) in diameter and larger.
  - b. Light fixture, exit light, emergency battery pack, smoke detector, and other fire-alarm locations.
  - c. Panel board, switch board, switchgear, transformer, busway, generator, and motor control center locations.
  - d. Location of pull boxes and junction boxes dimensioned from column center lines.
8. Fire-Protection System: Show the following:
- a. Locations of standpipes, mains piping, branch lines, pipe drops, and sprinkler heads.
9. Review: Architect will review coordination drawings to confirm that the Work is being coordinated, but not for the details of the coordination, which are Contractor's responsibility. If Architect determines that coordination drawings are not being prepared in sufficient scope or detail, or are otherwise deficient, Architect will so inform Contractor, who shall make changes as directed and resubmit.
10. Coordination Drawing Prints: Prepare coordination drawing prints according to requirements in Section 013300 "Submittal Procedures."
- C. Coordination Digital Data Files: Prepare coordination digital data files according to the following requirements:
1. File Preparation Format: Same digital data software program, version, and operating system as original Drawings.
  2. File Preparation Format: **DWG** operating in **Microsoft Windows** operating system.
  3. File Submittal Format: Submit or post coordination drawing files using **Portable Data File (PDF) format**.
  4. Architect will furnish Contractor one set of digital data files of Drawings for use in preparing coordination digital data files.
    - a. Architect makes no representations as to the accuracy or completeness of digital data files as they relate to Drawings.
    - b. Digital Data Software Program: Drawings are available in **<Insert name and version of digital data software program and operating system>**.
    - c. Contractor shall execute a data licensing agreement in the form of **[AIA Document C106] [Agreement included in this Project Manual] [Agreement form acceptable to Owner and Architect]**.

1.7 REQUESTS FOR INFORMATION (RFIs)

- A. General: Immediately on discovery of the need for additional information or interpretation of the Contract Documents, Contractor shall prepare and submit an RFI in the form specified.
1. Construction Manager and/or Architect will return RFIs submitted by other entities controlled by Contractor with no response.
  2. Coordinate and submit RFIs in a prompt manner so as to avoid delays in Contractor's work or work of subcontractors.
- B. Content of the RFI: Include a detailed, legible description of item needing information or interpretation and the following:
1. Project name.
  2. Project number.
  3. Date.
  4. Name of Contractor.
  5. Name of Architect.
  6. RFI number, numbered sequentially.
  7. RFI subject.
  8. Specification Section number and title and related paragraphs, as appropriate.
  9. Drawing number and detail references, as appropriate.
  10. Field dimensions and conditions, as appropriate.
  11. Contractor's suggested resolution. If Contractor's suggested resolution impacts the Contract Time or the Contract Sum, Contractor shall state impact in the RFI.
  12. Contractor's signature.
  13. Attachments: Include sketches, descriptions, measurements, photos, Product Data, Shop Drawings, coordination drawings, and other information necessary to fully describe items needing interpretation.
    - a. Include dimensions, thicknesses, structural grid references, and details of affected materials, assemblies, and attachments on attached sketches.
- C. RFI Forms:
1. Attachments shall be electronic files in Adobe Acrobat PDF format.
- D. Architect's Action: Architect will review each RFI, determine action required, and respond. Allow **five** working days for Architect's response for each RFI. RFIs received by Architect after 1:00 p.m. will be considered as received the following working day.
1. The following Contractor-generated RFIs will be returned without action:
    - a. Requests for approval of submittals.
    - b. Requests for approval of substitutions.
    - c. Requests for approval of Contractor's means and methods.
    - d. Requests for coordination information already indicated in the Contract Documents.
    - e. Requests for adjustments in the Contract Time or the Contract Sum.
    - f. Requests for interpretation of Architect's actions on submittals.

- g. Incomplete RFIs or inaccurately prepared RFIs.
- 2. Architect's action may include a request for additional information, in which case Architect's time for response will date from time of receipt of additional information.
- 3. Architect's action on RFIs that may result in a change to the Contract Time or the Contract Sum may be eligible for Contractor to submit Change Proposal according to Section 012600 "Contract Modification Procedures."
  - a. If Contractor believes the RFI response warrants change in the Contract Time or the Contract Sum, notify Architect in writing within **10** days of receipt of the RFI response.
- E. On receipt of Architect's action, update the RFI log and immediately distribute the RFI response to affected parties. Review response and notify Architect within seven days if Contractor disagrees with response.

#### 1.8 PROJECT MEETINGS

- A. General: Construction Manager will schedule and conduct meetings and conferences at Project site unless otherwise indicated.
  - 1. Attendees: Inform participants and others involved, and individuals whose presence is required, of date and time of each meeting.
- B. Preconstruction Conference: Construction Manager will schedule and conduct a preconstruction conference before starting construction, at a time convenient to Owner and Architect, but no later than **15** days after execution of the Agreement.
  - 1. Conduct the conference to review responsibilities and personnel assignments.
  - 2. Attendees: Authorized representatives of Owner, Owner's Commissioning Agent, Construction Manager, Architect, and their consultants; Contractor and its superintendent; major subcontractors; suppliers; and other concerned parties shall attend the conference. Participants at the conference shall be familiar with Project and authorized to conclude matters relating to the Work.
  - 3. Agenda: Discuss items of significance that could affect progress, including the following:
    - a. Tentative construction schedule.
    - b. Phasing.
    - c. Critical work sequencing and long-lead items.
    - d. Designation of key personnel and their duties.
    - e. Lines of communications.
    - f. Procedures for processing field decisions and Change Orders.
    - g. Procedures for RFIs.
    - h. Procedures for testing and inspecting.
    - i. Procedures for processing Applications for Payment.
    - j. Distribution of the Contract Documents.
    - k. Submittal procedures.
    - l. Preparation of record documents.
    - m. Use of the premises[

- Work restrictions.
  - n. Working hours.
  - o. Owner's occupancy requirements.
  - p. Responsibility for temporary facilities and controls.
  - q. Procedures for moisture and mold control.
  - r. Procedures for disruptions and shutdowns.
  - s. Construction waste management and recycling.
  - t. Parking availability.
  - u. Office, work, and storage areas.
  - v. Equipment deliveries and priorities.
  - w. First aid.
  - x. Security.
  - y. Progress cleaning.
4. Minutes: Entity responsible for conducting meeting will record and distribute meeting minutes.
5. Attendees: Authorized representatives of Owner, **Owner's Commissioning Authority, Construction Manager**, Architect, and their consultants; Contractor and its superintendent and sustainable design coordinator; major subcontractors; suppliers; and other concerned parties shall attend the conference. Participants at the conference shall be familiar with Project and authorized to conclude matters relating to the Work.
- a. Project closeout requirements.
  - b. Construction waste management.
  - c. Construction operations and sustainable design requirements and restrictions.
6. Minutes: Entity responsible for conducting meeting will record and distribute meeting minutes.
- C. Pre-installation Conferences: Conduct a pre-installation conference at Project site before each construction activity that requires coordination with other construction.
1. Attendees: Installer and representatives of manufacturers and fabricators involved in or affected by the installation and its coordination or integration with other materials and installations that have preceded or will follow, shall attend the meeting. Advise Architect of scheduled meeting dates.
2. Agenda: Review progress of other construction activities and preparations for the particular activity under consideration, including requirements for the following:
- a. Contract Documents.
  - b. Options.
  - c. Related RFIs.
  - d. Related Change Orders.
  - e. Purchases.
  - f. Deliveries.
  - g. Submittals.
  - h. Review of mockups.
  - i. Possible conflicts.
  - j. Compatibility requirements.
  - k. Time schedules.

- l. Weather limitations.
  - m. Manufacturer's written instructions.
  - n. Warranty requirements.
  - o. Compatibility of materials.
  - p. Acceptability of substrates.
  - q. Temporary facilities and controls.
  - r. Space and access limitations.
  - s. Regulations of authorities having jurisdiction.
  - t. Testing and inspecting requirements.
  - u. Installation procedures.
  - v. Coordination with other work.
  - w. Required performance results.
  - x. Protection of adjacent work.
  - y. Protection of construction and personnel.
3. Record significant conference discussions, agreements, and disagreements, including required corrective measures and actions.
  4. Reporting: Distribute minutes of the meeting to each party present and to other parties requiring information.
  5. Do not proceed with installation if the conference cannot be successfully concluded. Initiate whatever actions are necessary to resolve impediments to performance of the Work and reconvene the conference at earliest feasible date.
- D. Project Closeout Conference: Construction Manager will schedule and conduct a project closeout conference, at a time convenient to Owner and Architect, but no later than **90** days prior to the scheduled date of Substantial Completion.
1. The conference to review requirements and responsibilities related to Project closeout.
  2. Attendees: Authorized representatives of Owner, Architect, and their consultants; Contractor and its superintendent; major subcontractors; suppliers; and other concerned parties shall attend the meeting. Participants at the meeting shall be familiar with Project and authorized to conclude matters relating to the Work.
  3. Agenda: Discuss items of significance that could affect or delay Project closeout, including the following:
    - a. Preparation of record documents.
    - b. Procedures required prior to inspection for Substantial Completion and for final inspection for acceptance.
    - c. Submittal of written warranties.
    - d. Requirements for preparing operations and maintenance data.
    - e. Requirements for delivery of material samples, attic stock, and spare parts.
    - f. Requirements for demonstration and training.
    - g. Preparation of Contractor's punch list.
    - h. Procedures for processing Applications for Payment at Substantial Completion and for final payment.
    - i. Submittal procedures.
    - j. Owner's partial occupancy requirements.
    - k. Installation of Owner's furniture, fixtures, and equipment.
    - l. Responsibility for removing temporary facilities and controls.

4. Minutes: Entity conducting meeting will record and distribute meeting minutes.
- E. Progress Meetings: Construction manager will conduct progress meetings at **weekly** intervals, unless such a meeting for any given week is deemed not necessary by the Owner.
1. Attendees: In addition to representatives of Owner, **Construction Manager**, and Architect, each contractor, subcontractor, supplier, and other entity concerned with current progress or involved in planning, coordination, or performance of future activities shall be represented at these meetings. All participants at the meeting shall be familiar with Project and authorized to conclude matters relating to the Work.
  2. Agenda: Review and correct or approve minutes of previous progress meeting. Review other items of significance that could affect progress. Include topics for discussion as appropriate to status of Project.
    - a. Contractor's Construction Schedule: Review progress since the last meeting. Determine whether each activity is on time, ahead of schedule, or behind schedule, in relation to Contractor's construction schedule. Determine how construction behind schedule will be expedited; secure commitments from parties involved to do so. Discuss whether schedule revisions are required to ensure that current and subsequent activities will be completed within the Contract Time.
      - 1) Review schedule for next period.
    - b. Review present and future needs of each entity present, including the following:
      - 1) Interface requirements.
      - 2) Sequence of operations.
      - 3) Status of submittals.
      - 4) Status of sustainable design documentation.
      - 5) Deliveries.
      - 6) Off-site fabrication.
      - 7) Access.
      - 8) Site utilization.
      - 9) Temporary facilities and controls.
      - 10) Progress cleaning.
      - 11) Quality and work standards.
      - 12) Status of correction of deficient items.
      - 13) Field observations.
      - 14) Status of RFIs.
      - 15) Status of proposal requests.
      - 16) Pending changes.
      - 17) Status of Change Orders.
      - 18) Pending claims and disputes.
      - 19) Documentation of information for payment requests.
  3. Minutes: Entity responsible for conducting the meeting will record and distribute the meeting minutes to each party present and to parties requiring information.
    - a. Schedule Updating: Revise Contractor's construction schedule after each progress meeting where revisions to the schedule have been made or recognized. Issue revised schedule concurrently with the report of each meeting.

4. Attendees: In addition to representatives of Owner, **Owner's Commissioning Authority, Construction Manager**, and Architect, each contractor, subcontractor, supplier, and other entity concerned with current progress or involved in planning, coordination, or performance of future activities shall be represented at these meetings. All participants at the meetings shall be familiar with Project and authorized to conclude matters relating to the Work.
5. Agenda: Review and correct or approve minutes of the previous coordination meeting. Review other items of significance that could affect progress. Include topics for discussion as appropriate to status of Project.
  - a. Combined Contractor's Construction Schedule: Review progress since the last coordination meeting. Determine whether each contract is on time, ahead of schedule, or behind schedule, in relation to combined Contractor's construction schedule. Determine how construction behind schedule will be expedited; secure commitments from parties involved to do so. Discuss whether schedule revisions are required to ensure that current and subsequent activities will be completed within the Contract Time.
  - b. Schedule Updating: Revise combined Contractor's construction schedule after each coordination meeting where revisions to the schedule have been made or recognized. Issue revised schedule concurrently with report of each meeting.
  - c. Review present and future needs of each contractor present, including the following:
    - 1) Interface requirements.
    - 2) Sequence of operations.
    - 3) Status of submittals.
    - 4) Deliveries.
    - 5) Off-site fabrication.
    - 6) Access.
    - 7) Site utilization.
    - 8) Temporary facilities and controls.
    - 9) Work hours.
    - 10) Hazards and risks.
    - 11) Progress cleaning.
    - 12) Quality and work standards.
    - 13) Change Orders.
6. Reporting: Record meeting results and distribute copies to everyone in attendance and to others affected by decisions or actions resulting from each meeting.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 013100

## SECTION 01 32 00 – CONSTRUCTION PROGRESS DOCUMENTATION

### PART 1 GENERAL

#### 1.1 SUMMARY

##### A. Section Includes:

1. Administrative and procedural requirements for documenting the progress of construction during performance of the Work, including the following:
  - a. Submittals.
  - b. Quality Assurance.
  - c. General Scheduling Requirements.
  - d. Preliminary Contract Schedule.
  - e. Contract Schedule.
  - f. Technical Requirements.
  - g. Update of Accepted Contract Schedule.
  - h. Revised Contract Schedule.
  - i. Recovery Schedule.
  - j. Short Interval Schedule.
  - k. Time Impact Analysis.
  - l. As-Built Schedule.

##### B. Related Sections:

1. Section 00 72 05 - Prosecution of Work.
2. Section 00 72 06 - Control of the Work.
3. Section 00 72 08 - Payments and Retention.
4. Section 00 73 00 - Supplementary Conditions.
5. Section 01 33 00 - Submittal Procedures.
6. Section 01 35 53 - Security Procedures.

#### 1.2 SUBMITTALS

- A. Preliminary Contract Schedule.
- B. Contract Schedule.
- C. Schedule Updates.
- D. As-built Schedule.
- E. Schedule Revisions.
- F. Resume of Project Scheduler.
- G. Other Schedules as may be required.

#### 1.3 QUALITY ASSURANCE

- A. Pre-scheduling Conference:



1. Convene a Pre-Schedule Meeting with the Owner Representative to review methods and procedures related to the Preliminary Contract and Contract Schedules, including, but not limited to, the following:
  - a. Provide verification that the personnel planned to develop and update the Schedule has proper qualifications.
  - b. Review dates established in the Contract Documents and other Milestones of important events.
  - c. Discuss constraints, access issues, Work restrictions, and security procedures.
  - d. Discuss sequencing, phasing, Work stages, area separations, interim Milestones, and Owner's requirements for activation activities and use prior to acceptance, if any.
  - e. Review timeline of mobilization activities on the Work Sites, including notices, permits and time to acquire, set up and occupy the field office(s).
  - f. Review Schedule general and technical requirements.
  - g. Review Schedule for Work of Owner's separate contracts and interface points with other contracts.
  - h. Review processes and procedures for updating of Schedule and progress evaluation.
    1. Review delivery durations and dates for Owner-furnished products.
    - J. Review procedures and durations for commissioning, startup and dose-out.
    - k. Review procedures for assessing Schedule impacts, Schedule delays, and time extensions.
      1. Data exchange and communications.
2. The Pre-scheduling conference must be attended by all of the Contractor's key Project personnel, listed Subcontractors and accepted Project Scheduler.

#### 1.4 GENERAL SCHEDULING REQUIREMENTS

- A. The term "Schedule(s)" refers to the Preliminary Contract, Contract Schedule and any variations, revisions or updates thereof.
- B. The Contractor will develop and maintain the Schedule for the scope of Work contained in the Contract Documents. The Schedule will be used to:
  1. Assure adequate planning, scheduling, and reporting during execution of the construction and related activities so they may be prosecuted in an orderly and expeditious manner, within the Contract Time and the Milestones stipulated by the **Contract Documents**;
  2. Assure coordination of the Work of the Contractor and the various Subcontractors and suppliers at all tiers;
  3. Form the basis of preparation and evaluation of the Contractor's monthly progress payments;
  4. Monitor the progress of the Work and evaluate potential schedule impacts of proposed changes to the Contract Documents; and,
  5. Assist in detecting problems for the purpose of taking corrective action and to provide a mechanism or tool for determining and monitoring such corrective actions.
- C. In developing the Schedule, the Contractor will be responsible for assuring that Subcontractor Work at all tiers, as well as Contractor's own Work, is included in the Schedule and well coordinated in a logical and reasonable plan of the Work.
- D. Time is of the essence. The Work will be prosecuted such that it will ensure meeting the specified Contract Time. By execution of the Agreement, the Contractor represents that he

has analyzed the Work, the materials and methods involved, the systems of the building, availability of qualified labor, restrictions of the Work Sites, constraints imposed, their own workload and capacity to perform the Work, and agrees that the specified times are reasonable considering the existing conditions prevailing in the locality of the Work, including weather conditions, and other factors, with reasonable allowance for variations from average or ideal conditions.

- E. The Preliminary Contract and Contract Schedules must be developed utilizing the Precedence Diagramming Method. The Contractor must use the latest version of Primavera P6 Enterprise Project Portfolio Management for scheduling the Work.
- F. Milestones
  1. The Milestone completion dates indicated are considered essential to the satisfactory performance of this Project and to the coordination of all Work therein.
  2. Milestone dates will not be changed by submission of a Schedule that shows earlier or later completion dates, unless specifically authorized by a Change Order.
- G. Float Time
  1. Total Float is the number of days by which an activity may be delayed without adversely affecting the Milestone completion date(s). Total Float is measured in reference to the Milestone date(s), and not the latest calculated Schedule finish date.
  2. Longest Critical Path is the longest series of dependent activities within the Schedule that determines when the Work of a Milestone or the entire Work of the Project is complete.
  3. A Critical Activity is one whose Total Float is equal to or less than zero, and whose Early Finish dates are equal to or later than the Late Finish dates by which it must be performed for the Project to complete by the Milestone date(s). A Critical Activity may or may not be on the Longest Critical Path.
  4. Project Float is the number of Days between the Contractor's Scheduled date for completion of the Work as indicated by its Longest Critical Path, and the Contract Time specified for the completion date of the Milestone.
  5. Float is not for the exclusive use or benefit of either the Contractor or Owner. Float time will be apportioned according to the needs of the Project and as accepted by Owner.
  6. An Early Completion Schedule is one that reflects earlier completion than the Contract final milestone completion date. In the event the Contractor submits an Early Completion Schedule, the difference between the Schedule's calculated completion and the final Milestone completion date will be considered part of the available Project float and will be subject to the float sharing requirements set forth herein. The Contractor will not be entitled to any Contract Time extensions, or extended Work Site expenses on account of any delays to the Schedule early completion dates unless all Project float has been consumed and performance of the Work extends beyond the Milestone dates.
  7. Owner reserves the right to issue a Change Order revising the Contract Time and associated Milestones to those indicated in the Contractor's Early Completion Schedule.
  8. The use of float suppression techniques such as preferential sequencing, special lead/lag logic restraints, unjustifiably extended activity durations, or constrained dates is not allowed and will be grounds for rejection of the Contract Schedule or any revisions or updates thereto.
- H. The Contractor must engage its major Subcontractors in the development and updating of all submitted Schedules and receives their buy-in on the Schedule prior to submittal.

- I. The Contractor must submit, for Owner's approval, the resume of their proposed Project Scheduler who will be responsible for developing, maintaining and providing Time Impact Analyses of the Schedules. The Project Scheduler must be proficient in CPM scheduling using Primavera P6 software, have demonstrated experience in Projects with similar scheduling complexity and requirements, and be capable of fulfilling the requirements of this Section.
- J. Acceptance by Owner of the Contractor's Schedule does not relieve the Contractor of any responsibility whatsoever for the accuracy or feasibility of the Schedule, or of the Contractor's ability to meet the Contract Time or Milestone dates, nor does such acceptance acknowledge or admit the reasonableness of the activities, logic, durations, manpower, or cost-loading of the Contractor's Schedule.
- K. Failure by the Contractor to include any element of Work required for performance of the Work or failure to properly sequence the Work will not excuse the Contractor from completing all Work within the Contract Time, regardless of Owner's Acceptance of the Contract Schedule.

15 PRELIMINARY CONTRACT SCHEDULE

- A. Within fourteen (14) Days after the date of the NTP, the Contractor must submit, for Owner's review, a Preliminary Contract Schedule. This Schedule must show detailed activities for Work to be completed in the first ninety (90) Days of the Project. All Work planned to be performed during the remainder of the Project performance period may be represented by summary activities.
- B. The Preliminary Contract Schedule must indicate Milestones for the Project and define the following:
  - 1. Proposed procurement activities to be accomplished during the first ninety (90) Days of the Project. Procurement activities must include product data and/or shop drawing submittals, submittals review and approval as well as fabrication and delivery of key and long lead procurement elements.
  - 2. Proposed construction activities to be accomplished during the first ninety (90) Days of the Project. For those activities, activity durations must be in units of whole working days and must be limited to a maximum of fifteen (15) working days for each activity, unless otherwise specified herein.
  - 3. Summary activities not included above, which are necessary to properly indicate the approach to scheduling the remaining Work areas or phases of the Work. The Work for each phase or area must be represented by at least one summary activity such that they cumulatively indicate the entire Work. The approximate cost and duration for each summary activity must be shown on the Preliminary Contract Schedule.
- C. The Preliminary Contract Schedule must conform to the requirements in Paragraph 1.7 of this Section.
- D. The cost-loaded Preliminary Contract Schedule accepted by Owner must be used as the Accepted Schedule of Values for progress payments during the first sixty (60) Days of the Project while the Contract Schedule (discussed hereafter) is being developed and accepted.
- E. The Preliminary Contract Schedule must be updated on a monthly basis while the Contract Schedule is being developed. The monthly updating of the Preliminary Contract Schedule

must be consistent with the procedures and requirements described in Paragraph 1.8 of this

Section.

- F. The Accepted Preliminary Contract Schedule must be used for the review of time extension request(s) during the first ninety (90) Days of the Project while the Contract Schedule is being developed.
- G. Within seven (7) Days after receipt by Owner of the Preliminary Contract Schedule, Owner will make recommendations to the Contractor as to adjustments to the Preliminary Contract Schedule. These recommendations, if accepted by both Owner and Contractor, will be incorporated into the development of the Contract Schedule. The Contractor must provide a response to the concerns of Owner, to its satisfaction, before the submittal of the Contract Schedule.
- H. Once accepted by Owner, the Preliminary Contract Schedule will form the basis of the initial Accepted Contract Schedule.

#### 1.6 CONTRACT SCHEDULE

- A. Within forty five (45) Days following Notice to Proceed, Contractor must submit to Owner a proposed Contract Schedule in CPM format.
- B. The proposed Contract Schedule must conform to the requirements in Paragraph 1.7 of this Section. The Contractor must use the Accepted Preliminary Contract Schedule and Owner comments thereon as the basis for the Contract Schedule.
- C. The proposed Contract Schedule will be reviewed in the following manner:
  - 1. Within fourteen (14) Days after receipt by Owner of the proposed Contract Schedule, Owner will notify the Contractor of any concerns it may have in regard to the Schedule.
  - 2. If Owner questions the Contractor's proposed activities, logic, durations, manpower, or cost loading, the Contractor must, within seven (7) Days after receipt of Owner's request, provide a satisfactory revision to, or adequate justification for, these activities, logic, durations, manpower, or cost-loading to the satisfaction of Owner.
  - 3. Upon the Contractor addressing the comments and Contract Schedule requirements to the satisfaction of Owner, the Owner will accept the proposed Contract Schedule and it will then be considered the Accepted Contract Schedule.
  - 4. In the event the Contractor fails to define any element of Work, activity or logic and Owner's review does not note this omission or error, such omission or error, when discovered by the Contractor or Owner, must be corrected by the Contractor and immediately submitted to Owner as a schedule revision request (see Paragraph 1.9) and will not affect the Contract Time.
- D. Accepted Contract Schedule
  - 1. The Accepted Contract Schedule will be used as the baseline to evaluate all Work yet to be performed and subsequent updates to the Contract Schedule.
  - 2. No activity is to be deleted from the initial Accepted Contract Schedule. In the event that an activity is no longer appropriate to the plan, either by change order or otherwise, it must be statused with "zero duration" as of the date such determination is made and offsetting cost adjustment made as required to balance within the activity's cost account.
  - 3. Redistribution of costs between activities will not be allowed, except after submission of a schedule revision request and with the written approval of Owner.
  - 4. Acceptance by Owner of the Contractor's Contract Schedule will be a condition precedent to the making of any progress payments after the first ninety (90) Days of the Contract.
  - 5. Upon Acceptance of the Contract Schedule by Owner, the cost-loaded values of the

Schedule will be used as the Accepted Schedule of Values for determining progress payments. Monthly progress payments will be based upon information developed during the monthly Schedule Update progress. The computer-produced cost report must be structured to directly roll up to the accepted billing summary and will be utilized by Owner for verification of the progress payment request submitted by the Contractor.

6. The cost-loaded values for detailed activities planned to be performed during the first ninety (90) Days after the NTP, as reflected by the Owner accepted Preliminary Contract Schedule, must remain unchanged in the Contract Schedule. Cost-loaded values for summary activities occurring thereafter must be further detailed in the Contract Schedule.
- E. The initial Contract Schedule submission must reflect the Contractor's initial "plan of execution" as contemplated at the date of the Notice to Proceed, with no regard for actual progress or conditions encountered through the preparation time for its submittal.
- F. If requested by Owner, the Contractor must furnish a written narrative of the Contractor's determination of durations and or sequence of Critical Activities. Such explanation must include the number of crews, crew composition, number of shifts per day, number of hours in a shift and the number of work days per week.

#### 1.7 TECHNICAL REQUIREMENTS

##### A. General:

1. Milestone dates must be adhered to and must be clearly identified on the Schedule.
2. Milestone dates must not be changed without the written consent of Owner via an executed Change Order
3. Agreement Start Milestones must be constrained by "Start On or before", or "Start No Earlier Than" constraints.
4. Agreement Completion Milestones must be constrained by "Finish On or before" constraints.
5. "Mandatory", "Start On", and "Finish On" constraints will not be allowed.
6. All other phasing & sequencing requirements prescribed in the Contract Documents must be represented by the use of appropriate constraints, as agreed to by Owner.

##### B. Scope Definition:

1. Activities scheduled to occur in the first ninety (90) Days in the Preliminary Contract Schedule and the entire Contract Schedule must be developed to an acceptable level of detail that is adequate for progress monitoring and payment evaluation, as determined by Owner. The level of detail of the Contractor's Schedule will be a function of the complexity of the Work involved. Construction activities must represent the continuous work of a single crew in a defined Work area or location and have duration of no longer than fifteen (15) work days, unless otherwise accepted by Owner. Non-construction activities (such as procurement, fabrication, etc.) may have durations in excess of fifteen (15) work days.
2. Activity descriptions must be unique, full, clear and readily identifiable from Construction Documents.
3. Activity IDs must be alpha-numeric, indicating the activity's building, area and location.
4. Indicate a responsibility code for each activity. Responsibility for each activity must be identified with a single performing organization, typically the Subcontractor name.
5. If requested by Owner Representative, the Schedule activities must also be assigned a code indicating the relevant Specification Section or drawing number.
6. The Schedule must be organized in a Work Breakdown Structure as agreed by Owner to

assist in understanding work flow and sequencing.

7. The Schedule must reflect the entire scope of Work required by the Contract Documents, including but not limited to:
  - a. Submittal & Procurement activities as set out under Paragraph C below.
  - b. Field testing of equipment and materials.
  - c. Detailed activities for mobilization, all temporary and preparatory Work necessary before the commencement of construction activities.
  - d. A finish milestone type activity denoting the "dry-in' of each building.
  - e. All construction of mock-ups, and prototypes and/or samples.
  - f. Work by Owner: Include a separate activity for each portion of Work performed by Owner.
  - g. Separate activities for Owner furnished products.
  - h. Separate activities for submittals, fabrication & delivery and installation of Contractor-Furnished-Contractor-Installed (CFCI) and Owner-Furnished- Contractor-Installed (OFICI) items.
  - i. Activities for Furnishings, Fixtures & Equipment (FFE) installation, whether performed by the Contractor or Owner.
- J. Complete startup, testing and commissioning sequence at each building / major area, including but not limited to: final utility connections, start-up & pre- functional testing of equipment/system, testing & balancing for water / air system, functional performance testing and building flush-out. The schedule must include all testing activities conducted by or authorities having jurisdiction. Allow a minimum of fifteen (15) working days for startup, testing and commissioning at each building / major area.
- k. All close-out activities including:
  - 1) Preparation and submittal of operations and maintenance manuals and as-built documents;
  - 2) Demonstration and training;
  - 3) Final cleanup;
  - 4) Owner pre-final inspection, Contractor certification of Milestone Completion Date, punch list development, Contractor's correction of punch list, Owner final inspection at each building and major areas as may be applicable. Activity duration for punch list development and punch list correction must be no less than fourteen (14) Days and twenty one (21) Days, respectively.

C. Submittals:

1. The Schedule must identify detailed activities for the following:
  - a. Preparation, review and approval of all Submittals which are key to timely and orderly completion of Work or as required by Owner's representative.
  - b. Procurement Activities: for all long lead items and / or major items requiring a total duration for all tasks below of more than sixty (60) Days, the Schedule must show a sequence of activities, including:
    - 1) Preparation of shop drawings and sample submissions.
    - 2) Review and approval of shop drawings and samples: Include review and re-submittal times specified in Section 01 33 00, Submittal Procedures, in the Schedule. Coordinate submittal review dates and durations in the Schedule with the Submittal Log.
    - 3) Anticipated execution date of purchase order.
    - 4) Shop fabrication time.
    - 5) Delivery time.

D. Durations:

1. Use "one workday" as the unit of time. Include list of nonworking days and holidays incorporated into the Schedule as a calendar. Calendars should account for all work hour restrictions, institutional holidays and security access requirements set forth under Section 01 35 53.
2. All activities whose durations are stipulated by the Contract Documents, as well as Milestones, must be Scheduled on a 7-day work week calendar
3. Proposed durations assigned to each activity will be the Contractor's best estimate of time required to complete the activity considering the scope and resources planned for the activity. However, activity durations and / or dates must not be resource driven.

E. Logic Network:

1. Include all constraints, phasing or Work restrictions indicated in the Contract Documents.
2. All activity start and finish ends must be tied into the Schedule by logical restraints. The Schedule must only contain two (2) open ended activities: NTP with no predecessor relationship, and the latest completion Milestone with no successor relationship.
3. All activities requiring time to complete must be included in the Schedule as an activity (Cure time, etc.).
4. The Schedule must not include any Start-to-Finish relationships.
5. The Schedule must not include any negative lags or finish-to-start relationships with positive lag. Lags in Start-to-Start or Finish-to-Finish relationships must not exceed the duration of the predecessor or successor activity, respectively.
6. The Schedule's Longest Critical Path must be comprised of the anticipated controlling operations, which are most significant in nature and are key for completing the Work per the Milestone dates.
7. The number of critical and near critical activities must be kept to a minimum and must not exceed twenty (20) percent. A near Critical Activity is one who's Total Float value is less than twenty (20) working days.
8. With the exception of Milestones, the use of constraints that override Schedule calculated early or late dates will not be allowed.
9. Acceptance of the Schedule will not preclude Owner from later rejecting what it deems to be float suppression. Correction of float suppression must be a prerequisite for consideration of any Milestone adjustment.

F. WEATHER

1. ANTICIPATED WEATHER DAYS

a. Time allowance for inclement weather:

- 1) Normal weather conditions shall be considered and included in the planning and scheduling of all weather-sensitive schedule activities. The amount of time allowed for inclement weather is defined in this section. Schedule activity duration(s) shall be formulated with allowance for normal weather conditions. Any activity which could be impacted by normally anticipated inclement weather (precipitation, high or low temperature, wind, etc.), or the effects thereof shall include an adjustment to include the anticipated weather impact from normal

Weather conditions. "Inclement weather" is a lost workday, caused by inclement weather conditions, and is defined as a day in which the Contractor's planned workforce for a critical path activity cannot work 50 percent or more of

the day on an activity on the critical path, thereby resulting in a delay to the critical path.

2) A "Rain Day" will only be a day where rain precipitation is greater than 0.10" within a 24-hour period as measured at the Salinas Municipal Airport NOAA station.

b. Weather related delays shall not entitle the Contractor to any additional compensation. The sole remedy of the Contractor shall be to seek a non-compensable extension of time.

## 2. INCLEMENT WEATHER ALLOWANCE

The County expects the Contractor to include in the duration of their activities an allowance for the average amount of inclement weather that would be expected to occur. The Contractor will find below the historic average data provided by the County to be used in developing the schedule. The normal inclement weather conditions have been determined by an assessment of average historical climatic conditions using the preceding ten (10) year records published by the National Ocean and Atmospheric Administration (NOAA).

<b>Month</b>	<b>Allowance (Work Days)</b>
January	6
February	6
March	6
April	3
May	1
June	0
July	0
August	0
September	0
October	2
November	3
December	6

## 3. WEATHER CALENDAR AND ACCOUNTING OF DAYS

a. The Contractor shall include a calendar for weather sensitive activities. This calendar shall be a working day calendar that includes the above stated Inclement Weather Allowance and all County holidays. The weather allowance for each month shall be shown as non-working



days and spread throughout the corresponding month. The weather calendar shall be assigned to all weather sensitive activities in the schedule.

- b. The accounting of weather days shall occur once monthly corresponding to the Monthly Schedule Update. The actual non-working days affecting the critical path attributable to weather shall be accounted for in the Weekly Statement of Contract Time, as prepared by the County, independent of the weather allowance. Actual weather days shall be added to the schedule monthly as a one work day schedule activity inserted behind the data date with an actual date equal to the non-working day as reflected in the Weekly Statement of Contract Time. A monthly reconciliation will occur between the inclement weather allowance and actual weather impact, as reflected in the Weekly Statement of Contract Time. Should the Contractor meet all contract requirements for demonstrating unavoidable delay, the Contractor shall be granted a time extension for actual weather impact days, beyond the weather allowance days for the same time period, for activities on the critical path.
  - c. No contract time adjustment shall be made in the event that actual non-working days attributable to weather affecting the critical path DOES NOT exceed the allowance. Unused weather allowance shall become project float.
  - d. No time extensions will be allowed due to inclement weather unless it impacts the Contract Time as demonstrated by a Time Impact Analysis prepared in accordance with Paragraph 1.12 of this Section.
- G. Cost Loading:
1. Schedule activities must be cost-loaded in whole dollars and the assigned dollar value of the Schedule activities must cumulatively equal the total Contract Price. The tasks and amounts in the cost-loaded Schedule will be utilized as the Accepted Schedule of Values for progress payment purposes.
  2. Payment for Mobilization, Insurance and Bonds must be listed separately. Copies of paid invoices for bonds and insurance must be submitted with the Preliminary Contract Schedule for reimbursement.
  3. Activities must only be assigned their respective direct costs and must not include any Contractor overhead and / or markups. The Schedule must identify a separate activity running throughout the Project duration with the budgeted cost of all of the Contractor's time-related overhead including, but not limited to Work Site expenses and indirect cost, home office overhead, profit and contingency.
  4. Payment for overhead costs will be made on a time-related basis, where the percent earned through each Schedule Update's Data Date will equal the percent of time lapsed from the NTP with respect to the Final Completion Milestone.
  5. Schedule procurement activities must not be cost-loaded. Material and equipment costs must be included in their respective installation activity(s) and identified separately as a Material type resource. Assigned Material and Equipment costs must not include any indirect costs. Any reimbursement of materials and equipment prior to their installation will be subject to the requirements of Section 00 72 08, Payments and Retention.
  6. With the exception of Milestones and Submittal activities, any and all activities performed by the Contractor or any of its Subcontractors must be cost-loaded.
  7. Excluding Material and Equipment costs, Schedule activities must not have individual dollar values in excess of \$100,000.
  8. The cost-loading of activities must be commensurate with the true value of labor, equipment and material. Unbalanced, inconsistent, or front-end loaded cost allocation is prohibited and will be grounds for rejection of the Contractor's Schedule.

9. The sum of all assigned costs for each Subcontractor must be equal to the value of their Subcontract with the Contractor.

H. Resource Loading:

1. Contractor will assign manpower-loading for each construction activity in the Schedule. Activities' resource loading must be based on the Contractor's estimate used in pricing the Work.
2. Resources and labor (man-hours) allocated to each activity must be consistent with activity duration as well as scope and supported by the Contractor's estimate and industry standard estimating / productivity guides such as "Means" and/or "Walker's".
3. The Schedule activities must not be resource leveled or resource constrained.

I. Reports: for the Preliminary Contract and Contract Schedules, provide:

1. An electronic copy of Schedule in P6 format, and labeled to comply with requirements for submittals. Include type of Schedule (Preliminary Contract, Contract Schedule, Update or Revision), revision number and date on label.
2. Narrative explaining:
  - a. The Schedule's general plan, sequencing and major crew rotation.
  - b. Work restrictions and / or constraints accounted for in the Schedule.
  - c. Adequate substantiation of critical and near-critical activities, identifying those to be performed by Owner.
  - d. The anticipated impact of weather delays on and how it has been accounted for in the Schedule.
  - e. Assumptions used for activity durations, assumptions regarding crew sizes, equipment requirements and production rates.
  - f. Any potential areas of concern or specific areas requiring coordination it may have identified.
  - g. Any long-lead time materials or equipment in the Work.
  - h. Major construction equipment intended for use on this Project's operations including types, number of units, unit capacities and the proposed time each piece of equipment will be on the job, keyed to the activities on which the equipment will be used
  - i. Any proposed deviations from the Contract scheduling requirements with adequate justification.
3. Activity Table grouped by WBS and sorted by Early Finish, including Activity ID, Activity Name, Original Duration, Early & Late dates, Total Float, Calendar together with a color coded Gantt Chart (Red being Longest Critical Path, Green Being non- critical) showing logic links. Activity Table must show subtotals per major area and Schedule Grand Totals.
4. Same report as described above filtered for the Longest Critical Path activities only.
5. Activity Table listing Activity ID, Activity Name, Original Duration, and Start & Finish dates, Total Float, Predecessors and Successors, together with a color coded Gantt chart showing logic links.
6. Activity Table including Activity ID, Activity Name, Original Duration, Start & Finish dates, Total Float, Activity Budgeted Cost, Activity Budgeted Labor Units, and Responsibility Code together with a color coded Gantt chart. Activity Table must show subtotals per major area and Schedule Grand Totals.
7. Manpower curve and histogram of Budgeted Labor hours per Major Subcontractor per Month (Initial Submittal and when revised).

- A. Update pertains to, and is limited to, the posting of actual progress of all activities.
- B. Logic changes, Schedule of Values adjustments, addition or deletion of activities, modifications to activity original durations are all considered Schedule revisions and must be submitted separately in a Schedule Revision request.
- C. On a monthly basis, the Contractor must meet with Owner for the purpose of updating the Schedule. This updating process will be performed by Owner and Contractor making an assessment of Schedule activity progress during a joint Work Site walkthrough with Owner's representative.
- D. Consistent with information recorded during the joint Work Site walkthrough, the Schedule must be updated with:
  - 1. Actual Start and Actual Finish dates, consistent with dates provided by the Contractor's Daily Report.
  - 2. Actual Start & Finish dates inserted into the Schedule must only be based on the activity's physical progress, irrespective of the dollar amount earned. Billing for stored materials and /or equipment does not constitute an Actual Start of an activity.
  - 3. Activity Physical Percent Complete, based on the actual progress of the activity through the update Data Date.
  - 4. Activity Remaining Duration and Duration Percent Complete.
  - 5. Dollar amounts earned for each activity during the update period, which must be the product of the activity's budgeted cost and the Physical Percent complete through the update Data Date.
- E. Once this information has been recorded, this data will be processed by computer by the Contractor, and will be used as the basis for the Contractor's monthly progress payment.
- F. In addition to these monthly updates, interim updates may be performed on the Contract Schedule at the discretion of Owner. While these interim updates will not be for payment purposes, the Contractor must provide such update data to Owner as required completing these updates.
- G. Logical relationships between activities performed out of sequence during the month of the schedule update, must be adjusted after their completion to reflect the actual sequence and must be identified in the accompanying narrative report. Sequence revisions occurring beyond the Update's data date must be submitted to Owner Representative per 1.9 C.
- H. All Change Orders must be added to the Schedule Updates at an appropriate level of detail, including responsible Subcontractor, activity value and manpower, consistent with the executed proposed Change Order
- I. The Schedule update calculations must:
  - 1. Retain the existing logic relationships when activities start or finish out-of-sequence. The use of "Progress Override" is prohibited;
  - 2. Not be resource leveled. Activity dates and durations must not be driven by assigned resources;
  - 3. Dissociate remaining duration from activity's Physical Percent Complete.
- J. Neither acceptance, nor lack of Owner's comment on a Schedule Update that shows late completion will modify the Contract Time or Milestones.
- K. Approved schedule revision requests and comments provided by Owner representative on the preceding month's update must be incorporated into the schedule

- L. Upon finalization of the computerized Schedule update, the Contractor must submit the following reports for the processing of the Contractor's payment application:
1. An electronic copy of the Schedule Update in P6 format.
  2. Activity Table including Activity ID, Activity Name, Original Duration, Remaining Duration, Physical Percent Complete, Start (Early or Actual Start), Finish (Early or Actual Finish), Total Float, Activity Budgeted Total Cost, Actual Period Cost, Actual Total Cost, Cost to Complete, together with a color coded Gantt Chart showing logic links. Activity Table must show subtotals per major area and Grand Totals.
  3. Activity Table and Gantt chart including Activity ID, Activity Name, Original Duration, Remaining Duration, latest Accepted Contract Schedule Start / Finish Dates & Total Float, current update Start / Finish dates & Total Float, and Finish Variance. Activity Table must show subtotals per major area and Grand Totals.
  4. Narrative report describing:
    - a. Actual Work performed during the reporting period.
    - b. Any areas of concern, current or anticipated Schedule impacts and proposed corrective actions to mitigate those impacts.
    - c. Corrected out-of-sequence occurrences in addition to any changes or deviations from the planned sequence as reflected in the Accepted Contract Schedule.
    - d. Proposed revisions, including added or deleted Work that will be submitted before the next schedule update via a schedule revision request.
    - e. The current Schedule's critical path Work and any changes thereto from the previous update. Review of Contractor's interface and coordination with other Work on the Project.
    - f. A list of major construction equipment used on the Work during the reporting period and any construction equipment idle during the reporting period.
    - g. A total number of labor by craft actually engaged on the Work during the reporting period, with such total stated separately as to office, supervisory, and direct labor per Subcontractor.
  5. The current status of long lead items and equipment and critical material deliveries.
- M. Progress Payments:
1. The submission and acceptance of progress updates and the cost reports calculating the value of Work done for any given pay period for each activity, based on the percentage complete for that activity, will be the basis for monthly progress payments.
  2. The monthly updating of the Contract Schedule must be an integral part and basic element of the estimate upon which progress payments will be made. If, in the judgment of Owner, the Contractor fails or refuses to provide information required to accomplish a complete Contract Schedule update, or has included unapproved revisions in the Schedule update, the Contractor will be deemed to have not provided the required estimate upon which progress payments may be made, and will not be entitled to progress payments until all necessary information has been provided to the satisfaction of Owner.

## 19 REVISED CONTRACT SCHEDULE

- A. Updating the Contract Schedule to reflect actual progress will not be considered revisions to the Contract Schedule.
- B. If, as a result of the monthly Schedule Update, the Contract Schedule no longer represents the actual prosecution and progress of the Work, or if Owner believes further Schedule detailing

Is necessary, upon Owner's request, the Contractor must propose a Revised Contract Schedule, within ten (10) Days.

- C. The Contractor may also request revisions to the Accepted Contract Schedule in the event the Contractor's planned performance methods are revised. If revisions to the Accepted Contract Schedule are contemplated, the Contractor must submit the proposed changes along with a written narrative of the proposed changes. If accepted by Owner, these changes will be incorporated into the Contract Schedule.
- D. Schedule revisions must be submitted utilizing a copy of the most recent Accepted Contract Schedule update as modified with proposed changes; a narrative explanation of the change(s); and a copy of a detailed comparison with the most recent Owner Accepted Contract Schedule update detailing all proposed changes.
- E. Upon acceptance, the revised Contract Schedule becomes the Accepted Contract Schedule and the basis for evaluating future progress payments, status, impacts, and / or changes.

#### 1.10 RECOVERY SCHEDULE

- A. If Owner Representative determines that Contractor's progress is not sufficient to achieve completion of Work within the Milestone dates or any adjustments thereof, Owner Representative may order the Contractor to do any or all of the following, at no cost to Owner:
  - 1. Furnish a plan and / or recovery Schedule, in Contract Schedule format, for improving progress and recovering the Contractor delays.
  - 2. Take steps as necessary to improve progress and advise Owner Representative thereof in writing.
  - 3. Increase the personnel employed, add overtime operations, increase the number of shifts per Day, increase the capacity of construction equipment and plants, change sequence of operations, change methods of operation, or take other steps to improve progress and recover the Contractor's delays.
- B. An order pursuant to the above will not be considered an order for Acceleration.

#### 1.11 SHORT INTERVAL SCHEDULE:

- A. The Contractor must submit, on a weekly basis, a progress Schedule, hereinafter referred to as Short Interval Schedule, listing the activities in progress or completed during the previous week and the activities Scheduled for the succeeding two (2) weeks.
- B. The Short Interval Schedule must be generated out of the Contract Schedule and include further details to provide a day-to-day plan of upcoming Work. All activities shown in this short interval Schedule must be identified by a corresponding Activity ID and Activity Description as shown in the Accepted Contract Schedule.

#### 1.12 TIME IMPACT ANALYSIS

- A. In the event the Contractor encounters an excusable delay and intends to submit a request for time extension, the Contractor must furnish a Time Impact Analysis illustrating the impact of the change or delay on the Milestone durations. The Time Impact Analysis must be prepared in accordance with the requirements set forth below:
  - 1. The impact must be represented by a sub-network of activities, hereinafter referred to as the Impact Fragnet that represents the scope of the change or delay.

2. The impact fragnet will be inserted into a copy of the latest Accepted Contract Schedule update prior to the onset of the impact's effect on the schedule. Said copy is defined as the "Impacted Schedule".
3. The impact fragnet must tie into the existing schedule activities that are immediately impacted by the change or delay. Every reasonable effort to mitigate the potential delay by either isolating its impact or planning "work-around" approaches to the Work must be considered and incorporated where deemed effective.
4. The Impacted Schedule must be calculated compared to the original Accepted Contract Schedule update used for the analysis to quantify the extent of the time adjustment due the Contractor.
5. The delay demonstrated by the Impacted Schedule must not exceed actual delay when the analysis is performed after the fact. The Impact Schedule must incorporate all actual dates and durations known as at the time of its submittal.
6. Correction of float suppression in the Impacted Schedule, as may be determined by Owner, may be a condition precedent to any time adjustment determination. No time extension will be awarded unless the delay: 1) impacts the Longest Critical Path, 2) consumes all available Total Float of the Longest Critical Path whether expressly indicated by the Schedule or embedded in the remaining activity durations and / or sequence, and 3) extends the remaining performance period beyond the Project Milestone date(s).
7. The Contractor must provide adequate justification for the Impact Fragnet durations and linkages to the schedule activities. The Impacted Schedule, along with a narrative describing the foregoing must be submitted to Owner for review.
8. If approved, the impact fragnet will become a permanent part of the Accepted Contract Schedule. The Contractor will not unilaterally make changes to the Accepted Contract Schedule to justify impacts without the approval of Owner.
9. Owner will not have any obligation to consider any time extension request unless the requirements of the General Conditions and of this Section are met. Owner will not be responsible or liable to Contractor for any constructive acceleration due to failure of Owner to grant time extensions should Contractor fail to substantially comply with the submission requirements and the justification requirements of this Contract for time extension requests.
10. If the Contractor is requesting compensation for the delay, the Time Impact Analysis must demonstrate lack of concurrency with other non-excusable or non-compensable critical delays. To establish entitlement to compensation, all activity paths and their respective float must be examined. The Contractor must clearly demonstrate that but-for the Owner caused delay, the Contractor could have finished the Work in accordance with the approved Contract Time.

#### 1.13 AS-BUILT SCHEDULE

As a condition precedent to the release of retention and making final payment, submit an "As-Built Schedule," as the last Schedule update showing all activities at 100 percent completion and indicating Actual Start and Finish Dates. This Schedule must reflect the sequence in which the Project was actually constructed.

PART 2 PRODUCTS - NOT USED  
PART 3 EXECUTION - NOT USED

END OF SECTION

## SECTION 013233 - PHOTOGRAPHIC DOCUMENTATION

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for the following:
  - 1. Preconstruction photographs.
  - 2. Periodic construction photographs.
  - 3. Final completion construction photographs.
- B. Related Requirements:
  - 1. Section 012200 "Unit Prices" for procedures for unit prices for extra photographs.
  - 2. Section 013300 "Submittal Procedures" for submitting photographic documentation.
  - 3. Section 017700 "Closeout Procedures" for submitting photographic documentation as project record documents at Project closeout.
  - 4. Section 017900 "Demonstration and Training" for submitting video recordings of demonstration of equipment and training of Owner's personnel.
  - 5. Section 024116 "Structure Demolition" for photographic documentation before building demolition operations commence.
  - 6. Section 024119 "Selective Structure Demolition" for photographic documentation before selective demolition operations commence.
  - 7. Section 311000 "Site Clearing" for photographic documentation before site clearing operations commence.

#### 1.3 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For photographer and Web-based photographic documentation service provider.
- B. Key Plan: Submit key plan of Project site and building with notation of vantage points marked for location and direction of each photograph. Indicate elevation or story of construction. Include same information as corresponding photographic documentation.
- C. Digital Photographs: Submit image files within three days of taking photographs.
  - 1. Digital Camera: Minimum sensor resolution of 8 megapixels.
  - 2. Format: Minimum 3200 by 2400 pixels, in unaltered original files, with same aspect ratio as the sensor, uncropped, date and time stamped, in folder named by date of photograph, accompanied by key plan file.
  - 3. Identification: Provide the following information with each image description in file metadata tag:

- a. Name of Project.
- b. Name and contact information for photographer.
- c. Name of Architect and Construction Manager.
- d. Name of Contractor.
- e. Date photograph was taken.
- f. Description of vantage point, indicating location, direction (by compass point), and elevation or story of construction.
- g. Unique sequential identifier keyed to accompanying key plan.

#### 1.4 USAGE RIGHTS

- A. Obtain and transfer copyright usage rights from contractor to Owner for unlimited reproduction of photographic documentation.

### PART 2 - PRODUCTS

#### 2.1 PHOTOGRAPHIC MEDIA

- A. Digital Images: Provide images in JPG format, produced by a digital camera with minimum sensor size of 8 megapixels, and at an image resolution of not less than 3200 by 2400 pixels.

### PART 3 - EXECUTION

#### 3.1 CONSTRUCTION PHOTOGRAPHS

- A. General: Take photographs using the maximum range of depth of field, and that are in focus, to clearly show the Work. Photographs with blurry or out-of-focus areas will not be accepted.
  1. Maintain key plan with each set of construction photographs that identifies each photographic location.
- B. Digital Images: Submit digital images exactly as originally recorded in the digital camera, without alteration, manipulation, editing, or modifications using image-editing software.
  1. Date and Time: Include date and time in file name for each image.
  2. Field Office Images: Maintain one set of images accessible in the field office at Project site, available at all times for reference. Identify images in the same manner as those submitted to Architect and Construction Manager.
- C. Preconstruction Photographs: Before starting construction, take photographs of Project site and surrounding properties, including existing items to remain during construction, from different vantage points.
  1. Flag construction limits before taking construction photographs.
  2. Take 20 photographs to Show existing conditions adjacent to Project site before starting the Work.
  3. Take additional photographs as required to record settlement or cracking of adjacent structures, pavements, and improvements.



4. Show protection efforts by Contractor.
    - a. Commencement of the Work, through completion of subgrade construction.
    - b. Above-grade structural framing.
    - c. Exterior building enclosure.
  5. Vantage Points: Following suggestions by Architect, and Construction Manager. Contractor shall select vantage points.
- D. Periodic Construction Photographs: Take 20 photographs monthly, coinciding with the cutoff date associated with each Application for Payment. Select vantage points to show status of construction and progress since last photographs were taken.
- E. Final Completion Construction Photographs: Take 20 photographs after date of Substantial Completion for submission as project record documents.
1. Show existing conditions adjacent to Project site before starting the Work.
  2. Show existing buildings either on or adjoining Project site to accurately record physical conditions at the start of demolition.
  3. Show protection efforts by Contractor.
    - a. Commencement of the Work, through completion of subgrade construction.
    - b. Above-grade structural framing.
    - c. Exterior building enclosure.
  4. Vantage Points: Following suggestions by Architect, and Construction Manager. Contractor shall select vantage points.

END OF SECTION 013233

## SECTION 013300 - SUBMITTAL PROCEDURES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes requirements for the submittal schedule and administrative and procedural requirements for submitting Shop Drawings, Product Data, Samples, and other submittals.
- B. Related Requirements:
  - 1. Section 012900 "Payment Procedures" for submitting Applications for Payment and the schedule of values.
  - 2. Section 013200 "Construction Progress Documentation" for submitting schedules and reports, including Contractor's construction schedule.
  - 3. Section 017823 "Operation and Maintenance Data" for submitting operation and maintenance manuals.
  - 4. Section 017839 "Project Record Documents" for submitting record Drawings, record Specifications, and record Product Data.
  - 5. Section 017900 "Demonstration and Training" for submitting video recordings of demonstration of equipment and training of Owner's personnel.

#### 1.3 DEFINITIONS

- A. Action Submittals: Written and graphic information and physical samples that require Architect's responsive action. Action submittals are those submittals indicated in individual Specification Sections as "action submittals."
- B. Informational Submittals: Written and graphic information and physical samples that do not require Architect's responsive action. Submittals may be rejected for not complying with requirements. Informational submittals are those submittals indicated in individual Specification Sections as "informational submittals."
- C. File Transfer Protocol (FTP): Communications protocol that enables transfer of files to and from another computer over a network and that serves as the basis for standard Internet protocols. An FTP site is a portion of a network located outside of network firewalls within which internal and external users are able to access files.
- D. Portable Document Format (PDF): An open standard file format licensed by Adobe Systems used for representing documents in a device-independent and display resolution-independent fixed-layout document format.

#### 1.4 ACTION SUBMITTALS

- A. Submittal Schedule: Submit a schedule of submittals, arranged in chronological order by dates required by construction schedule. Include time required for review, ordering, manufacturing, fabrication, and delivery when establishing dates. Include additional time required for making corrections or revisions to submittals noted by Architect and additional time for handling and reviewing submittals required by those corrections.
1. Coordinate submittal schedule with list of subcontracts, the schedule of values, and Contractor's construction schedule.
  2. Initial Submittal: Submit concurrently with startup construction schedule. Include submittals required during the first 60 days of construction. List those submittals required to maintain orderly progress of the Work and those required early because of long lead time for manufacture or fabrication.
  3. Final Submittal: Submit concurrently with the first complete submittal of Contractor's construction schedule.
    - a. Submit revised submittal schedule to reflect changes in current status and timing for submittals.
  4. Format: Arrange the following information in a tabular format:
    - a. Scheduled date for first submittal.
    - b. Specification Section number and title.
    - c. Submittal category: Action; informational.
    - d. Name of subcontractor.
    - e. Description of the Work covered.
    - f. Scheduled date for Architect's final release or approval.
    - g. Scheduled date of fabrication.
    - h. Scheduled dates for purchasing.
    - i. Scheduled dates for installation.
    - j. Activity or event number.

#### 1.5 SUBMITTAL ADMINISTRATIVE REQUIREMENTS

- A. Architect's Digital Data Files: Electronic digital data files of the Contract Drawings will be provided by Architect for Contractor's use in preparing submittals.
1. Architect will furnish Contractor one set of digital data drawing files of the Contract Drawings for use in preparing Shop Drawings.
    - a. Architect makes no representations as to the accuracy or completeness of digital data drawing files as they relate to the Contract Drawings.
    - b. Digital Drawing Software Program: The Contract Drawings are available in <Insert name and version of digital drawing software program and operating system>.
    - c. Contractor shall execute a data licensing agreement in the form of AIA Document C106, Digital Data Licensing Agreement
    - d. The following digital data files will be furnished for each appropriate discipline:
      - 1) Floor plans.
      - 2) Reflected ceiling plans.

- B. Coordination: Coordinate preparation and processing of submittals with performance of construction activities.
1. Coordinate each submittal with fabrication, purchasing, testing, delivery, other submittals, and related activities that require sequential activity.
  2. Submit all submittal items required for each Specification Section concurrently unless partial submittals for portions of the Work are indicated on approved submittal schedule.
  3. Submit action submittals and informational submittals required by the same Specification Section as separate packages under separate transmittals.
  4. Coordinate transmittal of different types of submittals for related parts of the Work so processing will not be delayed because of need to review submittals concurrently for coordination.
    - a. Architect reserves Architect reserve the right to withhold action on a submittal requiring coordination with other submittals until related submittals are received.
- C. Processing Time: Allow time for submittal review, including time for resubmittals, as follows. Time for review shall commence on Architect's receipt of submittal. No extension of the Contract Time will be authorized because of failure to transmit submittals enough in advance of the Work to permit processing, including resubmittals.
1. Initial Review: Allow 15 days for initial review of each submittal. Allow additional time if coordination with subsequent submittals is required. Architect will advise Contractor when a submittal being processed must be delayed for coordination.
  2. Intermediate Review: If intermediate submittal is necessary, process it in same manner as initial submittal.
  3. Resubmittal Review: Allow 15 days for review of each resubmittal.
  4. Concurrent Consultant Review: Where the Contract Documents indicate that submittals may be transmitted simultaneously to Architect and to Architect's consultants, allow 15 days for review of each submittal. Submittal will be returned to Construction Manager, through Architect, before being returned to Contractor.
- D. Paper Submittals: Place a permanent label or title block on each submittal item for identification.
1. Indicate name of firm or entity that prepared each submittal on label or title block.
  2. Provide a space approximately 6 by 8 inches (150 by 200 mm) on label or beside title block to record Contractor's review and approval markings and action taken by Architect.
  3. Include the following information for processing and recording action taken:
    - a. Project name.
    - b. Date.
    - c. Name of Architect.
    - d. Name of Construction Manager.
    - e. Name of Contractor.
    - f. Name of subcontractor.
    - g. Name of supplier.
    - h. Name of manufacturer.
    - i. Submittal number or other unique identifier, including revision identifier.
- 1) Submittal number shall use Specification Section number followed by a decimal point and then a sequential number (e.g., 061000.01). Resubmittals shall include an alphabetic suffix after another decimal point (e.g., 061000.01.A).

- j. Number and title of appropriate Specification Section.
  - k. Drawing number and detail references, as appropriate.
  - l. Location(s) where product is to be installed, as appropriate.
  - m. Other necessary identification.
4. Additional Paper Copies: Unless additional copies are required for final submittal, and unless Architect observes noncompliance with provisions in the Contract Documents, initial submittal may serve as final submittal.
- a. Submit one copy of submittal to concurrent reviewer in addition to specified number of copies to Architect and Construction Manager.
5. Transmittal for Paper Submittals: Assemble each submittal individually and appropriately for transmittal and handling. Transmit each submittal using a transmittal form. Architect and Construction Manager will return without review.
6. Transmittal Form for Paper Submittals:
- a. Transmittal Form for Paper Submittals: Provide locations on form for the following information:
    - 1) Project name.
    - 2) Date.
    - 3) Destination (To:).
    - 4) Source (From:).
    - 5) Name and address of Architect.
    - 6) Name of Construction Manager.
    - 7) Name of Contractor.
    - 8) Name of firm or entity that prepared submittal.
    - 9) Names of subcontractor, manufacturer, and supplier.
    - 10) Category and type of submittal.
    - 11) Submittal purpose and description.
    - 12) Specification Section number and title.
    - 13) Specification paragraph number or drawing designation and generic name for each of multiple items.
    - 14) Drawing number and detail references, as appropriate.
    - 15) Indication of full or partial submittal.
    - 16) Transmittal number, numbered consecutively.
    - 17) Submittal and transmittal distribution record.
    - 18) Remarks.
    - 19) Signature of transmitter.
- E. Electronic Submittals: Identify and incorporate information in each electronic submittal file as follows:
1. Assemble complete submittal package into a single indexed file incorporating submittal requirements of a single Specification Section and transmittal form with links enabling navigation to each item.
  2. Name file with submittal number or other unique identifier, including revision identifier.
    - a. File name shall use project identifier and Specification Section number followed by a decimal point and then a sequential number (e.g., LNHS-061000.01). Resubmittals shall include an alphabetic suffix after another decimal point (e.g., LNHS-061000.01.A).

3. Provide means for insertion to permanently record Contractor's review and approval markings and action taken by Architect.
  4. Transmittal Form for Electronic Submittals: Use electronic form acceptable to Owner, containing the following information:
    - a. Project name.
    - b. Date.
    - c. Name and address of Architect.
    - d. Name of Construction Manager.
    - e. Name of Contractor.
    - f. Name of firm or entity that prepared submittal.
    - g. Names of subcontractor, manufacturer, and supplier.
    - h. Category and type of submittal.
    - i. Submittal purpose and description.
    - j. Specification Section number and title.
    - k. Specification paragraph number or drawing designation and generic name for each of multiple items.
    - l. Drawing number and detail references, as appropriate.
    - m. Location(s) where product is to be installed, as appropriate.
    - n. Related physical samples submitted directly.
    - o. Indication of full or partial submittal.
    - p. Transmittal number, numbered consecutively.
    - q. Submittal and transmittal distribution record.
    - r. Other necessary identification.
    - s. Remarks.
  5. Metadata: Include the following information as keywords in the electronic submittal file metadata:
    - a. Project name.
    - b. Number and title of appropriate Specification Section.
    - c. Manufacturer name.
    - d. Product name.
- F. Options: Identify options requiring selection by Architect.
- G. Deviations and Additional Information: On an attached separate sheet, prepared on Contractor's letterhead, record relevant information, requests for data, revisions other than those requested by Architect on previous submittals, and deviations from requirements in the Contract Documents, including minor variations and limitations. Include same identification information as related submittal.
- H. Resubmittals: Make resubmittals in same form and number of copies as initial submittal.
  1. Note date and content of previous submittal.
  2. Note date and content of revision in label or title block and clearly indicate extent of revision.
  3. Resubmit submittals until they are marked with approval notation from Architect's and Construction Manager's action stamp.
- I. Distribution: Furnish copies of final submittals to manufacturers, subcontractors, suppliers, fabricators, installers, authorities having jurisdiction, and others as necessary for performance of construction activities. Show distribution on transmittal forms.

- J. Use for Construction: Retain complete copies of submittals on Project site. Use only final action submittals that are marked with approval notation from Architect's action stamp.

## PART 2 - PRODUCTS

### 2.1 SUBMITTAL PROCEDURES

- A. General Submittal Procedure Requirements: Prepare and submit submittals required by individual Specification Sections. Types of submittals are indicated in individual Specification Sections.
1. Post electronic submittals as PDF electronic files directly to Architect's FTP site specifically established for Project.
    - a. Architect will return annotated file. Annotate and retain one copy of file as an electronic Project record document file.
  2. Action Submittals: Submit three paper copies of each submittal unless otherwise indicated. Architect, through Construction Manager, will return two copies.
  3. Informational Submittals: Submit two paper copies of each submittal unless otherwise indicated. Architect and Construction Manager will not return copies.
  4. Certificates and Certifications Submittals: Provide a statement that includes signature of entity responsible for preparing certification. Certificates and certifications shall be signed by an officer or other individual authorized to sign documents on behalf of that entity.
    - a. Provide a digital signature with digital certificate on electronically submitted certificates and certifications where indicated.
- B. Product Data: Collect information into a single submittal for each element of construction and type of product or equipment.
1. If information must be specially prepared for submittal because standard published data are not suitable for use, submit as Shop Drawings, not as Product Data.
  2. Mark each copy of each submittal to show which products and options are applicable.
  3. Include the following information, as applicable:
    - a. Manufacturer's catalog cuts.
    - b. Manufacturer's product specifications.
    - c. Standard color charts.
    - d. Statement of compliance with specified referenced standards.
    - e. Testing by recognized testing agency.
    - f. Application of testing agency labels and seals.
    - g. Notation of coordination requirements.
    - h. Availability and delivery time information.
  4. For equipment, include the following in addition to the above, as applicable:
    - a. Wiring diagrams showing factory-installed wiring.
    - b. Printed performance curves.
    - c. Operational range diagrams.

- d. Clearances required to other construction, if not indicated on accompanying Shop Drawings.
  5. Submit Product Data before or concurrent with Samples.
  6. Submit Product Data in the following format:
    - a. PDF electronic file.
- C. Shop Drawings: Prepare Project-specific information, drawn accurately to scale. Do not base Shop Drawings on reproductions of the Contract Documents or standard printed data, unless submittal based on Architect's digital data drawing files is otherwise permitted.
1. Preparation: Fully illustrate requirements in the Contract Documents. Include the following information, as applicable:
    - a. Identification of products.
    - b. Schedules.
    - c. Compliance with specified standards.
    - d. Notation of coordination requirements.
    - e. Notation of dimensions established by field measurement.
    - f. Relationship and attachment to adjoining construction clearly indicated.
    - g. Seal and signature of professional engineer if specified.
  2. Sheet Size: Except for templates, patterns, and similar full-size drawings, submit Shop Drawings on sheets at least 8-1/2 by 11 inches (215 by 280 mm), but no larger than 30 by 42 inches (750 by 1067 mm).
  3. Submit Shop Drawings in the following format:
    - a. PDF electronic file.
- D. Samples: Submit Samples for review of kind, color, pattern, and texture for a check of these characteristics with other elements and for a comparison of these characteristics between submittal and actual component as delivered and installed.
1. Transmit Samples that contain multiple, related components such as accessories together in one submittal package.
  2. Identification: Attach label on unexposed side of Samples that includes the following:
    - a. Generic description of Sample.
    - b. Product name and name of manufacturer.
    - c. Sample source.
    - d. Number and title of applicable Specification Section.
    - e. Specification paragraph number and generic name of each item.
  3. For projects where electronic submittals are required, provide corresponding electronic submittal of Sample transmittal, digital image file illustrating Sample characteristics, and identification information for record.
  4. Disposition: Maintain sets of approved Samples at Project site, available for quality-control comparisons throughout the course of construction activity. Sample sets may be used to determine final acceptance of construction associated with each set.
    - a. Samples that may be incorporated into the Work are indicated in individual Specification Sections. Such Samples must be in an undamaged condition at time of use.



- b. Samples not incorporated into the Work, or otherwise designated as Owner's property, are the property of Contractor.
- 5. Samples for Initial Selection: Submit manufacturer's color charts consisting of units or sections of units showing the full range of colors, textures, and patterns available.
  - a. Number of Samples: Submit one full set(s) of available choices where color, pattern, texture, or similar characteristics are required to be selected from manufacturer's product line. Architect, will return submittal with options selected.
- 6. Samples for Verification: Submit full-size units or Samples of size indicated, prepared from same material to be used for the Work, cured and finished in manner specified, and physically identical with material or product proposed for use, and that show full range of color and texture variations expected. Samples include, but are not limited to, the following: partial sections of manufactured or fabricated components; small cuts or containers of materials; complete units of repetitively used materials; swatches showing color, texture, and pattern; color range sets; and components used for independent testing and inspection.
  - a. Number of Samples: Submit three sets of Samples. Architect and Construction Manager will retain two Sample sets; remainder will be returned. Mark up and retain one returned Sample set as a project record sample.
    - 1) Submit a single Sample where assembly details, workmanship, fabrication techniques, connections, operation, and other similar characteristics are to be demonstrated.
    - 2) If variation in color, pattern, texture, or other characteristic is inherent in material or product represented by a Sample, submit at least three sets of paired units that show approximate limits of variations.
- E. Product Schedule: As required in individual Specification Sections, prepare a written summary indicating types of products required for the Work and their intended location. Include the following information in tabular form:
  - 1. Type of product. Include unique identifier for each product indicated in the Contract Documents or assigned by Contractor if none is indicated.
  - 2. Manufacturer and product name, and model number if applicable.
  - 3. Number and name of room or space.
  - 4. Location within room or space.
  - 5. Submit product schedule in the following format:
    - a. PDF electronic file.
- F. Coordination Drawing Submittals: Comply with requirements specified in Section 013100 "Project Management and Coordination."
- G. Contractor's Construction Schedule: Comply with requirements specified in Section 013200 "Construction Progress Documentation."
- H. Application for Payment and Schedule of Values: Comply with requirements specified in Section 012900 "Payment Procedures."
- I. Test and Inspection Reports and Schedule of Tests and Inspections Submittals: Comply with requirements specified in Section 014000 "Quality Requirements."

- J. Closeout Submittals and Maintenance Material Submittals: Comply with requirements specified in Section 017700 "Closeout Procedures."
- K. Maintenance Data: Comply with requirements specified in Section 017823 "Operation and Maintenance Data."
- L. Welding Certificates: Prepare written certification that welding procedures and personnel comply with requirements in the Contract Documents. Submit record of Welding Procedure Specification and Procedure Qualification Record on AWS forms. Include names of firms and personnel certified.
- M. Installer Certificates: Submit written statements on manufacturer's letterhead certifying that Installer complies with requirements in the Contract Documents and, where required, is authorized by manufacturer for this specific Project.
- N. Manufacturer Certificates: Submit written statements on manufacturer's letterhead certifying that manufacturer complies with requirements in the Contract Documents. Include evidence of manufacturing experience where required.
- O. Product Certificates: Submit written statements on manufacturer's letterhead certifying that product complies with requirements in the Contract Documents.
- P. Material Certificates: Submit written statements on manufacturer's letterhead certifying that material complies with requirements in the Contract Documents.
- Q. Material Test Reports: Submit reports written by a qualified testing agency, on testing agency's standard form, indicating and interpreting test results of material for compliance with requirements in the Contract Documents.
- R. Product Test Reports: Submit written reports indicating that current product produced by manufacturer complies with requirements in the Contract Documents. Base reports on evaluation of tests performed by manufacturer and witnessed by a qualified testing agency, or on comprehensive tests performed by a qualified testing agency.
- S. Research Reports: Submit written evidence, from a model code organization acceptable to authorities having jurisdiction, that product complies with building code in effect for Project. Include the following information:
  - 1. Name of evaluation organization.
  - 2. Date of evaluation.
  - 3. Time period when report is in effect.
  - 4. Product and manufacturers' names.
  - 5. Description of product.
  - 6. Test procedures and results.
  - 7. Limitations of use.
- T. Preconstruction Test Reports: Submit reports written by a qualified testing agency, on testing agency's standard form, indicating and interpreting results of tests performed before installation of product, for compliance with performance requirements in the Contract Documents.
- U. Compatibility Test Reports: Submit reports written by a qualified testing agency, on testing agency's standard form, indicating and interpreting results of compatibility tests performed before installation of product. Include written recommendations for primers and substrate preparation needed for adhesion.

- V. Field Test Reports: Submit written reports indicating and interpreting results of field tests performed either during installation of product or after product is installed in its final location, for compliance with requirements in the Contract Documents.
- W. Design Data: Prepare and submit written and graphic information, including, but not limited to, performance and design criteria, list of applicable codes and regulations, and calculations. Include list of assumptions and other performance and design criteria and a summary of loads. Include load diagrams if applicable. Provide name and version of software, if any, used for calculations. Include page numbers.

## 2.2 DELEGATED-DESIGN SERVICES

- A. Performance and Design Criteria: Where professional design services or certifications by a design professional are specifically required of Contractor by the Contract Documents, provide products and systems complying with specific performance and design criteria indicated.
  - 1. If criteria indicated are not sufficient to perform services or certification required, submit a written request for additional information to Architect.
- B. Delegated-Design Services Certification: In addition to Shop Drawings, Product Data, and other required submittals, submit digitally signed PDF electronic file and three paper copies of certificate, signed and sealed by the responsible design professional, for each product and system specifically assigned to Contractor to be designed or certified by a design professional.
  - 1. Indicate that products and systems comply with performance and design criteria in the Contract Documents. Include list of codes, loads, and other factors used in performing these services.

## PART 3 - EXECUTION

### 3.1 CONTRACTOR'S REVIEW

- A. Action and Informational Submittals: Review each submittal and check for coordination with other Work of the Contract and for compliance with the Contract Documents. Note corrections and field dimensions. Mark with approval stamp before submitting to Architect through the Construction Manager.
- B. Project Closeout and Maintenance Material Submittals: See requirements in Section 017700 "Closeout Procedures."
- C. Approval Stamp: Stamp each submittal with a uniform, approval stamp. Include Project name and location, submittal number, Specification Section title and number, name of reviewer, date of Contractor's approval, and statement certifying that submittal has been reviewed, checked, and approved for compliance with the Contract Documents.

### 3.2 ARCHITECT'S AND CONSTRUCTION MANAGER'S ACTION

- A. Action Submittals: Architect and Construction Manager will review each submittal, make marks to indicate corrections or revisions required, and return it. Architect and Construction Manager will stamp each submittal with an action stamp and will mark stamp appropriately to indicate action.

- B. Informational Submittals: Architect will review each submittal and will not return it, or will return it if it does not comply with requirements. Architect will forward each submittal to appropriate party.
- C. Partial submittals prepared for a portion of the Work will be reviewed when use of partial submittals has received prior approval from Architect.
- D. Incomplete submittals are unacceptable, will be considered nonresponsive, and will be returned for resubmittal without review.
- E. Submittals not required by the Contract Documents may be returned by the Architect without action.

END OF SECTION 013300

## SECTION 013513.16 – SPECIAL PROJECT PROCEDURES FOR DETENTION FACILITIES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.
- B. Limits and scope of work under the Detention Equipment Contractor (DEC) Section shall be defined in these specifications and correspondingly shown on the drawings.
- C. Provide materials, labor, equipment and services necessary to furnish, deliver and install a completely functional integrated system.
- D. All equipment and work shall comply with all applicable codes.

#### 1.2 SUMMARY

- A. This Section includes the responsibilities for a single-source Detention Equipment Contractor (DEC) for detention work.
  - 1. The DEC shall submit an aggregate bid for Work described in the following specification sections. The details and specific Scope of Work related to the installation of the equipment shall be defined between the DEC and General Contractor at the time of Bid. The DEC shall be responsible for performing the coordination required between detention equipment and the security electronic systems, as well as the Electrical work as it relates to security hardware.
    - a. Detention Equipment Work required by, but not specified in, this Section includes the following:
      - 1) Section 083463, Detention Doors and Frames including Sidelites and interior Security Windows
      - 2) Section 087163, Detention Door Hardware
      - 3) Section 088853, Security Glazing
  - 2. Approved DEC firms must base their bid on the equipment and products specified herein. Design changes or substitutions will not be allowed unless approved prior to bidding. Value engineering proposals will not be considered.
  - 3. The DEC shall have in their employ a full time project manager and superintendent to supervise the work of this section. The superintendent's sole responsibility shall be to supervise and coordinate the scope of work of the DEC. The superintendent shall be at the site at all times when the work is being performed.
  - 4. If any portion of the work listed in paragraph 1.2.A.1.a above is subcontracted, the responsibility for equipment and system coordination remains with the DEC.

5. The DEC shall be fully responsible for review and coordination of detention devices with the security electronic drawings and specifications. The DEC shall notify the Architect / Consultant if any modifications are required prior to hardware or device installation.
6. The DEC shall be fully responsible for acquiring and paying for any and all licenses and permits required to perform their Work. If licenses are required before bidding, then the DEC shall not bid any portion of the Work until the required licenses are obtained.

### 1.3 SCOPE AND RESPONSIBILITY:

- A. The DEC shall be fully responsible for performing the coordination required between the Division 08 Detention Scope of Work with the Division 28 Security Electronics Scope of Work.
- B. The DEC shall be responsible for the coordination, integration and interfacing of the products and systems specified in Division 8 and Division 28, and in accordance with shop drawings and submittals approved by the Architect / Consultant.
- C. The DEC shall be responsible for all labor and equipment for receiving, unloading, distributing, setting and installation of all security related items. This includes, but may not be limited to, bars, plates, angles, access frames and doors, security frames and security sidelights, and miscellaneous security frames specified in Division 8.
- D. Under the requirements of this Section, the DEC shall be responsible for furnishing and installing the following, as specified in all locations. The details and specific scope of work related to a portion of the installation of this equipment shall be defined between the DEC and General Contractor at the time of Bid.
  1. Detention Hollow Metal Frames, Sidelights, and Interior Security Windows.
  2. Detention Hollow Metal Doors.
  3. Detention Hardware.
  4. Security and Non-Security Glass and Glazing for Security Hollow Metal and Security Windows.
- E. Installation of all systems and equipment is subject to clarifications as indicated in the reviewed shop drawings and field coordination drawings.
- F. The DEC shall be fully responsible for acquiring and paying for all licenses and permits required to perform their Work. If licenses are required before bidding, then the DEC shall not bid any portion of the Work until the required licenses are obtained.

### 1.4 SUBMITTALS

- A. General: Submittals shall be made in accordance with Conditions of Contract and Division 1 Sections. DEC shall review Detention Work submittals and verify construction details and provide answers to manufacturer's questions prior to submission to the General Contractor. Submittals shall be supplied on USB drive.
- B. Product Data: Mark each copy to show applicable choices and options where printed product data includes information on several products, some of which are not required, mark copies to indicate the applicable information.

- C. Shop Drawings: Highlight, encircle, or otherwise indicate deviations from the Contract Documents.
- D. Coordination Drawings: Prepare and submit Project-specific Coordination Drawings, drawn accurately to scale, for installation of detention work. Include the following information, as applicable:
  - 1. Show relationship of components shown on separate Shop Drawings.
  - 2. Show dimensions and clearances of interrelated detention work.
  - 3. Provide templates and patterns.
  - 4. Indicate required operation sequences of interrelated detention work.
  - 5. Indicate required installation sequences.
  - 6. Refer to Division 26 for specific Coordination Drawing requirements for electrical installations required for detention work.
- E. The submittal shall reflect the equipment and material as they are defined by the project plans and specifications, contract and signed/documented clarifications, substitutions and changes to the above documents by the Architect.
- F. It is the DEC's responsibility to coordinate detention/security items in this scope of work, and to answer all manufacturer questions or concerns that are not strictly design related. The DEC shall redline the manufacturers' individual shop drawings and/or schedules, and note corrections prior to submittal for Architectural/Consultant review. When multiple items are submitted by the manufacturer on a single cut sheet, the DEC shall note with an arrow, circle or note cloud, to show which product on the sheet is submitted for this scope of work. DEC submittals not reviewed and redlined prior to submittal to Architect/Consultant for final review, will be returned rejected.
- G. Qualified installers trained by the manufacturer shall perform the installation of all detention hardware and sliding devices. **Submittal of written confirmation from the manufacturer showing individual field technicians as approved installers shall be required.**
- H. The submittal documents shall be updated throughout the project construction. These documents shall be included with the operation and maintenance manuals to provide accurate as-built documentation of all installed equipment and material.
- I. Other Informational Submittals:
  - 1. Examination reports documenting inspections of substrates, areas, and conditions.
- J. Submittals not organized as specified shall be considered incomplete and will be rejected.

#### 1.5 OPERATING/MAINTENANCE MANUALS

- A. DEC shall furnish three (3) copies of Operation and Maintenance Manuals for all security and non-security items furnished under this specification. These manuals shall include:
  - 1. Instructions for the care and operation of the materials.
  - 2. Parts list with exploded views of material with moving parts to aid the Owner with ordering replacement parts.

3. Telephone, Fax, Address, website and instructions for contacting the appropriate personnel during the warranty period as well as for service.
  4. Refer to division 1 specification for additional requirements.
- B. Operation and Maintenance Manual shall include information for every mechanical item with moving parts and every electrical item submitted in the approved hardware schedule. This is to include all material in the related submittal and is not limited to “detention” equipment.
- C. Submittals shall be “AS BUILT” documents and shall include all changes from approved submittal documents clearly noted on each sheet. The document type and the document number that initiated the final change shall be clearly noted on these as builds.
- D. The owner has the right to request an interactive Operation Manual in place of the printed hard copy manuals described above. The interactive manual will utilize the files described above as a basis for an interactive document utilizing a web browser. All manuals, files, and data sheets would be published in a format compatible with Internet Browsers equal to Microsoft Internet Explorer. Hyperlinks would link each item in a master table of contents to individual manuals, shop drawings, and files. The DEC shall clarify with the owner the type of documentation required.
- E. Submittals not organized as specified shall be considered incomplete and will be rejected.

#### 1.6 SUBSTITUTIONS

- A. No substitutions of equipment or material will be permitted where specific trade names or a manufacturer is listed, unless the architect adds them by an addendum.
- B. Materials and products specified by name of manufacturer or brand trade name shall be the basis of the bids received unless changed by addendum prior to the bid dates.
- C. In the event a contractor wishes to use any materials or products other than those specified he shall make a written request to the Architect, naming the proposed substitution. All substitutions of locksets, must be accompanied by a written letter from the manufacturer stating that the substituted lockset matches the specified lockset function exactly as shown in the individual hardware sets per specification section 087163.
- D. All additional costs resulting from the use of an approved substitution shall be borne by the contractor without additional expense to the Owner. Such additional costs shall include necessary modifications and alterations to structures, equipment, raceways and furnishing of all additional materials required to affect the substitution.

#### 1.7 QUALITY ASSURANCE

- A. The following DEC's are pre-approved to perform the work of this Section:
1. CCC Group, Inc., San Antonio, TX: Phone 210-662-1694
  2. CML RW Security, Erie, Co: Phone 720-466-3650
  3. Cornerstone Detention Products, Inc., Decatur, AL: Phone 256-355-2396
  4. ISI Detention Contracting, San Antonio, TX: Phone 210-495-5245



5. Sierra Detention Systems, Brighton, CO: 303-278-6879
6. Southern Folger Detention Equipment Company, San Antonio, TX: Phone 210-533-1231 or other Southern Folger certified Detention Equipment Contractors

- B. Approval of a firm as a DEC does not relieve that DEC from furnishing all materials from the manufacturers as herein specified.
- C. All materials and labor specified in this Section of the Specifications shall be furnished by a single qualified DEC who shall assume responsibility for the detailing, coordinating, erecting, performance, and warranty of this work, in accordance with this specification.
- D. Qualified installers trained by the manufacturer shall perform the installation of all detention hardware and sliding devices. **Submittal of written confirmation from the manufacturer showing individual field technicians as approved installers shall be required.**

#### 1.8 COORDINATION

- A. Coordinate work to ensure efficient and orderly installation of each part of detention work. Coordinate and schedule detention work that depends on other work for proper and timely installation, connection, and operation.
  1. Coordinate installation of different detention components to ensure maximum accessibility for required maintenance, service, and repair.
  2. Coordinate provisions to accommodate detention work scheduled for later installation.
  3. Coordinate detention work with work by the Electronic Security Contractor (ESC).
- B. Coordinate selection of detention products for compatibility.
- C. Assemble and coordinate Shop Drawings for detention work provided by separate entities.
- D. Coordinate sequencing and scheduling of detention work. Secure time commitments for performing critical construction activities from separate entities responsible for detention work.
  1. Schedule construction operations in sequence required to obtain best results where installation of one part of detention work depends on installation of other components, before or after its own installation.
  2. Coordinate sequence of detention work activities to accommodate tests and inspections.
- E. Coordinate installation of anchorages and embedments for detention work. Obtain and distribute, to parties involved, setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors, that are to be embedded in concrete or masonry. Deliver such items to Project site in time for installation so as not to delay progress of the Work.
  1. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing detention work to comply with indicated requirements.
- F. Coordinate temporary facilities and controls required by detention work.
  1. Maintain an ongoing inventory of all material.

2. Arrange for a secure, dry, locked storage area or room in the building for storing detention equipment products prior to installation.
3. Receive, unload and distribute products to site storage location and/or installation locations. Minor scratches on painted surfaces shall be cleaned and touched-up with rust-inhibitive primer. Defective disfigured products shall be rejected.
4. Tag all products with markings that show proper installation locations.

G. Coordinate protection of installed detention work.

H. Coordinate preparation of Project Record Documents for detention work and integrate information from entities responsible for detention work to form one combined record.

I. Coordinate preparation of operation and maintenance manuals for detention work and integrate information from entities responsible for detention work to form one combined record.

J. Defective Products: Items found to be defective, either through manufacturing, damage in transit or by field installation, shall be replaced prior to final completion. DEC shall make special manufacturing and shipping arrangements to accomplish this replacement prior to completion.

K. Coordination Meetings: Conduct coordination meetings specifically for detention work at regular intervals. Coordination meetings are in addition to specific meetings held for other purposes, such as progress meetings and pre-installation conferences.

## 1.9 WARRANTY

A. The DEC shall warrant the material and equipment and labor furnished by the DEC under this Section to be free from defects in material and workmanship for a period of two (2) years after substantial completion. Should written notice be served on the DEC during the warranty period of any such defect, the DEC shall make good the defect at its own expense. Coordination of warranty problems between division 8 and 27/28 shall be the responsibility of the DEC.

B. The DEC must have full-time employees trained in and devoted to the maintenance and repair of systems and equipment furnished.

C. The DEC shall provide warranty service throughout the warranty period in a timely manner.

1. Service response requirements shall include the following:

- a. Twenty-four (24) hour phone number.
- b. DEC shall respond to warranty call within twenty-four (24) hours of notification.
- c. Response personnel shall be factory technicians trained by the manufacturers of the equipment, with five years experience, servicing equipment of the type included in this project.

## PART 2 - PRODUCTS (NOT USED)

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- A. Ensure quality of field welding of detention work and anchorages.
- B. Verify that detention work is installed and connected according to the Contract Documents.
- C. Verify that wiring installation complies with manufacturer's submittal and written installation requirements in Division 26, 27 and 28 Sections.
- D. Observe startup service of detention work.
- E. Observe installation and startup checks of detention work according to manufacturer's written instructions.
- F. Inspect installed detention work to verify compliance with requirements. Prepare inspection reports and indicate compliance with and deviations from the Contract Documents.
  - 1. Perform additional inspections to determine compliance of replaced or additional work.
  - 2. Prepare field quality-control certification that states installed detention work and its installation complies with requirements in the Contract Documents.
- G. Testing: After installing electrified detention work and after electrical circuitry has been installed, energized and is functional, test detention work for compliance with requirements.
  - 1. When testing reveals detention work is not in compliance with requirements, perform additional random testing to determine extent of noncompliance.
  - 2. Where test results indicate that detention work does not comply with specified requirements, retest after repairs or replacements are made.
- H. Perform additional testing and inspecting, at Contractor's expense, to determine compliance of replaced or additional work.

### 3.2 INSPECTIONS AND TESTING

- A. The General Contractor / Construction Manager and DEC shall be responsible for issuing a letter to the Architect and R&N Systems Design, LLC confirming that the work is complete and ready for inspection and testing. If the project is completed in phases, a letter will be submitted for each phase to be inspected. As an attachment to the letter confirming the work is "complete" and ready for inspection, the DEC must attach a self generated "field test" report for each device which confirms in detail that the DEC has performed their own inspection and test prior to the inspection by the Architect / Consultant.
- B. The inspection shall include control and monitoring of the hardware, as well as the installation and adjustments of the mechanical functions.

- C. The Superintendent and Project Manager shall be present and assist in the inspection / testing of the Work.
  - 1. If additional inspections are required because the Work is incomplete at the time of the scheduled inspection or if any portion of the system fails to function as designed, the DEC shall be responsible for paying for the time and expenses for the Architect and Security Consultant to re-schedule and re-inspect the Work. This cost shall include time and expense for all personnel of the Architectural and Security Consulting firm. The “time” cost shall include an hourly rate of \$190 per hour. This time will include travel time and inspection time. An estimated amount of this time and expense must be paid prior to re-scheduling the inspection.

### 3.3 SPARE PARTS

- A. The DEC shall deliver all spare parts at the completion of the project. The spare parts shall be clearly marked as to content and packaged for ease of handling by one (1) person without the use of forklifts or other equipment. The DEC shall obtain a signature from the owner’s representative receiving the spare parts.
- B. The DEC shall furnish the parts described in each subsection of the specifications provided by the DEC. Mark the specification section on the packaging for each device. **Refer to individual specification sections for spare parts to be provided as a requirement for each section.**

### 3.4 TRAINING

- A. The DEC shall provide without additional cost to the Owner, representatives specially trained in the operation of detention hardware and devices provided. The representatives shall train the Owner’s personnel in operations, repair, and upkeep of all Detention Work. Coordinate dates for training sessions with the Owner prior to scheduling dates.
- B. The DEC shall be responsible for notifying the Architect five (5) weeks prior to substantial completion of the total security system that training is scheduled. The DEC will coordinate the number to be trained with the Owner’s representative.
- C. The inspection shall include Systems, Subsystems, Equipment, and Components. Where these terms are used together or separately, they shall be referred to as “the system”. The DEC shall be prepared to test every point for each system.
- D. On-Site Training: Provide qualified personnel for instruction and a training period involving the Owner’s designated personnel and the DEC as designated by the user. Representatives must be capable of training Owner’s personnel in the adjustment, operation and repair of detention work, including pertinent safety requirements. Instruction shall be given during the first week after detention work has been accepted and turned over to the Owner for regular operation, except if adjustment and/or repairs are required for its use. In such case, training sessions are not to occur until such adjustments and/or repairs have been satisfactorily completed.
  - 1. On-site instruction and training shall include a minimum of four (4) consecutive eight (8) hour days.
  - 2. Training shall be coordinated with the scheduled training period for Division 27/28 work.

3. Training sessions to be videotaped. Tapes to be given to Owner.
  4. In addition to the training requirements listed above the DEC shall include all associated cost to provide additional onsite owner training following substantial completion. The additional training shall occur at the three (3) month period and shall cover topics as referenced in paragraph "D" above. Coordinate this additional training with the owner.
- E. During the warranty period, if significant changes or modifications take place in the equipment or system, additional instruction shall be provided at no cost to the Owner (unless such changes or modifications are Owner initiated) to acquaint the operating personnel with the changes or modifications.
- F. Training Certification
1. Each facility employee shall receive at the conclusion of the security systems training program a certificate certifying his attendance of the total session or portion thereof.
- G. DEC shall maintain attendance records of each class. This attendance shall be submitted to the Architect at the completion of training.

### STATEMENT OF QUALIFICATIONS

SUBMITTED BY:	Corporation	○
NAME:	Partnership	○
ADDRESS:	Individual	○
TELEPHONE NO.:	Joint Venture	○
FAX NO.:	Other	○
PRINCIPAL OFFICE:		

RESPONSE MEDIUM: Bind all files and information submitted into a single PDF searchable for keywords. Files less than 5 Megabytes can be emailed. Larger files must be located on an ftp or Box site with an emailed link.

#### TYPE OF WORK:

The Detention Equipment Contractor (DEC): The DEC shall be responsible for furnishing and installing custom fabricated detention hollow metal frames, detention doors, and detention glazing. The DEC shall be responsible for final installation adjustment of doors and hardware and final installation of detention glazing. The Scope of Work for this contractor will be defined in the drawings and specifications prepared by R&N Systems Design, LLC and the Architect.

The Detention Equipment Contractor (DEC) shall furnish at least 5 project references for correctional facilities of similar size and scope. DEC may list projects that are completed or currently under construction. Do not list projects completed before 2009. Include only project references where the DEC **self-performed** the detention equipment scope of work. Detention hollow metal, detention doors, and detention glazing must have all been furnished and installed by this contractor as a complete package.

Where there is not sufficient space in the form for a complete answer, insert the words "Refer to attached sheet" and add a page copying the referenced question and paragraph number at the top of the page. Each page shall reference one question for clarity.

**1. ORGANIZATION**

- 1.1 How many years has your organization been in business as a Detention Equipment Contractor (DEC)?
- 1.2 How many years has your organization been in business under its present business name?
  - 1.2.1 Under what other or former names has your organization operated?  
(Attach additional details with reference to this paragraph number if required.)

<u>Year</u>	<u>Name of Organization</u>	<u>Principal Owners</u>
-------------	-----------------------------	-------------------------

- 1.3 If your organization is a corporation, answer the following:
  - 1.3.1 Date of incorporation:
  - 1.3.2 State of incorporation:
  - 1.3.3 President's name:
  - 1.3.4 Vice-president's name(s):
  - 1.3.5 Secretary's name:
  - 1.3.6 Treasurer's name:
  - 1.3.7 ESOP Companies (list Board of Directors and Trustee)
- 1.4 If your organization is a partnership, answer the following:
  - 1.4.1 Date of organization:
  - 1.4.2 Type of partnership (if applicable):
  - 1.4.3 Name(s) of general partner(s):
- 1.5 If your organization is individually owned, answer the following:
  - 1.5.1 Date of organization:
  - 1.5.2 Name of owner:
- 1.6 If the form of your organization is other than those listed above, describe it and name the principals or owner: (Attach additional details with reference to this paragraph number if required.)

**2. LICENSING**

- 2.1 List jurisdictions and trade categories in which your organization is legally qualified to do business, and indicate registration or license numbers, if applicable. (Attach additional details with reference to this paragraph number if required.)
- 2.2 List license information for the State of California.
- 2.3 List jurisdictions in which your organization's partnership or trade name is filed.

**3. EXPERIENCE**

Check (√) the categories of work that your organization normally performs with its own forces:

Manufacturer	Supply	Installation	DETENTION EQUIPMENT
			Security Hollow Metal Doors
			Security Hollow Metal Frames
			Security Woven Rod Mesh Partitions and Doors
			Steel Grate Partitions and Doors
			Security Doors and Frames
			Security Metal Windows
			Security Hardware
			Locking Devices for Sliding Doors
			Security Glazing
			Security Furnishings
			Detention Hollow Metal Wall Panel Systems
			Security Ceilings

3.1 List 5 project references for correctional facilities of similar size and scope. Projects can be either or actively under construction. Do not list projects completed complete before 2009. (Attach additional pages giving details with reference to this paragraph number.) Provide the following:

1. Name of project.
2. Name of Owner. (Provide contact name and phone number.)
3. Name of Architect / Engineer. (Provide contact name and phone number.)
4. Name of General Contractor (If applicable) (Provide contact name and phone number.)
5. Contract Amount.
6. Occupancy.
7. List the year the project was/will be completed.
8. List the projects delivery method: (Design-Bid-Build, Design-Build)

3.2 In addition to the projects above, list the construction projects the organization currently has in progress with detention equipment subcontracts for correctional facilities. Provide the following:

1. Name of project:
2. Name of Owner. (Provide contact name and phone number.)
3. Name of Architect / Engineer. (Provide contact name and phone number.)



4. Name of General Contractor (If applicable) (Provide contact name and phone number.)
5. Contract Amount.
6. Occupancy.
7. List the anticipated year the project will be completed.
8. List the projects delivery method: (Design-Bid-Build, Design-Build)

3.4 State annual amount of detention equipment work performed during the past five years:

2011:

2012:

2013:

2014:

2015:

3.5 State total worth of detention equipment work currently under contract and in progress as of September 1, 2016.

3.6 Claims and Suits. List separately for each scope category listed above. (If the answer to any of the questions below is yes, please attach details with reference to the paragraph number).

3.6.1 Has your organization ever failed to complete any work awarded to it?

3.6.2 Are there any judgments, claims, arbitration proceedings or suits pending or outstanding against your organization or its officers?

3.6.3 Has your organization filed any law suits or requested arbitration with regard to construction contracts within the last five years?

3.7 Within the last five years, has any officer or principal of your organization ever been an officer or principal in another organization when it failed to complete a construction contract? (If the answer is yes, please attach details referencing this paragraph number.)

#### **4. PERSONNEL**

4.1 Provide an Attachment referencing this paragraph number, providing the following:

4.1.1 Specifically designate the superintendent that will be assigned to this project. This person must have experience in the past 5 years with correctional facilities. Provide a brief resume of this person, highlighting their experience.

4.2 Provide an Attachment referencing this paragraph number, providing the following:

4.2.1 Specifically designate the senior project manager that will be assigned to this project. This person must have experience in the past 5 years with correctional facilities. Provide a brief resume of this person, highlighting their experience.

## 5. REFERENCES

### 5.1 Architect/Engineer References (list three):

5.1.1 Name:  
Contact:  
Address:  
Telephone:

5.1.2 Name:  
Contact:  
Address:  
Telephone:

5.1.3 Name:  
Contact:  
Address:  
Telephone:

### 5.2 Owner References (list three):

5.2.1 Name:  
Address:  
Telephone:

5.2.2 Name:  
Address:  
Telephone:

5.2.3 Name:  
Address:  
Telephone:

## 6. SURETY

6.1 Name of bonding company:

6.2 Name and address of agent:

6.3 Provide a letter from your bonding company that states your current bonding capacity:

## **7. FINANCING**

### **7.1 Bankruptcy**

7.1.1 Has your organization filed bankruptcy in the past five (5) years? If yes, list the year in which bankruptcy was filed.

7.1.2 Has your organization under a previous name or other organizations that you have acquired ever filed bankruptcy?

If yes, list the organization's name and the year in which bankruptcy was filed.

7.1.3 Have any of the key personnel managing the scope of work defined in this qualification been a member of or employed by an entity that filed bankruptcy in the past five years?

If yes, list the organization's name and the year in which bankruptcy was filed.

## **8. MANUFACTURER CERTIFICATION:**

8.1 Along with the above required documents, the qualifying DEC shall be required to submit a written letter from an approved detention hardware manufacturer stating that individual field technicians employed by the DEC have been approved as installers.

**Submission Due Date: Electronic PDF must be received by 5:00 pm central time on TBD**  
**Email file or link to Frank Niedzwiedz - frankn@msystemsdesign.com.**

The Undersigned certifies that the information provided herein is true and sufficiently complete so as not to be misleading.

**SIGNATURE**

Dated this \_\_\_\_\_ day of \_\_\_\_\_ 2015.

Name of Organization: \_\_\_\_\_

(Signature) By: \_\_\_\_\_

Title: \_\_\_\_\_

(Printed) \_\_\_\_\_ certifies that the information provided herein is true and sufficiently complete so as not to be misleading.

Subscribed and sworn before me this \_\_\_\_\_ day of \_\_\_\_\_ 2015

Notary Public: \_\_\_\_\_

(Seal)

My Commission Expires:

END OF SECTION 013513.16

## SECTION 014000 - QUALITY REQUIREMENTS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for quality assurance and quality control.
- B. Testing and inspecting services are required to verify compliance with requirements specified or indicated. These services do not relieve Contractor of responsibility for compliance with the Contract Document requirements.
  - 1. Specific quality-assurance and -control requirements for individual construction activities are specified in the Sections that specify those activities. Requirements in those Sections may also cover production of standard products.
  - 2. Specified tests, inspections, and related actions do not limit Contractor's other quality-assurance and -control procedures that facilitate compliance with the Contract Document requirements.
  - 3. Requirements for Contractor to provide quality-assurance and -control services required by Architect, Owner, or authorities having jurisdiction are not limited by provisions of this Section.
  - 4. Specific test and inspection requirements are not specified in this Section.

#### 1.3 DEFINITIONS

- A. Quality-Assurance Services: Activities, actions, and procedures performed before and during execution of the Work to guard against defects and deficiencies and substantiate that proposed construction will comply with requirements.
- B. Quality-Control Services: Tests, inspections, procedures, and related actions during and after execution of the Work to evaluate that actual products incorporated into the Work and completed construction comply with requirements. Services do not include contract enforcement activities performed by Architect.
- C. Mockups: Full-size physical assemblies that are constructed on-site. Mockups are constructed to verify selections made under Sample submittals; to demonstrate aesthetic effects and, where indicated, qualities of materials and execution; to review coordination, testing, or operation; to show interface between dissimilar materials; and to demonstrate compliance with specified installation tolerances. Mockups are not Samples. Unless otherwise indicated, approved mockups establish the standard by which the Work will be judged.
  - 1. Mockups: Full-size physical assemblies constructed at testing facility to verify performance characteristics.
  - 2. Integrated Mockups: Mockups consisting of multiple products, assemblies, and subassemblies.

3. Room Mockups: Mockups of typical interior spaces complete with wall, floor, and ceiling finishes, doors, windows, millwork, casework, specialties, furnishings and equipment, and lighting.
- D. Preconstruction Testing: Tests and inspections performed specifically for Project before products and materials are incorporated into the Work, to verify performance or compliance with specified criteria.
- E. Product Testing: Tests and inspections that are performed by an NRTL, an NVLAP, or a testing agency qualified to conduct product testing and acceptable to authorities having jurisdiction, to establish product performance and compliance with specified requirements.
- F. Source Quality-Control Testing: Tests and inspections that are performed at the source, e.g., plant, mill, factory, or shop.
- G. Field Quality-Control Testing: Tests and inspections that are performed on-site for installation of the Work and for completed Work.
- H. Testing Agency: An entity engaged to perform specific tests, inspections, or both. Testing laboratory shall mean the same as testing agency.
- I. Installer/Applicator/Erector: Contractor or another entity engaged by Contractor as an employee, Subcontractor, or Sub-subcontractor, to perform a particular construction operation, including installation, erection, application, and similar operations.
  1. Use of trade-specific terminology in referring to a trade or entity does not require that certain construction activities be performed by accredited or unionized individuals, or that requirements specified apply exclusively to specific trade(s).
- J. Experienced: When used with an entity or individual, "experienced" means having successfully completed a minimum of five previous projects similar in nature, size, and extent to this Project; being familiar with special requirements indicated; and having complied with requirements of authorities having jurisdiction.

#### 1.4 CONFLICTING REQUIREMENTS

- A. Referenced Standards: If compliance with two or more standards is specified and the standards establish different or conflicting requirements for minimum quantities or quality levels, comply with the most stringent requirement. Refer conflicting requirements that are different, but apparently equal, to Architect for a decision before proceeding.
- B. Minimum Quantity or Quality Levels: The quantity or quality level shown or specified shall be the minimum provided or performed. The actual installation may comply exactly with the minimum quantity or quality specified, or it may exceed the minimum within reasonable limits. To comply with these requirements, indicated numeric values are minimum or maximum, as appropriate, for the context of requirements. Refer uncertainties to Architect for a decision before proceeding.

#### 1.5 ACTION SUBMITTALS

- A. Shop Drawings: For mockups, provide plans, sections, and elevations, indicating materials and size of mockup construction.

1. Indicate manufacturer and model number of individual components.
2. Provide axonometric drawings for conditions difficult to illustrate in two dimensions.

#### 1.6 INFORMATIONAL SUBMITTALS

- A. Contractor's Quality-Control Plan: For quality-assurance and quality-control activities and responsibilities.
- B. Qualification Data : For Contractor's quality-control personnel.
- C. Contractor's Statement of Responsibility: When required by authorities having jurisdiction, submit copy of written statement of responsibility sent to authorities having jurisdiction before starting work on the following systems:
  1. Seismic-force-resisting system, designated seismic system, or component listed in the designated seismic system quality-assurance plan prepared by Architect.
  2. Main wind-force-resisting system or a wind-resisting component listed in the wind-force-resisting system quality-assurance plan prepared by Architect.

#### 1.7 CONTRACTOR'S QUALITY-CONTROL PLAN

- A. Quality-Control Plan, General: Submit quality-control plan within 10 days of Notice to Proceed, and not less than five days prior to preconstruction conference. Submit in format acceptable to Architect. Identify personnel, procedures, controls, instructions, tests, records, and forms to be used to carry out Contractor's quality-assurance and quality-control responsibilities. Coordinate with Contractor's construction schedule.
- B. Quality-Control Personnel Qualifications: Engage qualified full-time personnel trained and experienced in managing and executing quality-assurance and quality-control procedures similar in nature and extent to those required for Project.
  1. Project quality-control manager may also serve as Project superintendent.
- C. Submittal Procedure: Describe procedures for ensuring compliance with requirements through review and management of submittal process. Indicate qualifications of personnel responsible for submittal review.
- D. Testing and Inspection: In quality-control plan, include a comprehensive schedule of Work requiring testing or inspection, including the following:
  1. Contractor-performed tests and inspections including subcontractor-performed tests and inspections. Include required tests and inspections and Contractor-elected tests and inspections.
  2. Special inspections required by authorities having jurisdiction and indicated on the "Statement of Special Inspections."
  3. Owner-performed tests and inspections indicated in the Contract Documents, including tests and inspections indicated to be performed by the Commissioning Authority.
- E. Continuous Inspection of Workmanship: Describe process for continuous inspection during construction to identify and correct deficiencies in workmanship in addition to testing and inspection specified. Indicate types of corrective actions to be required to bring work into compliance with standards of workmanship established by Contract requirements and approved mockups.

- F. **Monitoring and Documentation:** Maintain testing and inspection reports including log of approved and rejected results. Include work Architect has indicated as nonconforming or defective. Indicate corrective actions taken to bring nonconforming work into compliance with requirements. Comply with requirements of authorities having jurisdiction.

## 1.8 REPORTS AND DOCUMENTS

- A. **Inspection Reports:** Prepare and submit certified written reports specified in other Sections. Include the following:
1. Date of issue.
  2. Project title and number.
  3. Name, address, and telephone number of testing agency.
  4. Dates and locations of samples and tests or inspections.
  5. Names of individuals making tests and inspections.
  6. Description of the Work and test and inspection method.
  7. Identification of product and Specification Section.
  8. Complete test or inspection data.
  9. Test and inspection results and an interpretation of test results.
  10. Record of temperature and weather conditions at time of sample taking and testing and inspecting.
  11. Comments or professional opinion on whether tested or inspected Work complies with the Contract Document requirements.
  12. Name and signature of laboratory inspector.
  13. Recommendations on retesting and re-inspecting.
- B. **Manufacturer's Technical Representative's Field Reports:** Prepare written information documenting manufacturer's technical representative's tests and inspections specified in other Sections. Include the following:
1. Name, address, and telephone number of technical representative making report.
  2. Statement on condition of substrates and their acceptability for installation of product.
  3. Statement that products at Project site comply with requirements.
  4. Summary of installation procedures being followed, whether they comply with requirements and, if not, what corrective action was taken.
  5. Results of operational and other tests and a statement of whether observed performance complies with requirements.
  6. Statement whether conditions, products, and installation will affect warranty.
  7. Other required items indicated in individual Specification Sections.
- C. **Factory-Authorized Service Representative's Reports:** Prepare written information documenting manufacturer's factory-authorized service representative's tests and inspections specified in other Sections. Include the following:
1. Name, address, and telephone number of factory-authorized service representative making report.
  2. Statement that equipment complies with requirements.
  3. Results of operational and other tests and a statement of whether observed performance complies with requirements.
  4. Statement whether conditions, products, and installation will affect warranty.
  5. Other required items indicated in individual Specification Sections.



- D. Permits, Licenses, and Certificates: For Owner's records, submit copies of permits, licenses, certifications, inspection reports, releases, jurisdictional settlements, notices, receipts for fee payments, judgments, correspondence, records, and similar documents, established for compliance with standards and regulations bearing on performance of the Work.

#### 1.9 QUALITY ASSURANCE

- A. General: Qualifications paragraphs in this article establish the minimum qualification levels required; individual Specification Sections specify additional requirements.
- B. Manufacturer Qualifications: A firm experienced in manufacturing products or systems similar to those indicated for this Project and with a record of successful in-service performance, as well as sufficient production capacity to produce required units.
- C. Fabricator Qualifications: A firm experienced in producing products similar to those indicated for this Project and with a record of successful in-service performance, as well as sufficient production capacity to produce required units.
- D. Installer Qualifications: A firm or individual experienced in installing, erecting, or assembling work similar in material, design, and extent to that indicated for this Project, whose work has resulted in construction with a record of successful in-service performance.
- E. Specialists: Certain Specification Sections require that specific construction activities shall be performed by entities who are recognized experts in those operations. Specialists shall satisfy qualification requirements indicated and shall be engaged for the activities indicated.
  - 1. Requirements of authorities having jurisdiction shall supersede requirements for specialists.
- F. Testing Agency Qualifications: An NRTL, an NVLAP, or an independent agency with the experience and capability to conduct testing and inspecting indicated, as documented according to ASTM E 329; and with additional qualifications specified in individual Sections; and, where required by authorities having jurisdiction, that is acceptable to authorities.
  - 1. NRTL: A nationally recognized testing laboratory according to 29 CFR 1910.7.
  - 2. NVLAP: A testing agency accredited according to NIST's National Voluntary Laboratory Accreditation Program.
- G. Manufacturer's Technical Representative Qualifications: An authorized representative of manufacturer who is trained and approved by manufacturer to observe and inspect installation of manufacturer's products that are similar in material, design, and extent to those indicated for this Project.
- H. Factory-Authorized Service Representative Qualifications: An authorized representative of manufacturer who is trained and approved by manufacturer to inspect installation of manufacturer's products that are similar in material, design, and extent to those indicated for this Project.
- I. Preconstruction Testing: Where testing agency is indicated to perform preconstruction testing for compliance with specified requirements for performance and test methods, comply with the following:
  - 1. Contractor responsibilities include the following:
    - a. Provide test specimens representative of proposed products and construction.

- b. Submit specimens in a timely manner with sufficient time for testing and analyzing results to prevent delaying the Work.
  - c. Provide sizes and configurations of test assemblies, mockups, and laboratory mockups to adequately demonstrate capability of products to comply with performance requirements.
  - d. Build site-assembled test assemblies and mockups using installers who will perform same tasks for Project.
  - e. Build laboratory mockups at testing facility using personnel, products, and methods of construction indicated for the completed Work.
  - f. When testing is complete, remove test specimens, assemblies, and mockups; do not reuse products on Project.
2. Testing Agency Responsibilities: Submit a certified written report of each test, inspection, and similar quality-assurance service to Architect and Commissioning Authority, through Construction Manager, with copy to Contractor. Interpret tests and inspections and state in each report whether tested and inspected work complies with or deviates from the Contract Documents.
- J. Mockups: Before installing portions of the Work requiring mockups, build mockups for each form of construction and finish required to comply with the following requirements, using materials indicated for the completed Work:
1. Build mockups in location and of size indicated or, if not indicated, as directed by Architect or Construction Manager.
  2. Notify Architect and Construction Manager seven days in advance of dates and times when mockups will be constructed.
  3. Employ supervisory personnel who will oversee mockup construction. Employ workers that will be employed during the construction at Project.
  4. Demonstrate the proposed range of aesthetic effects and workmanship.
  5. Obtain Architect's and Construction Manager's approval of mockups before starting work, fabrication, or construction.
    - a. Allow seven days for initial review and each re-review of each mockup.
  6. Maintain mockups during construction in an undisturbed condition as a standard for judging the completed Work.
  7. Demolish and remove mockups when directed unless otherwise indicated.
- K. Integrated Exterior Mockups: Construct integrated exterior mockup according to approved Shop Drawings. Coordinate installation of exterior envelope materials and products for which mockups are required in individual Specification Sections, along with supporting materials.
- L. Room Mockups: Construct room mockups incorporating required materials and assemblies, finished according to requirements. Provide required lighting and additional lighting where required to enable Architect to evaluate quality of the Work. Provide room mockups of the following rooms:
1. Typical cell and typical ADA cell.
- 1.10 QUALITY CONTROL
- A. Owner Responsibilities: Where quality-control services are indicated as Owner's responsibility, Owner will engage a qualified testing agency to perform these services.

1. Owner will furnish Contractor with names, addresses, and telephone numbers of testing agencies engaged and a description of types of testing and inspecting they are engaged to perform.
  2. Costs for retesting and re-inspecting construction that replaces or is necessitated by work that failed to comply with the Contract Documents will be charged to Contractor.
- B. Contractor Responsibilities: Tests and inspections not explicitly assigned to Owner are Contractor's responsibility. Perform additional quality-control activities required to verify that the Work complies with requirements, whether specified or not.
1. Unless otherwise indicated, provide quality-control services specified and those required by authorities having jurisdiction. Perform quality-control services required of Contractor by authorities having jurisdiction, whether specified or not.
  2. Notify testing agencies at least 24 hours in advance of time when Work that requires testing or inspecting will be performed.
  3. Where quality-control services are indicated as Contractor's responsibility, submit a certified written report, in duplicate, of each quality-control service.
  4. Testing and inspecting requested by Contractor and not required by the Contract Documents are Contractor's responsibility.
  5. Submit additional copies of each written report directly to authorities having jurisdiction, when they so direct.
- C. Manufacturer's Field Services: Where indicated, engage a factory-authorized service representative to inspect field-assembled components and equipment installation, including service connections. Report results in writing as specified in Section 013300 "Submittal Procedures."
- D. Manufacturer's Technical Services: Where indicated, engage a manufacturer's technical representative to observe and inspect the Work. Manufacturer's technical representative's services include participation in pre-installation conferences, examination of substrates and conditions, verification of materials, observation of Installer activities, inspection of completed portions of the Work, and submittal of written reports.
- E. Retesting/Re-inspecting: Regardless of whether original tests or inspections were Contractor's responsibility, provide quality-control services, including retesting and re-inspecting, for construction that replaced Work that failed to comply with the Contract Documents.
- F. Testing Agency Responsibilities: Cooperate with Architect, Commissioning Authority, Construction Manager, and Contractor in performance of duties. Provide qualified personnel to perform required tests and inspections.
1. Notify Architect, Commissioning Authority, Construction Manager, and Contractor promptly of irregularities or deficiencies observed in the Work during performance of its services.
  2. Determine the location from which test samples will be taken and in which in-situ tests are conducted.
  3. Conduct and interpret tests and inspections and state in each report whether tested and inspected work complies with or deviates from requirements.
  4. Submit a certified written report, in duplicate, of each test, inspection, and similar quality-control service through Contractor.
  5. Do not release, revoke, alter, or increase the Contract Document requirements or approve or accept any portion of the Work.
  6. Do not perform any duties of Contractor.

- G. Associated Services: Cooperate with agencies performing required tests, inspections, and similar quality-control services, and provide reasonable auxiliary services as requested. Notify agency sufficiently in advance of operations to permit assignment of personnel. Provide the following:
1. Access to the Work.
  2. Incidental labor and facilities necessary to facilitate tests and inspections.
  3. Adequate quantities of representative samples of materials that require testing and inspecting. Assist agency in obtaining samples.
  4. Facilities for storage and field curing of test samples.
  5. Preliminary design mix proposed for use for material mixes that require control by testing agency.
  6. Security and protection for samples and for testing and inspecting equipment at Project site.
- H. Coordination: Coordinate sequence of activities to accommodate required quality-assurance and -control services with a minimum of delay and to avoid necessity of removing and replacing construction to accommodate testing and inspecting.
1. Schedule times for tests, inspections, obtaining samples, and similar activities.
- I. Schedule of Tests and Inspections: Prepare a schedule of tests, inspections, and similar quality-control services required by the Contract Documents as a component of Contractor's quality-control plan. Coordinate and submit concurrently with Contractor's construction schedule. Update as the Work progresses.
1. Distribution: Distribute schedule to Owner, Architect, Commissioning Authority, Construction Manager, testing agencies, and each party involved in performance of portions of the Work where tests and inspections are required.

#### 1.11 SPECIAL TESTS AND INSPECTIONS

- A. Special Tests and Inspections: Owner will engage a qualified testing agency to conduct special tests and inspections required by authorities having jurisdiction as the responsibility of Owner, as indicated in Statement of Special Inspections attached to this Section, and as follows:
1. Verifying that manufacturer maintains detailed fabrication and quality-control procedures and reviews the completeness and adequacy of those procedures to perform the Work.
  2. Notifying Architect, Commissioning Authority, , Construction Manager, and Contractor promptly of irregularities and deficiencies observed in the Work during performance of its services.
  3. Submitting a certified written report of each test, inspection, and similar quality-control service to Architect and Commissioning Authority, through Construction Manager, with copy to Contractor and to authorities having jurisdiction.
  4. Submitting a final report of special tests and inspections at Substantial Completion, which includes a list of unresolved deficiencies.
  5. Interpreting tests and inspections and stating in each report whether tested and inspected work complies with or deviates from the Contract Documents.
  6. Retesting and re-inspecting corrected work.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION

3.1 TEST AND INSPECTION LOG

- A. Test and Inspection Log: Prepare a record of tests and inspections. Include the following:
  - 1. Date test or inspection was conducted.
  - 2. Description of the Work tested or inspected.
  - 3. Date test or inspection results were transmitted to Architect.
  - 4. Identification of testing agency or special inspector conducting test or inspection.
- B. Maintain log at Project site. Post changes and revisions as they occur. Provide access to test and inspection log for Architect's, Commissioning Authority's, and Construction Manager's reference during normal working hours.

3.2 REPAIR AND PROTECTION

- A. General: On completion of testing, inspecting, sample taking, and similar services, repair damaged construction and restore substrates and finishes.
  - 1. Provide materials and comply with installation requirements specified in other Specification Sections or matching existing substrates and finishes. Restore patched areas and extend restoration into adjoining areas with durable seams that are as invisible as possible. Comply with the Contract Document requirements for cutting and patching in Section 017300 "Execution."
- B. Protect construction exposed by or for quality-control service activities.
- C. Repair and protection are Contractor's responsibility, regardless of the assignment of responsibility for quality-control services.

END OF SECTION 014000

## SECTION 014200 - REFERENCES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 DEFINITIONS

- A. General: Basic Contract definitions are included in the Conditions of the Contract.
- B. "Approved": When used to convey Architect's action on Contractor's submittals, applications, and requests, "approved" is limited to Architect's duties and responsibilities as stated in the Conditions of the Contract.
- C. "Directed": A command or instruction by Architect. Other terms including "requested," "authorized," "selected," "required," and "permitted" have the same meaning as "directed."
- D. "Indicated": Requirements expressed by graphic representations or in written form on Drawings, in Specifications, and in other Contract Documents. Other terms including "shown," "noted," "scheduled," and "specified" have the same meaning as "indicated."
- E. "Regulations": Laws, ordinances, statutes, and lawful orders issued by authorities having jurisdiction, and rules, conventions, and agreements within the construction industry that control performance of the Work.
- F. "Furnish": Supply and deliver to Project site, ready for unloading, unpacking, assembly, installation, and similar operations.
- G. "Install": Operations at Project site including unloading, temporarily storing, unpacking, assembling, erecting, placing, anchoring, applying, working to dimension, finishing, curing, protecting, cleaning, and similar operations.
- H. "Provide": Furnish and install, complete and ready for the intended use.
- I. "Project Site": Space available for performing construction activities. The extent of Project site is shown on Drawings and may or may not be identical with the description of the land on which Project is to be built.

#### 1.3 INDUSTRY STANDARDS

- A. Applicability of Standards: Unless the Contract Documents include more stringent requirements, applicable construction industry standards have the same force and effect as if bound or copied directly into the Contract Documents to the extent referenced. Such standards are made a part of the Contract Documents by reference.

- B. Publication Dates: Comply with standards in effect as of date of the Contract Documents unless otherwise indicated.
- C. Copies of Standards: Each entity engaged in construction on Project should be familiar with industry standards applicable to its construction activity. Copies of applicable standards are not bound with the Contract Documents.
  - 1. Where copies of standards are needed to perform a required construction activity, obtain copies directly from publication source.

#### 1.4 ABBREVIATIONS AND ACRONYMS

- A. Industry Organizations: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities indicated in Gale's "Encyclopedia of Associations: National Organizations of the U.S." or in Columbia Books' "National Trade & Professional Associations of the United States."
- B. Industry Organizations: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. Names, telephone numbers, and Web sites are subject to change and are believed to be accurate and up-to-date as of the date of the Contract Documents.

AABC	Associated Air Balance Council www.aabc.com	(202) 737-0202
AAMA	American Architectural Manufacturers Association www.aamanet.org	(847) 303-5664
AASHTO	American Association of State Highway and Transportation Officials www.transportation.org	(202) 624-5800
AATCC	American Association of Textile Chemists and Colorists www.aatcc.org	(919) 549-8141
ABMA	American Bearing Manufacturers Association www.americanbearings.org	(202) 367-1155
ACI	American Concrete Institute (Formerly: ACI International) www.concrete.org	(248) 848-3700
ACPA	American Concrete Pipe Association www.concrete-pipe.org	(972) 506-7216
AEIC	Association of Edison Illuminating Companies, Inc. (The) www.aeic.org	(205) 257-2530
AF&PA	American Forest & Paper Association www.afandpa.org	(800) 878-8878 (202) 463-2700

AGA	American Gas Association <a href="http://www.aga.org">www.aga.org</a>	(202) 824-7000
AHAM	Association of Home Appliance Manufacturers <a href="http://www.aham.org">www.aham.org</a>	(202) 872-5955
AHRI	Air-Conditioning, Heating, and Refrigeration Institute (The) <a href="http://www.ahrinet.org">www.ahrinet.org</a>	(703) 524-8800
AI	Asphalt Institute <a href="http://www.asphaltinstitute.org">www.asphaltinstitute.org</a>	(859) 288-4960
AIA	American Institute of Architects (The) <a href="http://www.aia.org">www.aia.org</a>	(800) 242-3837 (202) 626-7300
AISC	American Institute of Steel Construction <a href="http://www.aisc.org">www.aisc.org</a>	(800) 644-2400 (312) 670-2400
AISI	American Iron and Steel Institute <a href="http://www.steel.org">www.steel.org</a>	(202) 452-7100
AITC	American Institute of Timber Construction <a href="http://www.aitc-glulam.org">www.aitc-glulam.org</a>	(303) 792-9559
AMCA	Air Movement and Control Association International, Inc. <a href="http://www.amca.org">www.amca.org</a>	(847) 394-0150
ANSI	American National Standards Institute <a href="http://www.ansi.org">www.ansi.org</a>	(202) 293-8020
AOSA	Association of Official Seed Analysts, Inc. <a href="http://www.aosaseed.com">www.aosaseed.com</a>	(607) 256-3313
APA	APA - The Engineered Wood Association <a href="http://www.apawood.org">www.apawood.org</a>	(253) 565-6600
APA	Architectural Precast Association <a href="http://www.archprecast.org">www.archprecast.org</a>	(239) 454-6989
API	American Petroleum Institute <a href="http://www.api.org">www.api.org</a>	(202) 682-8000
ARI	Air-Conditioning & Refrigeration Institute (See AHRI)	
ARI	American Refrigeration Institute (See AHRI)	
ARMA	Asphalt Roofing Manufacturers Association <a href="http://www.asphaltroofing.org">www.asphaltroofing.org</a>	(202) 207-0917
ASCE	American Society of Civil Engineers	(800) 548-2723



	www.asce.org	(703) 295-6300
ASCE/SEI	American Society of Civil Engineers/Structural Engineering Institute (See ASCE)	
ASHRAE	American Society of Heating, Refrigerating and Air-Conditioning Engineers www.ashrae.org	(800) 527-4723 (404) 636-8400
ASME	ASME International (American Society of Mechanical Engineers) www.asme.org	(800) 843-2763 (973) 882-1170
ASSE	American Society of Safety Engineers (The) www.asse.org	(847) 699-2929
ASSE	American Society of Sanitary Engineering www.asse-plumbing.org	(440) 835-3040
ASTM	ASTM International (American Society for Testing and Materials International) www.astm.org	(610) 832-9500
ATIS	Alliance for Telecommunications Industry Solutions www.atis.org	(202) 628-6380
AWEA	American Wind Energy Association www.awea.org	(202) 383-2500
AWI	Architectural Woodwork Institute www.awinet.org	(571) 323-3636
AWMAC	Architectural Woodwork Manufacturers Association of Canada www.awmac.com	(403) 453-7387
AWPA	American Wood Protection Association (Formerly: American Wood-Preservers' Association) www.awpa.com	(205) 733-4077
AWS	American Welding Society www.aws.org	(800) 443-9353 (305) 443-9353
AWWA	American Water Works Association www.awwa.org	(800) 926-7337 (303) 794-7711
BHMA	Builders Hardware Manufacturers Association www.buildershardware.com	(212) 297-2122
BIA	Brick Industry Association (The) www.gobrick.com	(703) 620-0010

BICSI	BICSI, Inc. www.bicsi.org	(800) 242-7405 (813) 979-1991
BIFMA	BIFMA International (Business and Institutional Furniture Manufacturer's Association) www.bifma.com	(616) 285-3963
BISSC	Baking Industry Sanitation Standards Committee www.bissc.org	(866) 342-4772
BOCA	BOCA (Building Officials and Code Administrators International Inc.) (See ICC)	
BWF	Badminton World Federation (Formerly: International Badminton Federation) www.bwfbadminton.org	60 3 9283 7155
CDA	Copper Development Association www.copper.org	(800) 232-3282 (212) 251-7200
CEA	Canadian Electricity Association www.electricity.ca	(613) 230-9263
CEA	Consumer Electronics Association www.ce.org	(866) 858-1555 (703) 907-7600
CFFA	Chemical Fabrics & Film Association, Inc. www.chemicalfabricsandfilm.com	(216) 241-7333
CFSEI	Cold-Formed Steel Engineers Institute www.cfsei.org	(866) 465-4732 (202) 263-4488
CGA	Compressed Gas Association www.cganet.com	(703) 788-2700
CIMA	Cellulose Insulation Manufacturers Association www.cellulose.org	(888) 881-2462 (937) 222-2462
CISCA	Ceilings & Interior Systems Construction Association www.cisca.org	(630) 584-1919
CISPI	Cast Iron Soil Pipe Institute www.cispi.org	(404) 622-0073
CLFMI	Chain Link Fence Manufacturers Institute www.chainlinkinfo.org	(301) 596-2583
CPA	Composite Panel Association	(703) 724-1128

	<a href="http://www.pbmdf.com">www.pbmdf.com</a>	
CRI	Carpet and Rug Institute (The) <a href="http://www.carpet-rug.org">www.carpet-rug.org</a>	(706) 278-3176
CRRC	Cool Roof Rating Council <a href="http://www.coolroofs.org">www.coolroofs.org</a>	(866) 465-2523 (510) 485-7175
CRSI	Concrete Reinforcing Steel Institute <a href="http://www.crsi.org">www.crsi.org</a>	(800) 328-6306 (847) 517-1200
CSA	Canadian Standards Association <a href="http://www.csa.ca">www.csa.ca</a>	(800) 463-6727 (416) 747-4000
CSA	CSA International (Formerly: IAS - International Approval Services) <a href="http://www.csa-international.org">www.csa-international.org</a>	(866) 797-4272 (416) 747-4000
CSI	Construction Specifications Institute (The) <a href="http://www.csinet.org">www.csinet.org</a>	(800) 689-2900 (703) 684-0300
CSSB	Cedar Shake & Shingle Bureau <a href="http://www.cedarbureau.org">www.cedarbureau.org</a>	(604) 820-7700
CTI	Cooling Technology Institute (Formerly: Cooling Tower Institute) <a href="http://www.cti.org">www.cti.org</a>	(281) 583-4087
CWC	Composite Wood Council (See CPA)	
DASMA	Door and Access Systems Manufacturers Association <a href="http://www.dasma.com">www.dasma.com</a>	(216) 241-7333
DHI	Door and Hardware Institute <a href="http://www.dhi.org">www.dhi.org</a>	(703) 222-2010
ECA	Electronic Components Association <a href="http://www.ec-central.org">www.ec-central.org</a>	(703) 907-8024
ECAMA	Electronic Components Assemblies & Materials Association (See ECA)	
EIA	Electronic Industries Alliance (See TIA)	
EIMA	EIFS Industry Members Association <a href="http://www.eima.com">www.eima.com</a>	(800) 294-3462 (703) 538-1616
EJMA	Expansion Joint Manufacturers Association, Inc. <a href="http://www.ejma.org">www.ejma.org</a>	(914) 332-0040

ESD	ESD Association (Electrostatic Discharge Association) www.esda.org	(315) 339-6937
ESTA	Entertainment Services and Technology Association (See PLASA)	
EVO	Efficiency Valuation Organization www.evo-world.org	(415) 367-3643 44 20 88 167 857
FIBA	Fédération Internationale de Basketball (The International Basketball Federation) www.fiba.com	41 22 545 00 00
FIVB	Fédération Internationale de Volleyball (The International Volleyball Federation) www.fivb.org	41 21 345 35 45
FM Approvals	FM Approvals LLC www.fmglobal.com	(781) 762-4300
FM Global	FM Global (Formerly: FMG - FM Global) www.fmglobal.com	(401) 275-3000
FRSA	Florida Roofing, Sheet Metal & Air Conditioning Contractors Association, Inc. www.floridarroof.com	(407) 671-3772
FSA	Fluid Sealing Association www.fluidsealing.com	(610) 971-4850
FSC	Forest Stewardship Council U.S. www.fscus.org	(612) 353-4511
GA	Gypsum Association www.gypsum.org	(301) 277-8686
GANA	Glass Association of North America www.glasswebsite.com	(785) 271-0208
GS	Green Seal www.greenseal.org	(202) 872-6400
HI	Hydraulic Institute www.pumps.org	(973) 267-9700
HI/GAMA	Hydronics Institute/Gas Appliance Manufacturers Association (See AHRI)	
HMMA	Hollow Metal Manufacturers Association	

(See NAAMM)

HPVA	Hardwood Plywood & Veneer Association www.hpva.org	(703) 435-2900
HPW	H. P. White Laboratory, Inc. www.hpwhite.com	(410) 838-6550
IAPSC	International Association of Professional Security Consultants www.iapsc.org	(415) 536-0288
IAS	International Approval Services (See CSA)	
ICBO	International Conference of Building Officials (See ICC)	
ICC	International Code Council www.iccsafe.org	(888) 422-7233 (202) 370-1800
ICEA	Insulated Cable Engineers Association, Inc. www.icea.net	(770) 830-0369
ICPA	International Cast Polymer Alliance www.icpa-hq.org	(703) 525-0511
ICRI	International Concrete Repair Institute, Inc. www.icri.org	(847) 827-0830
IEC	International Electrotechnical Commission www.iec.ch	41 22 919 02 11
IEEE	Institute of Electrical and Electronics Engineers, Inc. (The) www.ieee.org	(212) 419-7900
IES	Illuminating Engineering Society (Formerly: Illuminating Engineering Society of North America) www.ies.org	(212) 248-5000
IESNA	Illuminating Engineering Society of North America (See IES)	
IEST	Institute of Environmental Sciences and Technology www.iest.org	(847) 981-0100
IGMA	Insulating Glass Manufacturers Alliance www.igmaonline.org	(613) 233-1510
IGSHPA	International Ground Source Heat Pump Association www.igshpa.okstate.edu	(405) 744-5175

ILI	Indiana Limestone Institute of America, Inc. www.iliai.com	(812) 275-4426
Intertek	Intertek Group (Formerly: ETL SEMCO; Intertek Testing Service NA) www.intertek.com	(800) 967-5352
ISA	International Society of Automation (The) (Formerly: Instrumentation, Systems, and Automation Society) www.isa.org	(919) 549-8411
ISAS	Instrumentation, Systems, and Automation Society (The) (See ISA)	
ISFA	International Surface Fabricators Association (Formerly: International Solid Surface Fabricators Association) www.isfanow.org	(877) 464-7732 (801) 341-7360
ISO	International Organization for Standardization www.iso.org	41 22 749 01 11
ISSFA	International Solid Surface Fabricators Association (See ISFA)	
ITU	International Telecommunication Union www.itu.int/home	41 22 730 51 11
KCMA	Kitchen Cabinet Manufacturers Association www.kcma.org	(703) 264-1690
LMA	Laminating Materials Association (See CPA)	
LPI	Lightning Protection Institute www.lightning.org	(800) 488-6864
MBMA	Metal Building Manufacturers Association www.mbma.com	(216) 241-7333
MCA	Metal Construction Association www.metalconstruction.org	(847) 375-4718
MFMA	Maple Flooring Manufacturers Association, Inc. www.maplefloor.org	(888) 480-9138
MFMA	Metal Framing Manufacturers Association, Inc. www.metalframingmfg.org	(312) 644-6610
MHIA	Material Handling Industry of America www.mhia.org	(800) 345-1815 (704) 676-1190

MIA	Marble Institute of America <a href="http://www.marble-institute.com">www.marble-institute.com</a>	(440) 250-9222
MMPA	Moulding & Millwork Producers Association (Formerly: Wood Moulding & Millwork Producers Association) <a href="http://www.wmmpa.com">www.wmmpa.com</a>	(800) 550-7889 (530) 661-9591
MPI	Master Painters Institute <a href="http://www.paintinfo.com">www.paintinfo.com</a>	(888) 674-8937 (604) 298-7578
MSS	Manufacturers Standardization Society of The Valve and Fittings Industry Inc. <a href="http://www.mss-hq.org">www.mss-hq.org</a>	(703) 281-6613
NAAMM	National Association of Architectural Metal Manufacturers <a href="http://www.naamm.org">www.naamm.org</a>	(630) 942-6591
NACE	NACE International (National Association of Corrosion Engineers International) <a href="http://www.nace.org">www.nace.org</a>	(800) 797-6223 (281) 228-6200
NADCA	National Air Duct Cleaners Association <a href="http://www.nadca.com">www.nadca.com</a>	(202) 737-2926
NAIMA	North American Insulation Manufacturers Association <a href="http://www.naima.org">www.naima.org</a>	(703) 684-0084
NBGQA	National Building Granite Quarries Association, Inc. <a href="http://www.nbgqa.com">www.nbgqa.com</a>	(800) 557-2848
NCAA	National Collegiate Athletic Association (The) <a href="http://www.ncaa.org">www.ncaa.org</a>	(317) 917-6222
NCMA	National Concrete Masonry Association <a href="http://www.ncma.org">www.ncma.org</a>	(703) 713-1900
NEBB	National Environmental Balancing Bureau <a href="http://www.nebb.org">www.nebb.org</a>	(301) 977-3698
NECA	National Electrical Contractors Association <a href="http://www.necanet.org">www.necanet.org</a>	(301) 657-3110
NeLMA	Northeastern Lumber Manufacturers Association <a href="http://www.nelma.org">www.nelma.org</a>	(207) 829-6901
NEMA	National Electrical Manufacturers Association <a href="http://www.nema.org">www.nema.org</a>	(703) 841-3200
NETA	InterNational Electrical Testing Association <a href="http://www.netaworld.org">www.netaworld.org</a>	(888) 300-6382 (269) 488-6382

NFHS	National Federation of State High School Associations www.nfhs.org	(317) 972-6900
NFPA	NFPA (National Fire Protection Association) www.nfpa.org	(800) 344-3555 (617) 770-3000
NFPA	NFPA International (See NFPA)	
NFRC	National Fenestration Rating Council www.nfrc.org	(301) 589-1776
NHLA	National Hardwood Lumber Association www.nhla.com	(800) 933-0318 (901) 377-1818
NLGA	National Lumber Grades Authority www.nlga.org	(604) 524-2393
NOFMA	National Oak Flooring Manufacturers Association (See NWFA)	
NOMMA	National Ornamental & Miscellaneous Metals Association www.nomma.org	(888) 516-8585
NRCA	National Roofing Contractors Association www.nrca.net	(800) 323-9545 (847) 299-9070
NRMCA	National Ready Mixed Concrete Association www.nrmca.org	(888) 846-7622 (301) 587-1400
NSF	NSF International (National Sanitation Foundation International) www.nsf.org	(800) 673-6275 (734) 769-8010
NSPE	National Society of Professional Engineers www.nspe.org	(703) 684-2800
NSSGA	National Stone, Sand & Gravel Association www.nssga.org	(800) 342-1415 (703) 525-8788
NTMA	National Terrazzo & Mosaic Association, Inc. (The) www.ntma.com	(800) 323-9736
NWFA	National Wood Flooring Association www.nwfa.org	(800) 422-4556 (636) 519-9663
PCI	Precast/Prestressed Concrete Institute www.pci.org	(312) 786-0300
PDI	Plumbing & Drainage Institute	(800) 589-8956



	www.pdionline.org	(978) 557-0720
PLASA	PLASA (Formerly: ESTA - Entertainment Services and Technology Association) www.plasa.org	(212) 244-1505
RCSC	Research Council on Structural Connections www.boltcouncil.org	
RFCI	Resilient Floor Covering Institute www.rfci.com	(706) 882-3833
RIS	Redwood Inspection Service www.redwoodinspection.com	(925) 935-1499
SAE	SAE International (Society of Automotive Engineers) www.sae.org	(877) 606-7323 (724) 776-4841
SBCCI	Southern Building Code Congress International, Inc. (See ICC)	
SCTE	Society of Cable Telecommunications Engineers www.scte.org	(800) 542-5040 (610) 363-6888
SDI	Steel Deck Institute www.sdi.org	(847) 458-4647
SDI	Steel Door Institute www.steeldoor.org	(440) 899-0010
SEFA	Scientific Equipment and Furniture Association www.sefalabs.com	(877) 294-5424 (516) 294-5424
SEI/ASCE	Structural Engineering Institute/American Society of Civil Engineers (See ASCE)	
SIA	Security Industry Association www.siaonline.org	(866) 817-8888 (703) 683-2075
SJI	Steel Joist Institute www.steeljoist.org	(843) 293-1995
SMA	Screen Manufacturers Association www.smainfo.org	(773) 636-0672
SMACNA	Sheet Metal and Air Conditioning Contractors' National Association www.smacna.org	(703) 803-2980

SMPTE	Society of Motion Picture and Television Engineers <a href="http://www.smpte.org">www.smpte.org</a>	(914) 761-1100
SPFA	Spray Polyurethane Foam Alliance <a href="http://www.sprayfoam.org">www.sprayfoam.org</a>	(800) 523-6154
SPIB	Southern Pine Inspection Bureau <a href="http://www.spib.org">www.spib.org</a>	(850) 434-2611
SPRI	Single Ply Roofing Industry <a href="http://www.spri.org">www.spri.org</a>	(781) 647-7026
SRCC	Solar Rating and Certification Corporation <a href="http://www.solar-rating.org">www.solar-rating.org</a>	(321) 638-1537
SSINA	Specialty Steel Industry of North America <a href="http://www.ssina.com">www.ssina.com</a>	(800) 982-0355 (202) 342-8630
SSPC	SSPC: The Society for Protective Coatings <a href="http://www.sspc.org">www.sspc.org</a>	(877) 281-7772 (412) 281-2331
STI	Steel Tank Institute <a href="http://www.steeltank.com">www.steeltank.com</a>	(847) 438-8265
SWI	Steel Window Institute <a href="http://www.steelwindows.com">www.steelwindows.com</a>	(216) 241-7333
SWPA	Submersible Wastewater Pump Association <a href="http://www.swpa.org">www.swpa.org</a>	(847) 681-1868
TCA	Tilt-Up Concrete Association <a href="http://www.tilt-up.org">www.tilt-up.org</a>	(319) 895-6911
TCNA	Tile Council of North America, Inc. (Formerly: Tile Council of America) <a href="http://www.tileusa.com">www.tileusa.com</a>	(864) 646-8453
TEMA	Tubular Exchanger Manufacturers Association, Inc. <a href="http://www.tema.org">www.tema.org</a>	(914) 332-0040
TIA	Telecommunications Industry Association (Formerly: TIA/EIA - Telecommunications Industry Association/Electronic Industries Alliance) <a href="http://www.tiaonline.org">www.tiaonline.org</a>	(703) 907-7700
TIA/EIA	Telecommunications Industry Association/Electronic Industries Alliance (See TIA)	
TMS	The Masonry Society <a href="http://www.masonrysociety.org">www.masonrysociety.org</a>	(303) 939-9700

TPI	Truss Plate Institute <a href="http://www.tpinst.org">www.tpinst.org</a>	(703) 683-1010
TPI	Turfgrass Producers International <a href="http://www.turfgrassod.org">www.turfgrassod.org</a>	(800) 405-8873 (847) 649-5555
TRI	Tile Roofing Institute <a href="http://www.tilerroofing.org">www.tilerroofing.org</a>	(312) 670-4177
UBC	Uniform Building Code (See ICC)	
UL	Underwriters Laboratories Inc. <a href="http://www.ul.com">www.ul.com</a>	(877) 854-3577
UNI	Uni-Bell PVC Pipe Association <a href="http://www.uni-bell.org">www.uni-bell.org</a>	(972) 243-3902
USAV	USA Volleyball <a href="http://www.usavolleyball.org">www.usavolleyball.org</a>	(888) 786-5539 (719) 228-6800
USGBC	U.S. Green Building Council <a href="http://www.usgbc.org">www.usgbc.org</a>	(800) 795-1747
USITT	United States Institute for Theatre Technology, Inc. <a href="http://www.usitt.org">www.usitt.org</a>	(800) 938-7488 (315) 463-6463
WASTECH	Waste Equipment Technology Association <a href="http://www.wastec.org">www.wastec.org</a>	(800) 424-2869 (202) 244-4700
WCLIB	West Coast Lumber Inspection Bureau <a href="http://www.wclib.org">www.wclib.org</a>	(800) 283-1486 (503) 639-0651
WCMA	Window Covering Manufacturers Association <a href="http://www.wcmanet.org">www.wcmanet.org</a>	(212) 297-2122
WDMA	Window & Door Manufacturers Association <a href="http://www.wdma.com">www.wdma.com</a>	(800) 223-2301 (312) 321-6802
WI	Woodwork Institute (Formerly: WIC - Woodwork Institute of California) <a href="http://www.wicnet.org">www.wicnet.org</a>	(916) 372-9943
WMMPA	Wood Moulding & Millwork Producers Association (See MMPA)	
WSRCA	Western States Roofing Contractors Association <a href="http://www.wsrca.com">www.wsrca.com</a>	(800) 725-0333 (650) 938-5441
WWPA	Western Wood Products Association <a href="http://www.wwpa.org">www.wwpa.org</a>	(503) 224-3930

C. Code Agencies: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. Names, telephone numbers, and Web sites are subject to change and are believed to be accurate and up-to-date as of the date of the Contract Documents.

DIN	Deutsches Institut für Normung e.V. www.din.de	49 30 2601-0
IAPMO	International Association of Plumbing and Mechanical Officials www.iapmo.org	(909) 472-4100
ICC	International Code Council www.iccsafe.org	(888) 422-7233
ICC-ES	ICC Evaluation Service, LLC www.icc-es.org	(800) 423-6587 (562) 699-0543

D. Federal Government Agencies: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. Names, telephone numbers, and Web sites are subject to change and are believed to be accurate and up-to-date as of the date of the Contract Documents.

COE	Army Corps of Engineers www.usace.army.mil	(202) 761-0011
CPSC	Consumer Product Safety Commission www.cpsc.gov	(800) 638-2772 (301) 504-7923
DOC	Department of Commerce National Institute of Standards and Technology www.nist.gov	(301) 975-4040
DOD	Department of Defense http://dodssp.daps.dla.mil	(215) 697-2664
DOE	Department of Energy www.energy.gov	(202) 586-9220
EPA	Environmental Protection Agency www.epa.gov	(202) 272-0167
FAA	Federal Aviation Administration www.faa.gov	(866) 835-5322
FG	Federal Government Publications www.gpo.gov	(202) 512-1800
GSA	General Services Administration www.gsa.gov	(800) 488-3111 (202) 619-8925

HUD	Department of Housing and Urban Development <a href="http://www.hud.gov">www.hud.gov</a>	(202) 708-1112
LBL	Lawrence Berkeley National Laboratory Environmental Energy Technologies Division <a href="http://eetd.lbl.gov">http://eetd.lbl.gov</a>	(510) 486-4000
OSHA	Occupational Safety & Health Administration <a href="http://www.osha.gov">www.osha.gov</a>	(800) 321-6742
SD	Department of State <a href="http://www.state.gov">www.state.gov</a>	(202) 647-4000
TRB	Transportation Research Board National Cooperative Highway Research Program <a href="http://www.trb.org">www.trb.org</a>	(202) 334-2934
USDA	Department of Agriculture Agriculture Research Service U.S. Salinity Laboratory <a href="http://www.ars.usda.gov">www.ars.usda.gov</a>	(202) 720-3656
USDA	Department of Agriculture Rural Utilities Service <a href="http://www.usda.gov">www.usda.gov</a>	(202) 720-2791
USDJ	Department of Justice Office of Justice Programs National Institute of Justice <a href="http://www.ojp.usdoj.gov">www.ojp.usdoj.gov</a>	(202) 307-0703
USP	U.S. Pharmacopeia <a href="http://www.usp.org">www.usp.org</a>	(800) 227-8772 (301) 881-0666
USPS	United States Postal Service <a href="http://www.usps.com">www.usps.com</a>	(202) 268-2000

E. Standards and Regulations: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the standards and regulations in the following list. Names, telephone numbers, and Web sites are subject to change and are believed to be accurate and up-to-date as of the date of the Contract Documents.

CFR	Code of Federal Regulations Available from Government Printing Office <a href="http://www.gpo.gov/fdsys">www.gpo.gov/fdsys</a>	(866) 512-1800 (202) 512-1800
DOD	Department of Defense Military Specifications and Standards Available from Department of Defense Single Stock Point <a href="http://dodssp.daps.dla.mil">http://dodssp.daps.dla.mil</a>	(215) 697-2664

DSCC	Defense Supply Center Columbus (See FS)	
FED-STD	Federal Standard (See FS)	
FS	Federal Specification Available from Department of Defense Single Stock Point <a href="http://dodssp.daps.dla.mil">http://dodssp.daps.dla.mil</a>  Available from Defense Standardization Program <a href="http://www.dsp.dla.mil">www.dsp.dla.mil</a>  Available from General Services Administration <a href="http://www.gsa.gov">www.gsa.gov</a>  Available from National Institute of Building Sciences/Whole Building Design Guide <a href="http://www.wbdg.org/ccb">www.wbdg.org/ccb</a>	(215) 697-2664          (800) 488-3111 (202) 619-8925   (202) 289-7800
MILSPEC	Military Specification and Standards (See DOD)	
USAB	United States Access Board <a href="http://www.access-board.gov">www.access-board.gov</a>	(800) 872-2253 (202) 272-0080
USATBC B	U.S. Architectural & Transportation Barriers Compliance Board  (See USAB)	

F. State Government Agencies: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. Names, telephone numbers, and Web sites are subject to change and are believed to be accurate and up-to-date as of the date of the Contract Documents.

CBHF	State of California Department of Consumer Affairs Bureau of Electronic Appliance and Repair, Home Furnishings and Thermal Insulation <a href="http://www.bearhfti.ca.gov">www.bearhfti.ca.gov</a>	(800) 952-5210 (916) 574-2041
CCR	California Code of Regulations Office of Administrative Law California Title 24 Energy Code <a href="http://www.calregs.com">www.calregs.com</a>	(916) 323-6225
CDHS	California Department of Health Care Services (Formerly: California Department of Health Services) (See CCR)	

CDPH	California Department of Public Health Indoor Air Quality Program <a href="http://www.cal-iaq.org">www.cal-iaq.org</a>	
CPUC	California Public Utilities Commission <a href="http://www.cpuc.ca.gov">www.cpuc.ca.gov</a>	(800) 848-5580 (415) 703-2782
SCAQM D	South Coast Air Quality Management District <a href="http://www.aqmd.gov">www.aqmd.gov</a>	(909) 396-2000
TFS	Texas Forest Service Forest Resource Development and Sustainable Forestry <a href="http://txforests-service.tamu.edu">http://txforests-service.tamu.edu</a>	(979) 458-6606

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 014200

## SECTION 015000 - TEMPORARY FACILITIES AND CONTROLS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes requirements for temporary utilities, support facilities, and security and protection facilities.
- B. Related Sections:
  - 1. Section 01 1000 "Summary" for work restrictions and limitations on utility interruptions.

#### 1.3 USE CHARGES

- A. General: Installation and removal of and use charges for temporary facilities shall be included in the Contract Sum unless otherwise indicated. Allow other entities to use temporary services and facilities without cost, including, but not limited to, Owner's construction forces, Architect, testing agencies, and authorities having jurisdiction.
- B. Electric Power Service: Pay electric power service use charges for electricity used by all entities for construction operations.
- C. Electric Power Service from Existing System: Electric power from Owner's existing system is available for use by metering and payment of monthly use charges. Provide connections and extensions of services as required for construction operations.

#### 1.4 INFORMATIONAL SUBMITTALS

- A. Site Plan: Show temporary facilities, utility hookups, staging areas, and parking areas for construction personnel.
- B. Erosion- and Sedimentation-Control Plan: The State of California Regional Water Quality Board requires that all projects disturbing one acre or more of land shall file a Notice of Intent to the Board and must implement a Storm Water Pollution Prevention Plan (SWPPP) in order to meet the requirements of the Construction General Permit 2009-0009-DWQ. Construction work shall not commence until the SWPPP is completed. It shall be the Contractor's responsibility to insure that the SWPPP implementation and documents are kept up to date and in compliance with State requirements. In addition, Contractor shall comply with any additional regulations under the authority having jurisdiction, including local authorities.



- C. Moisture-Protection Plan: Describe procedures and controls for protecting materials and construction from water absorption and damage, including delivery, handling, and storage provisions for materials subject to water absorption or water damage, discarding water-damaged materials, protocols for mitigating water intrusion into completed Work, and replacing water damaged Work.
  - 1. Indicate sequencing of work that requires water, such as sprayed fire-resistive materials, plastering, and terrazzo grinding, and describe plans for dealing with water from these operations. Show procedures for verifying that wet construction has dried sufficiently to permit installation of finish materials.
- D. Dust-Control and HVAC-Control Plan: Submit coordination drawing and narrative that indicates the dust-control and HVAC-control measures proposed for use, proposed locations, and proposed time frame for their operation. Identify further options if proposed measures are later determined to be inadequate. Include the following:
  - 1. Locations of dust-control partitions at each phase of the work.
  - 2. HVAC system isolation schematic drawing.
  - 3. Other dust-control measures.
  - 4. Waste management plan.

## 1.5 QUALITY ASSURANCE

- A. Tests and Inspections: Arrange for authorities having jurisdiction to test and inspect each temporary utility before use. Obtain required certifications and permits.
- B. Accessible Temporary Egress: Comply with applicable provisions in the U.S. Architectural & Transportation Barriers Compliance Board's ADA-ABA Accessibility Guidelines.

## 1.6 PROJECT CONDITIONS

- A. Temporary Use of Permanent Facilities: Engage installer of each permanent service to assume responsibility for operation, maintenance, and protection of each permanent service during its use as a construction facility before Owner's acceptance, regardless of previously assigned responsibilities.

## PART 2 - PRODUCTS

### 2.1 TEMPORARY FACILITIES

- A. Field Offices, General: Prefabricated or mobile units with serviceable finishes, temperature controls, and foundations adequate for normal loading.
- B. CM Field Office: CM office will be located in existing Natividad Hospital Building 700 (approx. 1,200 sq. ft.). Contractor to maintain and service existing toilets to County satisfaction. Provide janitorial type services to keep office clean and orderly throughout duration of the project. Furnish and equip the CM office as follows for the duration of the project:

1. Furniture required includes: 4 drawer file cabinet, wall mounted sloped plan review surface (3 feet by 7 feet), metal plan racks capable of holding the entire set of construction drawings, 5 shelf bookcases (2), desks with return (3), padded desk chairs (3), four (4) 4 foot x 3 foot whiteboards, and a 4 foot square tack board. Furniture required for Project-site documents including file cabinets, plan tables, plan racks, and bookcases. Existing Conference room area will accommodate 16 individuals. Furnish conference room with conference (3) folding (3ft.x6 ft.) tables, (20) folding metal chairs, and 4-foot- square tack and marker boards.
2. Land roll-over phone lines (one outlet per office, one outlet for networked copier, one outlet for fax, one outlet for conference table, one outlet for plan table). Speaker phones (4 each) and integral answering machine.
3. Network capable printer/scanner/fax/copier unit (Minolta / Konica Bizhub Model C652) networked to email and phone with automatic paper feed, Provide toner and paper supplies (8 1/2" x 11", 11"x17", etc...) for the duration of the project
4. Network capable printer (2) units (HP LaserJet P2055dn or similar).
5. High-speed wireless internet (broadband) connection (100 Mbps minimum) for the duration of the project
6. GoToMeeting® subscription in Construction Manager's name to be used for the duration of the project.
7. Drinking water and dispensing unit, coat rack, coffee maker, and coffee supplies for the duration of the project.
8. 50" TV Monitor, 120 Hz, 1080p, for electronic review of RFI, Submittals, Record Documents, BIM coordination drawings.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION, GENERAL

- A. Locate facilities where they will serve Project adequately and result in minimum interference with performance of the Work. Relocate and modify facilities as required by progress of the Work.
  1. Locate facilities to limit site disturbance as specified in Division 01 Section "Summary."
- B. Provide each facility ready for use when needed to avoid delay. Do not remove until facilities are no longer needed or are replaced by authorized use of completed permanent facilities.

#### 3.2 TEMPORARY UTILITY INSTALLATION

- A. General: Install temporary service or connect to existing service.
  1. Arrange with utility company, Owner, and existing users for time when service can be interrupted, if necessary, to make connections for temporary services.

- B. Telephone Service: Provide temporary telephone service in common-use facilities for use by all construction personnel. Install one telephone line for each contractor field office.
  - 1. Provide additional telephone lines for the following:
    - a. Provide a dedicated telephone line for each facsimile machine in each field office.
    - b. Provide one telephone line for Owner's use. See Section 2.1 for County Field Office.
  - 2. At each telephone, post a list of important telephone numbers.
    - a. Police and fire departments.
    - b. Ambulance service.
    - c. Contractor's home office.
  - 3. Provide contractor's project manager and superintendent with cellular telephone or portable two-way radio for use when away from field office.

### 3.3 SUPPORT FACILITIES INSTALLATION

- A. General: Comply with the following:
  - 1. Maintain support facilities until Architect schedules Substantial Completion inspection. Remove before Substantial Completion. Personnel remaining after Substantial Completion will be permitted to use permanent facilities, under conditions acceptable to Owner.
- B. Temporary Use of Permanent Roads and Paved Areas: Locate temporary roads and paved areas in same location as permanent roads and paved areas. Construct and maintain temporary roads and paved areas adequate for construction operations. Extend temporary roads and paved areas, within construction limits indicated, as necessary for construction operations.
  - 1. Coordinate elevations of temporary roads and paved areas with permanent roads and paved areas.
  - 2. Prepare subgrade and install subbase and base for temporary roads and paved areas according to Division 31 Section "Earth Moving."
  - 3. Recondition base after temporary use, including removing contaminated material, regrading, proofrolling, compacting, and testing.
- C. Traffic Controls: Comply with requirements of authorities having jurisdiction.
  - 1. Protect existing site improvements to remain including curbs, pavement, and utilities.
  - 2. Maintain access for fire-fighting equipment and access to fire hydrants.
- D. Waste Disposal Facilities: Provide waste-collection containers in sizes adequate to handle waste from construction operations. Comply with requirements of authorities having jurisdiction. Comply with Division 01 Section "Execution" for progress cleaning requirements.

### 3.4 OPERATION, TERMINATION, AND REMOVAL

- A. Supervision: Enforce strict discipline in use of temporary facilities. To minimize waste and abuse, limit availability of temporary facilities to essential and intended uses.
- B. Maintenance: Maintain facilities in good operating condition until removal.
- C. Temporary Facility Changeover: Do not change over from using temporary security and protection facilities to permanent facilities until Substantial Completion.
- D. Termination and Removal: Remove each temporary facility when need for its service has ended, when it has been replaced by authorized use of a permanent facility, or no later than Substantial Completion.

Complete or, if necessary, restore permanent construction that may have been delayed because of interference with temporary facility. Repair damaged Work, clean exposed surfaces, and replace construction that cannot be satisfactorily repaired.

1. Materials and facilities that constitute temporary facilities are property of Contractor. Owner reserves right to take possession of Project identification signs.
2. At Substantial Completion, repair, renovate, and clean permanent facilities used during construction period. Comply with final cleaning requirements specified in Division 01 Section "Closeout Procedures."

END OF SECTION 01 50 00

## SECTION 015639 - TEMPORARY TREE AND PLANT PROTECTION

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes general protection and pruning of existing trees and plants that are affected by execution of the Work, whether temporary or permanent construction.
- B. Related Sections:
  - 1. Section 015000 "Temporary Facilities and Controls" for temporary site fencing.
  - 2. Section 311000 "Site Clearing" for removing existing trees and shrubs.

#### 1.3 DEFINITIONS

- A. Caliper: Diameter of a trunk measured by the average of the smallest and largest diameters at 6 inches (150 mm) above the ground for trees up to, and including, 4-inch (100-mm) size; and 12 inches (300 mm) above the ground for trees larger than 4-inch (100-mm) size.
- B. Plant-Protection Zone: Area surrounding individual trees, groups of trees, shrubs, or other vegetation to be protected during construction, and indicated on Drawings.
- C. Tree-Protection Zone: Area surrounding individual trees or groups of trees to be protected during construction, and defined by a circle concentric with each tree with a radius 1.5 times the diameter of the drip line unless otherwise indicated.
- D. Vegetation: Trees, shrubs, groundcovers, grass, and other plants.

#### 1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Samples for Verification: For each type of the following:
  - 1. Organic Mulch: 1-quart (1-L) volume of organic mulch; in sealed plastic bags labeled with composition of materials by percentage of weight and source of mulch.
  - 2. Protection-Zone Fencing: Assembled Samples of manufacturer's standard size made from full-size components.
  - 3. Protection-Zone Signage: Full-size Samples of each size and text, ready for installation.

#### 1.5 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For qualified arborist and tree service firm.
- B. Certification: From arborist, certifying that trees indicated to remain have been protected during construction according to recognized standards and that trees were promptly and properly treated and repaired when damaged.
- C. Maintenance Recommendations: From arborist, for care and protection of trees affected by construction during and after completing the Work.
- D. Existing Conditions: Documentation of existing trees and plantings indicated to remain, which establishes preconstruction conditions that might be misconstrued as damage caused by construction activities.
  - 1. Use sufficiently detailed photographs or videotape.
  - 2. Include plans and notations to indicate specific wounds and damage conditions of each tree or other plants designated to remain.

#### 1.6 QUALITY ASSURANCE

- A. Arborist Qualifications: Certified Arborist as certified by ISA.
- B. Tree Service Firm Qualifications: An experienced tree service firm that has successfully completed tree and plant protection work similar to that required for this Project and that will assign an experienced, qualified arborist to Project site during execution of the Work.
- C. Preinstallation Conference: Conduct conference at Project site.
  - 1. Review methods and procedures related to temporary tree and plant protection including, but not limited to, the following:
    - a. Construction schedule. Verify availability of materials, personnel, and equipment needed to make progress and avoid delays.
    - b. Enforcing requirements for protection zones.
    - c. Arborist's responsibilities.
    - d. Field quality control.

#### 1.7 PROJECT CONDITIONS

- A. The following practices are prohibited within protection zones:
  - 1. Storage of construction materials, debris, or excavated material.
  - 2. Parking vehicles or equipment.
  - 3. Foot traffic.
  - 4. Erection of sheds or structures.
  - 5. Impoundment of water.
  - 6. Excavation or other digging unless otherwise indicated.
  - 7. Attachment of signs to or wrapping materials around trees or plants unless otherwise indicated.
- B. Do not direct vehicle or equipment exhaust toward protection zones.

- C. Prohibit heat sources, flames, ignition sources, and smoking within or near protection zones and organic mulch.

## PART 2 - PRODUCTS

### 2.1 MATERIALS

- A. Topsoil: Natural or cultivated top layer of the soil profile or manufactured topsoil; containing organic matter and sand, silt, and clay particles; friable, pervious, and black or a darker shade of brown, gray, or red than underlying subsoil; reasonably free of subsoil, clay lumps, gravel, and other objects more than 1 inch (25 mm) in diameter; and free of weeds, roots, and toxic and other nonsoil materials.
  - 1. Obtain topsoil only from well-drained sites where topsoil is 4 inches (100 mm) deep or more; do not obtain from bogs or marshes.
- B. Organic Mulch: Free from deleterious materials and suitable as a top dressing for trees and shrubs, consisting of one of the following:
  - 1. Type: Shredded hardwood.
  - 2. Size Range: 3 inches (76 mm) maximum, 1/2 inch (13 mm) minimum.
  - 3. Color: Natural.
- C. Protection-Zone Fencing: Fencing fixed in position and meeting one of the following requirements. Previously used materials may be used when approved by Architect.
  - 1. Chain-Link Protection-Zone Fencing: Galvanized-steel fencing fabricated from minimum 2-inch (50-mm) opening, 0.148-inch- (3.76-mm-) diameter wire chain-link fabric; with pipe posts, minimum 2-3/8-inch- (60-mm-) OD line posts, and 2-7/8-inch- (73-mm-) OD corner and pull posts; with 1-5/8-inch- (42-mm-) OD top rails; and 0.177-inch- (4.5-mm-) diameter bottom tension wire; with tie wires, hog ring ties, and other accessories for a complete fence system.
    - a. Height: 6 feet (1.8 m).
  - 2. Plastic Protection-Zone Fencing: Plastic construction fencing constructed of high-density extruded and stretched polyethylene fabric with 2-inch (50-mm) maximum opening in pattern and weighing a minimum of 0.4 lb/ft. (0.6 kg/m); remaining flexible from minus 60 to plus 200 deg F (minus 16 to plus 93 deg C); inert to most chemicals and acids; minimum tensile yield strength of 2000 psi (13.8 MPa) and ultimate tensile strength of 2680 psi (18.5 MPa); secured with plastic bands or galvanized-steel or stainless-steel wire ties; and supported by tubular or T-shape galvanized-steel posts spaced not more than 8 feet (2.4 m) apart.
    - a. Height: 4 feet (1.2 m).
    - b. Color: High-visibility orange, nonfading.
  - 3. Gates: Single swing access gates matching material and appearance of fencing, to allow for maintenance activities within protection zones; leaf width 36 inches (914 mm).
- D. Protection-Zone Signage: Shop-fabricated, rigid plastic or metal sheet with attachment holes prepunched and reinforced; legibly printed with nonfading lettering and as follows:
  - 1. Size and Text: As shown on Drawings.

2. Lettering: 3-inch- (75-mm-) high minimum, black characters on white background.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Erosion and Sedimentation Control: Examine the site to verify that temporary erosion- and sedimentation-control measures are in place. Verify that flows of water redirected from construction areas or generated by construction activity do not enter or cross protection zones.
- B. For the record, prepare written report, endorsed by arborist, listing conditions detrimental to tree and plant protection.
- C. Soil Aeration: Where directed by Architect, aerate surface soil compacted during construction. Aerate 10 feet (3 m) beyond drip line and no closer than 36 inches (900 mm) to tree trunk. Drill 2-inch- (50-mm-) diameter holes a minimum of 12 inches (300 mm) deep at 24 inches (600 mm) o.c. Backfill holes with an equal mix of augered soil and sand.

#### 3.2 DISPOSAL OF SURPLUS AND WASTE MATERIALS

- A. Disposal: Remove excess excavated material, displaced trees, trash and debris, and legally dispose of them off Owner's property.

END OF SECTION 015639



## SECTION 016000 - PRODUCT REQUIREMENTS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for selection of products for use in Project; product delivery, storage, and handling; manufacturers' standard warranties on products; special warranties; and comparable products.
- B. Related Requirements:
  - 1. Section 012100 "Allowances" for products selected under an allowance.
  - 2. Section 012300 "Alternates" for products selected under an alternate.
  - 3. Section 012500 "Substitution Procedures" for requests for substitutions.
  - 4. Section 014200 "References" for applicable industry standards for products specified.

#### 1.3 DEFINITIONS

- A. Products: Items obtained for incorporating into the Work, whether purchased for Project or taken from previously purchased stock. The term "product" includes the terms "material," "equipment," "system," and terms of similar intent.
  - 1. Named Products: Items identified by manufacturer's product name, including make or model number or other designation shown or listed in manufacturer's published product literature, that is current as of date of the Contract Documents.
  - 2. New Products: Items that have not previously been incorporated into another project or facility. Products salvaged or recycled from other projects are not considered new products.
  - 3. Comparable Product: Product that is demonstrated and approved through submittal process to have the indicated qualities related to type, function, dimension, in-service performance, physical properties, appearance, and other characteristics that equal or exceed those of specified product.
- B. Basis-of-Design Product Specification: A specification in which a specific manufacturer's product is named and accompanied by the words "basis-of-design product," including make or model number or other designation, to establish the significant qualities related to type, function, dimension, in-service performance, physical properties, appearance, and other characteristics for purposes of evaluating comparable products of additional manufacturers named in the specification.

#### 1.4 ACTION SUBMITTALS

- A. Comparable Product Requests: Submit request for consideration of each comparable product. Identify product or fabrication or installation method to be replaced. Include Specification Section number and title and Drawing numbers and titles.
1. Include data to indicate compliance with the requirements specified in "Comparable Products" Article.
  2. Architect's Action: If necessary, Architect will request additional information or documentation for evaluation within one week of receipt of a comparable product request. Architect will notify Contractor through Construction Manager of approval or rejection of proposed comparable product request within 15 days of receipt of request, or seven days of receipt of additional information or documentation, whichever is later.
    - a. Form of Approval: As specified in Section 013300 "Submittal Procedures."
    - b. Use product specified if Architect does not issue a decision on use of a comparable product request within time allocated.
- B. Basis-of-Design Product Specification Submittal: Comply with requirements in Section 013300 "Submittal Procedures." Show compliance with requirements.

#### 1.5 QUALITY ASSURANCE

- A. Compatibility of Options: If Contractor is given option of selecting between two or more products for use on Project, select product compatible with products previously selected, even if previously selected products were also options.

#### 1.6 PRODUCT DELIVERY, STORAGE, AND HANDLING

- A. Deliver, store, and handle products using means and methods that will prevent damage, deterioration, and loss, including theft and vandalism. Comply with manufacturer's written instructions.
- B. Delivery and Handling:
1. Schedule delivery to minimize long-term storage at Project site and to prevent overcrowding of construction spaces.
  2. Coordinate delivery with installation time to ensure minimum holding time for items that are flammable, hazardous, easily damaged, or sensitive to deterioration, theft, and other losses.
  3. Deliver products to Project site in an undamaged condition in manufacturer's original sealed container or other packaging system, complete with labels and instructions for handling, storing, unpacking, protecting, and installing.
  4. Inspect products on delivery to determine compliance with the Contract Documents and to determine that products are undamaged and properly protected.
- C. Storage:
1. Store products to allow for inspection and measurement of quantity or counting of units.
  2. Store materials in a manner that will not endanger Project structure.
  3. Store products that are subject to damage by the elements, under cover in a weathertight enclosure above ground, with ventilation adequate to prevent condensation.

4. Protect foam plastic from exposure to sunlight, except to extent necessary for period of installation and concealment.
5. Comply with product manufacturer's written instructions for temperature, humidity, ventilation, and weather-protection requirements for storage.
6. Protect stored products from damage and liquids from freezing.

## 1.7 PRODUCT WARRANTIES

- A. Warranties specified in other Sections shall be in addition to, and run concurrent with, other warranties required by the Contract Documents. Manufacturer's disclaimers and limitations on product warranties do not relieve Contractor of obligations under requirements of the Contract Documents.
  1. **Manufacturer's Warranty:** Written warranty furnished by individual manufacturer for a particular product and specifically endorsed by manufacturer to Owner.
  2. **Special Warranty:** Written warranty required by the Contract Documents to provide specific rights for Owner.
- B. **Special Warranties:** Prepare a written document that contains appropriate terms and identification, ready for execution.
  1. **Manufacturer's Standard Form:** Modified to include Project-specific information and properly executed.
  2. **Specified Form:** When specified forms are included with the Specifications, prepare a written document using indicated form properly executed.
  3. See other Sections for specific content requirements and particular requirements for submitting special warranties.
- C. **Submittal Time:** Comply with requirements in Section 017700 "Closeout Procedures."

## PART 2 - PRODUCTS

### 2.1 PRODUCT SELECTION PROCEDURES

- A. **General Product Requirements:** Provide products that comply with the Contract Documents, are undamaged and, unless otherwise indicated, are new at time of installation.
  1. Provide products complete with accessories, trim, finish, fasteners, and other items needed for a complete installation and indicated use and effect.
  2. **Standard Products:** If available, and unless custom products or nonstandard options are specified, provide standard products of types that have been produced and used successfully in similar situations on other projects.
  3. Owner reserves the right to limit selection to products with warranties not in conflict with requirements of the Contract Documents.
  4. Where products are accompanied by the term "as selected," Architect will make selection.
  5. Descriptive, performance, and reference standard requirements in the Specifications establish salient characteristics of products.
  6. **Or Equal:** For products specified by name and accompanied by the term "or equal," or "or approved equal," or "or approved," comply with requirements in "Comparable Products" Article to obtain approval for use of an unnamed product.

B. Product Selection Procedures:

1. Product: Where Specifications name a single manufacturer and product, provide the named product that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered.
  2. Manufacturer/Source: Where Specifications name a single manufacturer or source, provide a product by the named manufacturer or source that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered.
  3. Products:
    - a. Restricted List: Where Specifications include a list of names of both manufacturers and products, provide one of the products listed that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered unless otherwise indicated.
    - b. Nonrestricted List: Where Specifications include a list of names of both available manufacturers and products, provide one of the products listed, or an unnamed product, that complies with requirements. Comply with requirements in "Comparable Products" Article for consideration of an unnamed product.
  4. Manufacturers:
    - a. Restricted List: Where Specifications include a list of manufacturers' names, provide a product by one of the manufacturers listed that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered.
    - b. Nonrestricted List: Where Specifications include a list of available manufacturers, provide a product by one of the manufacturers listed, or a product by an unnamed manufacturer, that complies with requirements. Comply with requirements in "Comparable Products" Article for consideration of an unnamed manufacturer's product.
  5. Basis-of-Design Product: Where Specifications name a product, or refer to a product indicated on Drawings, and include a list of manufacturers, provide the specified or indicated product or a comparable product by one of the other named manufacturers. Drawings and Specifications indicate sizes, profiles, dimensions, and other characteristics that are based on the product named. Comply with requirements in "Comparable Products" Article for consideration of an unnamed product by one of the other named manufacturers.
- C. Visual Matching Specification: Where Specifications require "match Architect's sample", provide a product that complies with requirements and matches Architect's sample. Architect's decision will be final on whether a proposed product matches.
1. If no product available within specified category matches and complies with other specified requirements, comply with requirements in Section 012500 "Substitution Procedures" for proposal of product.
- D. Visual Selection Specification: Where Specifications include the phrase "as selected by Architect from manufacturer's full range" or similar phrase, select a product that complies with requirements. Architect will select color, gloss, pattern, density, or texture from manufacturer's product line that includes both standard and premium items.

## 2.2 COMPARABLE PRODUCTS

- A. Conditions for Consideration: Architect will consider Contractor's request for comparable product when the following conditions are satisfied. If the following conditions are not satisfied, Architect may return requests without action, except to record noncompliance with these requirements:
1. Evidence that the proposed product does not require revisions to the Contract Documents, that it is consistent with the Contract Documents and will produce the indicated results, and that it is compatible with other portions of the Work.
  2. Detailed comparison of significant qualities of proposed product with those named in the Specifications. Significant qualities include attributes such as performance, weight, size, durability, visual effect, and specific features and requirements indicated.
  3. Evidence that proposed product provides specified warranty.
  4. List of similar installations for completed projects with project names and addresses and names and addresses of architects and owners, if requested.
  5. Samples, if requested.

PART 3 - EXECUTION (Not Used)

END OF SECTION 016000

## SECTION 017300 - EXECUTION

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes general administrative and procedural requirements governing execution of the Work including, but not limited to, the following:

1. Construction layout.
2. Field engineering and surveying.
3. Installation of the Work.
4. Cutting and patching.
5. Coordination of Owner-installed products.
6. Progress cleaning.
7. Starting and adjusting.
8. Protection of installed construction.
9. Correction of the Work.

- B. Related Requirements:

1. Section 011000 "Summary" for limits on use of Project site.
2. Section 013300 "Submittal Procedures" for submitting surveys.
3. Section 017700 "Closeout Procedures" for submitting final property survey with Project Record Documents, recording of Owner-accepted deviations from indicated lines and levels, and final cleaning.
4. Section 024119 "Selective Demolition" for demolition and removal of selected portions of the building.
5. Section 078413 "Penetration Firestopping" for patching penetrations in fire-rated construction.

#### 1.3 DEFINITIONS

- A. Cutting: Removal of in-place construction necessary to permit installation or performance of other work.
- B. Patching: Fitting and repair work required to restore construction to original conditions after installation of other work.

#### 1.4 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For professional engineer.

- B. Certificates: Submit certificate signed by professional engineer certifying that location and elevation of improvements comply with requirements.
- C. Cutting and Patching Plan: Submit plan describing procedures at least 10 days prior to the time cutting and patching will be performed. Include the following information:
  - 1. Extent: Describe reason for and extent of each occurrence of cutting and patching.
  - 2. Changes to In-Place Construction: Describe anticipated results. Include changes to structural elements and operating components as well as changes in building appearance and other significant visual elements.
  - 3. Products: List products to be used for patching and firms or entities that will perform patching work.
  - 4. Dates: Indicate when cutting and patching will be performed.
  - 5. Utilities and Mechanical and Electrical Systems: List services and systems that cutting and patching procedures will disturb or affect. List services and systems that will be relocated and those that will be temporarily out of service. Indicate length of time permanent services and systems will be disrupted.
    - a. Include description of provisions for temporary services and systems during interruption of permanent services and systems.
- D. Landfill Receipts: Submit copy of receipts issued by a landfill facility, licensed to accept hazardous materials, for hazardous waste disposal.
- E. Certified Surveys: Submit two copies signed by professional engineer.
- F. Final Property Survey: Submit 10 copies showing the Work performed and record survey data.

## 1.5 QUALITY ASSURANCE

- A. Land Surveyor Qualifications: A professional land surveyor who is legally qualified to practice in jurisdiction where Project is located and who is experienced in providing land-surveying services of the kind indicated.
- B. Cutting and Patching: Comply with requirements for and limitations on cutting and patching of construction elements.
  - 1. Structural Elements: When cutting and patching structural elements, notify Architect of locations and details of cutting and await directions from Architect before proceeding. Shore, brace, and support structural elements during cutting and patching. Do not cut and patch structural elements in a manner that could change their load-carrying capacity or increase deflection
  - 2. Operational Elements: Do not cut and patch operating elements and related components in a manner that results in reducing their capacity to perform as intended or that results in increased maintenance or decreased operational life or safety. Operational elements include the following:
    - a. Primary operational systems and equipment.
    - b. Fire separation assemblies.
    - c. Air or smoke barriers.
    - d. Fire-suppression systems.
    - e. Mechanical systems piping and ducts.
    - f. Control systems.

- g. Communication systems.
  - h. Fire-detection and -alarm systems.
  - i. Conveying systems.
  - j. Electrical wiring systems.
3. Other Construction Elements: Do not cut and patch other construction elements or components in a manner that could change their load-carrying capacity, that results in reducing their capacity to perform as intended, or that results in increased maintenance or decreased operational life or safety. Other construction elements include but are not limited to the following:
- a. Water, moisture, or vapor barriers.
  - b. Membranes and flashings.
  - c. Exterior curtain-wall construction.
  - d. Sprayed fire-resistive material.
  - e. Equipment supports.
  - f. Piping, ductwork, vessels, and equipment.
  - g. Noise- and vibration-control elements and systems.
4. Visual Elements: Do not cut and patch construction in a manner that results in visual evidence of cutting and patching. Do not cut and patch exposed construction in a manner that would, in Architect's opinion, reduce the building's aesthetic qualities. Remove and replace construction that has been cut and patched in a visually unsatisfactory manner.
- C. Manufacturer's Installation Instructions: Obtain and maintain on-site manufacturer's written recommendations and instructions for installation of products and equipment.

## PART 2 - PRODUCTS

### 2.1 MATERIALS

- A. General: Comply with requirements specified in other Sections.
- B. In-Place Materials: Use materials for patching identical to in-place materials. For exposed surfaces, use materials that visually match in-place adjacent surfaces to the fullest extent possible.
  - 1. If identical materials are unavailable or cannot be used, use materials that, when installed, will provide a match acceptable to Architect for the visual and functional performance of in-place materials.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Existing Conditions: The existence and location of underground and other utilities and construction indicated as existing are not guaranteed. Before beginning sitework, investigate and verify the existence and location of underground utilities, mechanical and electrical systems, and other construction affecting the Work.



1. Before construction, verify the location and invert elevation at points of connection of sanitary sewer, storm sewer, and water-service piping; underground electrical services, and other utilities.
  2. Furnish location data for work related to Project that must be performed by public utilities serving Project site.
- B. Examination and Acceptance of Conditions: Before proceeding with each component of the Work, examine substrates, areas, and conditions, with Installer or Applicator present where indicated, for compliance with requirements for installation tolerances and other conditions affecting performance. Record observations.
1. Examine roughing-in for mechanical and electrical systems to verify actual locations of connections before equipment and fixture installation.
  2. Examine walls, floors, and roofs for suitable conditions where products and systems are to be installed.
  3. Verify compatibility with and suitability of substrates, including compatibility with existing finishes or primers.
- C. Proceed with installation only after unsatisfactory conditions have been corrected. Proceeding with the Work indicates acceptance of surfaces and conditions.

### 3.2 PREPARATION

- A. Existing Utility Information: Furnish information to Owner that is necessary to adjust, move, or relocate existing utility structures, utility poles, lines, services, or other utility appurtenances located in or affected by construction. Coordinate with authorities having jurisdiction.
- B. Field Measurements: Take field measurements as required to fit the Work properly. Recheck measurements before installing each product. Where portions of the Work are indicated to fit to other construction, verify dimensions of other construction by field measurements before fabrication. Coordinate fabrication schedule with construction progress to avoid delaying the Work.
- C. Space Requirements: Verify space requirements and dimensions of items shown diagrammatically on Drawings.
- D. Review of Contract Documents and Field Conditions: Immediately on discovery of the need for clarification of the Contract Documents caused by differing field conditions outside the control of Contractor, submit a request for information to Architect according to requirements in Section 013100 "Project Management and Coordination."

### 3.3 CONSTRUCTION LAYOUT

- A. Verification: Before proceeding to lay out the Work, verify layout information shown on Drawings, in relation to the property survey and existing benchmarks. If discrepancies are discovered, notify Architect and Construction Manager promptly.
- B. General: Engage a professional engineer to lay out the Work using accepted surveying practices.
1. Establish benchmarks and control points to set lines and levels at each story of construction and elsewhere as needed to locate each element of Project.
  2. Establish limits on use of Project site.

3. Establish dimensions within tolerances indicated. Do not scale Drawings to obtain required dimensions.
4. Inform installers of lines and levels to which they must comply.
5. Check the location, level and plumb, of every major element as the Work progresses.
6. Notify Architect and Construction Manager when deviations from required lines and levels exceed allowable tolerances.
7. Close site surveys with an error of closure equal to or less than the standard established by authorities having jurisdiction.

- C. Site Improvements: Locate and lay out site improvements, including pavements, grading, fill and topsoil placement, utility slopes, and rim and invert elevations.
- D. Building Lines and Levels: Locate and lay out control lines and levels for structures, building foundations, column grids, and floor levels, including those required for mechanical and electrical work. Transfer survey markings and elevations for use with control lines and levels. Level foundations and piers from two or more locations.
- E. Record Log: Maintain a log of layout control work. Record deviations from required lines and levels. Include beginning and ending dates and times of surveys, weather conditions, name and duty of each survey party member, and types of instruments and tapes used. Make the log available for reference by Architect.

#### 3.4 FIELD ENGINEERING

- A. Identification: Owner will identify existing benchmarks, control points, and property corners.
- B. Reference Points: Locate existing permanent benchmarks, control points, and similar reference points before beginning the Work. Preserve and protect permanent benchmarks and control points during construction operations.
1. Do not change or relocate existing benchmarks or control points without prior written approval of Architect. Report lost or destroyed permanent benchmarks or control points promptly. Report the need to relocate permanent benchmarks or control points to Architect before proceeding.
  2. Replace lost or destroyed permanent benchmarks and control points promptly. Base replacements on the original survey control points.
- C. Benchmarks: Establish and maintain a minimum of two permanent benchmarks on Project site, referenced to data established by survey control points. Comply with authorities having jurisdiction for type and size of benchmark.
1. Record benchmark locations, with horizontal and vertical data, on Project Record Documents.
  2. Where the actual location or elevation of layout points cannot be marked, provide temporary reference points sufficient to locate the Work.
  3. Remove temporary reference points when no longer needed. Restore marked construction to its original condition.
- D. Certified Survey: On completion of foundation walls, major site improvements, and other work requiring field-engineering services, prepare a certified survey showing dimensions, locations, angles, and elevations of construction and sitework.
- E. Final Property Survey: Engage a professional engineer to prepare a final property survey showing significant features (real property) for Project. Include on the survey a certification, signed by

professional engineer, that principal metes, bounds, lines, and levels of Project are accurately positioned as shown on the survey.

1. Show boundary lines, monuments, streets, site improvements and utilities, existing improvements and significant vegetation, adjoining properties, acreage, grade contours, and the distance and bearing from a site corner to a legal point.
2. Recording: At Substantial Completion, have the final property survey recorded by or with authorities having jurisdiction as the official "property survey."

### 3.5 INSTALLATION

- A. General: Locate the Work and components of the Work accurately, in correct alignment and elevation, as indicated.
  1. Make vertical work plumb and make horizontal work level.
  2. Where space is limited, install components to maximize space available for maintenance and ease of removal for replacement.
  3. Conceal pipes, ducts, and wiring in finished areas unless otherwise indicated.
  4. Maintain minimum headroom clearance of 96 inches (2440 mm) in occupied spaces and 90 inches (2300 mm) in unoccupied spaces.
- B. Comply with manufacturer's written instructions and recommendations for installing products in applications indicated.
- C. Install products at the time and under conditions that will ensure the best possible results. Maintain conditions required for product performance until Substantial Completion.
- D. Conduct construction operations so no part of the Work is subjected to damaging operations or loading in excess of that expected during normal conditions of occupancy.
- E. Sequence the Work and allow adequate clearances to accommodate movement of construction items on site and placement in permanent locations.
- F. Tools and Equipment: Do not use tools or equipment that produce harmful noise levels.
- G. Templates: Obtain and distribute to the parties involved templates for work specified to be factory prepared and field installed. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing products to comply with indicated requirements.
- H. Attachment: Provide blocking and attachment plates and anchors and fasteners of adequate size and number to securely anchor each component in place, accurately located and aligned with other portions of the Work. Where size and type of attachments are not indicated, verify size and type required for load conditions.
  1. Mounting Heights: Where mounting heights are not indicated, mount components at heights directed by Architect.
  2. Allow for building movement, including thermal expansion and contraction.
  3. Coordinate installation of anchorages. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors, that are to be embedded in concrete or masonry. Deliver such items to Project site in time for installation.

- I. Joints: Make joints of uniform width. Where joint locations in exposed work are not indicated, arrange joints for the best visual effect. Fit exposed connections together to form hairline joints.
- J. Hazardous Materials: Use products, cleaners, and installation materials that are not considered hazardous.

### 3.6 CUTTING AND PATCHING

- A. Cutting and Patching, General: Employ skilled workers to perform cutting and patching. Proceed with cutting and patching at the earliest feasible time, and complete without delay.
  - 1. Cut in-place construction to provide for installation of other components or performance of other construction, and subsequently patch as required to restore surfaces to their original condition.
- B. Existing Warranties: Remove, replace, patch, and repair materials and surfaces cut or damaged during installation or cutting and patching operations, by methods and with materials so as not to void existing warranties.
- C. Temporary Support: Provide temporary support of work to be cut.
- D. Protection: Protect in-place construction during cutting and patching to prevent damage. Provide protection from adverse weather conditions for portions of Project that might be exposed during cutting and patching operations.
- E. Adjacent Occupied Areas: Where interference with use of adjoining areas or interruption of free passage to adjoining areas is unavoidable, coordinate cutting and patching according to requirements in Section 011000 "Summary."
- F. Existing Utility Services and Mechanical/Electrical Systems: Where existing services/systems are required to be removed, relocated, or abandoned, bypass such services/systems before cutting to prevent interruption to occupied areas.
- G. Cutting: Cut in-place construction by sawing, drilling, breaking, chipping, grinding, and similar operations, including excavation, using methods least likely to damage elements retained or adjoining construction. If possible, review proposed procedures with original Installer; comply with original Installer's written recommendations.
  - 1. In general, use hand or small power tools designed for sawing and grinding, not hammering and chopping. Cut holes and slots neatly to minimum size required, and with minimum disturbance of adjacent surfaces. Temporarily cover openings when not in use.
  - 2. Finished Surfaces: Cut or drill from the exposed or finished side into concealed surfaces.
  - 3. Concrete and Masonry: Cut using a cutting machine, such as an abrasive saw or a diamond-core drill.
  - 4. Excavating and Backfilling: Comply with requirements in applicable Sections where required by cutting and patching operations.
  - 5. Mechanical and Electrical Services: Cut off pipe or conduit in walls or partitions to be removed. Cap, valve, or plug and seal remaining portion of pipe or conduit to prevent entrance of moisture or other foreign matter after cutting.
  - 6. Proceed with patching after construction operations requiring cutting are complete.
- H. Patching: Patch construction by filling, repairing, refinishing, closing up, and similar operations following performance of other work. Patch with durable seams that are as invisible as practicable.

Provide materials and comply with installation requirements specified in other Sections, where applicable.

1. Inspection: Where feasible, test and inspect patched areas after completion to demonstrate physical integrity of installation.
  2. Exposed Finishes: Restore exposed finishes of patched areas and extend finish restoration into retained adjoining construction in a manner that will minimize evidence of patching and refinishing.
    - a. Clean piping, conduit, and similar features before applying paint or other finishing materials.
    - b. Restore damaged pipe covering to its original condition.
  3. Floors and Walls: Where walls or partitions that are removed extend one finished area into another, patch and repair floor and wall surfaces in the new space. Provide an even surface of uniform finish, color, texture, and appearance. Remove in-place floor and wall coverings and replace with new materials, if necessary, to achieve uniform color and appearance.
    - a. Where patching occurs in a painted surface, prepare substrate and apply primer and intermediate paint coats appropriate for substrate over the patch, and apply final paint coat over entire unbroken surface containing the patch. Provide additional coats until patch blends with adjacent surfaces.
  4. Ceilings: Patch, repair, or rehang in-place ceilings as necessary to provide an even-plane surface of uniform appearance.
  5. Exterior Building Enclosure: Patch components in a manner that restores enclosure to a weathertight condition and ensures thermal and moisture integrity of building enclosure.
- I. Cleaning: Clean areas and spaces where cutting and patching are performed. Remove paint, mortar, oils, putty, and similar materials from adjacent finished surfaces.

### 3.7 OWNER-INSTALLED PRODUCTS

- A. Site Access: Provide access to Project site for Owner's construction personnel.
- B. Coordination: Coordinate construction and operations of the Work with work performed by Owner's construction personnel.
  1. Construction Schedule: Inform Owner of Contractor's preferred construction schedule for Owner's portion of the Work. Adjust construction schedule based on a mutually agreeable timetable. Notify Owner if changes to schedule are required due to differences in actual construction progress.
  2. Preinstallation Conferences: Include Owner's construction personnel at preinstallation conferences covering portions of the Work that are to receive Owner's work. Attend preinstallation conferences conducted by Owner's construction personnel if portions of the Work depend on Owner's construction.

### 3.8 PROGRESS CLEANING

- A. General: Clean Project site and work areas daily, including common areas. Enforce requirements strictly. Dispose of materials lawfully.

1. Comply with requirements in NFPA 241 for removal of combustible waste materials and debris.
  2. Do not hold waste materials more than seven days during normal weather or three days if the temperature is expected to rise above 80 deg F (27 deg C).
  3. Containerize hazardous and unsanitary waste materials separately from other waste. Mark containers appropriately and dispose of legally, according to regulations.
    - a. Use containers intended for holding waste materials of type to be stored.
- B. Site: Maintain Project site free of waste materials and debris.
- C. Work Areas: Clean areas where work is in progress to the level of cleanliness necessary for proper execution of the Work.
1. Remove liquid spills promptly.
  2. Where dust would impair proper execution of the Work, broom-clean or vacuum the entire work area, as appropriate.
- D. Installed Work: Keep installed work clean. Clean installed surfaces according to written instructions of manufacturer or fabricator of product installed, using only cleaning materials specifically recommended. If specific cleaning materials are not recommended, use cleaning materials that are not hazardous to health or property and that will not damage exposed surfaces.
- E. Concealed Spaces: Remove debris from concealed spaces before enclosing the space.
- F. Exposed Surfaces in Finished Areas: Clean exposed surfaces and protect as necessary to ensure freedom from damage and deterioration at time of Substantial Completion.
- G. Waste Disposal: Do not bury or burn waste materials on-site. Do not wash waste materials down sewers or into waterways. Comply with waste disposal requirements in Section 015000 "Temporary Facilities and Controls."
- H. During handling and installation, clean and protect construction in progress and adjoining materials already in place. Apply protective covering where required to ensure protection from damage or deterioration at Substantial Completion.
- I. Clean and provide maintenance on completed construction as frequently as necessary through the remainder of the construction period. Adjust and lubricate operable components to ensure operability without damaging effects.
- J. Limiting Exposures: Supervise construction operations to assure that no part of the construction, completed or in progress, is subject to harmful, dangerous, damaging, or otherwise deleterious exposure during the construction period.

### 3.9 STARTING AND ADJUSTING

- A. Coordinate startup and adjusting of equipment and operating components with requirements in Section 019113 "General Commissioning Requirements."
- B. Start equipment and operating components to confirm proper operation. Remove malfunctioning units, replace with new units, and retest.

- C. Adjust equipment for proper operation. Adjust operating components for proper operation without binding.
- D. Test each piece of equipment to verify proper operation. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- E. Manufacturer's Field Service: Comply with qualification requirements in Section 014000 "Quality Requirements."

3.10 PROTECTION OF INSTALLED CONSTRUCTION

- A. Provide final protection and maintain conditions that ensure installed Work is without damage or deterioration at time of Substantial Completion.
- B. Comply with manufacturer's written instructions for temperature and relative humidity.

END OF SECTION 017300

<b>FORM CWM-1: CONSTRUCTION WASTE IDENTIFICATION</b>							
<b>MATERIAL CATEGORY</b>	<b>GENERATION POINT</b>	<b>EST. QUANTITY OF MATERIALS RECEIVED* (A)</b>	<b>EST. WASTE - % (B)</b>	<b>TOTAL EST. QUANTITY OF WASTE* (C = A x B)</b>	<b>EST. VOLUME CY (CM)</b>	<b>EST. WEIGHT TONS (TONNES)</b>	<b>REMARKS AND ASSUMPTIONS</b>
Packaging: Cardboard							
Packaging: Boxes							
Packaging: Plastic Sheet or Film							
Packaging: Polystyrene							
Packaging: Pallets or Skids							
Packaging: Crates							
Packaging: Paint Cans							
Packaging: Plastic Pails							
Site-Clearing Waste							
Masonry or CMU							
Lumber: Cut-Offs							
Lumber: Warped Pieces							
Plywood or OSB (scraps)							
Wood Forms							
Wood Waste Chutes							
Wood Trim (cut-offs)							
Metals							
Insulation							
Roofing							
Joint Sealant Tubes							
Gypsum Board (scraps)							
Carpet and Pad (scraps)							
Piping							
Electrical Conduit							
Other:							

\* Insert units of measure.



<b>FORM CWM-2: DEMOLITION WASTE IDENTIFICATION</b>				
<b>MATERIAL DESCRIPTION</b>	<b>EST. QUANTITY</b>	<b>EST. VOLUME CY (CM)</b>	<b>EST. WEIGHT TONS (TONNES)</b>	<b>REMARKS AND ASSUMPTIONS</b>
Asphaltic Concrete Paving				
Concrete				
Brick				
CMU				
Lumber				
Plywood and OSB				
Wood Paneling				
Wood Trim				
Miscellaneous Metals				
Structural Steel				
Rough Hardware				
Insulation				
Roofing				
Doors and Frames				
Door Hardware				
Windows				
Glazing				
Acoustical Tile				
Carpet				
Carpet Pad				
Demountable Partitions				
Equipment				
Cabinets				
Plumbing Fixtures				
Piping				
Piping Supports and Hangers				
Valves				
Sprinklers				
Mechanical Equipment				
Electrical Conduit				
Copper Wiring				
Light Fixtures				
Lamps				
Lighting Ballasts				
Electrical Devices				
Switchgear and Panelboards				
Transformers				
Other:				

<b>FORM CWM-3: CONSTRUCTION WASTE REDUCTION WORK PLAN</b>						
<b>MATERIAL CATEGORY</b>	<b>GENERATION POINT</b>	<b>TOTAL EST. QUANTITY OF WASTE TONS (TONNES)</b>	<b>DISPOSAL METHOD AND QUANTITY</b>			<b>HANDLING AND TRANSPORTION PROCEDURES</b>
			<b>EST. AMOUNT SALVAGED TONS (TONNES)</b>	<b>EST. AMOUNT RECYCLED TONS (TONNES)</b>	<b>EST. AMOUNT DISPOSED TO LANDFILL TONS (TONNES)</b>	
Packaging: Cardboard						
Packaging: Boxes						
Packaging: Plastic Sheet or Film						
Packaging: Polystyrene						
Packaging: Pallets or Skids						
Packaging: Crates						
Packaging: Paint Cans						
Packaging: Plastic Pails						
Site-Clearing Waste						
Masonry or CMU						
Lumber: Cut-Offs						
Lumber: Warped Pieces						
Plywood or OSB (scraps)						
Wood Forms						
Wood Waste Chutes						
Wood Trim (cut-offs)						
Metals						
Insulation						
Roofing						
Joint Sealant Tubes						
Gypsum Board (scraps)						
Carpet and Pad (scraps)						
Piping						
Electrical Conduit						
Other:						

<b>FORM CWM-4: DEMOLITION WASTE REDUCTION WORK PLAN</b>						
<b>MATERIAL CATEGORY</b>	<b>GENERATION POINT</b>	<b>TOTAL EST. QUANTITY OF WASTE TONS (TONNES)</b>	<b>DISPOSAL METHOD AND QUANTITY</b>			<b>HANDLING AND TRANSPORTION PROCEDURES</b>
			<b>EST. AMOUNT SALVAGED TONS (TONNES)</b>	<b>EST. AMOUNT RECYCLED TONS (TONNES)</b>	<b>EST. AMOUNT DISPOSED TO LANDFILL TONS (TONNES)</b>	
Asphaltic Concrete Paving						
Concrete						
Brick						
CMU						
Lumber						
Plywood and OSB						
Wood Paneling						
Wood Trim						
Miscellaneous Metals						
Structural Steel						
Rough Hardware						
Insulation						
Roofing						
Doors and Frames						
Door Hardware						
Windows						
Glazing						
Acoustical Tile						
Carpet						
Carpet Pad						
Demountable Partitions						
Equipment						
Cabinets						
Plumbing Fixtures						
Piping						
Supports and Hangers						
Valves						
Sprinklers						
Mechanical Equipment						
Electrical Conduit						
Copper Wiring						
Light Fixtures						
Lamps						
Lighting Ballasts						
Electrical Devices						
Switchgear and Panelboards						
Transformers						
Other:						















## SECTION 017419 - CONSTRUCTION WASTE MANAGEMENT AND DISPOSAL

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for the following:
  - 1. Salvaging nonhazardous demolition and construction waste.
  - 2. Recycling nonhazardous demolition and construction waste.
  - 3. Disposing of nonhazardous demolition and construction waste.
- B. Related Requirements:
  - 1. Section 042000 "Unit Masonry" for disposal requirements for masonry waste.
  - 2. Section 311100 "Clearing and Grubbing" for disposition of waste resulting from site clearing and removal of above- and below-grade improvements.

#### 1.3 DEFINITIONS

- A. Construction Waste: Building and site improvement materials and other solid waste resulting from construction, remodeling, renovation, or repair operations. Construction waste includes packaging.
- B. Demolition Waste: Building and site improvement materials resulting from demolition or selective demolition operations.
- C. Disposal: Removal off-site of demolition and construction waste and subsequent sale, recycling, reuse, or deposit in landfill or incinerator acceptable to authorities having jurisdiction.
- D. Recycle: Recovery of demolition or construction waste for subsequent processing in preparation for reuse.
- E. Salvage: Recovery of demolition or construction waste and subsequent sale or reuse in another facility.
- F. Salvage and Reuse: Recovery of demolition or construction waste and subsequent incorporation into the Work.

#### 1.4 PERFORMANCE REQUIREMENTS

- A. General: Achieve end-of-Project rates for salvage/recycling of 50 percent by weight of total non-hazardous solid waste generated by the Work. Practice efficient waste management in the use of materials in the course of the Work. Use all reasonable means to divert construction and demolition

waste from landfills and incinerators. Facilitate recycling and salvage of materials, including the following:

1. Demolition Waste:
  - a. Asphalt paving.
  - b. Concrete.
  - c. Concrete reinforcing steel.
  - d. Brick.
  - e. Concrete masonry units.
  - f. Wood studs.
  - g. Wood joists.
  - h. Plywood and oriented strand board.
  - i. Wood paneling.
  - j. Wood trim.
  - k. Structural and miscellaneous steel.
  - l. Rough hardware.
  - m. Roofing.
  - n. Insulation.
  - o. Doors and frames.
  - p. Door hardware.
  - q. Windows.
  - r. Glazing.
  - s. Metal studs.
  - t. Gypsum board.
  - u. Acoustical tile and panels.
  - v. Carpet.
  - w. Carpet pad.
  - x. Demountable partitions.
  - y. Equipment.
  - z. Cabinets.
  - aa. Plumbing fixtures.
  - bb. Piping.
  - cc. Supports and hangers.
  - dd. Valves.
  - ee. Sprinklers.
  - ff. Mechanical equipment.
  - gg. Refrigerants.
  - hh. Electrical conduit.
  - ii. Copper wiring.
  - jj. Lighting fixtures.
  - kk. Lamps.
  - ll. Ballasts.
  - mm. Electrical devices.
  - nn. Switchgear and panelboards.
  - oo. Transformers.
2. Construction Waste:
  - a. Masonry and CMU.
  - b. Lumber.
  - c. Wood sheet materials.

- d. Wood trim.
- e. Metals.
- f. Roofing.
- g. Insulation.
- h. Carpet and pad.
- i. Gypsum board.
- j. Piping.
- k. Electrical conduit.
- l. Packaging: Regardless of salvage/recycle goal indicated in "General" Paragraph above, salvage or recycle 100 percent of the following uncontaminated packaging materials:
  - 1) Paper.
  - 2) Cardboard.
  - 3) Boxes.
  - 4) Plastic sheet and film.
  - 5) Polystyrene packaging.
  - 6) Wood crates.
  - 7) Plastic pails.

#### 1.5 ACTION SUBMITTALS

- A. Waste Management Plan: Submit plan within 30 days of date established for the Notice to Proceed.

#### 1.6 INFORMATIONAL SUBMITTALS

- A. Waste Reduction Progress Reports: Concurrent with each Application for Payment, submit report. Use attached forms. Include the following information:
  - 1. Material category.
  - 2. Generation point of waste.
  - 3. Total quantity of waste in tons (tonnes).
  - 4. Quantity of waste salvaged, both estimated and actual in tons (tonnes).
  - 5. Quantity of waste recycled, both estimated and actual in tons (tonnes).
  - 6. Total quantity of waste recovered (salvaged plus recycled) in tons (tonnes).
  - 7. Total quantity of waste recovered (salvaged plus recycled) as a percentage of total waste.
- B. Qualification Data: For waste management coordinator and refrigerant recovery technician.
- C. Statement of Refrigerant Recovery: Signed by refrigerant recovery technician responsible for recovering refrigerant, stating that all refrigerant that was present was recovered and that recovery was performed according to EPA regulations. Include name and address of technician and date refrigerant was recovered.

#### 1.7 QUALITY ASSURANCE

- A. Refrigerant Recovery Technician Qualifications: Certified by EPA-approved certification program.
- B. Regulatory Requirements: Comply with hauling and disposal regulations of authorities having jurisdiction.

1. Review and discuss waste management plan including responsibilities of waste management coordinator.
2. Review requirements for documenting quantities of each type of waste and its disposition.
3. Review and finalize procedures for materials separation and verify availability of containers and bins needed to avoid delays.
4. Review procedures for periodic waste collection and transportation to recycling and disposal facilities.
5. Review waste management requirements for each trade.

#### 1.8 WASTE MANAGEMENT PLAN

- A. General: Develop a waste management plan according to ASTM E 1609 and requirements in this Section. Plan shall consist of waste identification, waste reduction work plan, and cost/revenue analysis. Distinguish between demolition and construction waste. Indicate quantities by weight or volume, but use same units of measure throughout waste management plan.
- B. Waste Identification: Indicate anticipated types and quantities of demolition site-clearing and construction waste generated by the Work. Use Owner's Form designation. Include estimated quantities and assumptions for estimates.
- C. Waste Reduction Work Plan: List each type of waste and whether it will be salvaged, recycled, or disposed of in landfill or incinerator. Use Owner's Form designation. Include points of waste generation, total quantity of each type of waste, quantity for each means of recovery, and handling and transportation procedures.
  1. Salvaged Materials for Reuse: For materials that will be salvaged and reused in this Project, describe methods for preparing salvaged materials before incorporation into the Work.
  2. Salvaged Materials for Sale: For materials that will be sold to individuals and organizations, include list of their names, addresses, and telephone numbers.
  3. Salvaged Materials for Donation: For materials that will be donated to individuals and organizations, include list of their names, addresses, and telephone numbers.
  4. Recycled Materials: Include list of local receivers and processors and type of recycled materials each will accept. Include names, addresses, and telephone numbers.
  5. Disposed Materials: Indicate how and where materials will be disposed of. Include name, address, and telephone number of each landfill and incinerator facility.
  6. Handling and Transportation Procedures: Include method that will be used for separating recyclable waste including sizes of containers, container labeling, and designated location where materials separation will be performed.
- D. Cost/Revenue Analysis: Indicate total cost of waste disposal as if there was no waste management plan and net additional cost or net savings resulting from implementing waste management plan. Use Owner's Form designation. Include the following:
  1. Total quantity of waste.
  2. Estimated cost of disposal (cost per unit). Include hauling and tipping fees and cost of collection containers for each type of waste.
  3. Total cost of disposal (with no waste management).
  4. Revenue from salvaged materials.
  5. Revenue from recycled materials.
  6. Savings in hauling and tipping fees by donating materials.
  7. Savings in hauling and tipping fees that are avoided.
  8. Handling and transportation costs. Include cost of collection containers for each type of waste.

9. Net additional cost or net savings from waste management plan.

## PART 2 - PRODUCTS (Not Used)

## PART 3 - EXECUTION

### 3.1 PLAN IMPLEMENTATION

- A. General: Implement approved waste management plan. Provide handling, containers, storage, signage, transportation, and other items as required to implement waste management plan during the entire duration of the Contract.
  1. Comply with operation, termination, and removal requirements in Section 015000 "Temporary Facilities and Controls."
- B. Waste Management Coordinator: Engage a waste management coordinator to be responsible for implementing, monitoring, and reporting status of waste management work plan.
- C. Training: Train workers, subcontractors, and suppliers on proper waste management procedures, as appropriate for the Work.
  1. Distribute waste management plan to everyone concerned within three days of submittal return.
  2. Distribute waste management plan to entities when they first begin work on-site. Review plan procedures and locations established for salvage, recycling, and disposal.
- D. Site Access and Temporary Controls: Conduct waste management operations to ensure minimum interference with roads, streets, walks, walkways, and other adjacent occupied and used facilities.
  1. Designate and label specific areas on Project site necessary for separating materials that are to be salvaged, recycled, reused, donated, and sold.
  2. Comply with Section 015000 "Temporary Facilities and Controls" for controlling dust and dirt, environmental protection, and noise control.

### 3.2 SALVAGING DEMOLITION WASTE

- A. Salvaged Items for Reuse in the Work: Salvage items for reuse and handle as follows:
  1. Clean salvaged items.
  2. Pack or crate items after cleaning. Identify contents of containers with label indicating elements, date of removal, quantity, and location where removed.
  3. Store items in a secure area until installation.
  4. Protect items from damage during transport and storage.
  5. Install salvaged items to comply with installation requirements for new materials and equipment. Provide connections, supports, and miscellaneous materials necessary to make items functional for use indicated.
- B. Salvaged Items for Sale and Donation: Not permitted on Project site.
- C. Salvaged Items for Owner's Use: Salvage items for Owner's use and handle as follows:

1. Clean salvaged items.
2. Pack or crate items after cleaning. Identify contents of containers with label indicating elements, date of removal, quantity, and location where removed.
3. Store items in a secure area until delivery to Owner.
4. Transport items to Owner's storage area off-site designated by Owner.
5. Protect items from damage during transport and storage.

### 3.3 DISPOSAL OF WASTE

- A. General: Except for items or materials to be salvaged, recycled, or otherwise reused, remove waste materials from Project site and legally dispose of them in a landfill or incinerator acceptable to authorities having jurisdiction.
  1. Except as otherwise specified, do not allow waste materials that are to be disposed of accumulate on-site.
  2. Remove and transport debris in a manner that will prevent spillage on adjacent surfaces and areas.
- B. Burning: Do not burn waste materials.
- C. Disposal: Remove waste materials from Owner's property and legally dispose of them.

### 3.4 ATTACHMENTS

- A. Form CWM-1 for construction waste identification.
- B. Form CWM-2 for demolition waste identification.
- C. Form CWM-3 for construction waste reduction work plan.
- D. Form CWM-4 for demolition waste reduction work plan.
- E. Form CWM-5 cost/revenue analysis of construction waste reduction work plan.
- F. Form CWM-6 cost/revenue analysis of demolition waste reduction work plan.
- G. Form CWM-7 for construction waste
- H. Form CWM-8 for demolition waste.

END OF SECTION 017419

## SECTION 017700 - CLOSEOUT PROCEDURES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for contract closeout, including, but not limited to, the following:

1. Substantial Completion procedures.
2. Final completion procedures.
3. Warranties.
4. Final cleaning.
5. Repair of the Work.

- B. Related Requirements:

1. Section 013233 "Photographic Documentation" for submitting final completion construction photographic documentation.
2. Section 017300 "Execution" for progress cleaning of Project site.
3. Section 017823 "Operation and Maintenance Data" for operation and maintenance manual requirements.
4. Section 017839 "Project Record Documents" for submitting record Drawings, record Specifications, and record Product Data.
5. Section 017900 "Demonstration and Training" for requirements for instructing Owner's personnel.

#### 1.3 ACTION SUBMITTALS

- A. Product Data: For cleaning agents.
- B. Contractor's List of Incomplete Items: Initial submittal at Substantial Completion.
- C. Certified List of Incomplete Items: Final submittal at Final Completion.

#### 1.4 CLOSEOUT SUBMITTALS

- A. Certificates of Release: From authorities having jurisdiction.
- B. Certificate of Insurance: For continuing coverage.
- C. Field Report: For pest control inspection.



1.5 MAINTENANCE MATERIAL SUBMITTALS

- A. Schedule of Maintenance Material Items: For maintenance material submittal items specified in other Sections.

1.6 SUBSTANTIAL COMPLETION PROCEDURES

- A. Contractor's List of Incomplete Items: Prepare and submit a list of items to be completed and corrected (Contractor's punch list), indicating the value of each item on the list and reasons why the Work is incomplete.

- B. Submittals Prior to Substantial Completion: Complete the following a minimum of 10 days prior to requesting inspection for determining date of Substantial Completion. List items below that are incomplete at time of request.

1. Certificates of Release: Obtain and submit releases from authorities having jurisdiction permitting Owner unrestricted use of the Work and access to services and utilities. Include occupancy permits, operating certificates, and similar releases.
2. Submit closeout submittals specified in other Division 01 Sections, including project record documents, operation and maintenance manuals, final completion construction photographic documentation, damage or settlement surveys, property surveys, and similar final record information.
3. Submit closeout submittals specified in individual Sections, including specific warranties, workmanship bonds, maintenance service agreements, final certifications, and similar documents.
4. Submit maintenance material submittals specified in individual Sections, including tools, spare parts, extra materials, and similar items, and deliver to location designated by Architect. Label with manufacturer's name and model number where applicable.
  - a. Schedule of Maintenance Material Items: Prepare and submit schedule of maintenance material submittal items, including name and quantity of each item and name and number of related Specification Section. Obtain Architect's signature for receipt of submittals.
5. Submit test/adjust/balance records.
6. Submit changeover information related to Owner's occupancy, use, operation, and maintenance.

- C. Procedures Prior to Substantial Completion: Complete the following a minimum of 10 days prior to requesting inspection for determining date of Substantial Completion. List items below that are incomplete at time of request.

1. Advise Owner of pending insurance changeover requirements.
2. Make final changeover of permanent locks and deliver keys to Owner. Advise Owner's personnel of changeover in security provisions.
3. Complete startup and testing of systems and equipment.
4. Perform preventive maintenance on equipment used prior to Substantial Completion.
5. Instruct Owner's personnel in operation, adjustment, and maintenance of products, equipment, and systems. Submit demonstration and training video recordings specified in Section 017900 "Demonstration and Training."
6. Advise Owner of changeover in heat and other utilities.
7. Participate with Owner in conducting inspection and walkthrough with local emergency responders.
8. Terminate and remove temporary facilities from Project site, along with mockups, construction tools, and similar elements.

9. Complete final cleaning requirements, including touchup painting.
10. Touch up and otherwise repair and restore marred exposed finishes to eliminate visual defects.

D. Inspection: Submit a written request for inspection to determine Substantial Completion a minimum of 10 days prior to date the work will be completed and ready for final inspection and tests. On receipt of request, Architect will either proceed with inspection or notify Contractor of unfulfilled requirements. Architect will prepare the Certificate of Substantial Completion after inspection or will notify Contractor of items, either on Contractor's list or additional items identified by Architect, that must be completed or corrected before certificate will be issued.

1. Re-inspection: Request re-inspection when the Work identified in previous inspections as incomplete is completed or corrected.
2. Results of completed inspection will form the basis of requirements for final completion.

#### 1.7 FINAL COMPLETION PROCEDURES

A. Submittals Prior to Final Completion: Before requesting final inspection for determining final completion, complete the following:

1. Submit a final Application for Payment according to Section 012900 "Payment Procedures."
2. Certified List of Incomplete Items: Submit certified copy of Architect's Substantial Completion inspection list of items to be completed or corrected (punch list), endorsed and dated by Architect. Certified copy of the list shall state that each item has been completed or otherwise resolved for acceptance.
3. Certificate of Insurance: Submit evidence of final, continuing insurance coverage complying with insurance requirements.
4. Submit pest-control final inspection report.

B. Inspection: Submit a written request for final inspection to determine acceptance a minimum of 10 days prior to date the work will be completed and ready for final inspection and tests. On receipt of request, Architect will either proceed with inspection or notify Contractor of unfulfilled requirements. Architect will prepare a final Certificate for Payment after inspection or will notify Contractor of construction that must be completed or corrected before certificate will be issued.

1. Re-inspection: Request re-inspection when the Work identified in previous inspections as incomplete is completed or corrected.

#### 1.8 LIST OF INCOMPLETE ITEMS (PUNCH LIST)

A. Organization of List: Include name and identification of each space and area affected by construction operations for incomplete items and items needing correction including, if necessary, areas disturbed by Contractor that are outside the limits of construction.

1. Organize list of spaces in sequential order, starting with exterior areas first and proceeding from lowest floor to highest floor .
2. Organize items applying to each space by major element, including categories for ceiling, individual walls, floors, equipment, and building systems.
3. Include the following information at the top of each page:
  - a. Project name.
  - b. Date.

- c. Name of Architect.
  - d. Name of Contractor.
  - e. Page number.
4. Submit list of incomplete items in the following format:
- a. MS Excel electronic file. Architect, through Construction Manager, will return annotated file.
  - b. Three paper copies. Architect will return two copies.

## 1.9 SUBMITTAL OF PROJECT WARRANTIES

- A. Time of Submittal: Submit written warranties on request of Architect for designated portions of the Work where commencement of warranties other than date of Substantial Completion is indicated, or when delay in submittal of warranties might limit Owner's rights under warranty.
- B. Partial Occupancy: Submit properly executed warranties within 15 days of completion of designated portions of the Work that are completed and occupied or used by Owner during construction period by separate agreement with Contractor.
- C. Organize warranty documents into an orderly sequence based on the table of contents of Project Manual.
  1. Bind warranties and bonds in heavy-duty, three-ring, vinyl-covered, loose-leaf binders, thickness as necessary to accommodate contents, and sized to receive 8-1/2-by-11-inch (215-by-280-mm) paper.
  2. Provide heavy paper dividers with plastic-covered tabs for each separate warranty. Mark tab to identify the product or installation. Provide a typed description of the product or installation, including the name of the product and the name, address, and telephone number of Installer.
  3. Identify each binder on the front and spine with the typed or printed title "WARRANTIES," Project name, and name of Contractor.
  4. Warranty Electronic File: Scan warranties and bonds and assemble complete warranty and bond submittal package into a single indexed electronic PDF file with links enabling navigation to each item. Provide bookmarked table of contents at beginning of document.
- D. Provide three (3) additional copies of each warranty to include in operation and maintenance manuals.

## PART 2 - PRODUCTS

### 2.1 MATERIALS

- A. Cleaning Agents: Use cleaning materials and agents recommended by manufacturer or fabricator of the surface to be cleaned. Do not use cleaning agents that are potentially hazardous to health or property or that might damage finished surfaces.

## PART 3 - EXECUTION

### 3.1 FINAL CLEANING

- A. General: Perform final cleaning. Conduct cleaning and waste-removal operations to comply with local laws and ordinances and Federal and local environmental and antipollution regulations.
- B. Cleaning: Employ experienced workers or professional cleaners for final cleaning. Clean each surface or unit to condition expected in an average commercial building cleaning and maintenance program. Comply with manufacturer's written instructions.
  - 1. Complete the following cleaning operations before requesting inspection for certification of Substantial Completion for entire Project or for a designated portion of Project:
    - a. Clean Project site, yard, and grounds, in areas disturbed by construction activities, including landscape development areas, of rubbish, waste material, litter, and other foreign substances.
    - b. Sweep paved areas broom clean. Remove petrochemical spills, stains, and other foreign deposits.
    - c. Rake grounds that are neither planted nor paved to a smooth, even-textured surface.
    - d. Remove tools, construction equipment, machinery, and surplus material from Project site.
    - e. Remove snow and ice to provide safe access to building.
    - f. Clean exposed exterior and interior hard-surfaced finishes to a dirt-free condition, free of stains, films, and similar foreign substances. Avoid disturbing natural weathering of exterior surfaces. Restore reflective surfaces to their original condition.
    - g. Remove debris and surface dust from limited access spaces, including roofs, plenums, shafts, trenches, equipment vaults, manholes, attics, and similar spaces.
    - h. Sweep concrete floors broom clean in unoccupied spaces.
    - i. Vacuum carpet and similar soft surfaces, removing debris and excess nap; clean according to manufacturer's recommendations if visible soil or stains remain.
    - j. Clean transparent materials, including mirrors and glass in doors and windows. Remove glazing compounds and other noticeable, vision-obscuring materials. Polish mirrors and glass, taking care not to scratch surfaces.
    - k. Remove labels that are not permanent.
    - l. Wipe surfaces of mechanical and electrical equipment, elevator equipment, and similar equipment. Remove excess lubrication, paint and mortar droppings, and other foreign substances.
    - m. Clean plumbing fixtures to a sanitary condition, free of stains, including stains resulting from water exposure.
    - n. Replace disposable air filters and clean permanent air filters. Clean exposed surfaces of diffusers, registers, and grills.
    - o. Clean ducts, blowers, and coils if units were operated without filters during construction or that display contamination with particulate matter on inspection.
    - p. Clean light fixtures, lamps, globes, and reflectors to function with full efficiency.
    - q. Leave Project clean and ready for occupancy.
- C. Pest Control: Comply with pest control requirements in Section 015000 "Temporary Facilities and Controls." Prepare written report.

- D. Construction Waste Disposal: Comply with waste disposal requirements in Section 015000 "Temporary Facilities and Controls."

### 3.2 REPAIR OF THE WORK

- A. Complete repair and restoration operations before requesting inspection for determination of Substantial Completion.
- B. Repair or remove and replace defective construction. Repairing includes replacing defective parts, refinishing damaged surfaces, touching up with matching materials, and properly adjusting operating equipment. Where damaged or worn items cannot be repaired or restored, provide replacements. Remove and replace operating components that cannot be repaired. Restore damaged construction and permanent facilities used during construction to specified condition.
  - 1. Remove and replace chipped, scratched, and broken glass, reflective surfaces, and other damaged transparent materials.
  - 2. Touch up and otherwise repair and restore marred or exposed finishes and surfaces. Replace finishes and surfaces that that already show evidence of repair or restoration.
    - a. Do not paint over "UL" and other required labels and identification, including mechanical and electrical nameplates. Remove paint applied to required labels and identification.
  - 3. Replace parts subject to operating conditions during construction that may impede operation or reduce longevity.
  - 4. Replace burned-out bulbs, bulbs noticeably dimmed by hours of use, and defective and noisy starters in fluorescent and mercury vapor fixtures to comply with requirements for new fixtures.

END OF SECTION 017700

## SECTION 017823 - OPERATION AND MAINTENANCE DATA

### GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for preparing operation and maintenance manuals, including the following:
  - 1. Operation and maintenance documentation directory.
  - 2. Emergency manuals.
  - 3. Operation manuals for systems, subsystems, and equipment.
  - 4. Product maintenance manuals.
  - 5. Systems and equipment maintenance manuals.
- B. Related Requirements:
  - 1. Section 013300 "Submittal Procedures" for submitting copies of submittals for operation and maintenance manuals.
  - 2. Section 019113 "General Commissioning Requirements" for verification and compilation of data into operation and maintenance manuals.

#### 1.3 DEFINITIONS

- A. System: An organized collection of parts, equipment, or subsystems united by regular interaction.
- B. Subsystem: A portion of a system with characteristics similar to a system.

#### 1.4 CLOSEOUT SUBMITTALS

- A. Manual Content: Operations and maintenance manual content is specified in individual Specification Sections to be reviewed at the time of Section submittals. Submit reviewed manual content formatted and organized as required by this Section.
  - 1. Architect will comment on whether content of operations and maintenance submittals are acceptable.
  - 2. Where applicable, clarify and update reviewed manual content to correspond to revisions and field conditions.
- B. Format: Submit operations and maintenance manuals in the following format:
  - 1. PDF electronic file. Assemble each manual into a composite electronically indexed file. Submit on digital media acceptable to Architect.

- a. Name each indexed document file in composite electronic index with applicable item name. Include a complete electronically linked operation and maintenance directory.
  - b. Enable inserted reviewer comments on draft submittals.
2. Three paper copies. Include a complete operation and maintenance directory. Enclose title pages and directories in clear plastic sleeves. Architect, will return two copies.
- C. Initial Manual Submittal: Submit draft copy of each manual at least 30 days before commencing demonstration and training. Architect will comment on whether general scope and content of manual are acceptable.
- D. Final Manual Submittal: Submit each manual in final form prior to requesting inspection for Substantial Completion and at least 15 days before commencing demonstration and training. Architect will return copy with comments.
1. Correct or revise each manual to comply with Architect's comments. Submit copies of each corrected manual within 15 days of receipt of Architect's comments and prior to commencing demonstration and training.

## PART 2 - PRODUCTS

### 2.1 OPERATION AND MAINTENANCE DOCUMENTATION DIRECTORY

- A. Directory: Prepare a single, comprehensive directory of emergency, operation, and maintenance data and materials, listing items and their location to facilitate ready access to desired information. Include a section in the directory for each of the following:
1. List of documents.
  2. List of systems.
  3. List of equipment.
  4. Table of contents.
- B. List of Systems and Subsystems: List systems alphabetically. Include references to operation and maintenance manuals that contain information about each system.
- C. List of Equipment: List equipment for each system, organized alphabetically by system. For pieces of equipment not part of system, list alphabetically in separate list.
- D. Tables of Contents: Include a table of contents for each emergency, operation, and maintenance manual.
- E. Identification: In the documentation directory and in each operation and maintenance manual, identify each system, subsystem, and piece of equipment with same designation used in the Contract Documents. If no designation exists, assign a designation according to ASHRAE Guideline 4, "Preparation of Operating and Maintenance Documentation for Building Systems."

### 2.2 REQUIREMENTS FOR EMERGENCY, OPERATION, AND MAINTENANCE MANUALS

- A. Organization: Unless otherwise indicated, organize each manual into a separate section for each system and subsystem, and a separate section for each piece of equipment not part of a system. Each manual shall contain the following materials, in the order listed:

1. Title page.
2. Table of contents.
3. Manual contents.

B. Title Page: Include the following information:

1. Subject matter included in manual.
2. Name and address of Project.
3. Name and address of Owner.
4. Date of submittal.
5. Name and contact information for Contractor.
6. Name and contact information for Construction Manager.
7. Name and contact information for Architect.
8. Name and contact information for Commissioning Authority.
9. Names and contact information for major consultants to the Architect that designed the systems contained in the manuals.
10. Cross-reference to related systems in other operation and maintenance manuals.

C. Table of Contents: List each product included in manual, identified by product name, indexed to the content of the volume, and cross-referenced to Specification Section number in Project Manual.

D. Manual Contents: Organize into sets of manageable size. Arrange contents alphabetically by system, subsystem, and equipment. If possible, assemble instructions for subsystems, equipment, and components of one system into a single binder.

E. Manuals, Electronic Files: Submit manuals in the form of a multiple file composite electronic PDF file for each manual type required.

1. Electronic Files: Use electronic files prepared by manufacturer where available. Where scanning of paper documents is required, configure scanned file for minimum readable file size.
2. File Names and Bookmarks: Enable bookmarking of individual documents based on file names. Name document files to correspond to system, subsystem, and equipment names used in manual directory and table of contents. Group documents for each system and subsystem into individual composite bookmarked files, then create composite manual, so that resulting bookmarks reflect the system, subsystem, and equipment names in a readily navigated file tree. Configure electronic manual to display bookmark panel on opening file.

F. Manuals, Paper Copy: Submit manuals in the form of hard copy, bound and labeled volumes.

1. Binders: Heavy-duty, three-ring, vinyl-covered, loose-leaf binders, in thickness necessary to accommodate contents, sized to hold 8-1/2-by-11-inch (215-by-280-mm) paper; with clear plastic sleeve on spine to hold label describing contents and with pockets inside covers to hold folded oversize sheets.
  - a. If two or more binders are necessary to accommodate data of a system, organize data in each binder into groupings by subsystem and related components. Cross-reference other binders if necessary to provide essential information for proper operation or maintenance of equipment or system.
  - b. Identify each binder on front and spine, with printed title "OPERATION AND MAINTENANCE MANUAL," Project title or name, and subject matter of contents, and indicate Specification Section number on bottom of spine. Indicate volume number for multiple-volume sets.



2. Dividers: Heavy-paper dividers with plastic-covered tabs for each section of the manual. Mark each tab to indicate contents. Include typed list of products and major components of equipment included in the section on each divider, cross-referenced to Specification Section number and title of Project Manual.
3. Protective Plastic Sleeves: Transparent plastic sleeves designed to enclose diagnostic software storage media for computerized electronic equipment.
4. Supplementary Text: Prepared on 8-1/2-by-11-inch (215-by-280-mm) white bond paper.
5. Drawings: Attach reinforced, punched binder tabs on drawings and bind with text.
  - a. If oversize drawings are necessary, fold drawings to same size as text pages and use as foldouts.
  - b. If drawings are too large to be used as foldouts, fold and place drawings in labeled envelopes and bind envelopes in rear of manual. At appropriate locations in manual, insert typewritten pages indicating drawing titles, descriptions of contents, and drawing locations.

### 2.3 EMERGENCY MANUALS

A. Content: Organize manual into a separate section for each of the following:

1. Type of emergency.
2. Emergency instructions.
3. Emergency procedures.

B. Type of Emergency: Where applicable for each type of emergency indicated below, include instructions and procedures for each system, subsystem, piece of equipment, and component:

1. Fire.
2. Flood.
3. Gas leak.
4. Water leak.
5. Power failure.
6. Water outage.
7. System, subsystem, or equipment failure.
8. Chemical release or spill.

C. Emergency Instructions: Describe and explain warnings, trouble indications, error messages, and similar codes and signals. Include responsibilities of Owner's operating personnel for notification of Installer, supplier, and manufacturer to maintain warranties.

D. Emergency Procedures: Include the following, as applicable:

1. Instructions on stopping.
2. Shutdown instructions for each type of emergency.
3. Operating instructions for conditions outside normal operating limits.
4. Required sequences for electric or electronic systems.
5. Special operating instructions and procedures.

### 2.4 OPERATION MANUALS

A. Content: In addition to requirements in this Section, include operation data required in individual Specification Sections and the following information:

1. System, subsystem, and equipment descriptions. Use designations for systems and equipment indicated on Contract Documents.
2. Performance and design criteria if Contractor has delegated design responsibility.
3. Operating standards.
4. Operating procedures.
5. Operating logs.
6. Wiring diagrams.
7. Control diagrams.
8. Piped system diagrams.
9. Precautions against improper use.
10. License requirements including inspection and renewal dates.

B. Descriptions: Include the following:

1. Product name and model number. Use designations for products indicated on Contract Documents.
2. Manufacturer's name.
3. Equipment identification with serial number of each component.
4. Equipment function.
5. Operating characteristics.
6. Limiting conditions.
7. Performance curves.
8. Engineering data and tests.
9. Complete nomenclature and number of replacement parts.

C. Operating Procedures: Include the following, as applicable:

1. Startup procedures.
2. Equipment or system break-in procedures.
3. Routine and normal operating instructions.
4. Regulation and control procedures.
5. Instructions on stopping.
6. Normal shutdown instructions.
7. Seasonal and weekend operating instructions.
8. Required sequences for electric or electronic systems.
9. Special operating instructions and procedures.

D. Systems and Equipment Controls: Describe the sequence of operation, and diagram controls as installed.

E. Piped Systems: Diagram piping as installed, and identify color-coding where required for identification.

## 2.5 PRODUCT MAINTENANCE MANUALS

A. Content: Organize manual into a separate section for each product, material, and finish. Include source information, product information, maintenance procedures, repair materials and sources, and warranties and bonds, as described below.

B. Source Information: List each product included in manual, identified by product name and arranged to match manual's table of contents. For each product, list name, address, and telephone number of Installer or supplier and maintenance service agent, and cross-reference Specification Section number and title in Project Manual and drawing or schedule designation or identifier where applicable.

C. Product Information: Include the following, as applicable:

1. Product name and model number.
2. Manufacturer's name.
3. Color, pattern, and texture.
4. Material and chemical composition.
5. Reordering information for specially manufactured products.

D. Maintenance Procedures: Include manufacturer's written recommendations and the following:

1. Inspection procedures.
2. Types of cleaning agents to be used and methods of cleaning.
3. List of cleaning agents and methods of cleaning detrimental to product.
4. Schedule for routine cleaning and maintenance.
5. Repair instructions.

E. Repair Materials and Sources: Include lists of materials and local sources of materials and related services.

F. Warranties and Bonds: Include copies of warranties and bonds and lists of circumstances and conditions that would affect validity of warranties or bonds.

## 2.6 SYSTEMS AND EQUIPMENT MAINTENANCE MANUALS

A. Content: For each system, subsystem, and piece of equipment not part of a system, include source information, manufacturers' maintenance documentation, maintenance procedures, maintenance and service schedules, spare parts list and source information, maintenance service contracts, and warranty and bond information, as described below.

B. Source Information: List each system, subsystem, and piece of equipment included in manual, identified by product name and arranged to match manual's table of contents. For each product, list name, address, and telephone number of Installer or supplier and maintenance service agent, and cross-reference Specification Section number and title in Project Manual and drawing or schedule designation or identifier where applicable.

C. Manufacturers' Maintenance Documentation: Manufacturers' maintenance documentation including the following information for each component part or piece of equipment:

1. Standard maintenance instructions and bulletins.
2. Drawings, diagrams, and instructions required for maintenance, including disassembly and component removal, replacement, and assembly.
3. Identification and nomenclature of parts and components.
4. List of items recommended to be stocked as spare parts.

D. Maintenance Procedures: Include the following information and items that detail essential maintenance procedures:

1. Test and inspection instructions.
2. Troubleshooting guide.
3. Precautions against improper maintenance.
4. Disassembly; component removal, repair, and replacement; and reassembly instructions.
5. Aligning, adjusting, and checking instructions.

6. Demonstration and training video recording, if available.
- E. Maintenance and Service Schedules: Include service and lubrication requirements, list of required lubricants for equipment, and separate schedules for preventive and routine maintenance and service with standard time allotment.
  1. Scheduled Maintenance and Service: Tabulate actions for daily, weekly, monthly, quarterly, semiannual, and annual frequencies.
  2. Maintenance and Service Record: Include manufacturers' forms for recording maintenance.
- F. Spare Parts List and Source Information: Include lists of replacement and repair parts, with parts identified and cross-referenced to manufacturers' maintenance documentation and local sources of maintenance materials and related services.
- G. Warranties and Bonds: Include copies of warranties and bonds and lists of circumstances and conditions that would affect validity of warranties or bonds.

### PART 3 - EXECUTION

#### 3.1 MANUAL PREPARATION

- A. Operation and Maintenance Documentation Directory: Prepare a separate manual that provides an organized reference to emergency, operation, and maintenance manuals.
- B. Emergency Manual: Assemble a complete set of emergency information indicating procedures for use by emergency personnel and by Owner's operating personnel for types of emergencies indicated.
- C. Product Maintenance Manual: Assemble a complete set of maintenance data indicating care and maintenance of each product, material, and finish incorporated into the Work.
- D. Operation and Maintenance Manuals: Assemble a complete set of operation and maintenance data indicating operation and maintenance of each system, subsystem, and piece of equipment not part of a system.
  1. Engage a factory-authorized service representative to assemble and prepare information for each system, subsystem, and piece of equipment not part of a system.
  2. Prepare a separate manual for each system and subsystem, in the form of an instructional manual for use by Owner's operating personnel.
- E. Manufacturers' Data: Where manuals contain manufacturers' standard printed data, include only sheets pertinent to product or component installed. Mark each sheet to identify each product or component incorporated into the Work. If data include more than one item in a tabular format, identify each item using appropriate references from the Contract Documents. Identify data applicable to the Work and delete references to information not applicable.
  1. Prepare supplementary text if manufacturers' standard printed data are not available and where the information is necessary for proper operation and maintenance of equipment or systems.
- F. Drawings: Prepare drawings supplementing manufacturers' printed data to illustrate the relationship of component parts of equipment and systems and to illustrate control sequence and flow diagrams.

Coordinate these drawings with information contained in record Drawings to ensure correct illustration of completed installation.

1. Comply with requirements of newly prepared record Drawings in Section 017839 "Project Record Documents."
- G. Comply with Section 017700 "Closeout Procedures" for schedule for submitting operation and maintenance documentation.

END OF SECTION 017823

## SECTION 017839 - PROJECT RECORD DOCUMENTS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for project record documents, including the following:
  - 1. Record Drawings.
  - 2. Record Specifications.
  - 3. Record Product Data.
  - 4. Miscellaneous record submittals.
- B. Related Requirements:
  - 1. Section 011200 "Multiple Contract Summary" for coordinating project record documents covering the Work of multiple contracts.
  - 2. Section 017300 "Execution" for final property survey.
  - 3. Section 017700 "Closeout Procedures" for general closeout procedures.
  - 4. Section 017823 "Operation and Maintenance Data" for operation and maintenance manual requirements.

#### 1.3 CLOSEOUT SUBMITTALS

- A. Record Drawings: Comply with the following:
  - 1. Number of Copies: Submit one set(s) of marked-up record prints.
  - 2. Number of Copies: Submit copies of record Drawings as follows:
    - a. Initial Submittal:
      - 1) Submit PDF electronic files of scanned record prints and one of file prints.
    - b. Final Submittal:
      - 1) Submit PDF electronic files of scanned record prints and three set(s) of prints.
    - c. Final Submittal:
      - 1) Submit record digital data files and three set(s) of record digital data file plots.
- B. Record Specifications: Submit annotated PDF electronic files of Project's Specifications, including addenda and contract modifications.
- C. Record Product Data: Submit annotated PDF electronic files and directories of each submittal.

1. Where record Product Data are required as part of operation and maintenance manuals, submit duplicate marked-up Product Data as a component of manual.
- D. Reports: Submit written report weekly indicating items incorporated into project record documents concurrent with progress of the Work, including revisions, concealed conditions, field changes, product selections, and other notations incorporated.

## PART 2 - PRODUCTS

### 2.1 RECORD DRAWINGS

- A. Record Prints: Maintain one set of marked-up paper copies of the Contract Drawings and Shop Drawings, incorporating new and revised drawings as modifications are issued.
  1. Preparation: Mark record prints to show the actual installation where installation varies from that shown originally. Require individual or entity who obtained record data, whether individual or entity is Installer, subcontractor, or similar entity, to provide information for preparation of corresponding marked-up record prints.
    - a. Give particular attention to information on concealed elements that would be difficult to identify or measure and record later.
    - b. Accurately record information in an acceptable drawing technique.
    - c. Record data as soon as possible after obtaining it.
    - d. Record and check the markup before enclosing concealed installations.
    - e. Cross-reference record prints to corresponding archive photographic documentation.
  2. Content: Types of items requiring marking include, but are not limited to, the following:
    - a. Dimensional changes to Drawings.
    - b. Revisions to details shown on Drawings.
    - c. Depths of foundations below first floor.
    - d. Locations and depths of underground utilities.
    - e. Revisions to routing of piping and conduits.
    - f. Revisions to electrical circuitry.
    - g. Actual equipment locations.
    - h. Duct size and routing.
    - i. Locations of concealed internal utilities.
    - j. Changes made by Change Order or Change Directive.
    - k. Details not on the original Contract Drawings.
    - l. Field records for variable and concealed conditions.
    - m. Record information on the Work that is shown only schematically.
  3. Mark the Contract Drawings and Shop Drawings completely and accurately. Use personnel proficient at recording graphic information in production of marked-up record prints.
  4. Mark record sets with erasable, red-colored pencil. Use other colors to distinguish between changes for different categories of the Work at same location.
  5. Mark important additional information that was either shown schematically or omitted from original Drawings.
  6. Note Construction Change Directive numbers, alternate numbers, Change Order numbers, and similar identification, where applicable.

- B. Record Digital Data Files: Immediately before inspection for Certificate of Substantial Completion, review marked-up record prints with Architect. When authorized, prepare a full set of corrected digital data files of the Contract Drawings, as follows:
1. Format: DWG, Version, Microsoft Windows operating system.
  2. Incorporate changes and additional information previously marked on record prints. Delete, redraw, and add details and notations where applicable.
  3. Refer instances of uncertainty to Architect through Construction Manager for resolution.
  4. Architect will furnish Contractor one set of digital data files of the Contract Drawings for use in recording information.
    - a. See Section 013300 "Submittal Procedures" for requirements related to use of Architect's digital data files.
    - b. Architect will provide data file layer information. Record markups in separate layers.
  5. New Drawings may be required when a Change Order is issued as a result of accepting an alternate, substitution, or other modification.
  6. Consult Architect for proper scale and scope of detailing and notations required to record the actual physical installation and its relation to other construction. Integrate newly prepared record Drawings into record Drawing sets; comply with procedures for formatting, organizing, copying, binding, and submitting.
- C. Format: Identify and date each record Drawing; include the designation "PROJECT RECORD DRAWING" in a prominent location.
1. Record Prints: Organize record prints and newly prepared record Drawings into manageable sets. Bind each set with durable paper cover sheets. Include identification on cover sheets.
  2. Format: Annotated PDF electronic file with comment function enabled.
  3. Record Digital Data Files: Organize digital data information into separate electronic files that correspond to each sheet of the Contract Drawings. Name each file with the sheet identification. Include identification in each digital data file.
  4. Identification: As follows:
    - a. Project name.
    - b. Date.
    - c. Designation "PROJECT RECORD DRAWINGS."
    - d. Name of Architect .
    - e. Name of Contractor.

## 2.2 RECORD SPECIFICATIONS

- A. Preparation: Mark Specifications to indicate the actual product installation where installation varies from that indicated in Specifications, addenda, and contract modifications.
1. Give particular attention to information on concealed products and installations that cannot be readily identified and recorded later.
  2. Mark copy with the proprietary name and model number of products, materials, and equipment furnished, including substitutions and product options selected.
  3. Record the name of manufacturer, supplier, Installer, and other information necessary to provide a record of selections made.
  4. For each principal product, indicate whether record Product Data has been submitted in operation and maintenance manuals instead of submitted as record Product Data.
  5. Note related Change Orders, record Product Data, and record Drawings where applicable.



- B. Format: Submit record Specifications as annotated PDF electronic file.

### 2.3 RECORD PRODUCT DATA

- A. Preparation: Mark Product Data to indicate the actual product installation where installation varies substantially from that indicated in Product Data submittal.
  - 1. Give particular attention to information on concealed products and installations that cannot be readily identified and recorded later.
  - 2. Include significant changes in the product delivered to Project site and changes in manufacturer's written instructions for installation.
  - 3. Note related Change Orders, record Specifications, and record Drawings where applicable.
- B. Format: Submit record Product Data as annotated PDF electronic file.
  - 1. Include record Product Data directory organized by Specification Section number and title, electronically linked to each item of record Product Data.

### 2.4 MISCELLANEOUS RECORD SUBMITTALS

- A. Assemble miscellaneous records required by other Specification Sections for miscellaneous record keeping and submittal in connection with actual performance of the Work. Bind or file miscellaneous records and identify each, ready for continued use and reference.
- B. Format: Submit miscellaneous record submittals as scanned PDF electronic file(s) of marked-up miscellaneous record submittals.
  - 1. Include miscellaneous record submittals directory organized by Specification Section number and title, electronically linked to each item of miscellaneous record submittals.

## PART 3 - EXECUTION

### 3.1 RECORDING AND MAINTENANCE

- A. Recording: Maintain one copy of each submittal during the construction period for project record document purposes. Post changes and revisions to project record documents as they occur; do not wait until end of Project.
- B. Maintenance of Record Documents and Samples: Store record documents and Samples in the field office apart from the Contract Documents used for construction. Do not use project record documents for construction purposes. Maintain record documents in good order and in a clean, dry, legible condition, protected from deterioration and loss. Provide access to project record documents for Architect's reference during normal working hours.

END OF SECTION 017839

## SECTION 017900 - DEMONSTRATION AND TRAINING

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for instructing Owner's personnel, including the following:
  - 1. Demonstration of operation of systems, subsystems, and equipment.
  - 2. Training in operation and maintenance of systems, subsystems, and equipment.
  - 3. Demonstration and training video recordings.

#### 1.3 INFORMATIONAL SUBMITTALS

- A. Instruction Program: Submit outline of instructional program for demonstration and training, including a list of training modules and a schedule of proposed dates, times, length of instruction time, and instructors' names for each training module. Include learning objective and outline for each training module.
  - 1. Indicate proposed training modules using manufacturer-produced demonstration and training video recordings for systems, equipment, and products in lieu of video recording of live instructional module.
- B. Qualification Data: For instructor.
- C. Attendance Record: For each training module, submit list of participants and length of instruction time.
- D. Evaluations: For each participant and for each training module, submit results and documentation of performance-based test.

#### 1.4 CLOSEOUT SUBMITTALS

- A. Demonstration and Training Video Recordings: Submit two copies within seven days of end of each training module.
  - 1. Identification: On each copy, provide an applied label with the following information:
    - a. Name of Project.
    - b. Name and address of videographer.
    - c. Name of Architect.
    - d. Name of Construction Manager.

- e. Name of Contractor.
- f. Date of video recording.
- 2. Transcript: Prepared in PDF electronic format. Include a cover sheet with same label information as the corresponding video recording and a table of contents with links to corresponding training components. Include name of Project and date of video recording on each page.
- 3. At completion of training, submit complete training manual(s) for Owner's use in PDF electronic file format on compact disc.

## 1.5 QUALITY ASSURANCE

- A. Facilitator Qualifications: A firm or individual experienced in training or educating maintenance personnel in a training program similar in content and extent to that indicated for this Project, and whose work has resulted in training or education with a record of successful learning performance.
- B. Instructor Qualifications: A factory-authorized service representative, complying with requirements in Section 014000 "Quality Requirements," experienced in operation and maintenance procedures and training.
- C. Videographer Qualifications: A professional videographer who is experienced photographing demonstration and training events similar to those required.
- D. Preinstruction Conference: Conduct conference at Project site to comply with requirements in Section 013100 "Project Management and Coordination." Review methods and procedures related to demonstration and training including, but not limited to, the following:

## 1.6 COORDINATION

- A. Coordinate instruction schedule with Owner's operations. Adjust schedule as required to minimize disrupting Owner's operations and to ensure availability of Owner's personnel.
- B. Coordinate instructors, including providing notification of dates, times, length of instruction time, and course content.
- C. Coordinate content of training modules with content of approved emergency, operation, and maintenance manuals. Do not submit instruction program until operation and maintenance data has been reviewed and approved by Architect.

## PART 2 - PRODUCTS

### 2.1 INSTRUCTION PROGRAM

- A. Program Structure: Develop an instruction program that includes individual training modules for each system and for equipment not part of a system, as required by individual Specification Sections.
- B. Training Modules: Develop a learning objective and teaching outline for each module. Include a description of specific skills and knowledge that participant is expected to master. For each module, include instruction for the following as applicable to the system, equipment, or component:
  - 1. Basis of System Design, Operational Requirements, and Criteria: Include the following:

- a. System, subsystem, and equipment descriptions.
  - b. Performance and design criteria if Contractor is delegated design responsibility.
  - c. Operating standards.
  - d. Regulatory requirements.
  - e. Equipment function.
  - f. Operating characteristics.
  - g. Limiting conditions.
  - h. Performance curves.
2. Documentation: Review the following items in detail:
- a. Emergency manuals.
  - b. Operations manuals.
  - c. Maintenance manuals.
  - d. Project record documents.
  - e. Identification systems.
  - f. Warranties and bonds.
  - g. Maintenance service agreements and similar continuing commitments.
3. Emergencies: Include the following, as applicable:
- a. Instructions on meaning of warnings, trouble indications, and error messages.
  - b. Instructions on stopping.
  - c. Shutdown instructions for each type of emergency.
  - d. Operating instructions for conditions outside of normal operating limits.
  - e. Sequences for electric or electronic systems.
  - f. Special operating instructions and procedures.
4. Operations: Include the following, as applicable:
- a. Startup procedures.
  - b. Equipment or system break-in procedures.
  - c. Routine and normal operating instructions.
  - d. Regulation and control procedures.
  - e. Control sequences.
  - f. Safety procedures.
  - g. Instructions on stopping.
  - h. Normal shutdown instructions.
  - i. Operating procedures for emergencies.
  - j. Operating procedures for system, subsystem, or equipment failure.
  - k. Seasonal and weekend operating instructions.
  - l. Required sequences for electric or electronic systems.
  - m. Special operating instructions and procedures.
5. Adjustments: Include the following:
- a. Alignments.
  - b. Checking adjustments.
  - c. Noise and vibration adjustments.
  - d. Economy and efficiency adjustments.
6. Troubleshooting: Include the following:

- a. Diagnostic instructions.
  - b. Test and inspection procedures.
7. Maintenance: Include the following:
- a. Inspection procedures.
  - b. Types of cleaning agents to be used and methods of cleaning.
  - c. List of cleaning agents and methods of cleaning detrimental to product.
  - d. Procedures for routine cleaning
  - e. Procedures for preventive maintenance.
  - f. Procedures for routine maintenance.
  - g. Instruction on use of special tools.
8. Repairs: Include the following:
- a. Diagnosis instructions.
  - b. Repair instructions.
  - c. Disassembly; component removal, repair, and replacement; and reassembly instructions.
  - d. Instructions for identifying parts and components.
  - e. Review of spare parts needed for operation and maintenance.

### PART 3 - EXECUTION

#### 3.1 PREPARATION

- A. Assemble educational materials necessary for instruction, including documentation and training module. Assemble training modules into a training manual organized in coordination with requirements in Section 017823 "Operation and Maintenance Data."
- B. Set up instructional equipment at instruction location.

#### 3.2 INSTRUCTION

- A. Facilitator: Engage a qualified facilitator to prepare instruction program and training modules, to coordinate instructors, and to coordinate between Contractor and Owner for number of participants, instruction times, and location.
- B. Engage qualified instructors to instruct Owner's personnel to adjust, operate, and maintain systems, subsystems, and equipment not part of a system.
  1. Architect will furnish an instructor to describe basis of system design, operational requirements, criteria, and regulatory requirements.
  2. Owner will furnish Contractor with names and positions of participants.
- C. Scheduling: Provide instruction at mutually agreed on times. For equipment that requires seasonal operation, provide similar instruction at start of each season.
  1. Schedule training with Owner, through Construction Manager, with at least seven days' advance notice.

- D. Training Location and Reference Material: Conduct training on-site in the completed and fully operational facility using the actual equipment in-place. Conduct training using final operation and maintenance data submittals.
- E. Evaluation: At conclusion of each training module, assess and document each participant's mastery of module by use of a demonstration performance-based test.
- F. Cleanup: Collect used and leftover educational materials and give to Owner. Remove instructional equipment. Restore systems and equipment to condition existing before initial training use.

### 3.3 DEMONSTRATION AND TRAINING VIDEO RECORDINGS

- A. Video: Provide minimum 640 x 480 video resolution converted to format file type acceptable to Owner, on electronic media.
  - 1. Electronic Media: Read-only format compact disc acceptable to Owner, with commercial-grade graphic label.
  - 2. File Hierarchy: Organize folder structure and file locations according to project manual table of contents. Provide complete screen-based menu.
  - 3. File Names: Utilize file names based upon name of equipment generally described in video segment, as identified in Project specifications.
  - 4. Contractor and Installer Contact File: Using appropriate software, create a file for inclusion on the Equipment Demonstration and Training DVD that describes the following for each Contractor involved on the Project, arranged according to Project table of contents:
    - a. Name of Contractor/Installer.
    - b. Business address.
    - c. Business phone number.
    - d. Point of contact.
    - e. E-mail address.
- B. Recording: Mount camera on tripod before starting recording, unless otherwise necessary to adequately cover area of demonstration and training. Display continuous running time.
  - 1. Film training session(s) in segments not to exceed 15 minutes.
    - a. Produce segments to present a single significant piece of equipment per segment.
    - b. Organize segments with multiple pieces of equipment to follow order of Project Manual table of contents.
    - c. Where a training session on a particular piece of equipment exceeds 15 minutes, stop filming and pause training session. Begin training session again upon commencement of new filming segment.
- C. Light Levels: Verify light levels are adequate to properly light equipment. Verify equipment markings are clearly visible prior to recording.
  - 1. Furnish additional portable lighting as required.

END OF SECTION 017900

## **DIVISION 02 – EXISTING CONDITIONS**





SECTION 024116 - STRUCTURE DEMOLITION

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Demolition and removal of buildings **and site improvements**.
2. **Removing** below-grade construction.
3. Disconnecting, capping or sealing, and **removing** site utilities.
4. Salvaging items for reuse by Owner.

B. Related Requirements:

1. Section 011000 "Summary" for use of the premises and phasing requirements.
2. Section 013200 "Construction Progress Documentation" for preconstruction photographs taken before building demolition.
3. Section 024119 "Selective Demolition" for partial demolition of buildings, structures, and site improvements.
4. Section 311000 "Site Clearing" for site clearing and removal of above- and below-grade site improvements not part of building demolition.

1.3 DEFINITIONS

- A. Remove: Detach items from existing construction and dispose of them off-site unless indicated to be salvaged.
- B. Remove and Salvage: Detach items from existing construction, in a manner to prevent damage, and **deliver to Owner ready for reuse or storage**. Include fasteners or brackets needed for reattachment elsewhere.

1.4 MATERIALS OWNERSHIP

- A. Unless otherwise indicated, demolition waste becomes property of Contractor.
- B. Historic items, relics, antiques, and similar objects including, but not limited to, cornerstones and their contents, commemorative plaques and tablets, and other items of interest or value to Owner that may be uncovered during demolition remain the property of Owner.

1. Carefully salvage in a manner to prevent damage and promptly return to Owner.

1.5 PREINSTALLATION MEETINGS

- A. Predemolition Conference: Conduct conference at **Project site**.
1. Inspect and discuss condition of construction to be demolished.
  2. Review structural load limitations of existing structures.
  3. Review and finalize building demolition schedule and verify availability of demolition personnel, equipment, and facilities needed to make progress and avoid delays.
  4. Review and finalize protection requirements.
  5. Review procedures for **noise control and dust control**.
  6. Review procedures for protection of adjacent buildings.
  7. Review items to be salvaged and returned to Owner.

1.6 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For refrigerant recovery technician.
- B. Engineering Survey: Submit engineering survey of condition of building.
- C. Proposed Protection Measures: Submit report, including Drawings, that indicates the measures proposed for protecting individuals and property, **for environmental protection, for dust control and, for noise control**. Indicate proposed locations and construction of barriers.
1. Adjacent Buildings: Detail special measures proposed to protect adjacent buildings to remain **including means of egress from those buildings**.
- D. Schedule of Building Demolition Activities: Indicate the following:
1. Detailed sequence of demolition work, with starting and ending dates for each activity.
  2. Temporary interruption of utility services.
  3. Shutoff and capping **or re-routing** of utility services.
- E. Predemolition Photographs or Video: Show existing conditions of adjoining construction and site improvements, including finish surfaces, that might be misconstrued as damage caused by demolition operations. Comply with Section 013233 "Photographic Documentation." Submit before the Work begins.
- F. Statement of Refrigerant Recovery: Signed by refrigerant recovery technician responsible for recovering refrigerant, stating that all refrigerant that was present was recovered and that recovery was performed according to EPA regulations. Include name and address of technician and date refrigerant was recovered.

1.7 CLOSEOUT SUBMITTALS

- A. Inventory: Submit a list of items that have been removed and salvaged.

1.8 QUALITY ASSURANCE

- A. Refrigerant Recovery Technician Qualifications: Certified by EPA-approved certification program.

1.9 FIELD CONDITIONS

- A. Buildings to be demolished will be vacated and their use discontinued before start of the Work.
- B. Buildings immediately adjacent to demolition area will be occupied. Conduct building demolition so operations of occupied buildings will not be disrupted.
  - 1. Provide not less than **72** hours' notice of activities that will affect operations of adjacent occupied buildings.
  - 2. Maintain access to existing walkways, exits, and other facilities used by occupants of adjacent buildings.
    - a. Do not close or obstruct walkways, exits, or other facilities used by occupants of adjacent buildings without written permission from authorities having jurisdiction.
- C. Conditions existing at time of inspection for bidding purpose will be maintained by Owner as far as practical.
  - 1. Before building demolition, Owner will remove the following items:
    - a. **<Insert items to be removed by Owner>**.
- D. Hazardous Materials: Present in buildings and structures to be demolished. A report on the presence of hazardous materials is on file for review and use. Examine report to become aware of locations where hazardous materials are present.
  - 1. Owner will provide material safety data sheets for materials that are known to be present in buildings and structures to be demolished because of building operations or processes performed there.
- E. On-site storage or sale of removed items or materials is not permitted.

1.10 COORDINATION

- A. Arrange demolition schedule so as not to interfere with **operations of adjacent occupied buildings**.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Regulatory Requirements: Comply with governing EPA notification regulations before beginning demolition. Comply with hauling and disposal regulations of authorities having jurisdiction.

- B. Standards: Comply with ASSE A10.6 and NFPA 241.

## 2.2 SOIL MATERIALS

- A. Satisfactory Soils: Comply with requirements in Section 312000 "Earth Moving."

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Verify that utilities have been disconnected and capped before starting demolition operations.
- B. Review Project Record Documents of existing construction or other existing condition and hazardous material information provided by Owner. Owner does not guarantee that existing conditions are same as those indicated in Project Record Documents.
- C. **Engage a professional engineer to perform** an engineering survey of condition of building to determine whether removing any element might result in structural deficiency or unplanned collapse of any portion of structure or adjacent structures during building demolition operations.
- D. Steel Tendons: Locate tensioned steel tendons and include recommendations for de-tensioning.
- E. Verify that hazardous materials have been remediated before proceeding with building demolition operations.
- F. Inventory and record the condition of items to be removed and salvaged. Provide photographs or video of conditions that might be misconstrued as damage caused by salvage operations. Comply with Section 013233 "Photographic Documentation.

### 3.2 PREPARATION

- A. Refrigerant: Before starting demolition, remove refrigerant from mechanical equipment according to 40 CFR 82 and regulations of authorities having jurisdiction.
- B. Salvaged Items: Comply with the following:
  - 1. Clean salvaged items of dirt and demolition debris.
  - 2. Pack or crate items after cleaning. Identify contents of containers.
  - 3. Store items in a secure area until delivery to Owner.
  - 4. Transport items to storage area **designated by Owner**.
  - 5. Protect items from damage during transport and storage.

### 3.3 UTILITY SERVICES AND MECHANICAL/ELECTRICAL SYSTEMS

- A. Existing Utilities to be Disconnected: Locate, identify, disconnect, and seal or cap off utilities serving buildings and structures to be demolished.

1. Arrange to shut off utilities with utility companies.

STRUCTURE DEMOLITION

024116 - - 4

2. If removal, relocation, or abandonment of utility services will affect adjacent occupied buildings, then provide temporary utilities that bypass buildings and structures to be demolished and that maintain continuity of service to other buildings and structures.
3. Cut off pipe or conduit a minimum of **24 inches (610 mm)** below grade. Cap, valve, or plug and seal remaining portion of pipe or conduit after bypassing according to requirements of authorities having jurisdiction.
4. Do not start demolition work until utility disconnecting and sealing have been completed and verified in writing.

### 3.4 PROTECTION

- A. Existing Facilities: Protect adjacent walkways, loading docks, building entries, and other building facilities during demolition operations. Maintain exits from existing buildings.
- B. Temporary Shoring: Provide and maintain interior and exterior shoring, bracing, or structural support to preserve stability and prevent unexpected movement or collapse of construction being demolished.
  1. Strengthen or add new supports when required during progress of demolition.
- C. Existing Utilities to Remain: Maintain utility services to remain and protect from damage during demolition operations.
  1. Do not interrupt existing utilities serving adjacent occupied or operating facilities unless authorized in writing by Owner and authorities having jurisdiction.
  2. Provide temporary services during interruptions to existing utilities, as acceptable to Owner and authorities having jurisdiction.
    - a. Provide at least **72 hours'** notice to occupants of affected buildings if shutdown of service is required during changeover.
- D. Temporary Protection: Erect temporary protection, such as walks, fences, railings, canopies, and covered passageways, where required by authorities having jurisdiction and as indicated. Comply with requirements in Section 015000 "Temporary Facilities and Controls."
  1. Protect adjacent buildings and facilities from damage due to demolition activities.
  2. Protect existing site improvements, appurtenances, and landscaping to remain.
  3. Erect a plainly visible fence around drip line of individual trees or around perimeter drip line of groups of trees to remain.
  4. Provide temporary barricades and other protection required to prevent injury to people and damage to adjacent buildings and facilities to remain.
  5. Provide protection to ensure safe passage of people around building demolition area and to and from occupied portions of adjacent buildings and structures.
  6. Protect walls, windows, roofs, and other adjacent exterior construction that are to remain and that are exposed to building demolition operations.
  7. Erect and maintain dustproof partitions and temporary enclosures to limit dust, noise, and dirt migration to occupied portions of adjacent buildings.

COUNTY OF MONTEREY  
NEW JUVENILE HALL

75-14126-00

STRUCTURE DEMOLITION

024116 - - 5

STRUCTURE DEMOLITION

024116 - 8  
09/01/2015



- E. Remove temporary barriers and protections where hazards no longer exist. Where open excavations or other hazardous conditions remain, leave temporary barriers and protections in place.

### 3.5 DEMOLITION, GENERAL

- A. General: Demolish indicated buildings **and site improvements** completely. Use methods required to complete the Work within limitations of governing regulations and as follows:
  - 1. Do not use cutting torches until work area is cleared of flammable materials. Maintain portable fire-suppression devices during flame-cutting operations.
  - 2. Maintain fire watch during and for at least 2 hours after flame-cutting operations.
  - 3. Maintain adequate ventilation when using cutting torches.
  - 4. Locate building demolition equipment and remove debris and materials so as not to impose excessive loads on supporting walls, floors, or framing.
- B. Site Access and Temporary Controls: Conduct building demolition and debris-removal operations to ensure minimum interference with roads, streets, walks, walkways, and other adjacent occupied and used facilities.
  - 1. Do not close or obstruct streets, walks, walkways, or other adjacent occupied or used facilities without permission from Owner and authorities having jurisdiction. Provide alternate routes around closed or obstructed trafficways if required by authorities having jurisdiction.
  - 2. Use water mist and other suitable methods to limit spread of dust and dirt. Comply with governing environmental-protection regulations. Do not use water when it may damage adjacent construction or create hazardous or objectionable conditions, such as ice, flooding, and pollution.

### 3.6 DEMOLITION BY MECHANICAL MEANS

- A. Proceed with demolition of structural framing members systematically, from higher to lower level. Complete building demolition operations above each floor or tier before disturbing supporting members on the next lower level.
- B. Remove debris from elevated portions of the building by chute, hoist, or other device that will convey debris to grade level in a controlled descent.
  - 1. Remove structural framing members and lower to ground by method suitable to minimize ground impact and dust generation.
- C. Salvage: Items to be removed and salvaged are indicated **below**:
  - 1. Doors and door hardware.
  - 2. Windows.
  - 3. Cabinets.
  - 4. Mirrors.
  - 5. Chalkboards.
  - 6. Tackboards.

COUNTY OF MONTEREY  
NEW JUVENILE HALL

75-14126-00

STRUCTURE DEMOLITION

024116 - - 6

STRUCTURE DEMOLITION

024116 - 10  
09/01/2015

7. Marker boards.
8. Plumbing fixtures.
9. **<Insert items to be salvaged>**.

D. Below-Grade Construction: Demolish foundation walls and other below-grade construction.

1. Remove below-grade construction, including basements, foundation walls, and footings, **completely**.

E. Existing Utilities: Demolish and remove existing utilities and below-grade utility structures.

### 3.7 SITE RESTORATION

A. Below-Grade Areas: Completely fill below-grade areas and voids resulting from building demolition operations with **satisfactory soil materials** according to backfill requirements in Section 312000 "Earth Moving."

B. Site Grading: Uniformly rough grade area of demolished construction to a smooth surface, free from irregular surface changes. Provide a smooth transition between adjacent existing grades and new grades.

### 3.8 REPAIRS

A. Promptly repair damage to adjacent buildings caused by demolition operations.

### 3.9 DISPOSAL OF DEMOLISHED MATERIALS

A. Remove demolition waste materials from Project site **and dispose of them in an EPA-approved construction and demolition waste landfill acceptable to authorities having jurisdiction.and recycle or dispose of them according to Section 017419 "Construction Waste Management and Disposal."**

1. Do not allow demolished materials to accumulate on-site.
2. Remove and transport debris in a manner that will prevent spillage on adjacent surfaces and areas.

B. Do not burn demolished materials.

COUNTY OF MONTEREY  
NEW JUVENILE HALL

75-14126-00

STRUCTURE DEMOLITION

024116 - - 7

STRUCTURE DEMOLITION

024116 - 12  
09/01/2015

CLEANING

- C. Clean adjacent structures and improvements of dust, dirt, and debris caused by building demolition operations. Return adjacent areas to condition existing before building demolition operations began.

- 1. Clean roadways of debris caused by debris transport.

END OF SECTION 024116

COUNTY OF MONTEREY  
NEW JUVENILE HALL

75-14126-00

STRUCTURE DEMOLITION

024116 - - 8

STRUCTURE DEMOLITION

024116 - 14  
09/01/2015

SECTION 024119 - SELECTIVE DEMOLITION

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Demolition and removal of selected portions of building or structure.
2. Demolition and removal of selected site elements.
3. Salvage of existing items to be reused or recycled.

B. Related Requirements:

1. Section 011000 "Summary" for restrictions on use of the premises, Owner-occupancy requirements, and phasing requirements.
2. Section 015639 "Temporary Tree and Plant Protection" for temporary protection of existing trees and plants that are affected by selective demolition.
3. Section 017300 "Execution" for cutting and patching procedures.
4. Section 013516 "Alteration Project Procedures" for general protection and work procedures for alteration projects.
5. Section 311000 "Site Clearing" for site clearing and removal of above- and below-grade improvements not part of selective demolition.

1.3 DEFINITIONS

- A. Remove: Detach items from existing construction and dispose of them off-site unless indicated to be salvaged or reinstalled.
- B. Remove and Salvage: Detach items from existing construction, in a manner to prevent damage, and **deliver to Owner ready for reuse**.
- C. Remove and Reinstall: Detach items from existing construction, in a manner to prevent damage, prepare for reuse, and reinstall where indicated.
- D. Existing to Remain: Leave existing items that are not to be removed and that are not otherwise indicated to be salvaged or reinstalled.
- E. Dismantle: To remove by disassembling or detaching an item from a surface, using gentle methods and equipment to prevent damage to the item and surfaces; disposing of items unless indicated to be salvaged or reinstalled.

1.4 MATERIALS OWNERSHIP

- A. Unless otherwise indicated, demolition waste becomes property of Contractor.
- B. Historic items, relics, antiques, and similar objects including, but not limited to, cornerstones and their contents, commemorative plaques and tablets, and other items of interest or value to Owner that may be uncovered during demolition remain the property of Owner.
  - 1. Carefully salvage in a manner to prevent damage and promptly return to Owner.

1.5 PREINSTALLATION MEETINGS

- A. Predemolition Conference: Conduct conference at **Project site**.
  - 1. Inspect and discuss condition of construction to be selectively demolished.
  - 2. Review structural load limitations of existing structure.
  - 3. Review and finalize selective demolition schedule and verify availability of materials, demolition personnel, equipment, and facilities needed to make progress and avoid delays.
  - 4. Review requirements of work performed by other trades that rely on substrates exposed by selective demolition operations.
  - 5. Review areas where existing construction is to remain and requires protection.

1.6 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For refrigerant recovery technician.
- B. Engineering Survey: Submit engineering survey of condition of building.
- C. Proposed Protection Measures: Submit report, including Drawings, that indicates the measures proposed for protecting individuals and property, **for environmental protection, for dust control and, for noise control**. Indicate proposed locations and construction of barriers.
- D. Schedule of Selective Demolition Activities: Indicate the following:
  - 1. Detailed sequence of selective demolition and removal work, with starting and ending dates for each activity. Ensure Owner's on-site operations are uninterrupted.
  - 2. Interruption of utility services. Indicate how long utility services will be interrupted.
  - 3. Coordination for shutoff, capping, and continuation of utility services.
  - 4. Coordination of Owner's continuing occupancy of portions of existing building and of Owner's partial occupancy of completed Work.
- E. Predemolition Photographs or Video: Show existing conditions of adjoining construction, including finish surfaces, that might be misconstrued as damage caused by demolition operations. Comply with Section 013233 "Photographic Documentation." Submit before Work begins.
- F. Statement of Refrigerant Recovery: Signed by refrigerant recovery technician responsible for recovering refrigerant, stating that all refrigerant that was present was recovered and that



recovery was performed according to EPA regulations. Include name and address of technician and date refrigerant was recovered.

- G. Warranties: Documentation indicating that existing warranties are still in effect after completion of selective demolition.

#### 1.7 CLOSEOUT SUBMITTALS

- A. Inventory: Submit a list of items that have been removed and salvaged.

#### 1.8 QUALITY ASSURANCE

- A. Refrigerant Recovery Technician Qualifications: Certified by an EPA-approved certification program.

#### 1.9 FIELD CONDITIONS

- A. Owner will occupy portions of building immediately adjacent to selective demolition area. Conduct selective demolition so Owner's operations will not be disrupted.

- B. Conditions existing at time of inspection for bidding purpose will be maintained by Owner as far as practical.

- 1. Before selective demolition, Owner will remove the following items:

- a. **<Insert items to be removed by Owner>**.

- C. Notify Architect of discrepancies between existing conditions and Drawings before proceeding with selective demolition.

- D. Hazardous Materials: Present in buildings and structures to be selectively demolished. A report on the presence of hazardous materials is on file for review and use. Examine report to become aware of locations where hazardous materials are present.

- 1. Owner will provide material safety data sheets for suspected hazardous materials that are known to be present in buildings and structures to be selectively demolished because of building operations or processes performed there.

- E. Storage or sale of removed items or materials on-site is not permitted.

- F. Utility Service: Maintain existing utilities indicated to remain in service and protect them against damage during selective demolition operations.

- 1. Maintain fire-protection facilities in service during selective demolition operations.

#### 1.10 WARRANTY

- A. Existing Warranties: Remove, replace, patch, and repair materials and surfaces cut or damaged during selective demolition, by methods and with materials and using approved contractors so

as not to void existing warranties. Notify warrantor before proceeding. Existing warranties include the following:

1.<Insert warranted system>.

- B. Notify warrantor on completion of selective demolition, and obtain documentation verifying that existing system has been inspected and warranty remains in effect. Submit documentation at Project closeout.

#### 1.11 COORDINATION

- A. Arrange selective demolition schedule so as not to interfere with Owner's operations.

### PART 2 - PRODUCTS

#### 2.1 PERFORMANCE REQUIREMENTS

- A. Regulatory Requirements: Comply with governing EPA notification regulations before beginning selective demolition. Comply with hauling and disposal regulations of authorities having jurisdiction.
- B. Standards: Comply with ASSE A10.6 and NFPA 241.
- C. [<Double click to insert sustainable design text for building reuse.>](#)

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Verify that utilities have been disconnected and capped before starting selective demolition operations.
- B. Review Project Record Documents of existing construction or other existing condition and hazardous material information provided by Owner. Owner does not guarantee that existing conditions are same as those indicated in Project Record Documents.
- C. **Perform**]an engineering survey of condition of building to determine whether removing any element might result in structural deficiency or unplanned collapse of any portion of structure or adjacent structures during selective building demolition operations.
  - 1. Perform surveys as the Work progresses to detect hazards resulting from selective demolition activities.
- D. Steel Tendons: Locate tensioned steel tendons and include recommendations for de-tensioning.
- E. Verify that hazardous materials have been remediated before proceeding with building demolition operations.

F. Survey of Existing Conditions: Record existing conditions by use of **measured drawings preconstruction photographs or video and templates.**

1. Comply with requirements specified in Section 013233 "Photographic Documentation."
2. Inventory and record the condition of items to be removed and salvaged. Provide photographs or video of conditions that might be misconstrued as damage caused by salvage operations.
3. Before selective demolition or removal of existing building elements that will be reproduced or duplicated in final Work, make permanent record of measurements, materials, and construction details required to make exact reproduction.

3.2 PREPARATION

- A. Refrigerant: Before starting demolition, remove refrigerant from mechanical equipment according to 40 CFR 82 and regulations of authorities having jurisdiction.

3.3 UTILITY SERVICES AND MECHANICAL/ELECTRICAL SYSTEMS

- A. Existing Services/Systems to Remain: Maintain services/systems indicated to remain and protect them against damage.

- B. Existing Services/Systems to Be Removed, Relocated, or Abandoned: Locate, identify, disconnect, and seal or cap off utility services and mechanical/electrical systems serving areas to be selectively demolished.

1. Arrange to shut off utilities with utility companies.
2. If services/systems are required to be removed, relocated, or abandoned, provide temporary services/systems that bypass area of selective demolition and that maintain continuity of services/systems to other parts of building.
3. Disconnect, demolish, and remove fire-suppression systems, plumbing, and HVAC systems, equipment, and components indicated on Drawings to be removed.
  - a. Piping to Be Removed: Remove portion of piping indicated to be removed and cap or plug remaining piping with same or compatible piping material.
  - b. Equipment to Be Removed: Disconnect and cap services and remove equipment.
  - c. Equipment to Be Removed and Reinstalled: Disconnect and cap services and remove, clean, and store equipment; when appropriate, reinstall, reconnect, and make equipment operational.
  - d. Equipment to Be Removed and Salvaged: Disconnect and cap services and remove equipment and deliver to Owner.
  - e. Ducts to Be Removed: Remove portion of ducts indicated to be removed and plug remaining ducts with same or compatible ductwork material.

3.4 PROTECTION

- A. Temporary Protection: Provide temporary barricades and other protection required to prevent injury to people and damage to adjacent buildings and facilities to remain.

1. Provide protection to ensure safe passage of people around selective demolition area and to and from occupied portions of building.
  2. Provide temporary weather protection, during interval between selective demolition of existing construction on exterior surfaces and new construction, to prevent water leakage and damage to structure and interior areas.
  3. Protect walls, ceilings, floors, and other existing finish work that are to remain or that are exposed during selective demolition operations.
  4. Cover and protect furniture, furnishings, and equipment that have not been removed.
  5. Comply with requirements for temporary enclosures, dust control, heating, and cooling specified in Section 015000 "Temporary Facilities and Controls."
- B. Temporary Shoring: Design, provide, and maintain shoring, bracing, and structural supports as required to preserve stability and prevent movement, settlement, or collapse of construction and finishes to remain, and to prevent unexpected or uncontrolled movement or collapse of construction being demolished.
1. Strengthen or add new supports when required during progress of selective demolition.
- C. Remove temporary barricades and protections where hazards no longer exist.

### 3.5 SELECTIVE DEMOLITION, GENERAL

- A. General: Demolish and remove existing construction only to the extent required by new construction and as indicated. Use methods required to complete the Work within limitations of governing regulations and as follows:
1. Proceed with selective demolition systematically, from higher to lower level. Complete selective demolition operations above each floor or tier before disturbing supporting members on the next lower level.
  2. Neatly cut openings and holes plumb, square, and true to dimensions required. Use cutting methods least likely to damage construction to remain or adjoining construction. Use hand tools or small power tools designed for sawing or grinding, not hammering and chopping. Temporarily cover openings to remain.
  3. Cut or drill from the exposed or finished side into concealed surfaces to avoid marring existing finished surfaces.
  4. Do not use cutting torches until work area is cleared of flammable materials. At concealed spaces, such as duct and pipe interiors, verify condition and contents of hidden space before starting flame-cutting operations. Maintain portable fire-suppression devices during flame-cutting operations.
  5. Maintain fire watch during and for at least 2 hours after flame-cutting operations.
  6. Maintain adequate ventilation when using cutting torches.
  7. Remove decayed, vermin-infested, or otherwise dangerous or unsuitable materials and promptly dispose of off-site.
  8. Remove structural framing members and lower to ground by method suitable to avoid free fall and to prevent ground impact or dust generation.
  9. Locate selective demolition equipment and remove debris and materials so as not to impose excessive loads on supporting walls, floors, or framing.
  10. Dispose of demolished items and materials promptly. **Comply with requirements in Section 017419 "Construction Waste Management and Disposal."**

- B. Site Access and Temporary Controls: Conduct selective demolition and debris-removal operations to ensure minimum interference with roads, streets, walks, walkways, and other adjacent occupied and used facilities.
- C. Removed and Salvaged Items:
  - 1. Clean salvaged items.
  - 2. Pack or crate items after cleaning. Identify contents of containers.
  - 3. Store items in a secure area until delivery to Owner.
  - 4. Transport items to Owner's storage area [**on-site**] [**off-site**] [**designated by Owner**] [**indicated on Drawings**].
  - 5. Protect items from damage during transport and storage.
- D. Removed and Reinstalled Items:
  - 1. Clean and repair items to functional condition adequate for intended reuse.
  - 2. Pack or crate items after cleaning and repairing. Identify contents of containers.
  - 3. Protect items from damage during transport and storage.
  - 4. Reinstall items in locations indicated. Comply with installation requirements for new materials and equipment. Provide connections, supports, and miscellaneous materials necessary to make item functional for use indicated.
- E. Existing Items to Remain: Protect construction indicated to remain against damage and soiling during selective demolition. When permitted by Architect, items may be removed to a suitable, protected storage location during selective demolition **and cleaned** and reinstalled in their original locations after selective demolition operations are complete.

### 3.6 SELECTIVE DEMOLITION PROCEDURES FOR SPECIFIC MATERIALS

- A. Concrete: Demolish in sections. Cut concrete full depth at junctures with construction to remain and at regular intervals using power-driven saw, and then remove concrete between saw cuts.
- B. Masonry: Demolish in small sections. Cut masonry at junctures with construction to remain, using power-driven saw, and then remove masonry between saw cuts.
- C. Concrete Slabs-on-Grade: Saw-cut perimeter of area to be demolished, and then break up and remove.
- D. Roofing: Remove no more existing roofing than what can be covered in one day by new roofing and so that building interior remains watertight and weathertight. See Section 07500 for new roofing requirements.
  - 1. Remove existing roof membrane, flashings, copings, and roof accessories.
  - 2. Remove existing roofing system down to substrate.

### 3.7 DISPOSAL OF DEMOLISHED MATERIALS

- A. Remove demolition waste materials from Project site **and dispose of them in an EPA-approved construction and demolition waste landfill acceptable to authorities having**

**jurisdiction.] [and recycle or dispose of them according to Section 017419 "Construction Waste Management and Disposal."**

1. Do not allow demolished materials to accumulate on-site.
  2. Remove and transport debris in a manner that will prevent spillage on adjacent surfaces and areas.
  3. Comply with requirements specified in Section 017419 "Construction Waste Management and Disposal."
- B. Burning: Do not burn demolished materials.

3.8 CLEANING

- A. Clean adjacent structures and improvements of dust, dirt, and debris caused by selective demolition operations. Return adjacent areas to condition existing before selective demolition operations began.

3.9 SELECTIVE DEMOLITION SCHEDULE

- A. Remove: <Insert description of items and construction to remove>.
- B. Remove and Salvage: <Insert description of items to remove and salvage>.
- C. Remove and Reinstall: <Insert description of items to remove and reinstall>.
- D. Existing to Remain: <Insert description of items to remain>.
- E. Dismantle: <Insert description of items to be removed>.

END OF SECTION 024119

**DIVISION 03 – CONCRETE**





SECTION 03 3000 - CAST-IN-PLACE CONCRETE

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. Section includes cast-in-place concrete, including formwork, reinforcement, concrete materials, mixture design, placement procedures, and finishes, for the following:

- 1. Footings.
- 2. Slabs-on-grade.
- 3. Topping slabs.

- B. Related Sections:

- 1. Division 01 Sections as applicable to testing and quality control.
- 2. Division 072600 "Vapor Barrier" 11
- 3. Division 22 and 23 Sections as applicable to Plumbing and Mechanical items embedded in concrete.
- 4. Division 26 Sections as applicable to Electrical items embedded in concrete.
- 5. Division 31 Sections as applicable to earthwork.

1.3 DEFINITIONS

- A. Cementitious Materials: Portland cement alone or in combination with one or more of the following: blended hydraulic cement, fly ash and other pozzolans, ground granulated blast-furnace slag, and silica fume; subject to compliance with requirements.

1.4 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Design Mixtures: For each concrete mixture. Submit alternate design mixtures when characteristics of materials, Project conditions, weather, test results, or other circumstances warrant adjustments.
- C. Steel Reinforcement Shop Drawings: Placing drawings that detail fabrication, bending, and placement. Include bar sizes, lengths, material, grade, bar schedules, stirrup spacing, bent bar diagrams, bar arrangement, splices and laps, mechanical connections, tie spacing, hoop spacing, and supports for concrete reinforcement.

1. Mill certificates: Steel producer's certificates of mill analysis, tensile, and bend tests for reinforcing steel. Submit certificates accompanying the Shop Drawings.
  - D. Construction Joint Layout: Show locations of proposed construction and control joints other than, or in addition to, those as indicated on the drawings. Location of joints is subject to approval of the Architect.
  - E. Material Certificates: For each of the following, signed by manufacturers:
    1. Cementitious materials.
    2. Admixtures.
    3. Form materials and form-release agents.
    4. Steel reinforcement and accessories.
    5. Fiber reinforcement.
    6. Waterstops.
    7. Curing compounds.
    8. Floor and slab treatments.
    9. Bonding agents.
    10. Adhesives.
    11. Semirigid joint filler.
    12. Joint-filler strips.
    13. Repair materials.
  - F. Material Test Reports: For aggregates, from a qualified testing agency, indicating compliance with requirements:
  - G. Mill certificates: Steel producer's certificates of mill analysis, tensile, and bend tests for reinforcing steel. Submit certificates accompanying the Shop Drawings.
  - H. Steel Reinforcement Record Drawings: Shop drawings shall be corrected to reflect actual field changes and shall be submitted to the Architect.
  - I. Welding certificates.
  - J. Delivery Tags: Delivery tags for all concrete.
- 1.5 QUALITY ASSURANCE
- A. Installer Qualifications: A qualified installer who employs on Project personnel who shall be thoroughly familiar with the specified requirements, completely trained and experienced in the necessary skills required for work performed under this Section. In actual installation of the work of this Section, use adequate numbers of skilled workmen to insure installation in strict accordance with the contract documents design.
  - B. Concrete Manufacturer Qualifications: A firm experienced in manufacturing ready-mixed concrete products and that complies with ASTM C 94/C 94M requirements for production facilities and equipment.
  - C. Testing Agency: An independent agency retained by the Owner, acceptable to the Architect, and qualified according to ASTM C 1077 and ASTM E 329 for testing indicated.

- D. Source Limitations: Obtain each type or class of cementitious material of the same brand from the same manufacturer's plant, obtain aggregate from single source, and obtain admixtures from single source from single manufacturer.
- E. Welding Qualifications: Qualify procedures and personnel according to AWS D1.4/D 1.4M, "Structural Welding Code - Reinforcing Steel."
- F. ACI Publications: Comply with the following unless modified by requirements in the Contract Documents:
  - 1. ACI 301, "Specifications for Structural Concrete," Sections 1 through 5.
  - 2. ACI 318-11, "Building Code Requirements for Structural Concrete" with amendments per 2013 California Building Code, Chapter 19, Section 1908.
  - 3. ACI 117, "Specifications for Tolerances for Concrete Construction and Materials."
- G. Preinstallation Conference: Conduct conference at Project site.
  - 1. Review inspection and testing and inspecting agency procedures for field quality control, concrete finishes and finishing, cold- and hot-weather concreting procedures, curing procedures, construction contraction and isolation joints, and joint-filler strips, semirigid joint fillers, forms and form removal limitations, shoring and reshoring procedures, vapor-barrier installation, anchor rod and anchorage device installation tolerances, [steel reinforcement installation, floor and slab flatness and levelness measurement, concrete repair procedures, and concrete protection.

#### 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Steel Reinforcement: Deliver, store, and handle steel reinforcement to prevent bending and damage.
  - 1. Identification: Bundle and tag reinforcing steel with grades and suitable identification marks for checking, sorting and placing. Use waterproof tags and markings and do not remove until steel is in place.

#### 1.7 COORDINATION

- A. Slab Finishes: Coordinate slab finish requirements with trades installing or applying floor finishes or treatments over slabs. Finishes shall include but not be limited to concrete sealing, topical concrete vapor control barrier, ceramic tile, resinous/fluid applied floor systems, adhered resilient floor systems, and adhered carpet.

## PART 2 - PRODUCTS

### 2.1 FORM MATERIALS

- A. Earth Forms: Use for sides of footings only where soil is firm and stable and concrete will not be exposed. Where earth forms are used, cut excavations neat and accurate to size for placing concrete directly against the excavation.
- B. Rough-Formed Finished Concrete: Use for formed concrete that will not be exposed in the finished work, fabricate forms of plywood, lumber, metal, or another approved material. Provide lumber dressed on at least two edges and one side for tight fit.
- C. Smooth-Formed Finished Concrete: Use for formed concrete that will be exposed in the finished work, fabricate forms of form-facing panels that will provide continuous, true, and smooth concrete surfaces. Furnish in largest practicable sizes to minimize number of joints.
  - 1. Plywood, metal, or other approved panel materials.
- D. Chamfer Strips: Wood, metal, PVC, or rubber strips, 3/4 by 3/4 inch, minimum.
- E. Form Ties: Factory-fabricated, removable or snap-off metal or glass-fiber-reinforced plastic form ties designed to resist lateral pressure of fresh concrete on forms and to prevent spalling of concrete on removal.
  - 1. Furnish units that will leave no corrodible metal closer than 1 inch to the plane of exposed concrete surface.
  - 2. Furnish ties that, when removed, will leave holes no larger than 1 inch in diameter in concrete surface.
- F. Form-Release Agent: Commercially formulated form-release agent that will not bond with, stain, or adversely affect concrete surfaces and will not impair subsequent treatments of concrete surfaces.
  - 1. Formulate form-release agent with rust inhibitor for steel form-facing materials.

### 2.2 STEEL REINFORCEMENT

- A. Reinforcing Bars: ASTM A 615/A 615M, Grade 60, deformed.
- B. Low-Alloy-Steel Reinforcing Bars: ASTM A 706/A 706M, deformed.
- C. Plain-Steel Wire: ASTM A 1064/A 1064M, as drawn.
- D. Plain-Steel Welded Wire Reinforcement: ASTM A 1064/A 1064M, plain, fabricated from as-drawn steel wire into flat sheets.
- E. Bar Supports: Bolsters, chairs, spacers, and other devices for spacing, supporting, and fastening reinforcing bars and welded wire reinforcement in place. Manufacture bar supports from steel

wire, plastic, or precast concrete according to CRSI's "Manual of Standard Practice," of greater compressive strength than concrete and as follows:

1. Slabs on Grade and Foundations: Use precast concrete blocks, plastic-coated steel with bearing plates or specifically designed wire-fabric supports fabricated of plastic. Precast blocks shall be not less than 3 inches by 3 inches square and shall have a compressive strength equal to or greater than the strength of the surrounding concrete.
  2. For concrete surfaces exposed to view where legs of wire bar supports contact forms, use CRSI Class 1 plastic-protected steel wire or CRSI Class 2 stainless-steel bar supports.
- F. Fabricating Reinforcement: Fabricate steel reinforcement according to CRSI's "Manual of Standard Practice" or ACI SP-66 and the details shown on the Drawings.
1. In the case of fabricating errors, do not rebend or straighten reinforcement in a manner that will damage or weaken the material.
  2. Bends shall be made cold using pin sizes as recommended ACI 318 as modified by T24, CCR, Part 2.
  3. Unacceptable Work: Reinforcement with any of the following defects will not be permitted:
    - a. Bar lengths, depths, and bends exceeding specified fabrication tolerance.
    - b. Bends or kinks not indicated on the project Drawings or the final Shop Drawings.
    - c. Bars with reduced cross-section due to excessive rusting or other cause.

### 2.3 CONCRETE MATERIALS

- A. Cementitious Material: Use the following cementitious materials, of the same type, brand, and source, throughout Project:
1. Portland Cement: ASTM C 150, Type II, gray.
    - a. Fly Ash: ASTM C 618, Class F. The use of a quality fly ash will be permitted as a cement-reducing admixture up to a maximum of 15% of the weight of portland-cement. The loss on ignition in Table 1 of ASTM C618 shall not exceed 3%. Quality assurance testing and reports for a minimum of six months shall be submitted by the fly ash supplier. The amount retained on the 325 sieve in Table 2 of ASTM C618, shall not exceed 20%.
- B. Normal-Weight Aggregates: ASTM C 33, Class 3M coarse aggregate or better, graded. Provide aggregates from a single source.
1. Where concrete expansion from alkali silica or alkali carbonate reactions is anticipated, provide aggregate with documented service record data of at least 10 years' satisfactory service in similar applications and service conditions using similar aggregates and cementitious materials.
  2. Fine and coarse aggregates shall be regarded as separate ingredients. Each size of coarse aggregate, as well as the combination of sizes when two or more are used, shall conform to the grading requirements of ASTM C33.
  3. Coarse aggregate: Coarse aggregate shall consist of a clean, hard, fine grained, sound crushed rock, or washed gravel or a combination of both. It shall be free from oil, organic matter, or other deleterious substances. Aggregate shall be uniformly graded from one-quarter inch size to maximum size.

4. The maximum size of aggregates used in the project shall be consistent with the dimensions and form of the section being placed, the location and spacing of the reinforcing bars, and with the method of compaction, and shall be such as will produce dense and uniform concrete free from rock pockets, honey-comb and other irregularities. The nominal maximum size of the aggregate shall not be more than one-fifth the narrowest dimension between forms, one-third the depth of slabs nor three-fourths the minimum clear spacing between reinforcing bars.
5. Combined Grading: The combined grading shall be such that the percentage by weight of the combined aggregates shall fall within the limits established as follows:

Sieve number or size in inches (maximum)	Percentage by Weight		
	1-1/2"	1"	3/4"
Passing a 2 inch	---	---	---
Passing a 1-1/2 inch	95-100	---	---
Passing a 1 inch	70-90	90-100	---
Passing a 3/4 inch	50-80	70-95	90-100
Passing a 3/8 inch	40-60	45-70	55-75
Passing a No. 4	35-55	35-55	40-60
Passing a No. 8	25-40	27-45	30-46
Passing a No. 16	16-34	20-38	23-40
Passing a No. 30	12-25	12-27	13-28
Passing a No. 50	2-12	5-15	5-15
Passing a No. 100	0-3	0-5	0-5

6. Special grading or size limitations: When reviewed and approved by the Architect, other gradings or maximum size limitations may be used if mixes are designed and tested in accordance with Concrete Mixture Design Method C specified in "Concrete Mixtures" Article.
7. Soundness of Aggregates: Both the coarse and fine aggregate shall be tested by the use of a solution of sodium or magnesium sulfate, or both, whenever in the judgment of the Architect, such tests are necessary to determine the quality of the material. Such tests shall be performed in accordance with ASTM C88 and the results shall show compliance with the limits set forth in ASTM C33.
8. Reactivity: Aggregates shall be free from any substance which may be deleteriously reactive with the alkalis in the cement in an amount sufficient to cause excessive expansion of the concrete or which will interfere with normal hydration of the cement. Acceptability of the aggregate shall be based upon satisfactory evidence that the aggregate is free from such materials.
9. Aggregates shall be tested, when required by the Architect prior to the concrete mix being established, in accordance with the following specifications:

Test	Specification
Abrasion	ASTM C131 and C535
Gradation	ASTM C136
Alkali Reactivity	ASTM C289 and C227
Organic Impurities	ASTM C40
Clay Lumps	ASTM C142

10. Maximum Coarse-Aggregate Size: Nominal size as indicated on Drawings.

11. Fine Aggregate: Free of materials with deleterious reactivity to alkali in cement.

C. Water: ASTM C 94/C 94M and potable.

## 2.4 ADMIXTURES

A. Admixtures shall be reviewed and approved by the Architect

B. Calcium chloride, thiocyanates or admixtures containing more than 0.05% chloride ions are not permitted.

C. Chemical Admixtures: Provide admixtures certified by manufacturer to be compatible with other admixtures and that will not contribute water-soluble chloride ions exceeding those permitted in hardened concrete. Certification of requirements and chloride ion content is required from the admixture manufacturer prior to mix design review.

1. Air-entraining Admixture: ASTM C260.

a. Available Products: Subject to compliance with requirements, provide one of the following products:

- 1) Euclid Chemical Company (The); Air Mix.
- 2) BASF/Master Builders, Inc.; Micro-Air.
- 3) Sika Corporation; Sika AER.

2. Water-reducing Admixtures: ASTM C494 Type A.

a. Available Products: Subject to compliance with requirements, provide one of the following products:

- 1) Euclid Chemical Company (The); Eucon WR-75.
- 2) BASF/Master Builders Inc.; Pozzoloth 220N.
- 3) Sika Corporation; Plastocrete 161.

3. Water-reducing, Retarding Admixtures: ASTM C494 Type D.

a. Available Products: Subject to compliance with requirements, provide one of the following products:

- 1) Euclid Chemical Company (The); Eucon Barrier-75.
- 2) BASF/Master Builders Inc.; Pozzoloth 300 R.
- 3) Sika Corporation; Plastiment.

4. High Range Water-Reducing Admixture (HRWR): ASTM C494 type F or G.

a. Available Products: Subject to compliance with requirements, provide one of the following products:

- 1) Euclid Chemical Company (The); Eucon 37.
- 2) BASF/Master Builders Inc.; Rheobuild 1000.
- 3) Sika Corporation; Sikament 300.

b. When more than 30 minutes is required between the addition of admixtures to final placement of the concrete, a combination of water-reducing, set controlling admixtures (ASTM C494, Types A, D and E) may be used.

5. Non-Corrosive, Non-Chloride Accelerator: ASTM C494 Type C or E.

a. Available Products: Subject to compliance with requirements, provide one of the following products:

- 1) Euclid Chemical Company (The); Accelguard 80.
  - 2) BASF/Master Builders Inc.; Pozzutec 20+.
  - 3) Sika Corporation, Plastocrete 161FL.
- b. The admixture manufacturer shall have long-term (more than one year duration) non-corrosive test data on metal deck and reinforcing steel from an independent testing laboratory using an acceptable accelerated corrosion test method such as using electrical potential measures.

## 2.5 CURING AND SEALING MATERIALS

- A. Evaporation Barrier: Waterborne, monomolecular film forming, manufactured for application to fresh concrete.
1. Products: Subject to compliance with requirements, provide one of the following:
    - a. BASF Construction Chemicals - Building Systems; Confilm.
    - b. ChemMasters; SprayFilm.
    - c. Dayton Superior Corporation; AquaFilm J74/J74RTU).
    - d. Euclid Chemical Company (The), an RPM company; Eucobar.
    - e. Lambert Corporation; LAMBCO Skin.
    - f. L&M Construction Chemicals, Inc.; E-CON.
    - g. Meadows, W. R., Inc.; EVAPRE.
    - h. Sika Corporation; SikaFilm.
- B. Absorptive Cover: AASHTO M 182, Class 2, burlap cloth made from jute or kenaf, weighing approximately 9 oz./sq. yd. when dry.
- C. Moisture-Retaining Cover: ASTM C 171, clear or white polyethylene film, 6 mil minimum thickness, or white burlap-polyethylene sheet.
- D. Water: Potable.
- E. Clear, Waterborne, Membrane-Forming Curing Compound: ASTM C 309, Type 1, Class B, dissipating.
1. Products: Subject to compliance with requirements, provide one of the following:
    - a. BASF Construction Chemicals - Building Systems; Kure 200.
    - b. ChemMasters; Safe-Cure Clear.
    - c. Dayton Superior Corporation; Clear Resin Cure J11W.
    - d. Euclid Chemical Company (The), an RPM company; Kurez W VOX; TAMMSCURE WB 30C.
    - e. L&M Construction Chemicals, Inc.; L&M Cure R.
    - f. Meadows, W. R., Inc.; 1100-CLEAR.
- F. Clear, Waterborne, Membrane-Forming Curing and Sealing Compound: ASTM C 1315, Type 1, Class A. (SC-2 – SEALED CONCRETE)
1. Products: Subject to compliance with requirements, provide one of the following:
    - a. BASF Construction Chemicals - Building Systems; Kure 1315.
    - b. ChemMasters; Polyseal WB.
    - c. E Dayton Superior; Cure & Seal 1315 EF.



- d. Euclid Chemical Company (The), an RPM company; Super Diamond Clear VOX; LusterSeal WB 300.
  - e. Meadows, W. R., Inc.; Vocomp-30.
2. VOC Content: Curing and sealing compounds shall have a VOC content of 200 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

## 2.6 VAPOR BARRIERS

- A. Sheet Vapor Barrier: As specified in Division 07 Section "Underslab Vapor Barrier," ASTM E 1745, Class A, 15 mil thickness minimum.

## 2.7 RELATED MATERIALS

- A. Expansion- and Isolation-Joint-Filler Strips: ASTM D 1751, asphalt-saturated cellulosic fiber.
- B. Semirigid Joint Filler: Two-component, semirigid, 100 percent solids, epoxy resin with a Type A shore durometer hardness of 80 per ASTM D 2240.
- C. Bonding Agent: ASTM C 1059/C 1059M, Type II, non-redispersible, acrylic emulsion or styrene butadiene.
- D. Epoxy Bonding Adhesive: ASTM C 881, two-component epoxy resin, capable of humid curing and bonding to damp surfaces, of class suitable for application temperature and of grade to suit requirements.

## 2.8 REPAIR MATERIALS

- A. Repair Underlayment: Cement-based, polymer-modified, self-leveling product that can be applied in thicknesses from 1/8 inch and that can be feathered at edges to match adjacent floor elevations.
  - 1. Cement Binder: ASTM C 150, portland cement or hydraulic or blended hydraulic cement as defined in ASTM C 219.
  - 2. Primer: Product of underlayment manufacturer recommended for substrate, conditions, and application.
  - 3. Aggregate: Well-graded, washed gravel, 1/8 to 1/4 inch or coarse sand as recommended by underlayment manufacturer.
  - 4. Compressive Strength: Not less than 4100 psi at 28 days when tested according to ASTM C 109/C 109M.
- B. Repair Overlayment: Cement-based, polymer-modified, self-leveling product that can be applied in thicknesses from 1/4 inch and that can be filled in over a scarified surface to match adjacent floor elevations.
  - 1. Cement Binder: ASTM C 150, portland cement or hydraulic or blended hydraulic cement as defined in ASTM C 219.
  - 2. Primer: Product of topping manufacturer recommended for substrate, conditions, and application.

3. Aggregate: Well-graded, washed gravel, 1/8 to 1/4 inch or coarse sand as recommended by topping manufacturer.
4. Compressive Strength: Not less than 5000 psi at 28 days when tested according to ASTM C 109/C 109M.

## 2.9 CONCRETE MIXTURES, GENERAL

- A. Prepare design mixtures for each type and strength of concrete, proportioned on the basis of laboratory trial mixture or field test data, or both, according to ACI 301, ACI 318, Chapter 4, and Chapter 19 of the 2013 California Building Code.
- B. Cementitious Materials: Use fly ash, as needed to reduce the total amount of portland cement, which would otherwise be used, by not less than 40 percent. Limit percentage, by weight, of cementitious materials other than portland cement in concrete as follows:
  1. Fly Ash: 25 percent.
- C. Limit water-soluble, chloride-ion content in hardened concrete to the following percentages by weight of cement.
  1. Prestressed concrete: 0.06 percent.
  2. Reinforced concrete exposed to chloride in service: 0.15 percent.
  3. Reinforced concrete that will be dry or protected from moisture in service: 1.00 percent.
  4. Other reinforced concrete: 0.30 percent.
- D. Admixtures: Use admixtures according to manufacturer's written instructions.
  1. Use water-reducing, high-range water-reducing, or plasticizing admixture in concrete, as required, for placement and workability.
  2. Use water-reducing and retarding admixture when required by high temperatures, low humidity, or other adverse placement conditions.
  3. Use water-reducing admixture in pumped concrete, concrete for heavy-use industrial slabs and parking structure slabs, concrete required to be watertight, and concrete with a water-cementitious materials ratio below 0.50.

## 2.10 CONCRETE MIXTURES FOR BUILDING ELEMENTS

- A. Proportion normal-weight concrete mixture as indicated on Drawings for strength, slump, water/cement ratio, and maximum aggregate size.

## 2.11 CONCRETE MIXING

- A. Ready-Mixed Concrete: Measure, batch, mix, and deliver concrete according to ASTM C 94/C 94M, and furnish batch ticket information.
  1. When air temperature is between 85 and 90 deg F, reduce mixing and delivery time from 1-1/2 hours to 75 minutes; when air temperature is above 90 deg F, reduce mixing and delivery time to 60 minutes.

- B. Project-Site Mixing: Project site mixing of structural concrete will not be permitted. Project site mixing of concrete for other purposes may be permitted only when reviewed and approved by the Architect. When allowed, measure, batch, and mix concrete materials and concrete according to ASTM C 94/C 94M and ACI 318. Mix concrete materials in appropriate drum-type batch machine mixer, the capacity of the mixer shall be such that it will handle one or more full sack batches.
  - C. Control of Admixtures:
    - 1. Admixtures shall be charged into the mixer as solutions and shall be measured by means of an approved mechanical dispensing device. The liquid shall be considered a part of the mixing water. Admixtures that cannot be added in solution may be weighed or may be measured by volume if so recommended by the manufacturer.
    - 2. If two or more admixtures are used in the concrete, they shall be added separately to avoid possible interaction that might interfere with the efficiency of either admixture or adversely affect the concrete.
    - 3. Addition of retarding admixtures shall be completed within 1 minute after addition of water to the cement has been completed, or prior to the beginning of the last three-quarters of the required mixing, whichever occurs first.
    - 4. Admixtures shall be used in accordance with the manufacturer's instructions.
  - D. Concrete shall be mixed only in quantities for immediate use. Concrete which has set shall not be retempered, but shall be discarded.
  - E. When concrete arrives at the project with slump below that suitable for placing, as indicated by the specifications, water may be added only if neither the maximum permissible water-cement ratio nor the maximum slump is exceeded. The water shall be incorporated by additional mixing equal to at least half of the total mixing required. An addition of water shall be accompanied by a quantity of cement sufficient to maintain the proper water-cement ratio. Such addition shall be reviewed by the Architect.
- 2.12 CONCRETE FLOOR INTEGRAL COLOR: In areas indicated by the architectural drawings, provide BRICKFORM – COLOR 1080 ADOBE BUFF.
- ICC-1 = ADOBE BUFF on finish legend.

### PART 3 - EXECUTION

#### 3.1 FORMWORK

- A. Design, erect, shore, brace, and maintain formwork, according to ACI 301, to support vertical, lateral, static, and dynamic loads, and construction loads that might be applied, until structure can support such loads.
- B. Construct formwork so concrete members and structures are of size, shape, alignment, elevation, and position indicated, within tolerance limits of ACI 117.
  - 1. Where earth is used for forming sides of footings, increase the width of footings by 1 inch on each side of the footing.

- C. Limit concrete surface irregularities, designated by ACI 347 as abrupt or gradual, as follows:
  - 1. Class A, 1/8 inch for smooth-formed finished surfaces.
  - 2. Class B, 1/4 inch for rough-formed finished surfaces.
- D. Construct forms tight enough to prevent loss of concrete mortar.
- E. Fabricate forms for easy removal without hammering or prying against concrete surfaces. Provide crush or wrecking plates where stripping may damage cast concrete surfaces. Provide top forms for inclined surfaces steeper than 1.5 horizontal to 1 vertical.
  - 1. Install keyways, recesses, and the like, for easy removal.
  - 2. Do not use rust-stained steel form-facing material.
- F. Set edge forms, bulkheads, and intermediate screed strips for slabs to achieve required elevations and slopes in finished concrete surfaces. Provide and secure units to support screed strips; use strike-off templates or compacting-type screeds.
- G. Provide temporary openings for cleanouts and inspection ports where interior area of formwork is inaccessible. Close openings with panels tightly fitted to forms and securely braced to prevent loss of concrete mortar. Locate temporary openings in forms at inconspicuous locations.
- H. Chamfer exterior corners and edges of permanently exposed concrete.
- I. Form openings, chases, offsets, sinkages, keyways, blocking, screeds, and bulkheads required in the Work. Determine sizes and locations from trades providing such items.
- J. Clean forms and adjacent surfaces to receive concrete. Remove chips, wood, sawdust, dirt, and other debris just before placing concrete.
- K. Retighten forms and bracing before placing concrete, as required, to prevent mortar leaks and maintain proper alignment.
- L. Coat contact surfaces of forms with form-release agent, according to manufacturer's written instructions, before placing reinforcement.

### 3.2 EMBEDDED ITEMS

- A. Place and secure anchorage devices and other embedded items required for adjoining work that is attached to or supported by cast-in-place concrete. Use setting drawings, templates, diagrams, instructions, and directions furnished with items to be embedded.
  - 1. Install anchor rods, accurately located, to elevations required and complying with tolerances in Section 7.5 of AISC's "Code of Standard Practice for Steel Buildings and Bridges."
- B. Conduits and Pipes Embedded in Concrete:

1. Pipes, other than conduits for electrical circuits, shall not be embedded in structural concrete unless specifically reviewed and approved by the Architect. Any pipe or conduit may pass through any walls or floor slab by means of a sleeve so located that it does not impair the strength of the structure. Openings larger than 12 inches in any dimension shall be as detailed on the structural plans.
2. Unless otherwise approved, embedded pipes or conduits, other than those merely passing through, shall be not larger in outside dimension than one-third the thickness of the slab, wall, or beam in which they are embedded, nor shall they be spaced closer than three diameters or widths on center and shall have at least 1-1/2 inches concrete cover.
3. Sleeves, pipes, or conduits of aluminum shall not be embedded in structural concrete unless effectively coated or covered to prevent aluminum-concrete reaction or electrolytic action between aluminum and steel.

### 3.3 REMOVING AND REUSING FORMS

- A. General: Formwork for sides of beams, walls, columns, and similar parts of the Work that does not support weight of concrete may be removed after cumulatively curing at not less than 50 deg F for 24 hours after placing concrete. Concrete must be hard enough to not be damaged by form-removal operations and curing and protection operations need to be maintained.
- B. Clean and repair surfaces of forms to be reused in the Work. Split, frayed, delaminated, or otherwise damaged form-facing material will not be acceptable for exposed surfaces. Apply new form-release agent.
- C. When forms are reused, clean surfaces, remove fins and laitance, and tighten to close joints. Align and secure joints to avoid offsets. Do not use patched forms for exposed concrete surfaces unless approved by Architect.

### 3.4 VAPOR BARRIERS

- A. Vapor barriers shall be installed in accordance with the requirements of Division 07 Section "Underslab Vapor Barrier."

### 3.5 STEEL REINFORCEMENT

- A. General: Comply with CRSI's "Manual of Standard Practice" for placing reinforcement.
  1. Coordinate installation of steel reinforcement with installation of vapor barrier specified in Division 072600 "Vapor Barrier"
  2. Do not cut or puncture vapor barrier; if cut or damaged, vapor barrier shall be repaired in accordance with Division 072600 "Vapor Barrier"
- B. Clean reinforcement of loose rust and mill scale, earth, ice, and other foreign materials that would reduce bond to concrete.
- C. Accurately position, support, and secure reinforcement against displacement. Locate and support reinforcement with bar supports to maintain minimum concrete cover. Do not tack weld crossing reinforcing bars.

- D. Set wire ties with ends directed into concrete, not toward exposed concrete surfaces.

### 3.6 JOINTS

- A. General: Construct joints true to line with faces perpendicular to surface plane of concrete.
- B. Construction Joints: Install so strength and appearance of concrete are not impaired, at locations indicated or as approved by Architect.
  - 1. Place joints perpendicular to main reinforcement. Continue reinforcement across construction joints unless otherwise indicated. Do not continue reinforcement through sides of strip placements of floors and slabs.
  - 2. Use a bonding agent at locations where fresh concrete is placed against hardened or partially hardened concrete surfaces.
- C. Contraction Joints in Slabs-on-Grade: Form weakened-plane contraction joints, sectioning concrete into areas as indicated. Construct contraction joints for a depth equal to at least one-fourth of concrete thickness as follows:
  - 1. Grooved Joints: Form contraction joints after initial floating by grooving and finishing each edge of joint to a radius of 1/8 inch. Repeat grooving of contraction joints after applying surface finishes. Eliminate groover tool marks on concrete surfaces.
  - 2. Sawed Joints: Form contraction joints with power saws equipped with shatterproof abrasive or diamond-rimmed blades. Cut 1/8-inch wide joints into concrete when cutting action will not tear, abrade, or otherwise damage surface and before concrete develops random contraction cracks.
- D. Isolation Joints in Slabs-on-Grade: After removing formwork, install joint-filler strips at slab junctions with vertical surfaces, such as column pedestals, foundation walls, grade beams, and other locations, as indicated.
  - 1. Extend joint-filler strips full width and depth of joint, terminating flush with finished concrete surface unless otherwise indicated.
  - 2. Terminate full-width joint-filler strips not less than 1/2 inch or more than 1 inch below finished concrete surface where joint sealants, specified in Division 07 Section "Joint Sealants," are indicated.
  - 3. Install joint-filler strips in lengths as long as practicable. Where more than one length is required, lace or clip sections together.
- E. Doweled Joints: Install dowel bars and support assemblies at joints where indicated. Lubricate or asphalt coat one-half of dowel length to prevent concrete bonding to one side of joint.

### 3.7 CONVEYING

- A. Concrete shall be handled from the mixer to the place of final deposit as rapidly as practicable by methods which will prevent segregation or loss of ingredients and in a manner which will assure that the required quality of the concrete is maintained.

- B. Conveying equipment shall be of a size and design such that detectable setting of concrete shall not occur before adjacent concrete is placed. Conveying equipment shall be cleaned at the end of each operation or work day. Conveying equipment and operations shall conform to the following additional requirements:
  - 1. Truck mixers, agitators and non-agitating units and their manner of operation shall conform to the applicable requirements of ASTM C94.
  - 2. Belt conveyors shall be horizontal or at a slope which will not cause excessive segregation or loss of ingredients. Concrete shall be protected against undue drying or rise in temperature. A suitable device shall be used at the discharge end to prevent apparent segregation. Mortar shall not be allowed to adhere to the return length of the belt. Long runs shall be discharged into a hopper or through a baffle.
- C. Chutes shall be metal or metal-lined and shall have a slope not exceeding 1 vertical to 2 horizontal and not less than 1 vertical to 3 horizontal. Chutes more than 20 feet long and chutes not meeting the slope requirements may be used provided they discharge into a hopper before distribution.
- D. Pumping or pneumatic conveying equipment shall be of suitable kind with adequate pumping capacity. Pneumatic placement shall be controlled so that segregation is not apparent in the discharged concrete. The loss of slump in pumping or pneumatic conveying equipment shall not exceed 2 inches. Concrete shall not be conveyed through pipe made of aluminum or aluminum alloy. When the concrete is placed into final position by means of pumping, the pumping method for placing concrete shall be reviewed and approved by the Architect at least one week prior to placing the concrete.

### 3.8 CONCRETE PLACEMENT

- A. Before placing concrete, verify that installation of formwork, reinforcement, and embedded items is complete and that required inspections have been performed.
- B. Do not add water to concrete during delivery, at Project site, or during placement unless approved by Architect.
- C. Deposit concrete continuously in one layer or in horizontal layers of such thickness that no new concrete will be placed on concrete that has hardened enough to cause seams or planes of weakness. If a section cannot be placed continuously, provide construction joints as indicated. Deposit concrete to avoid segregation.
  - 1. Deposit concrete in horizontal layers of depth to not exceed formwork design pressures and in a manner to avoid inclined construction joints.
  - 2. Consolidate placed concrete with mechanical vibrating equipment according to ACI 301.
  - 3. Do not use vibrators to transport concrete inside forms. Insert and withdraw vibrators vertically at uniformly spaced locations to rapidly penetrate placed layer and at least 6 inches into preceding layer. Do not insert vibrators into lower layers of concrete that have begun to lose plasticity. At each insertion, limit duration of vibration to time necessary to consolidate concrete and complete embedment of reinforcement and other embedded items without causing mixture constituents to segregate.
- D. Deposit and consolidate concrete for floors and slabs in a continuous operation, within limits of construction joints, until placement of a panel or section is complete.

1. Consolidate concrete during placement operations so concrete is thoroughly worked around reinforcement and other embedded items and into corners.
  2. Maintain reinforcement in position on chairs during concrete placement.
  3. Screed slab surfaces with a straightedge and strike off to correct elevations.
  4. Slope surfaces uniformly to drains where required.
  5. Begin initial floating using bull floats or darbies to form a uniform and open-textured surface plane, before excess bleedwater appears on the surface. Do not further disturb slab surfaces before starting finishing operations.
- E. Cold-Weather Placement: Comply with ACI 306.1 and as follows. Protect concrete work from physical damage or reduced strength that could be caused by frost, freezing actions, or low temperatures.
1. When average high and low temperature is expected to fall below 40 deg F for three successive days, maintain delivered concrete mixture temperature within the temperature range required by ACI 301.
  2. Do not use frozen materials or materials containing ice or snow. Do not place concrete on frozen subgrade or on subgrade containing frozen materials.
  3. Do not use calcium chloride, salt, or other materials containing antifreeze agents or chemical accelerators unless otherwise specified and approved in mixture designs.
- F. Hot-Weather Placement: Comply with ACI 305 and as follows:
1. Maintain concrete temperature below 90 deg F at time of placement. Chilled mixing water or chopped ice may be used to control temperature, provided water equivalent of ice is calculated to total amount of mixing water. Using liquid nitrogen to cool concrete is Contractor's option.
  2. Fog-spray forms, steel reinforcement, and subgrade just before placing concrete. Keep subgrade uniformly moist without standing water, soft spots, or dry areas.

### 3.9 FINISHING FORMED SURFACES

- A. Rough-Formed Finish: As-cast concrete texture imparted by form-facing material with tie holes and defects repaired and patched. Remove fins and other projections that exceed specified limits on formed-surface irregularities.
1. Apply to concrete surfaces not permanently exposed to public view.
- B. Smooth-Formed Finish: As-cast concrete texture imparted by form-facing material, arranged in an orderly and symmetrical manner with a minimum of seams. Repair and patch tie holes and defects. Remove fins and other projections that exceed specified limits on formed-surface irregularities.
1. Apply to concrete surfaces permanently exposed to public view, to receive a rubbed finish, or to be covered with a coating or covering material applied directly to concrete.
- C. Rubbed Finish: Apply the following to smooth-formed finished as-cast concrete where indicated:



1. Smooth-Rubbed Finish: Not later than one day after form removal, moisten concrete surfaces and rub with carborundum brick or another abrasive until producing a uniform color and texture. Do not apply cement grout other than that created by the rubbing process.
- D. Related Unformed Surfaces: At tops of walls, horizontal offsets, and similar unformed surfaces adjacent to formed surfaces, strike off smooth and finish with a texture matching adjacent formed surfaces. Continue final surface treatment of formed surfaces uniformly across adjacent unformed surfaces unless otherwise indicated.

### 3.10 FINISHING FLOORS AND SLABS

- A. General: Comply with ACI 302.1R recommendations for screeding, restraightening, and finishing operations for concrete surfaces. Do not wet concrete surfaces.
- B. Slab Finishes: Provide finished slab surfaces as indicated below; confirm and coordinate surface finishes for adhered and fluid applied floor finishes with trades installing/applying respective floor systems required for the project conditions.

<u>Finish Floor Application</u>	<u>Slab Finish Type</u>
1. Surfaces to receive mortar setting beds for tile flooring and similar applications.	Scratch Finish
2. Surfaces to receive thinset tile flooring directly over concrete	Trowel and Fine Broom Finish
3. Surfaces to receive adhered carpet, resilient sheet, or resilient tile flooring	Trowel and Fine Broom Finish
4. Surfaces to receive epoxy or polyurethane fluid applied flooring	Light Broom Finish (Confirm with floor system manufacturer)
5. Surfaces to be exposed and sealed concrete	Troweled Finish
6. Ramped exposed concrete	Medium Broom Finish
7. Surfaces to receive waterproof membranes	Floated Finish

- C. Slab Finish Types: Slab finish types, flatness, and levelness tolerances shall be as indicated below. Where slabs are indicated to be sloped, slope shall be as indicted on the Drawings. Finished slabs shall have a slope not greater than 1/4 inch per one foot unless otherwise indicted on the Drawings.

1. Scratch Finish: While still plastic, texture concrete surface that has been screeded and bull-floated or darbied. Use stiff brushes, brooms, or rakes to produce a profile amplitude of 1/4 inch in one direction.
  - a. Slab surface shall be flat and level within 1/4 inch in 2 feet as determined by using a 2 foot straightedge placed anywhere on the slab in any direction.
2. Float Finish: Consolidate surface with power-driven floats or by hand floating if area is small or inaccessible to power driven floats. Restraighten, cut down high spots, and fill

low spots. Repeat float passes and restraightening until surface is left with a uniform, smooth, granular texture. Apply float finish to surfaces to receive trowel finish and to be covered with fluid-applied or sheet waterproofing.

- a. Slab surface shall be flat and level within 1/4 inch in 10 feet as determined by using a 10 foot straightedge placed anywhere on the slab in any direction.
3. Trowel Finish: After applying float finish, apply first troweling and consolidate concrete by hand or power-driven trowel. Continue troweling passes and restraighten until surface is free of trowel marks and uniform in texture and appearance. Grind smooth any surface defects that would telegraph through applied coatings or floor coverings.
  - a. Slab surface shall be flat and level to within 1/8 inch in 10 feet as determined by using a 10 foot straightedge placed anywhere on the slab in any direction.
4. Trowel and Fine-Broom Finish: After applying a trowel finish and while concrete is still plastic, slightly scarify surface with a fine broom to produce a fine directional finish.
  - a. Comply with flatness and levelness tolerances for trowel-finished floor surfaces.
5. Broom Finish: Immediately after float finishing, slightly roughen surface by brooming with fiber-bristle broom perpendicular to main traffic route and/or ramp surfaces. Coordinate required final finish with Architect before application.
  - a. Comply with flatness and levelness tolerances for float-finished floor surfaces.

### 3.11 MISCELLANEOUS CONCRETE ITEMS

- A. Filling In: Fill in holes and openings left in concrete structures after work of other trades is in place unless otherwise indicated. Mix, place, and cure concrete, as specified, to blend with in-place construction. Provide other miscellaneous concrete filling indicated or required to complete the Work.
- B. Curbs: Provide monolithic finish to interior curbs by stripping forms while concrete is still green and by steel-troweling surfaces to a hard, dense finish with corners, intersections, and terminations slightly rounded.
- C. Equipment Bases and Foundations: Provide machine and equipment bases and foundations as shown on Drawings. Set anchor bolts for machines and equipment at correct elevations, complying with diagrams or templates from manufacturer furnishing machines and equipment.

### 3.12 CONCRETE PROTECTING AND CURING

- A. General: Protect freshly placed concrete from premature drying and excessive cold or hot temperatures. Comply with ACI 306.1 for cold-weather protection and ACI 305 for hot-weather protection during curing.
- B. Evaporation Barrier: Apply evaporation barrier to unformed concrete surfaces if hot, dry, or windy conditions cause moisture loss approaching 0.2 lb/sq. ft. x h before and during finishing operations. Apply according to manufacturer's written instructions after placing, screeding, and bull floating or darbying concrete, but before float finishing.
- C. Formed Surfaces: Cure formed concrete surfaces, including underside of beams, supported slabs, and other similar surfaces. If forms remain during curing period, moist cure after loosening forms. If removing forms before end of curing period, continue curing for the remainder of the curing period.

- D. Unformed Surfaces: Begin curing immediately after finishing concrete. Cure unformed surfaces, including floors and slabs, concrete floor toppings, and other surfaces.
- E. Cure concrete according to ACI 308.1, by one or a combination of the following methods:
  - 1. Moisture Curing: Keep surfaces continuously moist for not less than seven days using a water saturated absorptive cover kept continuously wet. Cover concrete surfaces and edges with 12-inch lap over adjacent absorptive covers.
    - a. This method shall not be used on floor slabs receiving adhered floor systems, fluid applied floor systems, or sealers.
  - 2. Moisture-Retaining-Cover Curing: Cover concrete surfaces with moisture-retaining cover for curing concrete, placed in widest practicable width, with sides and ends lapped at least 12 inches, and sealed by waterproof tape or adhesive. Cure for not less than seven days. Immediately repair any holes or tears during curing period using cover material and waterproof tape.
    - a. Use moisture-retaining covers to cure concrete surfaces to receive penetrating liquid floor treatments.
    - b. Cure concrete surfaces to receive floor coverings with either a moisture-retaining cover or a curing compound that the manufacturer certifies will not interfere with bonding of floor covering used on Project.
  - 3. Curing Compound: Apply uniformly in continuous operation by power spray or roller according to manufacturer's written instructions. Recoat areas subjected to heavy rainfall within three hours after initial application. Maintain continuity of coating and repair damage during curing period.
    - a. Removal: After curing period has elapsed, remove curing compound without damaging concrete surfaces by method recommended by curing compound manufacturer unless manufacturer certifies curing compound will not interfere with bonding of floor covering used on Project.
  - 4. Curing and Sealing Compound: Apply uniformly to floors and slabs indicated in a continuous operation by power spray or roller according to manufacturer's written instructions. Recoat areas subjected to heavy rainfall within three hours after initial application. Repeat process 24 hours later and apply a second coat. Maintain continuity of coating and repair damage during curing period.

### 3.13 LIQUID FLOOR TREATMENTS

- A. Sealing Coat: Uniformly apply a continuous sealing coat of curing and sealing compound to hardened concrete by power spray or roller according to manufacturer's written instructions.

### 3.14 JOINT FILLING

- A. Prepare, clean, and install joint filler according to manufacturer's written instructions.
  - 1. Defer joint filling as long as possible and until concrete has aged at least one month. Do not fill joints until construction traffic has permanently ceased.
- B. Remove dirt, debris, saw cuttings, curing compounds, and sealers from joints; leave contact faces of joint clean and dry.

- C. Install semirigid joint filler full depth in saw-cut joints and at least 2 inches deep in formed joints. Overfill joint and trim joint filler flush with top of joint after hardening.

### 3.15 CONCRETE SURFACE REPAIRS

- A. Defective Concrete: Repair and patch defective areas when approved by Architect. Remove and replace concrete that cannot be repaired and patched to Architect's approval.
- B. Patching Mortar: Mix dry-pack patching mortar, consisting of one part portland cement to two and one-half parts fine aggregate passing a No. 16 sieve, using only enough water for handling and placing.
- C. Repairing Formed Surfaces: Surface defects include color and texture irregularities, cracks, spalls, air bubbles, honeycombs, rock pockets, fins and other projections on the surface, and stains and other discolorations that cannot be removed by cleaning.
  - 1. Immediately after form removal, cut out honeycombs, rock pockets, and voids more than 1/2 inch in any dimension to solid concrete.
    - a. Limit cut depth to 3/4 inch.
    - b. Make edges of cuts perpendicular to concrete surface.
    - c. Perimeters of cut areas shall be square or rectangular in shape with cuts vertical and horizontal.
    - d. Clean, dampen with water, and brush-coat holes and voids with bonding agent. Fill and compact with patching mortar before bonding agent has dried.
    - e. Fill form-tie voids with patching mortar or cone plugs secured in place with bonding agent.
  - 2. Repair defects on surfaces exposed to view by blending white portland cement and standard portland cement so that, when dry, patching mortar will match surrounding color. Patch a test area at inconspicuous locations to verify mixture and color match before proceeding with patching. Compact mortar in place and strike off slightly higher than surrounding surface.
  - 3. Repair defects on concealed formed surfaces that affect concrete's durability and structural performance as determined by Architect.
- D. Repairing Unformed Surfaces: Test unformed surfaces, such as floors and slabs, for finish and verify surface tolerances specified for each surface. Correct low and high areas. Test surfaces sloped to drain for trueness of slope and smoothness; use a sloped template.
  - 1. Repair finished surfaces containing defects. Surface defects include spalls, popouts, honeycombs, rock pockets, crazing and cracks in excess of 0.01 inch wide or that penetrate to reinforcement or completely through unreinforced sections regardless of width, and other objectionable conditions.
  - 2. After concrete has cured at least 14 days, correct high areas by grinding.
  - 3. Correct localized low areas during or immediately after completing surface finishing operations by cutting out low areas and replacing with patching mortar. Finish repaired areas to blend into adjacent concrete.
  - 4. Correct other low areas scheduled to receive floor coverings with a repair underlayment. Prepare, mix, and apply repair underlayment and primer according to manufacturer's written instructions to produce a smooth, uniform, plane, and level surface. Feather edges to match adjacent floor elevations.

5. Correct other low areas scheduled to remain exposed with a repair topping. Cut out low areas to ensure a minimum repair topping depth of 1/4 inch to match adjacent floor elevations. Prepare, mix, and apply repair topping and primer according to manufacturer's written instructions to produce a smooth, uniform, plane, and level surface.
  6. Repair defective areas, except random cracks and single holes 1 inch or less in diameter, by cutting out and replacing with fresh concrete. Remove defective areas with clean, square cuts and expose steel reinforcement with at least a 3/4-inch clearance all around. Dampen concrete surfaces in contact with patching concrete and apply bonding agent. Mix patching concrete of same materials and mixture as original concrete except without coarse aggregate. Place, compact, and finish to blend with adjacent finished concrete. Cure in same manner as adjacent concrete.
  7. Repair random cracks and single holes 1 inch or less in diameter with patching mortar. Groove top of cracks and cut out holes to sound concrete and clean off dust, dirt, and loose particles. Dampen cleaned concrete surfaces and apply bonding agent. Place patching mortar before bonding agent has dried. Compact patching mortar and finish to match adjacent concrete. Keep patched area continuously moist for at least 72 hours.
- E. Perform structural repairs of concrete, subject to Architect's approval, using epoxy adhesive and patching mortar.
- F. Repair materials and installation not specified above may be used, subject to Architect's approval.

### 3.16 FIELD QUALITY CONTROL

- A. Testing and Inspecting Agency: Owner will engage and pay for a qualified testing and inspecting agency to perform field tests and inspections and prepare test reports.
- B. Contractor Responsibilities:
1. Schedule tests and inspections with the Testing Agency sufficiently in advance of operations to allow for the assignment of testing personnel and for the completion of testing and inspecting responsibilities.
  2. Provide access to the work for the Testing Agency.
  3. Furnish any necessary labor to assist the designated testing agency in obtaining and handling samples at the project or other sources of materials.
  4. Provide and maintain for the sole use of the testing agency adequate facilities for safe storage and proper curing of concrete test specimens on the project site for the first 24 hr. as required by ASTM C31.
- C. Testing and Inspections:
1. Testing shall be performed by the designated Testing and Inspection Agency.
  2. Inspections shall be performed by the Testing and Inspection Agency.
  3. Testing and inspections shall be in accordance with the 2013 California Building Code, Section 1704.4 and Table 1704.4, and shall include but not be limited to the following:
    - a. Inspection of steel reinforcement.
    - b. Inspection of headed bolts and studs prior and during concrete placement.
    - c. Verification of use of required design mixture.

- d. Sampling of concrete for strength tests, slump, air content, and temperature of concrete at time of placement.
- e. Inspection of concrete placement, including conveying and depositing.
- f. Inspection of curing procedures and maintenance of curing temperature.
- g. Verification of concrete strength before removal of shores and forms from beams and slabs.
- h. Inspection of formwork.

D. Sampling and Testing of Steel Reinforcement:

1. Samples of reinforcing steel shall be taken by a designated approved testing agency at place of distribution prior to shipment or at project site.
2. Where samples are taken from bundles as delivered from the mill, with the bundles identified as to heat number and provided the mill analyses accompany the report, one tensile test and one bend test shall be made from a specimen from each 10 tons or fraction thereof of each size of reinforcing steel.
  - a. Where positive identification of the heat number cannot be made or where random samples are to be taken, one series of tests shall be made from each 2-1/2 tons or fraction thereof of each size of reinforcing steel.
3. Each sample shall consist of no fewer than two pieces, each 18 inches long, of each size and grade of reinforcing steel.

E. Batch Plant Inspection: The quality and quantity of materials used in transit mixed concrete and in batched aggregates shall be continuously inspected at the location where materials are measured by an approved Testing and Inspection Agency.

1. Waiver of Batch Plant Inspection: Batch plant inspection will not be required under the following conditions:
  - a. The concrete plant complies fully with the requirements of ASTM C94, Sections 8 and 9, and has a current certificate from the National Ready Mixed Concrete Association. The certification shall indicate that the plant has automatic batching and recording capabilities.
  - b. The Testing Agency shall check the first batching at the start of work and furnish mix proportions to the licensed weighmaster.
  - c. Licensed weighmaster shall positively identify materials as to quantity and certify to each load by a ticket.
  - d. Tickets shall be transmitted to the Contractor by cement truck driver with load identified thereon. Do not accept loads without a load ticket identifying the mix; Contractor shall keep a daily record of placements identifying each truck, its load and time of receipt, and approximate location of deposit in the structure and will transmit a copy of the daily record to the Architect.
  - e. At the end of the project, the weighmaster shall furnish an affidavit to the Architect certifying that all concrete furnished conforms in every particular to proportions established by mix designs.
  - f. The Testing Agency shall certify and submit evidence of compliance to the governing agency and obtain governing agency's approval prior for a waiver of batch plant inspection prior to mixing the concrete.

F. Placement Record: A record shall be kept on-site of the time and date of placing the concrete in each portion of the structure. Such record shall be kept until the completion of the structure and shall be open to the inspection of the governing agency.

- G. Concrete Tests: Testing of composite samples of fresh concrete obtained according to ASTM C 172 shall be performed according to the following requirements:
1. Testing Frequency: Obtain one composite sample for each day's pour of each concrete mixture but not less than one sample for each 50 cu. yd. or fraction thereof and one sample for each 2,000 square feet of slab area.
    - a. When frequency of testing will provide fewer than five compressive-strength tests for each concrete mixture, testing shall be conducted from at least five randomly selected batches or from each batch if fewer than five are used.
  2. Slump: ASTM C 143/C 143M; one test at point of placement for each composite sample, but not less than one test for each day's pour of each concrete mixture. Perform additional tests when concrete consistency appears to change.
  3. Air Content: ASTM C 231, pressure method, for normal-weight concrete; one test for each composite sample, but not less than one test for each day's pour of each concrete mixture.
  4. Concrete Temperature: ASTM C 1064/C 1064M; one test hourly when air temperature is 40 deg F and below and when 80 deg F and above, and one test for each composite sample.
  5. Compression Test Specimens: ASTM C 31/C 31M.
    - a. Cast and laboratory cure four standard cylinder specimens for each composite sample.
  6. Compressive-Strength Tests: ASTM C 39/C 39M; test one specimen at 7 days for information and two cured specimens at 28 days for strength acceptance, the fourth specimen shall be held in reserve in case additional testing is necessary.
    - a. A compressive-strength test shall be the average compressive strength from a set of two specimens obtained from same composite sample and tested at age indicated.
  7. Strength of each concrete mixture will be satisfactory if every average of any three consecutive compressive-strength tests equals or exceeds specified compressive strength and no compressive-strength test value falls below specified compressive strength by more than 500 psi.
  8. Test results shall be reported in writing to Architect, concrete manufacturer, and Contractor within 48 hours of testing. Reports of compressive-strength tests shall contain Project identification name and number, date of concrete placement, name of concrete testing and inspecting agency, location of concrete batch in Work, design compressive strength at 28 days, concrete mixture proportions and materials, compressive breaking strength, and type of break for both 7 and 28-day tests.
  9. Nondestructive Testing: Impact hammer, sonoscope, or other nondestructive device may be permitted by Architect but will not be used as sole basis for approval or rejection of concrete.
  10. Additional Tests: Testing and inspecting agency shall make additional tests of concrete when test results indicate that slump, air entrainment, compressive strengths, or other requirements have not been met, as directed by Architect. Testing and inspecting agency may conduct tests to determine adequacy of concrete by cored cylinders complying with ASTM C 42/C 42M or by other methods as directed by Architect.
  11. Additional testing and inspecting will be performed to determine compliance of replaced or additional work with specified requirements.
    - a. The cost of additional testing of replaced work will be paid for by the Owner with the amount being deducted from the Contract Amount by a Change Order.
  12. Correct deficiencies in the Work that test reports and inspections indicate do not comply with the Contract Documents.

3.17 PROTECTION OF SEALED FLOORS

- A. Protect sealed floor surfaces from damage and wear during the remainder of construction period. Use protective methods and materials, including temporary covering, recommended in writing by floor treatment installer.

END OF SECTION 03 3000



**DIVISION 04 – MASONRY**



SECTION 04 2200 - CONCRETE UNIT MASONRY

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Concrete masonry units.
2. Mortar and grout.
3. Steel reinforcing bars.
4. Miscellaneous masonry accessories.

B. Related Requirements:

1. Section 03 3000 "Cast-in-Place Concrete" for footings for masonry walls.
2. Section 07 9200 "Joint Sealants" for sealants for masonry wall control joints.

1.3 DEFINITIONS

A. CMU(s): Concrete masonry unit(s).

B. Reinforced Masonry: Masonry containing reinforcing steel in grouted cells.

1.4 PERFORMANCE REQUIREMENTS

- A. Determine net-area compressive strength (1500 psi) of masonry from average net-area compressive strengths of masonry units and mortar types (unit-strength method) according to Tables 1 and 2 in ACI 530.1/ASCE 6/TMS 602 and Table 2105.2.2.1.2 of the 2013 California Building Code.

1.5 PRECONSTRUCTION TESTING

- A. Preconstruction Testing Service: Owner will engage a qualified independent testing agency to perform preconstruction testing indicated below. Retesting of materials that fail to comply with specified requirements shall be deducted from the contract amount.
  1. Prism Test: For each type of construction required, according to ASTM C 1314.

1.6 PREINSTALLATION MEETINGS

- A. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 01 Sections applicable to project meetings.

1.7 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: For the following:
  - 1. Masonry Units: Show sizes, profiles, coursing, and locations of special shapes.
  - 2. Reinforcing Steel: Detail bending and placement of unit masonry reinforcing bars. Comply with ACI 315, "Details and Detailing of Concrete Reinforcement." Show elevations of reinforced walls.
- C. Samples for Verification: For each type and color of the following:
  - 1. Exposed concrete masonry units.

1.8 INFORMATIONAL SUBMITTALS

- A. Material Certificates: For each type and size of the following:
  - 1. Masonry units.
    - a. Include material test reports substantiating compliance with requirements.
    - b. For masonry units used in structural masonry, include data and calculations establishing average net-area compressive strength of units.
  - 2. Cementitious materials. Include name of manufacturer, brand name, and type.
  - 3. Preblended, dry mortar mixes. Include description of type and proportions of ingredients.
  - 4. Grout mixes. Include description of type and proportions of ingredients.
  - 5. Reinforcing bars.
  - 6. Joint reinforcement.
  - 7. Anchors, ties, and metal accessories.
- B. Mix Designs: For each type of mortar and grout. Include description of type and proportions of ingredients.
  - 1. Include test reports, per ASTM C 780 for mortar mixes required to comply with property specification.
  - 2. Include test reports, per ASTM C 1019 for grout mixes required to comply with compressive strength requirement.
- C. Statement of Compressive Strength of Masonry: For each combination of masonry unit type and mortar type, provide statement of average net-area compressive strength of masonry units, mortar type, and resulting net-area compressive strength of masonry determined according to Tables 1 and 2 in ACI 530.1/ASCE 6/TMS 602.

- D. List of Materials Used in Constructing Mockups: List generic product names together with manufacturers, manufacturers' product names, model numbers, lot numbers, batch numbers, source of supply, and other information as required to identify materials used. Include mix proportions for mortar and grout and source of aggregates.
  - 1. Submittal is for information only. Neither receipt of list nor approval of mockup constitutes approval of deviations from the Contract Documents unless such deviations are specifically brought to the attention of Architect and approved in writing.

#### 1.9 QUALITY ASSURANCE

- A. Testing Agency Qualifications: An independent agency qualified according to ASTM C 1093 for testing indicated, as documented according to ASTM E 548.
- B. Source Limitations for Masonry Units: Obtain exposed masonry units of a uniform texture and color, or a uniform blend within the ranges accepted for these characteristics, through one source from a single manufacturer for each product required.
- C. Source Limitations for Mortar Materials: Obtain mortar ingredients of a uniform quality, including color for exposed masonry, from a single manufacturer for each cementitious component and from one source or producer for each aggregate.
- D. Masonry Standard: Comply with ACI 530.1/ASCE 6/TMS 602 unless modified by requirements in the Contract Documents.
- E. Preconstruction Testing Service: Owner will engage a qualified independent testing agency to perform preconstruction testing indicated below. Payment for these services will be made by Owner. Retesting of materials that fail to meet specified requirements shall be done at Contractor's expense.
  - 1. Concrete Masonry Unit Test: For each type of unit required, per ASTM C 140.
  - 2. Mortar Test (Property Specification): For each mix required, per ASTM C 780.
  - 3. Grout Test (Compressive Strength): For each mix required, per ASTM C 1019.
  - 4. Prism Test: For each type of construction required, per ASTM C 1314.

#### 1.10 DELIVERY, STORAGE, AND HANDLING

- A. Store masonry units on elevated platforms in a dry location. If units are not stored in an enclosed location, cover tops and sides of stacks with waterproof sheeting, securely tied. If units become wet, do not install until they are dry.
- B. Store cementitious materials on elevated platforms, under cover, and in a dry location. Do not use cementitious materials that have become damp.
- C. Store aggregates where grading and other required characteristics can be maintained and contamination avoided.

- D. Deliver preblended, dry mortar mix in moisture-resistant containers designed for lifting and emptying into dispensing silo. Store preblended, dry mortar mix in delivery containers on elevated platforms, under cover, and in a dry location or in a metal dispensing silo with weatherproof cover.
- E. Store masonry accessories, including metal items, to prevent corrosion and accumulation of dirt and oil.

#### 1.11 FIELD CONDITIONS

- A. Protection of Masonry: During construction, cover tops of walls, projections, and sills with waterproof sheeting at end of each day's work. Cover partially completed masonry when construction is not in progress.
  - 1. Extend cover a minimum of 24 inches down both sides and hold cover securely in place.
- B. Do not apply uniform floor or roof loads for at least 12 hours and concentrated loads for at least 3 days after building masonry walls or columns.
- C. Stain Prevention: Prevent grout, mortar, and soil from staining the face of masonry to be left exposed or painted. Immediately remove grout, mortar, and soil that come in contact with such masonry.
  - 1. Protect base of walls from rain-splashed mud and from mortar splatter by spreading coverings on ground and over wall surface.
  - 2. Protect sills, ledges, and projections from mortar droppings.
  - 3. Protect surfaces of window and door frames, as well as similar products with painted and integral finishes, from mortar droppings.
  - 4. Turn scaffold boards near the wall on edge at the end of each day to prevent rain from splashing mortar and dirt onto completed masonry.
- D. Cold-Weather Requirements: Do not use frozen materials or materials mixed or coated with ice or frost. Do not build on frozen substrates. Remove and replace unit masonry damaged by frost or by freezing conditions. Comply with cold-weather construction requirements contained in ACI 530.1/ASCE 6/TMS 602 and Section 2104.3 in the 2013 California Building Code.
  - 1. Cold-Weather Cleaning: Use liquid cleaning methods only when air temperature is 40 deg F and above and will remain so until masonry has dried, but not less than 7 days after completing cleaning.
- E. Hot-Weather Requirements: Comply with hot-weather construction requirements contained in ACI 530.1/ASCE 6/TMS 602.

### PART 2 - PRODUCTS

#### 2.1 UNIT MASONRY, GENERAL

- A. Insulated masonry: Where required on the plans, exterior insulated masonry units shall be 12" Wide Hi-R H units (density = 110pcf or less, Rt = 14.297, U = 0.070). Hi-R H Concrete

masonry units shall be provided by Concrete Blocks Group, LLC. Insulating inserts shall be provided by Concrete block Insulating Systems, Inc.

- B. Non-insulated masonry: Where required on plans, masonry units shall be light weight masonry units (density is 105pcf or less)
- C. Defective Units: Referenced masonry unit standards may allow a certain percentage of units to exceed tolerances and to contain chips, cracks, or other defects exceeding limits stated in the standard. Do not use units where such defects, including dimensions that vary from specified dimensions by more than stated tolerances, will be exposed in the completed Work or will impair the quality of completed masonry.
- D. Fire-Resistance Ratings: Where indicated, provide units that comply with requirements for fire-resistance ratings indicated as determined by testing according to ASTM E 119, by equivalent masonry thickness, or by other means, as acceptable to authorities having jurisdiction.

## 2.2 CONCRETE MASONRY UNITS

- A. Shapes: Provide shapes indicated and as follows: 8x8x16 and 6x8x16.
  - 1. Provide special shapes for lintels, corners, jambs, sashes, movement joints, headers, bonding, and other special conditions.
  - 2. Provide rounded-edged units for interior room outside corners, unless otherwise indicated. This does not apply to exterior building wall(s) outside corners.
- B. Integral Water Repellent: Provide units made with integral water repellent for units exposed to the exterior.
  - 1. Integral Water Repellent: Liquid polymeric, integral water-repellent admixture that does not reduce flexural bond strength. Units made with integral water repellent, when tested according to ASTM E 514 as a wall assembly made with mortar containing integral water-repellent manufacturer's mortar additive, with test period extended to 24 hours, shall show no visible water or leaks on the back of test specimen.
    - a. Products: Subject to compliance with requirements, provide one of the following:
      - 1) ACM Chemistries; RainBloc.
      - 2) BASF Corporation; Construction Systems; MasterPel 240 (Pre-2014: Rheopel Plus) or MasterPel 200HD (Pre-2014: Rheopel 200HD).
      - 3) Grace Construction Products; W.R. Grace & Co. -- Conn.; Dry-Block.
- C. CMUs: ASTM C 90.
  - 1. Unit Compressive Strength: Provide units with minimum average net-area compressive strength of 1900 psi.
  - 2. Weight Classification
    - a. Density = 110 pcf for insulated block
    - b. Density = 105 pcf for non-insulated block
  - 3. Size (Width): Manufactured to the following dimensions:
    - a. 12 x 8 x 16 inch nominal, 11 5/8" wide x 7 5/8" tall x 15 5/8" long actual.

- b. 8 x 8 x 16 inch nominal, 7 5/8" wide x 7 5/8" tall x 15 5/8" long actual.
- c. 6 x 8 x 16 inch nominal, 5 7/8" wide x 7 5/8" tall x 15 5/8" long actual.
- 4. Exposed Faces: Precision face.
- 5. Color: Refer to architectural elevations.
  - a. At interior locations (both sides of wall interior), provide standard gray block for field painting unless otherwise indicated.

## 2.3 MORTAR AND GROUT MATERIALS

- A. Portland Cement: ASTM C 150, Type I or II, except Type III. Provide natural color or white cement as required to produce mortar color indicated.
- B. Mortar Pigments: Natural and synthetic iron oxides and chromium oxides, compounded for use in mortar mixes and complying with ASTM C 979/C 979M. Use only pigments with a record of satisfactory performance in masonry mortar.
  - 1. Use at integrally colored masonry only.
- C. Hydrated Lime: ASTM C 207, Type S.
- D. Portland Cement-Lime Mix: Packaged blend of portland cement complying with ASTM C 150, Type I or Type III, and hydrated lime complying with ASTM C 207, Type S.
- E. Masonry Cement: ASTM C 91/C 91M.
- F. Mortar Cement: ASTM C 1329/C 1329M.
- G. Aggregate for Mortar: ASTM C 144.
  - 1. For mortar that is exposed to view, use washed aggregate consisting of natural sand or crushed stone.
  - 2. For joints less than 1/4 inch thick, use aggregate graded with 100 percent passing the No. 16 sieve.
  - 3. White-Mortar Aggregates: Natural white sand or crushed white stone.
- H. Aggregate for Grout: ASTM C 404.
- I. Water-Repellent Admixture: Liquid water-repellent mortar admixture intended for use with CMUs containing integral water repellent by same manufacturer.
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. ACM Chemistries; RainBloc for Mortar.
    - b. BASF Corporation - Admixture Systems; MasterPel 240MA (Pre-2014: Rheopel Plus Mortar Admixture) or MasterPel 210D (Pre-2014: Rheopel Plus D).
    - c. Grace Construction Products; W.R. Grace & Co. -- Conn.; Dry-Block Mortar Admixture.
- J. Water: Potable.



2.4 REINFORCEMENT

- A. Uncoated Steel Reinforcing Bars: ASTM A 615, Grade 60 and as indicated on the Drawings.

2.5 TIES AND ANCHORS

- A. Anchor Bolts: Steel bolts complying with ASTM A 307, Grade A

2.6 MISCELLANEOUS MASONRY ACCESSORIES

- A. Compressible Filler: Premolded filler strips complying with ASTM D 1056, Grade 2A1; compressible up to 35 percent; of width and thickness indicated; formulated from neoprene, or PVC.
- B. Preformed Control-Joint Gaskets: Made from styrene-butadiene-rubber compound, complying with ASTM D 2000, Designation M2AA-805 and designed to fit standard sash block and to maintain lateral stability in masonry wall; size and configuration as indicated.

2.7 MASONRY CLEANERS

- A. Proprietary Acidic Cleaner: Manufacturer's standard-strength cleaner designed for removing mortar/grout stains, efflorescence, and other new construction stains from new masonry without discoloring or damaging masonry surfaces. Use product expressly approved for intended use by cleaner manufacturer and manufacturer of masonry units being cleaned.
  - 1. Manufacturers: Subject to compliance with requirements, provide one of the following:
    - a. Diedrich Technologies, Inc.
    - b. EaCo Chem, Inc.
    - c. ProSoCo, Inc.
    - d. Approved equivalent.

2.8 MORTAR AND GROUT MIXES

- A. General: Do not use admixtures, including pigments, air-entraining agents, accelerators, retarders, water-repellent agents, antifreeze compounds, or other admixtures, unless otherwise indicated.
  - 1. Do not use calcium chloride in mortar or grout.
  - 2. Limit cementitious materials in mortar to portland cement, mortar cement, and lime.
  - 3. Limit cementitious materials in mortar for exterior and reinforced masonry to portland cement, mortar cement, and lime.
  - 4. Add cold-weather admixture (if used) at same rate for all mortar that will be exposed to view, regardless of weather conditions, to ensure that mortar color is consistent.
- B. Preblended, Dry Mortar Mix: Furnish dry mortar ingredients in form of a preblended mix. Measure quantities by weight to ensure accurate proportions, and thoroughly blend ingredients before delivering to Project site.

- C. Mortar for Unit Masonry: Comply with ASTM C 270, Proportion Specification. Provide the following types of mortar for applications stated unless another type is indicated or needed to provide required compressive strength of masonry. See Structural Drawing.
  - 1. For masonry below grade or in contact with earth, use Type S.
  - 2. For reinforced masonry, use Type S.
  - 3. For exterior, above-grade, load-bearing and non-load-bearing walls and parapet walls; for interior load-bearing walls; for interior non-load-bearing partitions; and for other applications where another type is not indicated, use Type N.
  
- D. Grout for Unit Masonry: Comply with ASTM C 476.
  - 1. Use grout of type indicated or, if not otherwise indicated, of type (fine or coarse) that will comply with Table 1.15.1 in ACI 530.1/ASCE 6/TMS 602 for dimensions of grout spaces and pour height.
  - 2. Provide grout with a slump of 8 to 10 inches as measured according to ASTM C 143/C 143M or with slump as indicated on Drawings.

## 2.9 SOURCE QUALITY CONTROL

- A. Owner will engage a qualified independent testing agency to perform source quality-control testing indicated below:
  - 1. Payment for these services will be made by Owner.
  - 2. Retesting of materials failing to comply with specified requirements shall be done at Contractor's expense.
  
- B. Concrete Masonry Unit Test: For each type of unit furnished, per ASTM C 140.

## 2.10 MISCELLANEOUS MASONRY ACCESSORIES

- A. Compressible Filler: Premolded filler strips complying with ASTM D 1056, Grade 2A1; compressible up to 35 percent; of width and thickness indicated; formulated from neoprene, urethane, or, PVC.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of work.
  - 1. For the record, prepare written report, endorsed by Installer, listing conditions detrimental to performance of work.
  - 2. Verify that foundations are within tolerances specified.

3. Verify that reinforcing dowels are properly placed.
- B. Before installation, examine rough-in and built-in construction for piping systems to verify actual locations of piping connections.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION, GENERAL

- A. Thickness: Build cavity and composite walls and other masonry construction to full thickness shown. Build single-wythe walls to actual widths of masonry units, using units of widths indicated.
- B. Build chases and recesses to accommodate items specified in this and other Sections.
- C. Leave openings for equipment to be installed before completing masonry. After installing equipment, complete masonry to match construction immediately adjacent to opening.
- D. Use full-size units without cutting if possible. If cutting is required to provide a continuous pattern or to fit adjoining construction, cut units with motor-driven saws; provide clean, sharp, unchipped edges. Allow units to dry before laying unless wetting of units is specified. Install cut units with cut surfaces and, where possible, cut edges concealed.
- E. Tolerances: Comply with construction tolerances in ACI 530.1/ASCE 6/TMS 602 and with the following:
  1. For conspicuous vertical lines, such as external corners, door jambs, reveals, and expansion and control joints, do not vary from plumb by more than 1/8 inch in 10 feet, 1/4 inch in 20 feet, or 1/2 inch maximum.
  2. For vertical alignment of exposed head joints, do not vary from plumb by more than 1/4 inch in 10 feet, or 1/2 inch maximum.
  3. For conspicuous horizontal lines, such as lintels, sills, parapets, and reveals, do not vary from level by more than 1/8 inch in 10 feet, 1/4 inch in 20 feet, or 1/2 inch maximum.
  4. For exposed head joints, do not vary from thickness indicated by more than plus or minus 1/8 inch. Do not vary from adjacent bed-joint and head-joint thicknesses by more than 1/8 inch.
  5. For faces of adjacent exposed masonry units, do not vary from flush alignment by more than 1/16 inch except due to warpage of masonry units within tolerances specified for warpage of units.
  6. For exposed bed joints and head joints of stacked bond, do not vary from a straight line by more than 1/16 inch from one masonry unit to the next.

### 3.3 LAYING MASONRY WALLS

- A. Lay out walls in advance for accurate spacing of surface bond patterns with uniform joint thicknesses and for accurate location of openings, movement-type joints, returns, and offsets. Avoid using less-than-half-size units, particularly at corners, jambs, and, where possible, at other locations.

- B. Bond Pattern: Unless otherwise indicated, lay exposed masonry in running bond; do not use units with less than nominal 4-inch horizontal face dimensions at corners or jambs.
- C. Stopping and Resuming Work: Stop work by racking back units in each course from those in course below; do not tooth. When resuming work, clean masonry surfaces that are to receive mortar, remove loose masonry units and mortar.
- D. Built-in Work: As construction progresses, build in items specified in this and other Sections. Fill in solidly with masonry around built-in items.
- E. Fill space between steel frames and masonry solidly with mortar unless otherwise indicated.

### 3.4 MORTAR BEDDING AND JOINTING

- A. Lay concrete masonry units as follows:
  - 1. With face shells fully bedded in mortar and with head joints of depth equal to bed joints.
  - 2. With webs fully bedded in mortar in all courses of piers, columns, and pilasters.
  - 3. With webs fully bedded in mortar in grouted masonry, including starting course on footings.
  - 4. With entire units, including areas under cells, fully bedded in mortar at starting course on footings where cells are not grouted.
- B. Tool exposed joints slightly concave when thumbprint hard, using a jointer larger than joint thickness, unless otherwise indicated.
  - 1. Tool exterior joints with a horizontal rake.
- C. Cut joints flush for masonry walls to receive plaster or other direct-applied finishes (other than paint), unless otherwise indicated.

### 3.5 CONTROL AND EXPANSION JOINTS

- A. General: Install control and expansion joint materials in unit masonry as masonry progresses. Do not allow materials to span control and expansion joints without provision to allow for in-plane wall or partition movement.
  - 1. Locate joints as indicated on Drawings.
- B. Form control joints in concrete masonry using one of the following methods:
  - 1. Fit bond-breaker strips into hollow contour in ends of concrete masonry units on one side of control joint. Fill resultant core with grout and rake out joints in exposed faces for application of sealant.
  - 2. Install preformed control-joint gaskets designed to fit standard sash block.
  - 3. Install interlocking units designed for control joints. Install bond-breaker strips at joint. Keep head joints free and clear of mortar or rake out joint for application of sealant.
  - 4. Install temporary foam-plastic filler in head joints and remove filler when unit masonry is complete for application of sealant.

3.6 REINFORCED UNIT MASONRY INSTALLATION

- A. Temporary Formwork and Shores: Construct formwork and shores as needed to support reinforced masonry elements during construction.
  - 1. Construct formwork to provide shape, line, and dimensions of completed masonry as indicated. Make forms sufficiently tight to prevent leakage of mortar and grout. Brace, tie, and support forms to maintain position and shape during construction and curing of reinforced masonry.
  - 2. Do not remove forms and shores until reinforced masonry members have hardened sufficiently to carry their own weight and other temporary loads that may be placed on them during construction.
- B. Placing Reinforcement: Comply with requirements in ACI 530.1/ASCE 6/TMS 602, Section 2104.5 in the 2013 California Building Code.
- C. Grouting: Do not place grout until entire height of masonry to be grouted has attained enough strength to resist grout pressure.
  - 1. Comply with requirements in ACI 530.1/ASCE 6/TMS 602, Section 2104.6 in the 2013 California Building Code for cleanouts and for grout placement, including minimum grout space and maximum pour height.
  - 2. Limit height of vertical grout pours to not more than 60 inches.

3.7 FIELD QUALITY CONTROL

- A. Testing and Inspecting: Owner will engage and incur the expense for a qualified independent testing and inspecting agency to perform inspections and prepare reports. Allow inspectors access to scaffolding and work areas, as needed to perform inspections.
  - 1. The expense for retesting of materials that fail to comply with specified requirements shall be deducted from the contract amount.
- B. Inspections:
  - 1. Begin masonry construction only after inspectors have verified proportions of site-prepared mortar.
  - 2. Place grout only after inspectors have verified compliance of grout spaces and of grades, sizes, and locations of reinforcement.
  - 3. Place grout only after inspectors have verified proportions of site-prepared grout.
- C. Testing Frequency: One set of tests for each 5000 sq. ft. of wall area or portion thereof.
- D. Concrete Masonry Unit Test: For each type of unit provided, per ASTM C 140.
- E. Mortar Test (Property Specification): For each mix provided, per ASTM C 780. Test mortar for mortar air content and compressive strength.
- F. Grout Test (Compressive Strength): For each mix provided, per ASTM C 1019.

- G. Prism Test: For each type of construction provided, per ASTM C 1314.

### 3.8 REPAIRING, POINTING, AND CLEANING

- A. Remove and replace masonry units that are loose, chipped, broken, stained, or otherwise damaged or that do not match adjoining units. Install new units to match adjoining units; install in fresh mortar, pointed to eliminate evidence of replacement.
- B. Pointing: During the tooling of joints, enlarge voids and holes, except weep holes, and completely fill with mortar. Point up joints, including corners, openings, and adjacent construction, to provide a neat, uniform appearance. Prepare joints for sealant application, where indicated.
- C. In-Progress Cleaning: Clean unit masonry as work progresses by dry brushing to remove mortar fins and smears before tooling joints.
- D. Final Cleaning: After mortar is thoroughly set and cured, clean exposed masonry as follows:
  - 1. Remove large mortar particles by hand with wooden paddles and nonmetallic scrape hoes or chisels.
  - 2. Test cleaning methods on sample wall panel; leave one-half of panel uncleaned for comparison purposes. Obtain Architect's approval of sample cleaning before proceeding with cleaning of masonry.
  - 3. Protect adjacent stone and nonmasonry surfaces from contact with cleaner by covering them with liquid strippable masking agent or polyethylene film and waterproof masking tape.
  - 4. Wet wall surfaces with water before applying cleaners; remove cleaners promptly by rinsing surfaces thoroughly with clear water.
  - 5. Clean masonry with a proprietary acidic cleaner applied according to manufacturer's written instructions.
  - 6. Clean concrete masonry by cleaning method indicated in NCMA TEK 8-2A applicable to type of stain on exposed surfaces.

### 3.9 MASONRY WASTE DISPOSAL

- A. Salvageable Materials: Unless otherwise indicated, excess masonry materials are Contractor's property. At completion of unit masonry work, remove from Project site.

END OF SECTION 04 2200

**DIVISION 05 – METALS**





## SECTION 05 1200 - STRUCTURAL STEEL FRAMING

### PART 1 - GENERAL

#### 1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

#### 1.2 SUMMARY

- A. Section Includes:

- 1. Structural steel.
- 2. Grout.

- B. Related Sections:

- 1. Division 055000 Section "Metal Fabrications" for miscellaneous steel fabrications and other metal items not defined as structural steel.

#### 1.3 REFERENCED CODES AND STANDARDS

- A. Comply with pertinent provisions of the following codes and standards:

- 1. California Code of Regulations, Title 24, Part 2, California Building Code, 2013 Edition.
- 2. American Institute of Steel Construction (AISC) Publications:
  - a. Code of Standard Practice for Steel Buildings and Bridges, 2010 (AISC 303-10).
  - b. Quality Criteria and Inspection Standards, latest Edition.
  - c. Manual of Steel Construction, 14<sup>th</sup> Edition (2011).
  - d. Specification for Structural Steel Buildings, June 22 (AISC 360-10).
  - e. Seismic Provisions for Structural Steel Buildings including Supplement No. 1, (AISC 341-10).
- 3. American Welding Society (AWS):
  - a. D1.1 Structural Welding Code - Steel.
  - b. D1.8 Structural Welding Code – Seismic
- 4. Steel Structures Painting Council (SSPC):
  - a. Steel Structures Painting Manual, Vol. 2, Systems and Specifications, latest edition.
- 5. Research Council on Structural Connections of the Engineering Foundation (RCSC):
  - a. CRD-C621 Non-Shrink Grouts.

- b. Specification for structural joints using ASTM A325 or A490 Bolts, June 30, 2004.

#### 1.4 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: Show fabrication of structural-steel components.
  - 1. Include details of cuts, connections, splices, camber, holes, and other pertinent data.
  - 2. Include embedment drawings.
  - 3. Indicate welds by standard AWS symbols, distinguishing between shop and field welds, and show size, length, and type of each weld. Show backing bars that are to be removed and supplemental fillet welds where backing bars are to remain.
  - 4. Indicate type, size, and length of bolts, distinguishing between shop and field bolts. Identify pretensioned and slip-critical high-strength bolted connections.
- C. Qualification Data: For fabricator and installer.
- D. Welding certificates.
- E. Paint Compatibility Certificates: From manufacturers of topcoats applied over shop primers, certifying that shop primers are compatible with topcoats.
- F. Certified mill test reports for structural steel, including chemical and physical properties.
- G. Source quality-control reports.
- H. Affidavit signed by the fabricator stating the structural steel furnished meets the requirements of the grade specified.

#### 1.5 QUALITY ASSURANCE

- A. Fabricator Qualifications: A qualified fabricator who employs adequate numbers of skilled workers who are thoroughly trained and experienced in the necessary crafts and who are completely familiar with the specified requirements and the methods needed for proper performance of the work of this Section. The Fabricator shall have completed a project of similar size and scope, and shall have adequate facilities, personnel, and equipment to meet production and quality requirements to maintain proper job progress. Certification by the AISC Quality Certification Program will provide satisfactory evidence of compliance.
- B. Installer Qualifications: A qualified installer who employs adequate numbers of skilled workers who are thoroughly trained and experienced in the necessary crafts and who are completely familiar with the specified requirements and the methods needed for proper performance of the work of this Section. Certification by the AISC Quality Certification Program will provide satisfactory evidence of compliance.
- C. Contractor Qualifications: The Contractor shall have completed a project of similar scope and shall have adequate facilities, personnel, and equipment to meet production and quality

requirements to maintain proper job progress. Certification by the AISC Quality Certification Program will provide satisfactory evidence of compliance.

- D. Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code - Steel" and AWS D1.8/D1.8M, "Structural Welding Code – Seismic Supplement."
- E. Identification of Structural Steel: The fabricator shall maintain the identity of the material and shall maintain suitable procedures and records attesting that the specified grade has been furnished, in compliance with AISC 360 and 2013 CBC Section 2203.1

## 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Store materials to permit easy access for inspection and identification. Keep steel members off ground and spaced by using pallets, dunnage, or other supports and spacers. Protect steel members and packaged materials from corrosion and deterioration.
  - 1. Do not store materials on structure in a manner that might cause distortion, damage, or overload to members or supporting structures. Repair or replace damaged materials or structures as directed.
- B. Store fasteners in a protected place in sealed containers with manufacturer's labels intact.
  - 1. Fasteners may be repackaged provided Owner's testing and inspecting agency observes repackaging and seals containers.
  - 2. Clean and relubricate bolts and nuts that become dry or rusty before use.
  - 3. Comply with manufacturers' written recommendations for cleaning and lubricating ASTM F 1852 fasteners and for retesting fasteners after lubrication.

## 1.7 COORDINATION

- A. Coordinate selection of shop primers with topcoats to be applied over them. Comply with paint and coating manufacturers' recommendations to ensure that shop primers and topcoats are compatible with one another.
- B. Coordinate installation of anchorage items to be embedded in or attached to other construction without delaying the Work. Provide setting diagrams, sheet metal templates, instructions, and directions for installation.

## PART 2 - PRODUCTS

### 2.1 STRUCTURAL-STEEL MATERIALS

- A. W-Shapes: ASTM A 992.

1. For shapes that are part of the lateral force resisting system with flange thickness exceeding 1-1/2 inches and other shapes with flange thickness exceeding 2 inches, conform to the Supplementary Requirements of ASTM A6.
    - a. S30, Charpy V-Notch Impact Test for structural shapes: Alternate core location. Test to minimum average value of toughness of 20 ft-lb at 70°F.
  - B. Plate, Bar, Channels, and Angles: ASTM A 36 (A572 when specified).
    1. For plate 2 inches and thicker, conform to the Supplementary Requirements of ASTM A6.
      - a. S5, Charpy V-Notch Impact Test. Test to minimum average value of toughness of 20 ft-lb at 70°F.
  - C. Cold-Formed Hollow Structural Sections: ASTM A 500, Grade B, structural tubing.
  - D. Steel Pipe: ASTM A 53/A 53M, Type E or S, Grade B.
    1. Weight Class: Standard unless otherwise indicated on Drawings.
    2. Finish: Black except where indicated to be galvanized.
  - E. Welding Electrodes: Comply with AWS requirements, electrodes shall be compatible with the base material being welded. For welds designated as demand critical as part of the lateral force resisting system, filler metal shall have Charpy V-Notch rating per AISC 341. For filler metals used in combination with filler metals of different processes, provide certification of Charpy V-Notch compatibility per AISC 341 and AWS D1.8.
    1. Shielded Metal Arc Welding: AWS A5.1, E70XX.
    2. Submerged Arc Welding: AWS A5.17, E7X.
    3. Shelf-Shielded flux core - NR 233.
- 2.2 BOLTS, CONNECTORS, AND ANCHORS
- A. General: Provide hot dip zinc coated fasteners for exterior locations.
  - B. Bolts and Nuts:
    1. General Use: Regular hexagon head type, ASTM A307, Grade A.
    2. High Strength: Where high strength bolting is noted on drawings, bolts and nuts shall conform to following:
      - a. Bolts: ASTM A325, Type 1 or 2.
      - b. Nuts: ASTM C563.
  - C. Anchor Rods, Anchor Bolts, and Nuts:
    1. General Use: ASTM F1554, Grade 36 (36ksi).
    2. High Strength: ASTM F1554, Grade 55 (55ksi) with Supplementary Requirement No. 1 or Grade 105 (105ksi) where specified.
    3. Provide color coding per ASTM F1554 at each exposed end of anchor rods.

- D. Washers: Washers shall be suitable for use intended and as follows:
1. Circular washers shall be flat and smooth and conform to the requirements of ANSI B18.22.1, Type A.
  2. Washers for high strength bolts shall conform to ASTM F436.
  3. Plate Washers shall conform to the requirements of ASTM A36
  4. Beveled washers for American Standard beams and channels shall be square or rectangular, shall taper in thickness and shall be smooth.
  5. Lock washers shall conform to FF-W-84.
- E. Welded Studs, Connectors, and Anchors: ASTM A 108, Grades 1015 through 1020, AWS D1.1.
1. Shear Connectors: Nelson type S3L shear connector studs.
  2. Deformed bar anchors: Nelson D2L deformed bar anchors.

### 2.3 PRIMER

- A. Primer: Fabricator's standard lead free, nonasphaltic, rust-inhibiting primer complying with MPI#79 and compatible with topcoat.
- B. Galvanizing Repair Paint: ASTM A 780.

### 2.4 GROUT

- A. Nonmetallic, Shrinkage-Resistant Grout: ASTM C 1107, factory-packaged, nonmetallic aggregate grout, noncorrosive and nonstaining, mixed with water to consistency suitable for application and a 30-minute working time, and having the following characteristics:
1. Be capable of producing a flowable grouting material having no drying shrinkage or settlement at any age.
  2. Compressive strength of grout (2 inch cubes) shall be not less than 5,000 psi at age seven days and 7,500 psi at age 28 days.
  3. Conform to Corps of Engineers CRD-C621.
- B. Dry Pack Grout: 2 parts sand to 1 part cement.

### 2.5 FABRICATION

- A. Structural Steel: Fabricate and assemble in shop to greatest extent possible. Fabricate according to AISC 303 "Code of Standard Practice for Steel Buildings and Bridges," AISC 360 "Specification for Structural Steel Buildings," and AISC 341 "Seismic Provisions for Structural Steel Buildings"
1. Camber structural-steel members where indicated.
    - a. Camber horizontal members in accordance with AISC 360 Spec. Section M2. Do not use purely mechanical means to reverse over cambered beams.

2. Fabricate beams with rolling camber up.
  3. Identify high-strength structural steel according to ASTM A 6/A 6M and maintain markings until structural steel has been erected.
  4. Mark and match-mark materials for field assembly.
  5. Complete structural-steel assemblies, including welding of units, before starting shop-priming operations.
- B. Thermal Cutting: Perform thermal cutting by machine to greatest extent possible.
1. Plane thermally cut edges to be welded to comply with requirements in AWS D1.1/D1.1M.
  2. Thermal cutting will be permitted only with the specific approval of the Architect.
  3. Stresses shall not be transmitted through thermally cut surfaces unless such surfaces are cut by a mechanically guided torch.
  4. The radius of re-entrant flame cut fillets shall be as large as possible, but never less than one-half inch.
  5. All Thermal cutting shall be smooth and regular in contour per AWS.
  6. The net area of thermally cut members shall be determined by deducting one-eighth inch from the cut edges not made by a mechanically guided torch.
- C. Holes: Provide holes required for securing other work to structural steel and for other work to pass through steel framing members.
1. Holes: Cut holes perpendicular to steel surfaces by cutting, drilling, or punching holes, do not thermally cut bolt holes or enlarge holes by burning.
  2. Weld threaded nuts to framing and other specialty items indicated to receive other work.
  3. Remove outside burrs resulting from drilling or reaming operations with a tool making a 1/16 inch radius.
  4. Make bolt holes 1/16 inch oversize typical. Anchor bolt holes in column base plates shall be oversized per drawings..
- D. Finishing: Accurately finish ends of columns and other members transmitting bearing loads.
- E. Welded Construction:
1. The location and type of all welds shall be as shown on the drawings. No weld splices shall be made except as shown.
  2. All welds shall be made by the electric shielded arc or the submerged-arc methods. The welding sequence and technique of welding shall be carefully controlled to minimize locked-up stresses and distortion.
  3. Visible welded joints shall be considered "finished" welds and shall be carefully executed to preclude the necessity of grinding or otherwise finishing. However, when the appearance of the weld is unacceptable, in the opinion of the Architect, grinding shall be of the highest standard for both field and shop practice.
- F. Cleaning: Clean and prepare steel surfaces that are to remain unpainted as follows:
1. Remove oil, grease, and similar contaminants in accordance with SSPC-SP-1.
  2. Clean off heavy rust and loose mill scale in accordance with SSPC-SP-2 or SSPC-SP-3.

- G. Welded Threaded Studs, Shear Connectors, and Concrete Anchors: Prepare steel surfaces and automatically end weld studs and concrete anchors in accordance with AWS D1.1/D1.1M and the manufacturer's recommendations in such a manner as to provide complete fusion between the end of the stud and the plate. There should be no porosity or evidence of lack of fusion between the welded end of the stud and the plate. The stud shall decrease in length during welding approximately 1/8 inch for studs up to 5/8 inch in diameter, and approximately 3/16" in length for studs over 5/8 inch diameter.

## 2.6 SHOP CONNECTIONS

- A. Weld Connections: Comply with AWS D1.1/D1.1M for tolerances, appearances, welding procedure specifications, weld quality, and methods used in correcting welding work. In addition, comply with AWS D1.8/D1.8M for "High Seismic Applications" as defined in AISC 360 where applicable.
1. Assemble and weld built-up sections by methods that will maintain true alignment of axes without exceeding tolerances in AISC 303 for mill material.

## 2.7 SHOP PRIMING

- A. Shop prime steel surfaces except the following:
1. Surfaces embedded in concrete or mortar. Extend priming of partially embedded members to a depth of 2 inches.
  2. Surfaces to be field welded.
  3. Surfaces to be high-strength bolted with slip-critical connections.
  4. Surfaces to receive sprayed fire-resistive materials (applied fireproofing).
  5. Galvanized surfaces.
- B. Surface Preparation: Clean surfaces to be painted. Remove loose rust and mill scale and spatter, slag, or flux deposits. Prepare surfaces according to the following specifications and standards:
1. Remove oil, grease, and similar contaminants in accordance with SSPC-SP-1.
  2. Clean off heavy rust and loose mill scale in accordance with SSPC-SP-2 "Hand Tool Cleaning," or SSPC-SP-3 "Power Tool Cleaning."
- C. Priming: Immediately after surface preparation, apply primer according to manufacturer's written instructions and at rate recommended by SSPC to provide a minimum dry film thickness of 1.5 mils. Use priming methods that result in full coverage of joints, corners, edges, and exposed surfaces.
1. Stripe paint corners, crevices, bolts, welds, and sharp edges.
  2. Apply two coats of shop paint to surfaces that are inaccessible after assembly or erection. Change color of second coat to distinguish it from first.

2.8 GALVANIZING

- A. Hot-Dip Galvanized Finish: Apply zinc coating by the hot-dip process to structural steel according to ASTM A 123/A 123M.
  - 1. Fill vent and drain holes that will be exposed in the finished Work unless they will function as weep holes, by plugging with zinc solder and filing off smooth.
  - 2. Galvanize structural steel framing items located in exterior walls and where indicated on drawings.

2.9 SOURCE QUALITY CONTROL

- A. Waiver of Source Quality Control: Source quality control testing shall not be required when fabricator participates in the AISC Quality Certification Program and is designated an AISC-Certified Plant.
- B. Testing Agency: Owner will engage an independent testing and inspecting agency to perform shop tests and inspections and prepare test reports.
  - 1. Provide testing agency with access to places where structural-steel work is being fabricated or produced to perform tests and inspections.
  - 2. Testing and inspection agency shall be acceptable to the Architect.
- C. The Architect shall have the right to order the testing of any materials used in the steel construction to determine if they are of the quality specified.
- D. Testing and Inspection Services: The following tests and inspections shall be performed by the designated laboratory.
  - 1. Steel Testing:
    - a. All steel used for structural purposes shall be identified as required by 2013 CBC Section 2203.1 Manufacturer's mill analyses and test reports are acceptable for properly identified steel, but the enforcement agency may require additional testing to determine the quality of the steel if there is any doubt as to its acceptability. Any steel not properly identified shall be tested to meet the minimum chemical and mechanical requirements of the ASTM standard appropriate for the steel specified for the structure.
    - b. Fabrication shall not commence until steel members designated on the Structural Testing and Inspection Schedule have been tested. Tests shall be made by an independent testing laboratory approved by the Architect. Reports certifying that the materials and workmanship conform to the contract documents shall be submitted to the Architect.
  - 2. Inspection of Welding: Shop welding operations including the installation of automatic end-welded stud shear connectors shall be inspected by a certified Welding Inspector meeting the requirements of AWS QC1. The Fabricator shall schedule their operations to provide a minimum of 24 hours notice to the welding inspector so that all welding operations may be inspected.



- a. The Welding Inspector shall make a systematic record of all welds; recording shall include the following:
  - 1) Names and identification marks of welders.
  - 2) List of defective welds.
  - 3) Manner of correction of defects.
- b. The Welding Inspector shall check the material, equipment, procedure, welds, and the ability of each welder.
- c. Acceptance criteria shall be based on statically loaded connections. Upon detection of a rejectable weld, the inspector shall notify the Contractor, and observe removal of defects and repairs.
- d. The welding inspector shall tag or stamp accepted weldments with the inspector's identification stamp.
- e. A report stating that the welding they are required to inspect, is proper and has been done in conformity with approved drawings and specifications shall be furnished to the Architect.
- f. Welding inspections, testing and frequency shall conform to AWS D1.1, AWS D1.8 and related AISC documents. The Welding Inspector shall use all means necessary to determine the quality of the welds. However, the following tests and inspections shall be performed as a minimum:
  - 1) Visual Inspection of Welding:
    - a) Observe multi-pass and full penetration welds continuously (i.e. the welding inspector shall be present at all times).
    - b) Observe single pass fillet welds periodically. The inspector shall check the qualifications of the welders at the start of the work and then make final inspection of all welds for compliance prior to completion of welding.
    - c) After the welding is completed, Contractor shall hand or power nylon brush welds, and thoroughly clean them before inspection.
    - d) Inspect welds with magnifiers under strong, adequate light for surface cracking, porosity, and slag inclusions; excessive roughness; unfilled craters; gas pockets; undercuts; overlaps; size; and insufficient throat and concavity.
    - e) Inspect the preparation of groove welds for adequate throat opening and for snug positioning of back-up bars.
    - f) Check the type and size of electrodes to be used for the various joints and positions. Check the storage facilities to see if they are adequate to keep the electrodes dry.
    - g) Verify the use of proper pre-heat and interpass temperatures.
    - h) Observe the technique of each welder periodically with the use of a welding inspection shield.
  - 2) Nondestructive Testing of Welding:
    - a) Welds shall be non-destructive tested by one of the following methods in accordance with AWS D1.1 and AWS D1.8 at testing agency's option or as required by AWS or AISC at the frequency noted below:

<u>Test Method</u>	<u>Frequency</u>
Liquid Dye Penetrant Testing ASTM E165	When requested by Architect.
Magnetic Particle Testing ASTM E709	10% of all fillet welds and 100% of all full penetration welds on members thinner than 5/16".
Ultrasonic Testing ASTM E164	100% of all full penetration welds on members thicker than 5/16"
Radiographic Testing ASTM E94	When requested by Architect or as substitute for magnetic particles testing or ultrasonic testing.

- b) Reduced Frequency of Testing: Initially, all welds requiring 100% testing shall be tested at the rate of 100% in order to establish the qualifications of each individual welder. If the reject rate is demonstrated to be less than 5% of the welds tested for each welder, then the frequency of testing for that welder may be reduced to 25%. If the reject rate increases to 5% or more, 100% testing shall be re-established until the rate is reduced to less than 5%. The percentage of rejects shall be calculated for each welder independently. A sample of at least 40 completed welds shall be made for such reduction evaluation. Reject rate is defined as the number of welds containing rejectable defects divided by the number of welds completed. For evaluating the reject rate of continuous welds over 3 feet in length, each 12 linear inch increment of welds, one inch or less in thickness, shall be considered one weld. For evaluating the reject rate of continuous welds greater than 2 inch thickness, each 6 linear inches shall be considered one weld.
  - g. Correction of Defective Welds: Weld areas containing defects exceeding the standards of acceptance in AWS D1.1 and AWS D1.8 shall be corrected in accordance with AWS D1.1, Section 3.7 and AWS D1.8. Additional testing of the repaired areas shall be required.
3. Welded Threaded Studs, Concrete Anchors, and Shear Connector Studs: Test and inspect installation in accordance with AWS D1.1. Random sample and test from stock furnished to each project. Tests shall meet the requirements of ASTM A108.
- a. Bend tests will be performed if visual inspections reveal either a less-than-continuous 360-degree flash or welding repairs to any shear connector.
  - b. Tests will be conducted on additional shear connectors if weld fracture occurs on shear connectors already tested, according to requirements in AWS D1.1/D1.1M.
4. Testing High Strength Bolts, Nuts and Washers: Bolted Connections: Shop-bolted connections will be tested and inspected according to RCSC's "Specification for Structural Joints Using ASTM A 325 or A 490 Bolts."

- a. Materials: If the manufacturer's certification is not available, sample and test bolts, nuts and washers in accordance with ASTM A325 or A490, shipping lot method.
- b. Installation:
  - 1) Inspect slip critical connections and connections subject to direct tension in accordance with RCSC Specification for Structural Joints Using ASTM A325 or A490 Bolts.
  - 2) Tests shall be performed by an approved testing laboratory specifically approved for that purpose.
  - 3) The inspector shall check the materials, equipment, details of construction and installation procedure.
  - 4) The inspector shall furnish the Architect with a report that the work has been completed in every material respect in compliance with the approved drawings and specifications.
5. Correct deficiencies in Work that test reports and inspections indicate does not comply with the Contract Documents.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Verify, with steel Erector present, elevations of concrete and masonry-bearing surfaces and locations of anchor rods, bearing plates, and other embedments for compliance with requirements.
  1. Prepare a certified survey of bearing surfaces, anchor rods, bearing plates, and other embedments showing dimensions, locations, angles, and elevations.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 PREPARATION

- A. Provide temporary shores, guys, braces, and other supports during erection to keep structural steel secure, plumb, and in alignment against temporary construction loads and loads equal in intensity to design loads. Remove temporary supports when permanent structural steel, connections, and bracing are in place unless otherwise indicated.

#### 3.3 ERECTION

- A. Set structural steel accurately in locations and to elevations indicated and according to AISC 303 and AISC 360.
- B. Erect steel in accordance with the AISC Specification Section M4 and AISC Code Section 7 Except as modified herein.

1. Where parts cannot be assembled or fitted properly as a result of errors in fabrication or of deformation due to handling or transportation, report such condition immediately to the Architect and obtain approval for the methods of correction before proceeding with making any corrections.
  2. Do not heat heat-treated parts for straightening.
  3. Drain steelwork properly; fill pockets in structures exposed to the weather with an approved waterproof material.
  4. When calibrated wrenches are used for tightening bolts, calibrate them at least once each working day using not less than three typical bolts of each diameter.
- C. All structural steel framing shall be erected by experienced riggers and shall be carefully planned and laid out so that minimum cutting will be required. The work shall be erected plumb, square, and true to a line and level and in precise position as indicated. Temporary bracing, shoring and guys shall be introduced wherever necessary to provide for loads and stresses to which the structure may be subjected. Temporary bracing shall be left in place as long as may be required for safeguarding all parts of the work. As the erection progresses, the work shall be securely bolted up or welded, as required by the drawings to take care of all dead load, lateral forces and erection stresses.
- D. Provide anchor bolts and other connections required for securing structural steel to foundations and other in-place work. Furnish templates and other devices as necessary for setting bolts to accurate locations. Tighten anchor bolts after supporting members have been positioned and plumbed. Do not use impact torque wrenches to tighten anchor bolts set in concrete or masonry.
- E. Base Bearing and Leveling Plates: Clean concrete and masonry-bearing surfaces of bond-reducing materials, and roughen surfaces prior to setting plates. Clean bottom surface of plates.
1. Set plates for structural members on wedges, shims, or setting nuts as required to maintain plates in proper position while being grouted. Do not remove wedges or shims but, if protruding, cut off flush with edge of plate before packing with grout.
  2. Promptly pack grout solidly between bearing surfaces and plates so no voids remain. Neatly finish exposed surfaces; protect grout and allow to cure prior to imposing dead or live loading on columns. Comply with manufacturer's written installation instructions for shrinkage-resistant grouts.
- F. Field Welding: Comply with AWS Code for procedures of manual shielded metal-arc welding, appearance and quality of weld made, and methods in correcting welding work. Visible welded joints shall be considered "finished" welds and shall be carefully executed to preclude the necessity of grinding or otherwise finishing. However, when the appearance of the weld is unacceptable, in the opinion of the Architect, grinding shall be of the highest standard for both field and shop practice.
- G. Connections: Design connections for which details are not indicated in accordance with AISC "Manual of Steel Construction" for the full allowable shear capacity of the member.
- H. Temporary welds, run-off plates, and backing strips shall be removed where exposed in the final structure.
- I. Remove erection bolts on exposed, welded construction, fill holes with plug welds and grind smooth.

- J. Maintain erection tolerances of structural steel within AISC's "Code of Standard Practice for Steel Buildings and Bridges."
- K. Align and adjust various members that form part of complete frame or structure before permanently fastening. Before assembly, clean bearing surfaces and other surfaces that will be in permanent contact with members. Perform necessary adjustments to compensate for discrepancies in elevations and alignment.
  - 1. Level and plumb individual members of structure.
  - 2. Make allowances for difference between temperature at time of erection and mean temperature when structure is completed and in service.
- L. Splice members only where indicated.
- M. Do not use thermal cutting during erection.
- N. Do not enlarge unfair holes in members by burning or using drift pins. Ream holes that must be enlarged to admit bolts.
- O. Shear Connectors: Prepare steel surfaces as recommended by manufacturer of shear connectors. Use automatic end welding of headed-stud shear connectors according to AWS D1.1/D1.1M and manufacturer's written instructions.

### 3.4 FIELD QUALITY CONTROL

- A. Testing Agency: Owner will engage a qualified independent testing and inspecting agency to inspect field welds, high-strength bolted connections, perform tests as applicable, and prepare reports.
  - 1. Testing and inspection agency shall be acceptable to the Architect.
- B. The Architect shall have the right to order the testing of any materials used in the steel construction to determine if they are of the quality specified.
- C. Responsibilities and Duties of Contractor:
  - 1. The Contractor shall maintain control of the quality of materials and workmanship in order to conform with the drawings and specifications.
  - 2. To facilitate testing and inspection, the contractor shall:
    - a. Notify the designated testing laboratory sufficiently in advance of operations to allow for completion of quality tests and for the assignment of personnel.
    - b. Provide access to the Work for the designated testing laboratory.
    - c. Furnish all necessary materials and labor to assist the designated testing agency in obtaining and handling samples at the project or other sources of materials.
    - d. Provide and maintain for the sole use of the testing laboratory adequate facilities for safe storage and proper curing of the test specimens on the project site.
  - 3. The Contractor shall correct deficiencies in Work that test reports and inspections indicate does not comply with the Contract Documents.

D. Testing and Inspection Services: The following tests and inspections shall be performed by the designated laboratory.

1. Steel Testing:

- a. All steel used for structural purposes shall be identified as required by 2013 CBC Section 2203.1. Manufacturer's mill analyses and test reports are acceptable for properly identified steel, but the enforcement agency may require additional testing to determine the quality of the steel if there is any doubt as to its acceptability. Any steel not properly identified shall be tested to meet the minimum chemical and mechanical requirements of the ASTM standard appropriate for the steel specified for the structure.
- b. Fabrication shall not commence until steel members designated on the Structural Testing and Inspection Schedule have been tested. Tests shall be made by an independent testing laboratory approved by the Architect. Reports certifying that the materials and workmanship conform to the contract documents shall be submitted to the Architect.

2. Inspection of Field Erection:

- a. Verify qualifications of field procedures and personnel.
- b. Inspect erection of structural steel work for conformance with the drawings and specifications.

3. Inspection of Welding: Field welding operations including the installation of automatic end-welded stud shear connectors shall be inspected by a certified Welding Inspector meeting the requirements of AWS QC1. The Contractor shall schedule their operations to provide a minimum of 24 hours notice to the welding inspector so that all welding operations may be inspected.

- a. The Welding Inspector shall make a systematic record of all welds; recording shall include the following:
  - 1) Names and identification marks of welders.
  - 2) List of defective welds.
  - 3) Manner of correction of defects.
- b. The Welding Inspector shall check the material, equipment, procedure, welds, and the ability of each welder.
- c. Acceptance criteria shall be based on statically loaded connections. Upon detection of a rejectable weld, the inspector shall notify the Contractor, and observe removal of defects and repairs.
- d. The welding inspector shall tag or stamp accepted weldments with the inspector's identification stamp.
- e. A report stating that the welding required to be inspected is proper and has been done in conformity with approved drawings and specifications shall be furnished to the Architect.
- f. Welding inspections, testing, and frequency shall conform to AWS D1.1, AWS D1.8, and related AISC documents. The Welding Inspector shall use all means

necessary to determine the quality of the welds. However, the following tests and inspections shall be performed as a minimum:

- 1) Visual Inspection of Welding:
  - a) Observe multi-pass and full penetration welds continuously (i.e. the welding inspector shall be present at all times).
  - b) Observe single pass fillet welds periodically. The inspector shall check the qualifications of the welders at the start of the work and then make final inspection of all welds for compliance prior to completion of welding.
  - c) After the welding is completed, Contractor shall hand or power nylon brush welds, and thoroughly clean them before inspection.
  - d) Inspect welds with magnifiers under strong, adequate light for surface cracking, porosity, and slag inclusions; excessive roughness; unfilled craters; gas pockets; undercuts; overlaps; size; and insufficient throat and concavity.
  - e) Inspect the preparation of groove welds for adequate throat opening and for snug positioning of back-up bars.
  - f) Check the type and size of electrodes to be used for the various joints and positions. Check the storage facilities to see if they are adequate to keep the electrodes dry.
  - g) Verify the use of proper pre-heat and interpass temperatures.
  - h) Observe the technique of each welder periodically with the use of a welding inspection shield.

2) Nondestructive Testing of Welding:

- a) Welds shall be non-destructive tested by one of the following methods in accordance with AWS D1.1 and AWS D1.8 at the frequency noted below:

<u>Test Method</u>	<u>Frequency</u>
Liquid Dye Penetrant Testing	When requested by Architect.
Magnetic Particle Testing	10% of all fillet welds and 100% of all full penetration welds on members thinner than 5/16".
Ultrasonic Testing	100% of all full penetration welds on members thicker than 5/16"
Radiographic Testing	When requested by Architect or as substitute for magnetic particles testing or ultrasonic testing.

- b) Reduced Frequency of Testing: Initially, all welds requiring 100% testing shall be tested at the rate of 100% in order to establish the qualifications of each individual welder. If the reject rate is demonstrated to be less than 5% of the welds tested for each welder,

then the frequency of testing for that welder may be reduced to 25%. If the reject rate increases to 5% or more, 100% testing shall be re-established until the rate is reduced to less than 5%. The percentage of rejects shall be calculated for each welder independently. A sample of at least 40 completed welds shall be made for such reduction evaluation. Reject rate is defined as the number of welds containing rejectable defects divided by the number of welds completed. For evaluating the reject rate of continuous welds over 3 feet in length, each 12 linear inch increment of welds, one inch or less in thickness, shall be considered one weld. For evaluating the reject rate of continuous welds greater than 2 inch thickness, each 6 linear inches shall be considered one weld.

- g. Correction of Defective Welds: Weld areas containing defects exceeding the standards of acceptance in AWS D1.1 and AWS D1.8 shall be corrected in accordance with AWS D1.1, Section 3.7 and AWS D1.8. Additional testing of the repaired areas shall be required.
4. Welded Threaded Studs, Concrete Anchors, and Shear Connector Studs: Test installation in accordance with AWS D1.1. Random sample and test from stock furnished to each project. Tests shall meet the requirements of ASTM A108.
- a. Bend tests will be performed if visual inspections reveal either a less-than-continuous 360-degree flash or welding repairs to any shear connector.
  - b. Tests will be conducted on additional shear connectors if weld fracture occurs on shear connectors already tested, according to requirements in AWS D1.1/D1.1M.
5. Testing High Strength Bolts, Nuts and Washers:
- a. Materials: If the manufacturer's certification is not available, sample and test bolts, nuts and washers in accordance with ASTM A325 or A490, shipping lot method.
  - b. Installation:
    - 1) Inspect slip critical connections and connections subject to direct tension in accordance with RCSC Specification for Structural Joints Using ASTM A325 or A490 Bolts.
    - 2) Tests shall be performed by an approved testing laboratory specifically approved for that purpose.
    - 3) The inspector shall check the materials, equipment, details of construction and installation procedure.
    - 4) The inspector shall furnish the Architect with a report that the work has been completed in every material respect in compliance with the approved drawings and specifications.

### 3.5 REPAIRS AND PROTECTION

- A. Galvanized Surfaces: Clean areas where galvanizing is damaged or missing and repair galvanizing to comply with ASTM A 780.



- B. Touchup Painting: Immediately after erection, clean exposed areas where primer is damaged or missing and paint with the same material as used for shop painting to comply with SSPC-PA 1 for touching up shop-painted surfaces.
  - 1. Clean and prepare surfaces by SSPC-SP 2 hand-tool cleaning or SSPC-SP 3 power-tool cleaning.

END OF SECTION



## SECTION 054000 - COLD-FORMED METAL FRAMING

### PART 1 - GENERAL

#### 1.1 SUMMARY

- A. Section Includes:
  - 1. Interior non-load-bearing wall framing.

#### 1.2 ACTION SUBMITTALS

- A. Product Data: For each type of cold-formed steel framing product and accessory.
- B. Shop Drawings:
  - 1. Include layout, spacings, sizes, thicknesses, and types of cold-formed steel framing; fabrication; and fastening and anchorage details, including mechanical fasteners.
  - 2. Indicate reinforcing channels, opening framing, supplemental framing, strapping, bracing, bridging, splices, accessories, connection details, and attachment to adjoining work.

#### 1.3 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For testing agency.
- B. Welding certificates.
- C. Product test reports.
- D. Research reports.

#### 1.4 QUALITY ASSURANCE

- A. Product Tests: Mill certificates or data from a qualified independent testing agency.
- B. Welding Qualifications: Qualify procedures and personnel according to AWS D1.3/D1.3M, "Structural Welding Code - Sheet Steel."
- C. Comply with AISI S230 "Standard for Cold-Formed Steel Framing - Prescriptive Method for One and Two Family Dwellings."

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. Clark Dietrich or approved equal.

### 2.2 COLD-FORMED STEEL FRAMING, GENERAL

- A. Steel Sheet: ASTM A 1003/A 1003M, Structural Grade, Type H, metallic coated, of grade and coating weight as follows:
  - 1. Grade: ST33H (ST230H) for 20 and 18 gage, ST50H (ST340H) for 16 gage.
  - 2. Coating: G60 (Z180), A60 (ZF180), AZ50 (AZ150), or GF30 (ZGF90).
- B. Steel Sheet for Vertical Deflection and Drift Clips: ASTM A 653/A 653M, structural steel, zinc coated, of grade and coating as follows:
  - 1. Grade: [33 (230) for 20 and 18 gage, 50 (340), Class 1 for 18 gage
  - 2. Coating: G60 (Z180).

### 2.3 WALL FRAMING

- A. Steel Studs: Manufacturer's standard C-shaped steel studs, of web depths indicated, punched, with stiffened flanges, and as follows:
  - 1. Minimum Base-Metal Thickness: 0.0329 inch (0.84 mm)
  - 2. Flange Width: 1-3/8 inches (35 mm)
- B. Steel Track: Manufacturer's standard U-shaped steel track, of web depths indicated, unpunched, with straight flanges, and matching minimum base-metal thickness of steel studs.

### 2.4 FRAMING ACCESSORIES

- A. Fabricate steel-framing accessories from steel sheet, ASTM A 1003/A 1003M, Structural Grade, Type H, metallic coated, of same grade and coating weight used for framing members.
- B. Provide accessories of manufacturer's standard thickness and configuration.

### 2.5 ANCHORS, CLIPS, AND FASTENERS

- A. Steel Shapes and Clips: ASTM A 36/A 36M, zinc coated by hot-dip process according to ASTM A 123/A 123M.
- B. Power-Actuated Anchors: Fastener system of type suitable for application indicated, fabricated from corrosion-resistant materials, with allowable load capacities calculated according to ICC-ES AC70, greater than or equal to the design load, as determined by testing per ASTM E 1190 conducted by a qualified testing agency.

- C. Mechanical Fasteners: ASTM C 1513, corrosion-resistant-coated, self-drilling, self-tapping, steel drill screws.
  - 1. Head Type: Low-profile head beneath sheathing, manufacturer's standard elsewhere.

## 2.6 MISCELLANEOUS MATERIALS

- A. Galvanizing Repair Paint: SSPC-Paint 20 or MIL-P-2103B.

## PART 3 - EXECUTION

### 3.1 PREPARATION

- A. Install load bearing shims or grout between the underside of load-bearing wall bottom track and the top of foundation wall or slab at locations with a gap larger than 1/4 inch (6 mm) to ensure a uniform bearing surface on supporting concrete or masonry construction.
- B. Install sealer gaskets at the underside of wall bottom track or rim track and at the top of foundation wall or slab at stud or joist locations.

### 3.2 INSTALLATION, GENERAL

- A. Cold-formed steel framing may be shop or field fabricated for installation, or it may be field assembled.
- B. Install cold-formed steel framing according to AISI S200 and to manufacturer's written instructions unless more stringent requirements are indicated.
- C. Install cold-formed steel framing and accessories plumb, square, and true to line, and with connections securely fastened.
- D. Install framing members in one-piece lengths.
- E. Install temporary bracing and supports to secure framing and support loads comparable in intensity to those for which structure was designed. Maintain braces and supports in place, undisturbed, until entire integrated supporting structure has been completed and permanent connections to framing are secured.
- F. Do not bridge building expansion joints with cold-formed steel framing. Independently frame both sides of joints.
- G. Install insulation, specified in Section 072100 "Thermal Insulation," in built-up exterior framing members, such as headers, sills, boxed joists, and multiple studs at openings, that are inaccessible on completion of framing work.
- H. Fasten hole reinforcing plate over web penetrations that exceed size of manufacturer's approved or standard punched openings.

- I. Erection Tolerances: Install cold-formed steel framing level, plumb, and true to line to a maximum allowable tolerance variation of 1/8 inch in 10 feet (1:960) and as follows:
  - 1. Space individual framing members no more than plus or minus 1/8 inch (3 mm) from plan location. Cumulative error shall not exceed minimum fastening requirements of sheathing or other finishing materials.

### 3.3 WALL INSTALLATION

- A. Install continuous top and bottom tracks sized to match studs. Align tracks accurately and securely anchor at corners and ends, and at spacings as follows:
  - 1. Anchor Spacing: 32 inches (610 mm)
- B. Squarely seat studs against top and bottom tracks with gap not exceeding of 1/8 inch (3 mm) between the end of wall framing member and the web of track. Fasten both flanges of studs to top and bottom tracks. Space studs as follows:
  - 1. Stud Spacing: 24 inches (610 mm).
- C. Set studs plumb, except as needed for diagonal bracing or required for nonplumb walls or warped surfaces and similar configurations.
- D. Install headers over wall openings wider than stud spacing. Locate headers above openings as indicated. Fabricate headers of compound shapes indicated or required to transfer load to supporting studs, complete with clip-angle connectors, web stiffeners, or gusset plates.
  - 1. Frame wall openings with not less than a double stud at each jamb of frame as indicated on Shop Drawings. Fasten jamb members together to uniformly distribute loads.
  - 2. Install runner tracks and jack studs above and below wall openings. Anchor tracks to jamb studs with clip angles or by welding, and space jack studs same as full-height wall studs.
- E. Install supplementary framing, blocking, and bracing in stud framing indicated to support fixtures, equipment, services, casework, heavy trim, furnishings, and similar work requiring attachment to framing.
- F. Install horizontal bridging in stud system, spaced vertically 48 inches (1220 mm) where sheathing is not provided on both sides. Fasten at each stud intersection.
  - 1. Bridging: Cold-rolled steel channel, welded or mechanically fastened to webs of punched studs with a minimum of two screws into each flange of the clip angle for framing members up to 6 inches (150 mm) deep.
- G. Install miscellaneous framing and connections, including supplementary framing, web stiffeners, clip angles, continuous angles, anchors, and fasteners, to provide a complete and stable wall-framing system.

### 3.4 FIELD QUALITY CONTROL

- A. Testing: Owner will engage a qualified independent testing and inspecting agency to perform field tests and inspections and prepare test reports.
- B. Field and shop welds will be subject to testing and inspecting.
- C. Testing agency will report test results promptly and in writing to Contractor and Architect.
- D. Remove and replace work where test results indicate that it does not comply with specified requirements.
- E. Additional testing and inspecting, at Contractor's expense, will be performed to determine compliance of replaced or additional work with specified requirements.

### 3.5 REPAIRS AND PROTECTION

- A. Galvanizing Repairs: Prepare and repair damaged galvanized coatings on fabricated and installed cold-formed steel framing with galvanized repair paint according to ASTM A 780 and manufacturer's written instructions.
- B. Provide final protection and maintain conditions, in a manner acceptable to manufacturer and Installer, that ensure that cold-formed steel framing is without damage or deterioration at time of Substantial Completion.

END OF SECTION 054000



SECTION 05 5000 - METAL FABRICATIONS

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following:
1. Steel framing and supports for applications where framing and supports are not specified in other Sections.
  2. Loose bearing and leveling plates.
  3. Steel weld plates and angles for casting into concrete not specified in other Sections.
  4. Metal bollards.
  5. Security grilles not specified in other sections.
  6. Fasteners and Anchors
- B. Products furnished, but not installed, under this Section include the following:
1. Anchor bolts, steel pipe sleeves, and wedge-type inserts indicated to be cast into concrete or built into unit masonry.
  2. Security and non-security fasteners and anchors.
- C. Related Sections include the following:
1. Division 033000 Section "Cast-in-Place Concrete" for installing anchor bolts, steel pipe sleeves, wedge-type inserts and other items indicated to be cast into concrete.
  2. Division 042200 Section "Unit Masonry" for installing loose lintels, anchor bolts, and other items indicated to be built into unit masonry.
  3. Division 055100 Section "Metal Stairs."
  4. Division 055213 Section "Pipe and Tube Railings."
  5. Division 061000 Section "Rough Carpentry" for metal framing anchors.
  6. Division 099113 and 099123 Section "Exterior and Interior Painting" for field painting.
  7. Division 102213 Section "Wire Mesh Partitions."

1.3 PERFORMANCE REQUIREMENTS

- A. Thermal Movements: Provide exterior metal fabrications that allow for thermal movements resulting from the following maximum change (range) in ambient and surface temperatures by preventing buckling, opening of joints, overstressing of components, failure of connections, and other detrimental effects. Base engineering calculation on surface temperatures of materials due to both solar heat gain and nighttime-sky heat loss.
1. Temperature Change (Range): 120 deg F, ambient; 180 deg F, material surfaces.

#### 1.4 SUBMITTALS

- A. Product Data: For the following:
  - 1. Grout.
- B. Shop Drawings: Show fabrication and installation details for metal fabrications.
  - 1. Include plans, elevations, sections, and details of metal fabrications and their connections. Show anchorage and accessory items.
  - 2. Provide templates for anchors and bolts specified for installation under other Sections.
  - 3. For installed products indicated to comply with design loads, include structural analysis data signed and sealed by the qualified professional engineer responsible for their preparation.
- C. Mill Certificates: Signed by manufacturers of stainless-steel sheet certifying that products furnished comply with requirements.
- D. Welding certificates.
- E. Qualification Data: For professional engineer.

#### 1.5 QUALITY ASSURANCE

- A. Welding: Qualify procedures and personnel according to the following:
  - 1. AWS D1.1, "Structural Welding Code--Steel."
  - 2. AWS D1.2, "Structural Welding Code--Aluminum."
  - 3. AWS D1.3, "Structural Welding Code--Sheet Steel."
  - 4. AWS D1.6, "Structural Welding Code--Stainless Steel."

#### 1.6 PROJECT CONDITIONS

- A. Field Measurements: Verify actual locations of walls and other construction contiguous with metal fabrications by field measurements before fabrication and indicate measurements on Shop Drawings.
  - 1. Established Dimensions: Where field measurements cannot be made without delaying the Work, establish dimensions and proceed with fabricating metal fabrications without field measurements. Coordinate wall and other contiguous construction to ensure that actual dimensions correspond to established dimensions.
  - 2. Provide allowance for trimming and fitting at site.

#### 1.7 COORDINATION

- A. Coordinate installation of anchorages for metal fabrications. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors, that are to be embedded in concrete or masonry. Deliver such items to Project site in time for installation.

- B. Coordinate installation of steel weld plates and angles for casting into concrete that are specified in this Section but required for work of another Section. Deliver such items to Project site in time for installation.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, manufacturers specified.

### 2.2 METALS, GENERAL

- A. Metal Surfaces, General: Provide materials with smooth, flat surfaces, unless otherwise indicated. For metal fabrications exposed to view in the completed Work, provide materials without seam marks, roller marks, rolled trade names, or blemishes.

### 2.3 FERROUS METALS

- A. Steel Plates, Shapes, and Bars: ASTM A 36/A 36M.
- B. High Strength, Low Alloy Steel Plate, Shape and Bars: ASTM A 572/A 572M Grade 50.
- C. Stainless-Steel Sheet, Strip, Plate, and Flat Bars: ASTM A 666, Type 304.
- D. Stainless-Steel Bars and Shapes: ASTM A 276, Type 304.
- E. Rolled-Steel Floor Plate: ASTM A 786/A 786M, rolled from plate complying with ASTM A 36/A 36M or ASTM A 283/A 283M, Grade C or D.
- F. Rolled-Stainless-Steel Floor Plate: ASTM A 793.
- G. Steel Tubing: ASTM A 500, cold-formed steel tubing.
- H. Steel Pipe: ASTM A 53/A 53M, standard weight (Schedule 40), unless another weight is indicated or required by structural loads.
- I. Slotted Channel Framing: Cold-formed metal channels with continuous slot complying with MFMA-3.
  - 1. Size of Channels: 1-5/8 by 1-5/8 inches (41 by 41 mm)As indicated.
  - 2. Material: Galvanized steel complying with ASTM A 653/A 653M, commercial steel, Type B, with G90 (Z275) coating; 0.079-inch (2-mm) nominal thickness.
- J. Cast Iron: ASTM A 48/A 48M, Class 30, unless another class is indicated or required by structural loads.

- K. Homogenous Tool Resisting Steel Round Bars: ASTM A 627.
- L. Homogenous Tool Resisting Steel Flat Bars: ASTM A 629.

## 2.4 FASTENERS

- A. General: Unless otherwise indicated, provide Type 304 stainless-steel fasteners for exterior use and zinc-plated fasteners with coating complying with ASTM B 633, Class Fe/Zn 5, at exterior walls. Provide stainless-steel fasteners for fastening aluminum. Select fasteners for type, grade, and class required.
- B. Expansion Anchors: Anchor bolt and sleeve assembly with capability to sustain, without failure, a load equal to six times the load imposed when installed in unit masonry and four times the load imposed when installed in concrete, as determined by testing according to ASTM E 488, conducted by a qualified independent testing agency.
  - 1. Material for Anchors in Interior Locations: Carbon-steel components zinc-plated to comply with ASTM B 633, Class Fe/Zn 5.
  - 2. Material for Anchors in Exterior Locations: Alloy Group 1 (A1) stainless-steel bolts complying with ASTM F 593 (ASTM F 738M) and nuts complying with ASTM F 594 (ASTM F 836M).

### C. Fasteners and Anchors

- 1. Security Fasteners: Operable only by tools produced for use on specific type of fastener by fastener manufacturer or other licensed fabricator. Drive system type, head style, material, and protective coating as required for assembly, installation, and strength, and as follows:
  - a. Drive System Types: Pinned Torx-Plus or pinned Torx.
  - b. Socket Flat Countersunk Head Fasteners:
    - 1) Heat-treated alloy steel, ASTM F 835 (ASTM F 835M).
    - 2) Stainless steel, ASTM F 879 (ASTM F 879M), Group 1 CW.
  - c. Socket Button Head Fasteners:
    - 1) Heat-treated alloy steel, ASTM F 835 (ASTM F 835M).
    - 2) Stainless steel, ASTM F 879 (ASTM F 879M), Group 1 CW.
  - d. Socket Head Cap Fasteners:
    - 1) Heat-treated alloy steel, ASTM A 574 (ASTM A 574M).
    - 2) Stainless steel, ASTM F 837 (ASTM F 837M), Group 1 CW.
  - e. Protective Coatings for Heat-Treated Alloy Steel:
    - 1) Zinc chromate, ASTM F 1135, Grade 3 or 4; for exterior applications and interior applications where indicated.
  - f. Acceptable Manufacturers for types indicated above: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - 1) Camcar Textron Inc.
    - 2) Holo-Krome; a Danaher Corporation.
    - 3) Safety Socket Screw Corporation.
    - 4) Tamper-Pruf Screws, Inc.
    - 5) Tanner Bolt & Nut Co.
    - 6) Bryer Fastener Co., Inc.
- 2. Break-off Security nuts and bolts:

- a. Steel: SAE\_1429 Grade 2, zinc plated with minimum yield strength of 57,000 psi and tensile strength of 74,000 psi.
  - b. Stainless steel: Type 303 with minimum yield strength of 30,000 psi and tensile strength of 75,000 psi minimum.
  - c. Aluminum: Grade 2024-T351 per QQA 22516, with minimum yield strength of 47,000 psi and tensile strength of 68,000 psi minimum.
  - d. Acceptable manufacturer:
    - 1) J.P. Ruklic Screw Co.
  - e. Threaded rod for use with nuts: ASTM A325 or A490, diameter as required.
3. Chemical anchors: System consisting of threaded rod, breakoff security nut and epoxy adhesive.
- a. Epoxy adhesive: ASTM C881, Type I, II, IV or V, Grade 3, Class A, B and C.
  - b. Threaded rod: ASTM A325 or A490 steel, minimum ½ inch (13 mm) diameter.
  - c. Breakoff security nuts as indicated above.
  - d. Use for all floor mounted detention equipment inside the secure perimeter and where indicated.
4. Provide zinc-coated fasteners for exterior use or where built into exterior walls. Select fasteners for the type, grade, and class required.

## 2.5 MISCELLANEOUS MATERIALS

- A. Welding Rods and Bare Electrodes: Select according to AWS specifications for metal alloy welded.
- B. Shop Primers: Provide primers that comply with Division 09 painting Sections.
- C. Zinc-Rich Primer: Complying with SSPC-Paint 20 or SSPC-Paint 29 and compatible with topcoat.
  1. Use primer with a VOC content of 420 g/L (3.5 lb/gal.) or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- D. Galvanizing Repair Paint: High-zinc-dust-content paint for regalvanizing welds in steel, complying with SSPC-Paint 20.
- E. Bituminous Paint: Cold-applied asphalt emulsion complying with ASTM D 1187.
- F. Nonshrink, Nonmetallic Grout: Factory-packaged, nonstaining, noncorrosive, nongaseous grout complying with ASTM C 1107. Provide grout specifically recommended by manufacturer for interior and exterior applications.
- G. Concrete Materials and Properties: Comply with requirements in Division 03 Section "Cast-in-Place Concrete" for normal-weight, air-entrained, ready-mix concrete with a minimum 28-day compressive strength of 3000 psi (20 MPa), unless otherwise indicated.

## 2.6 FABRICATION, GENERAL

- A. Shop Assembly: Preassemble items in the shop to greatest extent possible. Disassemble units only as necessary for shipping and handling limitations. Use connections that maintain

structural value of joined pieces. Clearly mark units for reassembly and coordinated installation.

- B. Cut, drill, and punch metals cleanly and accurately. Remove burrs and ease edges to a radius of approximately 1/32 inch (1 mm), unless otherwise indicated. Remove sharp or rough areas on exposed surfaces.
- C. Form bent-metal corners to smallest radius possible without causing grain separation or otherwise impairing work.
- D. Form exposed work true to line and level with accurate angles and surfaces and straight edges.
- E. Weld corners and seams continuously to comply with the following:
  - 1. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
  - 2. Obtain fusion without undercut or overlap.
  - 3. Remove welding flux immediately.
  - 4. At exposed connections, finish exposed welds and surfaces smooth and blended so no roughness shows after finishing and contour of welded surface matches that of adjacent surface.
- F. Form exposed connections with hairline joints, flush and smooth, using concealed fasteners where possible. Where exposed fasteners are required, use Phillips flat-head (countersunk) screws or bolts, unless otherwise indicated. Locate joints where least conspicuous.
- G. Fabricate seams and other connections that will be exposed to weather in a manner to exclude water. Provide weep holes where water may accumulate.
- H. Cut, reinforce, drill, and tap metal fabrications as indicated to receive finish hardware, screws, and similar items.
- I. Provide for anchorage of type indicated; coordinate with supporting structure. Space anchoring devices to secure metal fabrications rigidly in place and to support indicated loads.
  - 1. Where units are indicated to be cast into concrete or built into masonry, equip with integrally welded steel strap anchors, 1/8 by 1-1/2 inches (3.2 by 38 mm), with a minimum 6-inch (150-mm) embedment and 2-inch (50-mm) hook, not less than 8 inches (200 mm) from ends and corners of units and 24 inches (600 mm) o.c., unless otherwise indicated.

## 2.7 MISCELLANEOUS FRAMING AND SUPPORTS

- A. General: Provide steel framing and supports not specified in other Sections as needed to complete the Work.
- B. Fabricate units from steel shapes, plates, and bars of welded construction, unless otherwise indicated. Fabricate to sizes, shapes, and profiles indicated and as necessary to receive adjacent construction retained by framing and supports. Cut, drill, and tap units to receive hardware, hangers, and similar items.
- C. Galvanize miscellaneous framing and supports where indicated.

- D. Prime miscellaneous framing and supports with zinc-rich primer where indicated.

## 2.8 LOOSE STEEL LINTELS

- A. Fabricate loose steel lintels from steel angles and shapes of size indicated for openings and recesses in masonry walls and partitions at locations indicated. Weld adjoining members together to form a single unit where indicated.
- B. Size loose lintels to provide bearing length at each side of openings equal to 1/12 of clear span but not less than 8 inches (200 mm), unless otherwise indicated.
- C. Galvanize loose steel lintels located in exterior walls.

## 2.9 LOOSE BEARING AND LEVELING PLATES

- A. Provide loose bearing and leveling plates for steel items bearing on masonry or concrete construction. Drill plates to receive anchor bolts and for grouting.
- B. Galvanize plates after fabrication.

## 2.10 STEEL WELD PLATES AND ANGLES

- A. Provide steel weld plates and angles not specified in other Sections, for items supported from concrete construction as needed to complete the Work. Provide each unit with not less than two integrally welded steel strap anchors for embedding in concrete.

## 2.11 MISCELLANEOUS STEEL TRIM

- A. Unless otherwise indicated, fabricate units from steel shapes, plates, and bars of profiles shown with continuously welded joints and smooth exposed edges. Miter corners and use concealed field splices where possible.
- B. Provide cutouts, fittings, and anchorages as needed to coordinate assembly and installation with other work.
  - 1. Provide with integrally welded steel strap anchors for embedding in concrete or masonry construction.
- C. Galvanize exterior miscellaneous steel trim and interior miscellaneous steel trim, where indicated.

## 2.12 METAL BOLLARDS

- A. Fabricate metal bollards from Schedule 80 steel pipe.

2.13 SECURITY GRILLES

- A. Fabricate grilles using 3-inch x 5-inch x 3/8-inch mild steel angle (75 mm x 140 mm x 10 mm) (LLV) or 3/8-inch (10 mm) thick mild steel flat bar for the perimeter frame with minimum 1-inch (25 mm) diameter tool resistant steel round bars horizontally spaced at 6 inches (150 mm) o.c. vertically. When opening exceeds 18 inches (500 mm) in width, install 3/8-inch x 2-1/2-inch (10 mm x 64 mm) wide vertical tool resistant flat bars at 12 inches (305 mm) o.c. maximum spacing with bars running through middle of vertical bar. Weld entire assembly together.
- B. Provide security grilles at all openings and HVAC penetrations in secure perimeter envelope and other areas as indicated, including walls, floor and roof structures, except when the following conditions exist:
  - 1. Opening is 8 inches x 8 inches (200 mm x 200 mm) or smaller in size.
  - 2. Opening is 5 inches (125 mm) wide or smaller in one direction.
  - 3. Opening is smaller than 8 inches (200 mm) in diameter.

2.14 FINISHES, GENERAL

- A. Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Finish metal fabrications after assembly.

2.15 STEEL AND IRON FINISHES

- A. Galvanizing: Hot-dip galvanize items as indicated to comply with applicable standard listed below:
  - 1. ASTM A 123/A 123M, for galvanizing steel and iron products.
  - 2. ASTM A 153/A 153M, for galvanizing steel and iron hardware.
- B. Preparation for Shop Priming: Prepare uncoated ferrous-metal surfaces to comply with minimum requirements indicated below for SSPC surface preparation specifications and environmental exposure conditions of installed metal fabrications:
  - 1. Exteriors (SSPC Zone 1B)[ and Items Indicated to Receive Zinc-Rich Primer]: SSPC-SP 6/NACE No. 3, "Commercial Blast Cleaning."
  - 2. Interiors (SSPC Zone 1A): SSPC-SP 3, "Power Tool Cleaning."
- C. Shop Priming: Apply shop primer to uncoated surfaces of metal fabrications, except those with galvanized finishes and those to be embedded in concrete, sprayed-on fireproofing, or masonry, unless otherwise indicated. Comply with SSPC-PA 1, "Paint Application Specification No. 1: Shop, Field, and Maintenance Painting of Steel," for shop painting.

2.16 STAINLESS-STEEL FINISHES

- A. Remove tool and die marks and stretch lines or blend into finish.
- B. Dull Satin Finish: No. 6.



- C. When polishing is completed, passivate and rinse surfaces. Remove embedded foreign matter and leave surfaces chemically clean.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION, GENERAL

- A. Cutting, Fitting, and Placement: Perform cutting, drilling, and fitting required for installing metal fabrications. Set metal fabrications accurately in location, alignment, and elevation; with edges and surfaces level, plumb, true, and free of rack; and measured from established lines and levels.
- B. Fit exposed connections accurately together to form hairline joints. Weld connections that are not to be left as exposed joints but cannot be shop welded because of shipping size limitations. Do not weld, cut, or abrade surfaces of exterior units that have been hot-dip galvanized after fabrication and are for bolted or screwed field connections.
- C. Field Welding: Comply with the following requirements:
  - 1. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
  - 2. Obtain fusion without undercut or overlap.
  - 3. Remove welding flux immediately.
  - 4. At exposed connections, finish exposed welds and surfaces smooth and blended so no roughness shows after finishing and contour of welded surface matches that of adjacent surface.
- D. Fastening to In-Place Construction: Provide anchorage devices and fasteners where metal fabrications are required to be fastened to in-place construction. Provide threaded fasteners for use with concrete and masonry inserts, toggle bolts, through bolts, lag bolts, wood screws, and other connectors.
- E. Provide temporary bracing or anchors in formwork for items that are to be built into concrete, masonry, or similar construction.

#### 3.2 INSTALLING MISCELLANEOUS FRAMING AND SUPPORTS

- A. General: Install framing and supports to comply with requirements of items being supported, including manufacturers' written instructions and requirements indicated on Shop Drawings.
- B. Install pipe columns on concrete footings with grouted baseplates. Position and grout column baseplates as specified in "Installing Bearing and Leveling Plates" Article.
  - 1. Grout baseplates of columns supporting steel girders after girders are installed and leveled.

### 3.3 INSTALLING BEARING AND LEVELING PLATES

- A. Clean concrete and masonry bearing surfaces of bond-reducing materials, and roughen to improve bond to surfaces. Clean bottom surface of plates.
- B. Set bearing and leveling plates on wedges, shims, or leveling nuts. After bearing members have been positioned and plumbed, tighten anchor bolts. Do not remove wedges or shims but, if protruding, cut off flush with edge of bearing plate before packing with grout.
  - 1. Use nonshrink grout, either metallic or nonmetallic, in concealed locations where not exposed to moisture; use nonshrink, nonmetallic grout in exposed locations, unless otherwise indicated.
  - 2. Pack grout solidly between bearing surfaces and plates to ensure that no voids remain.

### 3.4 INSTALLING METAL BOLLARDS

- A. Anchor bollards in place with concrete footings. Center and align bollards in holes 3 inches (75 mm) above bottom of excavation. Place concrete and vibrate or tamp for consolidation. Support and brace bollards in position until concrete has cured.
- B. Fill bollards solidly with concrete, mounding top surface to shed water.

### 3.5 INSTALLATION OF SECURITY GRILLES

- A. Where angle frame is used, anchor by welding to embeds in structure or with 1/2-inch diameter x 3-inch (13 mm x 75 mm) long security type sleeve anchors at 8 inches (200 mm) on center.
- B. Where flat bar frame is used in masonry or cast-in-place concrete construction, weld 1/2-inch (13 mm) diameter x 3 inch (75 mm) long stud anchors to bar at 8 inches (200 mm) on center. Build grill into masonry walls as they are constructed. Cast into concrete structure.
- C. Where indicated, weld to substrate.

### 3.6 ADJUSTING AND CLEANING

- A. Touchup Painting: Cleaning and touchup painting of field welds, bolted connections, and abraded areas of shop paint are specified in Division 09 painting Sections.
- B. Galvanized Surfaces: Clean field welds, bolted connections, and abraded areas and repair galvanizing to comply with ASTM A780.

END OF SECTION 05 5000

SECTION 05 5213 - PIPE AND TUBE RAILINGS

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Steel pipe and tube railings.

1.3 PERFORMANCE REQUIREMENTS

- A. General: In engineering railings to withstand structural loads indicated, determine allowable design working stresses of railing materials based on the following:
  - 1. Steel: 72 percent of minimum yield strength.
- B. Structural Performance: Provide railings capable of withstanding the effects of gravity loads and the following loads and stresses within limits and under conditions indicated:
  - 1. Handrails:
    - a. Uniform load of 50 lbf/ ft. (0.73 kN/m) applied in any direction.
    - b. Concentrated load of 200 lbf (0.89 kN) applied in any direction.
    - c. Uniform and concentrated loads need not be assumed to act concurrently.
  - 2. Top Rails of Guards:
    - a. Uniform load of 50 lbf/ ft. (0.73 kN/m) applied in any direction..
    - b. Concentrated load of 200 lbf (0.89 kN) applied in any direction.
    - c. Uniform and concentrated loads need not be assumed to act concurrently.
  - 3. Infill of Guards:
    - a. Concentrated load of 200 lbf (0.89 kN) applied horizontally on an area of 1 sq. ft. (0.093 sq. m).
    - b. Uniform load of 25 lbf/sq. ft. (1.2 kN/sq. m) applied horizontally.
    - c. Infill load and other loads need not be assumed to act concurrently.
- C. Thermal Movements: Provide exterior railings that allow for thermal movements resulting from the following maximum change (range) in ambient and surface temperatures by preventing buckling, opening of joints, overstressing of components, failure of connections, and other detrimental effects. Base engineering calculation on surface temperatures of materials due to both solar heat gain and nighttime-sky heat loss.
  - 1. Temperature Change (Range): 120 deg F (67 deg C), ambient; 180 deg F (100 deg C), material surfaces.

- D. Control of Corrosion: Prevent galvanic action and other forms of corrosion by insulating metals and other materials from direct contact with incompatible materials.

#### 1.4 SUBMITTALS

- A. Product Data: For the following:
  - 1. Grout, anchoring cement, and paint products.
- B. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
  - 1. For installed products indicated to comply with design loads, include structural analysis data signed and sealed by the qualified professional engineer responsible for their preparation.
- C. Mill Certificates: Signed by manufacturers of stainless-steel products certifying that products furnished comply with requirements.
- D. Welding certificates.
- E. Qualification Data: For professional engineer.
- F. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency, according to ASTM E 894 and ASTM E 935.

#### 1.5 QUALITY ASSURANCE

- A. Source Limitations: Obtain each type of railing through one source from a single manufacturer.
- B. Welding: Qualify procedures and personnel according to the following:
  - 1. AWS D1.1, "Structural Welding Code--Steel."

#### 1.6 PROJECT CONDITIONS

- A. Field Measurements: Verify actual locations of walls and other construction contiguous with railings by field measurements before fabrication and indicate measurements on Shop Drawings.
  - 1. Established Dimensions: Where field measurements cannot be made without delaying the Work, establish dimensions and proceed with fabricating railings without field measurements. Coordinate wall and other contiguous construction to ensure that actual dimensions correspond to established dimensions.
  - 2. Provide allowance for trimming and fitting at site.

#### 1.7 COORDINATION AND SCHEDULING

- A. Coordinate installation of anchorages for railings. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors, that are to be embedded in concrete or masonry. Deliver such items to Project site in time for installation.

- B. Schedule installation so wall attachments are made only to completed walls. Do not support railings temporarily by any means that do not satisfy structural performance requirements.

## PART 2 - PRODUCTS

### 2.1 METALS, GENERAL

- A. Metal Surfaces, General: Provide materials with smooth surfaces, without seam marks, roller marks, rolled trade names, stains, discolorations, or blemishes.
- B. Brackets, Flanges, and Anchors: Cast or formed metal of same type of material and finish as supported rails, unless otherwise indicated.

### 2.2 STEEL AND IRON

- A. Tubing: ASTM A 500 (cold formed) or ASTM A 513, Type 5 (mandrel drawn).
- B. Pipe: ASTM A 53/A 53M, Type F or Type S, Grade A, Standard Weight (Schedule 40), unless another grade and weight are required by structural loads.
  - 1. Provide galvanized finish for exterior installations and where indicated.
- C. Plates, Shapes, and Bars: ASTM A 36/A 36M.
- D. Mesh Infill: 2 inch by 2 inch by 8 gage welded wire panels.

### 2.3 FASTENERS

- A. General: Provide the following:
  - 1. Steel Railings: Plated steel fasteners complying with ASTM B 633, Class Fe/Zn 25 for electrodeposited zinc coating.
- B. Fasteners for Anchoring Railings to Other Construction: Select fasteners of type, grade, and class required to produce connections suitable for anchoring railings to other types of construction indicated and capable of withstanding design loads.
- C. Fasteners for Interconnecting Railing Components:
  - 1. Provide concealed fasteners for interconnecting railing components and for attaching them to other work, unless otherwise indicated.
  - 2. Provide security-type flat-head machine screws for exposed fasteners, unless otherwise indicated.
- D. Anchors: Provide chemical anchors, fabricated from corrosion-resistant materials with capability to sustain, without failure, a load equal to six times the load imposed when installed in unit masonry and equal to four times the load imposed when installed in concrete, as determined by testing per ASTM E 488 conducted by a qualified independent testing agency.

## 2.4 MISCELLANEOUS MATERIALS

- A. Welding Rods and Bare Electrodes: Select according to AWS specifications for metal alloy welded.
- B. Shop Primers: Provide primers that comply with Division 09 painting Sections.
- C. Shop Primer for Galvanized Steel: Zinc-dust, zinc-oxide primer formulated for priming zinc-coated steel and for compatibility with finish paint systems indicated, and complying with SSPC-Paint 5.
- D. Galvanizing Repair Paint: High-zinc-dust-content paint for regalvanizing welds in steel, complying with SSPC-Paint 20.
- E. Bituminous Paint: Cold-applied asphalt emulsion complying with ASTM D 1187.
- F. Nonshrink, Nonmetallic Grout: Factory-packaged, nonstaining, noncorrosive, nongaseous grout complying with ASTM C 1107. Provide grout specifically recommended by manufacturer for interior and exterior applications.
- G. Anchoring Cement: Factory-packaged, nonshrink, nonstaining, hydraulic-controlled expansion cement formulation for mixing with water at Project site to create pourable anchoring, patching, and grouting compound.
  - 1. Water-Resistant Product: At exterior locations provide formulation that is resistant to erosion from water exposure without needing protection by a sealer or waterproof coating and that is recommended by manufacturer for exterior use.

## 2.5 FABRICATION

- A. General: Fabricate railings to comply with requirements indicated for design, dimensions, member sizes and spacing, details, finish, and anchorage, but not less than that required to support structural loads.
- B. Assemble railings in the shop to greatest extent possible to minimize field splicing and assembly. Disassemble units only as necessary for shipping and handling limitations. Clearly mark units for reassembly and coordinated installation. Use connections that maintain structural value of joined pieces.
- C. Cut, drill, and punch metals cleanly and accurately. Remove burrs and ease edges to a radius of approximately 1/32 inch (1 mm), unless otherwise indicated. Remove sharp or rough areas on exposed surfaces.
- D. Form work true to line and level with accurate angles and surfaces.
- E. Fabricate connections that will be exposed to weather in a manner to exclude water. Provide weep holes where water may accumulate.
- F. Cut, reinforce, drill, and tap as indicated to receive finish hardware, screws, and similar items.

- G. Connections: Fabricate railings with welded connections in inmate accessible areas and either welded or nonwelded connections in non-inmate accessible areas, unless otherwise indicated.
- H. Welded Connections: Cope components at connections to provide close fit, or use fittings designed for this purpose. Weld all around at connections, including at fittings.
  - 1. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
  - 2. Obtain fusion without undercut or overlap.
  - 3. Remove flux immediately.
  - 4. At exposed connections, finish exposed surfaces smooth and blended so no roughness shows after finishing and welded surface matches contours of adjoining surfaces.
- I. Nonwelded Connections: Connect members with concealed mechanical fasteners and fittings. Fabricate members and fittings to produce flush, smooth, rigid, hairline joints.
  - 1. Fabricate splice joints for field connection using an epoxy structural adhesive if this is manufacturer's standard splicing method.
- J. Form changes in direction as follows:
  - 1. As detailed.
  - 2. By bending or by inserting prefabricated elbow fittings.
  - 3. By flush bends or by inserting prefabricated flush-elbow fittings.
- K. Form simple and compound curves by bending members in jigs to produce uniform curvature for each repetitive configuration required; maintain cross section of member throughout entire bend without buckling, twisting, cracking, or otherwise deforming exposed surfaces of components.
- L. Close exposed ends of railing members with prefabricated end fittings.
- M. Provide wall returns at ends of wall-mounted handrails, unless otherwise indicated. Close ends of returns unless clearance between end of rail and wall is 1/4 inch (6 mm) or less.
- N. Brackets, Flanges, Fittings, and Anchors: Provide wall brackets, flanges, miscellaneous fittings, and anchors to interconnect railing members to other work, unless otherwise indicated.
- O. Provide inserts and other anchorage devices for connecting railings to concrete or masonry work. Fabricate anchorage devices capable of withstanding loads imposed by railings. Coordinate anchorage devices with supporting structure.
- P. Toe Boards: Where indicated, provide toe boards at railings around openings and at edge of open-sided floors and platforms. Fabricate to dimensions and details indicated.

## 2.6 FINISHES, GENERAL

- A. Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.

## 2.7 STEEL AND IRON FINISHES

- A. Galvanized Railings:
  - 1. Hot-dip galvanize exterior steel and iron railings, including hardware, after fabrication.
  - 2. Comply with ASTM A 123/A 123M for hot-dip galvanized railings.
- B. Fill vent and drain holes that will be exposed in the finished Work, unless indicated to remain as weep holes, by plugging with zinc solder and filing off smooth.
- C. For galvanized railings, provide hot-dip galvanized fittings, brackets, fasteners, sleeves, and other ferrous components.
- D. Preparation for Shop Priming: Prepare uncoated ferrous-metal surfaces to comply with minimum requirements indicated below for SSPC surface preparation specifications and environmental exposure conditions of installed railings:
  - 1. Exterior Railings (SSPC Zone 1B): SSPC-SP 6/NACE No. 3, "Commercial Blast Cleaning."
  - 2. Interior Railings (SSPC Zone 1A): SSPC-SP 7/NACE No. 4, "Brush-off Blast Cleaning."
- E. Apply shop primer to prepared surfaces of railings, unless otherwise indicated. Comply with requirements in SSPC-PA 1, "Paint Application Specification No. 1: Shop, Field, and Maintenance Painting of Steel," for shop painting. Primer need not be applied to surfaces to be embedded in concrete or masonry.
  - 1. Do not apply primer to galvanized surfaces.

## PART 3 - EXECUTION

### 3.1 INSTALLATION, GENERAL

- A. Fit exposed connections together to form tight, hairline joints.
- B. Perform cutting, drilling, and fitting required for installing railings. Set railings accurately in location, alignment, and elevation; measured from established lines and levels and free of rack.
  - 1. Do not weld, cut, or abrade surfaces of railing components that have been coated or finished after fabrication and that are intended for field connection by mechanical or other means without further cutting or fitting.
  - 2. Set posts plumb within a tolerance of 1/16 inch in 3 feet (2 mm in 1 m).
  - 3. Align rails so variations from level for horizontal members and variations from parallel with rake of steps and ramps for sloping members do not exceed 1/4 inch in 12 feet (5 mm in 3 m).
- C. Adjust railings before anchoring to ensure matching alignment at abutting joints.
- D. Fastening to In-Place Construction: Use anchorage devices and fasteners where necessary for securing railings and for properly transferring loads to in-place construction.



### 3.2 RAILING CONNECTIONS

- A. Welded Connections: Use fully welded joints for permanently connecting railing components. Comply with requirements for welded connections in Part 2 "Fabrication" Article whether welding is performed in the shop or in the field.

### 3.3 ANCHORING POSTS

- A. Form or core-drill holes not less than 5 inches (125 mm) deep and 3/4 inch (20 mm) larger than OD of post for installing posts in concrete. Clean holes of loose material, insert posts, and fill annular space between post and concrete with nonshrink, nonmetallic grout, mixed and placed to comply with anchoring material manufacturer's written instructions.
- B. Leave anchorage joint exposed; wipe off surplus anchoring material; and leave 1/8-inch (3-mm) buildup, sloped away from post.
- C. Anchor posts to metal surfaces as required by conditions, connected to posts and to metal supporting members as follows:
  - 1. For steel pipe railings, weld post to metal supporting surfaces.
  - 2. Where bottom of posts are exposed, weld end cap onto post to cover hole.

### 3.4 ATTACHING HANDRAILS TO WALLS

- A. Attach handrails to wall with wall brackets. Provide brackets with 1-1/2-inch (38-mm) clearance from inside face of handrail and finished wall surface.
  - 1. Use type of bracket with predrilled hole for exposed bolt anchorage.
- B. Locate brackets as indicated or, if not indicated, at spacing required to support structural loads.
- C. Secure wall brackets to building construction as follows:
  - 1. For concrete and solid masonry anchorage, use drilled-in expansion shields and hanger or lag bolts.
  - 2. For hollow masonry anchorage, use toggle bolts.
  - 3. Use security type fasteners in inmate areas.

### 3.5 ADJUSTING AND CLEANING

- A. Touchup Painting: Cleaning and touchup painting of field welds, bolted connections, and abraded areas of shop paint are specified in Division 09 painting Sections.
- B. Galvanized Surfaces: Clean field welds, bolted connections, and abraded areas and repair galvanizing to comply with ASTM A780.

3.6 PROTECTION

- A. Protect finishes of railings from damage during construction period with temporary protective coverings approved by railing manufacturer. Remove protective coverings at time of Substantial Completion.
- B. Restore finishes damaged during installation and construction period so no evidence remains of correction work. Return items that cannot be refinished in the field to the shop; make required alterations and refinish entire unit, or provide new units.

END OF SECTION 05 5213

SECTION 05 5963 - DETENTION ENCLOSURES

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following for detention/security applications:
  - 1. Bar-grille assemblies.
  - 2. Woven-rod-mesh assemblies (WRM)
- B. Related Sections include the following:
  - 1. Division 013513.16 Section "Special Project Procedures for Detention Facilities" for general requirements of detention work, including responsibilities of a single-source detention specialist.
  - 2. Division 033000 Section "Cast-in-Place Concrete" for building anchors into concrete construction.
  - 3. Division 042200 Section "Unit Masonry" for building anchors into and grouting detention enclosures installed in masonry construction.
  - 4. Division 087163 Section "Detention Door Hardware" for detention hinges, sliding-detention-door-device assemblies, detention locks and latches, cylinders, and keying for bar-grille assemblies and woven-rod-mesh assemblies.
  - 5. Division 099123 Interior painting Sections for field painting detention enclosures.

1.3 SUBMITTALS

- A. Product Data: Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for each type of detention enclosure indicated.
- B. Shop Drawings: For each type of detention enclosure. Include plans, elevations, sections, details, and attachments to other Work. Indicate type of steel for each detention enclosure component.
  - 1. Indicate requirements for cast-in anchors to be installed as work of other Sections.
- C. Coordination Drawings: Drawings of each opening in detention enclosures, drawn to scale and coordinating detention door hardware. Show the following:
  - 1. Locations, dimensions, and profiles of detention door hardware reinforcements.
  - 2. Locations and installation details of detention door hardware.
  - 3. Elevations of each detention enclosure door design type showing dimensions, locations of detention door hardware, and preparations for power, signal, and electrified control systems.
  - 4. Details of each detention enclosure frame.

- D. Welding certificates.
- E. Qualification Data: For Installer.
- F. Material Test Reports: For homogeneous tool-resisting steel.
- G. Material Certificates: For homogeneous tool-resisting steel, signed by manufacturers, indicating compliance with performance requirements for complete test sequence according to applicable ASTM standard.
- H. Mill Certificates: For homogeneous tool-resisting steel rods, certifying that rods were fabricated from material with same chemical and physical properties as material used to fabricate homogeneous tool-resisting steel round bars.
- I. Maintenance Data: For doors in bar-grille assemblies and doors in woven-rod-mesh assemblies to include in maintenance manuals.

#### 1.4 QUALITY ASSURANCE

- A. Installer Qualifications: An authorized representative of detention enclosure manufacturer for installation and maintenance of units required for this Project.
- B. Testing Agency Qualifications: Qualified according to ASTM E 329 for testing homogeneous tool-resisting steel, as documented according to ASTM E 548.
- C. Source Limitations: Obtain each type and variety of detention enclosure through one source from a single manufacturer, unless otherwise indicated.
- D. Product Options: Drawings indicate size, profiles, and dimensional requirements of bar-grille assemblies and woven-rod-mesh assemblies and are based on the specific system indicated. Refer to Division 01 Section "Product Requirements."
  - 1. Do not modify intended security performance, as judged solely by Architect, except with Architect's approval. If modifications are proposed, submit comprehensive explanatory data to Architect for review.
- E. Welding: Qualify procedures and personnel according to the following:
  - 1. AWS D1.1, "Structural Welding Code--Steel."
  - 2. AWS D1.3, "Structural Welding Code--Sheet Steel."
- F. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination."

#### 1.5 DELIVERY, STORAGE, AND HANDLING

- A. Deliver each woven-rod-mesh assembly securely enclosed in a dimension-lumber crate, packaged at the factory, to provide protection during transit and job storage.
  - 1. Provide additional interior bracing as required to protect locksets.

- B. Inspect woven-rod-mesh assemblies on delivery for damage. Minor damage may be repaired provided refinished items match new work and are acceptable to Architect; otherwise, remove and replace damaged items as directed.

#### 1.6 PROJECT CONDITIONS

- A. Field Measurements: Verify detention enclosure openings by field measurements before fabrication and indicate measurements on Shop Drawings.
  - 1. Established Dimensions: Where field measurements cannot be made without delaying the Work, establish opening dimensions and proceed with fabricating detention enclosures without field measurements. Coordinate wall and floor construction to ensure that actual opening dimensions correspond to established dimensions.

#### 1.7 COORDINATION

- A. Coordinate installation of anchorages for detention enclosures. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors that are to be embedded in concrete or masonry. Deliver such items to Project site in time for installation.

#### 1.8 MAINTENANCE TOOLS

- A. Tool Kit: Provide three sets of tools for use with security fasteners, each packaged in a compartmented kit configured for easy handling and storage.

#### 1.9 EXTRA MATERIALS

- A. Furnish extra materials described below that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Security Fasteners: Furnish not less than twenty of each type and size of security fastener installed.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply for product selection:
  - 1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, the products specified.
  - 2. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the manufacturers specified.

2.2 MATERIALS

- A. Mild Steel Plates, Shapes, and Bars: ASTM A 36/A 36M.
- B. Hot-Rolled Steel Sheet: ASTM A 569/A 569M.
- C. Cold-Rolled Steel Sheet: ASTM A 366/A 366M.
- D. Steel Tubing: ASTM A 501 or ASTM A 513, Type B, unless otherwise indicated.
- E. High Strength, Low Alloy Steel Plate, Shape and Bars: ASTM A 572/A 572M Grade 50.
- F. Homogeneous Tool-Resisting Steel Round Bars: ASTM A 627.
- G. Homogeneous Tool-Resisting Steel Flat Bars: ASTM A 629.
- H. Homogeneous Tool-Resisting Steel Round Rods: Fabricated from material with same chemical and physical properties as homogeneous tool-resisting steel round bars.
- I. Security Fasteners: Operable only by tools produced for use on specific type of fastener by fastener manufacturer or other licensed fabricator. Drive system type, head style, material, and protective coating as required for assembly, installation, and strength, and as follows:
  - 1. Drive System Types: Pinned Torx-Plus or pinned Torx.
  - 2. Socket Flat Countersunk Head Fasteners:
    - a. Heat-treated alloy steel, ASTM F 835 (ASTM F 835M).
    - b. Stainless steel, ASTM F 879 (ASTM F 879M), Group 1 CW.
  - 3. Socket Button Head Fasteners:
    - a. Heat-treated alloy steel, ASTM F 835 (ASTM F 835M).
    - b. Stainless steel, ASTM F 879 (ASTM F 879M), Group 1 CW.
  - 4. Socket Head Cap Fasteners:
    - a. Heat-treated alloy steel, ASTM A 574 (ASTM A 574M).
    - b. Stainless steel, ASTM F 837 (ASTM F 837M), Group 1 CW.
  - 5. Protective Coatings for Heat-Treated Alloy Steel:
    - a. Zinc chromate, ASTM F 1135, Grade 3 or 4; for exterior applications and interior applications where indicated.
    - b. Zinc phosphate with oil, ASTM F 1137, Grade I, or black oxide, unless otherwise indicated.
  - 6. Available Manufacturers:
    - a. Camcar Textron Inc.
    - b. Holo-Krome; a Danaher Corporation.
    - c. Safety Socket Screw Corporation.
    - d. Tamper-Pruf Screws, Inc.
    - e. Tanner Bolt and Nut Co.
- J. Concealed Bolts: ASTM A 307, Grade A, unless otherwise indicated.

- K. Cast-in-Place Anchors in Concrete: Anchors of type indicated below, fabricated from corrosion-resistant materials capable of sustaining, without failure, a load equal to 4 times the load imposed, as determined by testing per ASTM E 488, conducted by a qualified independent testing agency.
  - 1. Threaded or wedge type; galvanized ferrous castings, either ASTM A 47 (ASTM A 47M), malleable iron or ASTM A 27/A 27M, cast steel. Provide bolts, washers, and shims as needed, hot-dip galvanized per ASTM A 153/A 153M.
- L. Embedded Plate Anchors: Fabricated from mild steel shapes and plates, minimum 3/16 inch (4.8 mm) thick; with minimum 1/2-inch- (12.7-mm-) diameter headed studs welded to back of plate.
- M. Welding Rods and Bare Electrodes: Select according to AWS specifications for metal alloy welded.

### 2.3 BAR-GRILLE ASSEMBLIES

- A. Available Manufacturers:
  - 1. Maximum Security Products Corp.
  - 2. Southern Folger Detention Equipment Company
  - 3. Petersen Enterprises, Inc.
  - 4. Willo Products Company Inc.
  - 5. Viking
- B. Tool-Resisting Steel Bar Grilles, Type A:
  - 1. Vertical Bars: 7/8-inch- (22-mm-) diameter, double-ribbed, round homogeneous tool-resisting steel bars at 4 inches (102 mm) o.c.
  - 2. Horizontal Flat Bars: 3/8-by-2-1/4-inch (9.5-by-57-mm) homogeneous tool-resisting steel flat bars at 12 inches (305 mm) o.c.
  - 3. Framing: 3/8-by-2-1/4-inch (9.5-by-57-mm) homogeneous tool-resisting steel flat bars.
- C. Finish: Factory primed for field painting.

### 2.4 WOVEN-ROD-MESH ASSEMBLIES (WRM)

- A. Available Manufacturers:
  - 1. G-S Company (The).
  - 2. Kane Manufacturing Corp.
  - 3. Maximum Security Products Corp.
  - 4. Norment Industries; Div. of Norment Security Group.
  - 5. Southern Folger Detention Equipment Company.
  - 6. Willo Products Company Inc.
  - 7. Petersen Enterprises, Inc.
  - 8. Viking
- B. General: Provide woven rod mesh assemblies for Segregation Dayroom Cage Gates consisting of main framing, woven-rod panels, concealment plates, and other fittings necessary for a complete assembly.

- C. Main Framing: Formed from 1-1/2-by-2-1/2-inch (38-by-63.5-mm) built-up tubular steel, consisting of an open channel with fixed concealment plates.
  - 1. Open Channel: Formed from minimum 0.0966-inch- (2.5-mm-) thick steel sheet, tubing, or channel; with individual slots along inner edges to support woven-rod panels.
  - 2. Concealment Plates: Steel sheet to match open channel.
- D. Woven-Rod Panels: Formed from double crimped, 3/8-inch (9.5-mm) steel rod, woven horizontally and vertically into a rigid grille with rods at 2 inches (51 mm) o.c.
  - 1. Steel Rod for Galvanized Assemblies: Mild [Homogeneous tool-resisting] steel.
- E. Finishes:
  - 1. Exterior Locations: Factory primed for field painting Hot-dip galvanized after fabrication.
  - 2. Interior Locations: Factory primed for field painting.

## 2.5 FABRICATION, GENERAL

- A. Shop Assembly: Preassemble items in shop to greatest extent possible to minimize field splicing and assembly. Disassemble units only as necessary for shipping and handling limitations. Use connections that maintain structural value of joined pieces. Clearly mark units for reassembly and coordinated installation.
- B. Coordinate dimensions and attachment methods of detention enclosures with those of adjoining construction to produce integrated assemblies with closely fitting joints and with edges and surfaces aligned, unless otherwise indicated.
- C. Shear and punch metals cleanly and accurately. Remove burrs.
- D. Form edges and corners to be free of sharp edges or rough areas. Fold back exposed edges of unsupported sheet metal to form a 1/2-inch- (12.7-mm-) wide hem on the concealed side, or ease edges to a radius of approximately 1/32 inch (0.8 mm) and support with concealed stiffeners.
- E. Form metal in maximum lengths to minimize joints. Form bent-metal corners to smallest radius possible without causing grain separation or otherwise impairing work.
- F. Weld corners and seams continuously to comply with referenced AWS standard and the following:
  - 1. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
  - 2. Obtain fusion without undercut or overlap.
  - 3. Remove welding flux immediately.
  - 4. At exposed connections, finish exposed welds and surfaces smooth and blended so no roughness shows after finishing and contour of welded surface matches that of adjacent surface.
  - 5. Weld before finishing components to greatest extent possible. Remove weld spatter and welding oxides from exposed surfaces by descaling or grinding.



- G. Provide for anchorage of type indicated; coordinate with supporting structure. Fabricate and space anchoring devices to secure metal fabrications rigidly in place and to support indicated loads. Build in straps, plates, and brackets as needed to support and anchor fabricated items to adjoining construction. Reinforce formed-metal units as needed to attach and support other construction.
- H. Cut, reinforce, drill, and tap metal fabrications as indicated to receive hardware, security fasteners, and similar items.
- I. Form exposed work true to line and level with accurate angles and surfaces and straight sharp edges.
- J. Form exposed connections with hairline joints flush and smooth, using concealed fasteners where possible. Use exposed security fasteners of type indicated or, if not indicated, flat-head (countersunk) security screws. Locate joints where least conspicuous.
- K. Fabricate joints that will be exposed to weather in a manner to exclude water, or provide weep holes where water may accumulate.
- L. Provide detention enclosures that allow for thermal movement resulting from the following maximum change (range) in ambient and surface temperatures by preventing buckling, opening up of joints, overstressing of components, failure of connections, and other detrimental effects. Base engineering calculation on surface temperatures of materials due to both solar heat gain and nighttime-sky heat loss.
  - 1. Temperature Change (Range): 120 deg F, ambient; 180 deg F, material surfaces.

## 2.6 FABRICATION OF BAR-GRILLE ASSEMBLIES

- A. General: Fabricate bar-grille assemblies with materials and to sizes and configurations indicated, complete with mounting flanges and anchors.
  - 1. Pass vertical round bars through, and positively interlock them with, horizontal flat bars at each intersection without reducing circumference of round bars at these intersections and without using pipe sleeves, swedging, calking, or interlocks that depend on friction.
  - 2. Pass ends of round bars through framing at least 1 inch (25 mm), and weld bars to framing from back side of framing.
  - 3. Fabricate cutouts and openings in bar-grille assemblies for penetrations of sizes and at locations indicated. Frame openings with flat bars of same material and size as horizontal flat bars.
  - 4. Frame connections with plates; use flat bars of same material and size as horizontal flat bars.
- B. Partitions: Connect top horizontal flat bar to vertical flat bar framing members with 2-by-2-by-1/4-inch- (51-by-51-by-6-mm-) thick, steel plate angle knee welded into place. Connect intersections of horizontal flat bars with vertical flat bar framing members by 3/16-inch (4.8-mm) fillet welds. Weld vertical bars securely to top and bottom flat bar framing members.
- C. Doors: Fabricate doors of same type bar-grille assembly as bar-grille partition in which they are installed. Weld lockbox at lock jamb of door, fabricated of steel plate to match horizontal flat bars.

## 2.7 FABRICATION OF WOVEN-ROD-MESH ASSEMBLIES

- A. Main Framing: Before installing woven-rod panels, weld and grind smooth corners of open channel elements.
- B. Woven-Rod Panels: Install panels symmetrically in main framing. Extend end of each rod into main framing at least 1 inch (25 mm) and weld, from inside of channel, into each slot where it contacts main framing.
- C. Concealment Plates: Weld plates to main framing with minimum 1 inch (25 mm) welds at 10 inches (254 mm) o.c., staggered side to side and ground smooth, to form a fully enclosed tubular steel frame.
- D. Anchor Clips: For each enclosure panel, weld one anchor clip to secure side of main framing in line with vertical framing.

## 2.8 FINISHES

- A. Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Finish detention enclosures after assembly.
- C. Surface Preparation: Remove mill scale and rust, if present, from uncoated steel, complying with SSPC-SP 6/NACE No. 3, "Commercial Blast Cleaning," or SSPC-SP 8, "Pickling."
- D. Factory Priming for Field-Painted Finish: Apply manufacturer's standard prime coat immediately after surface preparation and pretreatment.
- E. Galvanizing: For those items indicated for galvanizing, apply zinc coating by hot-dip process complying with ASTM A 123/A 123M after fabrication.
- F. Apply shop primer to uncoated surfaces of detention enclosures, except those with galvanized finishes and those to be embedded in concrete or masonry, unless otherwise indicated. Comply with SSPC-PA 1, "Paint Application Specification No. 1," for shop painting.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of detention enclosures.
  - 1. Examine roughing-in for embedded and built-in anchors to verify actual locations of detention enclosure connections before detention enclosure installation.
  - 2. For the record, prepare written report, endorsed by Installer, listing conditions detrimental to performance of detention enclosures.

- B. Inspect built-in and cast-in anchor installations before installing detention enclosures to verify that anchor installations comply with requirements. Prepare inspection reports.
  - 1. Remove and replace anchors where inspections indicate that they do not comply with specified requirements. Reinspect after repairs or replacements are made.
  - 2. Perform additional inspections to determine compliance of replaced or additional work. Prepare inspection reports.
- C. Verify locations of detention enclosures with those indicated on Coordination Drawings.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION, GENERAL

- A. General: Install detention enclosures plumb, rigid, properly aligned, and securely fastened in place, complying with Drawings, Coordination Drawings, and manufacturer's written recommendations.
- B. Fastening to In-Place Construction: Provide anchorage devices and fasteners where necessary for securing detention enclosures to in-place construction. Include threaded fasteners for concrete and masonry inserts, security fasteners, and other connectors.
- C. Cutting, Fitting, and Placement: Obtain manufacturer's written approval for cutting, drilling, and fitting required for installing detention enclosures. Set detention enclosures accurately in location, alignment, and elevation; with edges and surfaces level, plumb, true, and free of rack; and measured from established lines and levels.
- D. Fit exposed connections accurately together to form hairline joints. Weld connections that are not to be left as exposed joints but cannot be shop welded because of shipping-size limitations. Do not weld, cut, or abrade surfaces of exterior units that have been hot-dip galvanized after fabrication and are for bolted or screwed field connections.
- E. Field Welding: Comply with the following requirements:
  - 1. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
  - 2. Obtain fusion without undercut or overlap.
  - 3. Remove welding flux immediately.
  - 4. At exposed connections, finish exposed welds and surfaces smooth and blended so no roughness shows after finishing and contour of welded surface matches that of adjacent surface.

### 3.3 INSTALLATION OF BAR-GRILLE ASSEMBLIES

- A. Wall and Ceiling Anchorage: Weld framing to continuous angles with continuous welds. Anchor angles to embedded anchors by welding.
- B. Partitions: Weld adjacent framing members to each other with continuous 1/4-inch (6-mm) deep welds on both sides; grind smooth.

- C. Doors: Install doors 2 inches (51 mm) above finish floor. Adjust doors to operate easily without binding.

### 3.4 INSTALLATION OF WOVEN-ROD-MESH ASSEMBLIES

- A. Woven Rod Panel Anchorage to Segregation Recreation Cage Gate framing:
  - 1. Weld main framing to tube steel gate framing with 1-inch (25-mm) welds at 8 inches o.c.

### 3.5 FIELD QUALITY CONTROL

- A. Inspect installed products to verify compliance with requirements. Prepare inspection reports and indicate compliance with and deviations from the Contract Documents.
- B. Remove and replace detention work where inspections indicate that work does not comply with specified requirements.
- C. Perform additional inspections to determine compliance of replaced or additional work. Prepare inspection reports.
- D. Prepare field quality-control certification that states installed products and their installation comply with requirements in the Contract Documents.

### 3.6 CLEANING AND PROTECTION

- A. Touchup Painting: Cleaning and touchup painting of field welds, bolted connections, and abraded areas of shop paint are specified in Division 09 painting Sections.
- B. Galvanized Surfaces: Clean field welds, bolted connections, and abraded areas and repair galvanizing to comply with ASTM A 780.

END OF SECTION 05 5963

**DIVISION 06 – WOOD, PLASTICS AND COMPOSITES**



SECTION 061323 - HEAVY TIMBER FRAMING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes framing using timbers.
- B. Related Requirements:
  - 1. Section 061516 "Wood Roof Decking."
  - 2. Section 061800 "Glued-Laminated Construction."

1.3 DEFINITIONS

- A. Timbers: Lumber of 5 inches nominal (114 mm actual) or greater in least dimension.
- B. Poles: Round wood members, called either "poles" or "posts" in the referenced standards.
- C. Inspection agencies, and the abbreviations used to reference them, include the following:
  - 1. NeLMA: Northeastern Lumber Manufacturers' Association.
  - 2. NHLA: National Hardwood Lumber Association.
  - 3. NLGA: National Lumber Grades Authority.
  - 4. SPIB: Southern Pine Inspection Bureau (The).
  - 5. WCLIB: West Coast Lumber Inspection Bureau.
  - 6. WWPA: Western Wood Products Association.

1.4 ACTION SUBMITTALS

- A. Product Data: For timber connectors.
  - 1. For timber connectors. Include installation instructions.
- B. Shop Drawings: For heavy timber framing. Show layout, dimensions of each member, and details of connections.

1.5 INFORMATIONAL SUBMITTALS

- A. Material Certificates:

SECTION 06 1000 - ROUGH CARPENTRY

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Framing with dimension lumber.
2. Framing with engineered wood products.
3. Shear wall panels.
4. Rooftop equipment bases and support curbs.
5. Wood blocking, cants, and nailers.
6. Wood furring and grounds.
7. Plywood backing panels.

B. Related Requirements:

1. Section 06 1600 "Sheathing" for sheathing, subflooring, and underlayment.
2. Section 06 1800 "Glue-Laminated Construction" for wood beams.

1.3 DEFINITIONS

- A. Boards or Strips: Lumber of less than 2 inches nominal (38 mm actual) size in least dimension.
- B. Dimension Lumber: Lumber of 2 inches nominal (38 mm actual) size or greater but less than 5 inches nominal (114 mm actual) size in least dimension.
- C. Exposed Framing: Framing not concealed by other construction.
- D. OSB: Oriented strand board.

1.4 INFORMATIONAL SUBMITTALS

A. Evaluation Reports: For the following, from ICC-ES:

1. Engineered wood products.
2. Power-driven fasteners.
3. Post-installed anchors.
4. Metal framing anchors.



1.5 DELIVERY, STORAGE, AND HANDLING

- A. Stack wood products flat with spacers beneath and between each bundle to provide air circulation. Protect wood products from weather by covering with waterproof sheeting, securely anchored. Provide for air circulation around stacks and under coverings.

PART 2 - PRODUCTS

2.1 WOOD PRODUCTS, GENERAL

- A. Lumber: DOC PS 20 and applicable rules of grading agencies indicated. If no grading agency is indicated, comply with the applicable rules of any rules-writing agency certified by the ALSC Board of Review. Grade lumber by an agency certified by the ALSC Board of Review to inspect and grade lumber under the rules indicated.
  - 1. Factory mark each piece of lumber with grade stamp of grading agency.
  - 2. For exposed lumber indicated to receive a stained or natural finish, mark grade stamp on end or back of each piece or omit grade stamp and provide certificates of grade compliance issued by grading agency.
  - 3. Dress lumber, S4S, unless otherwise indicated.
- B. Maximum Moisture Content of Lumber: 19 percent, unless otherwise indicated.
- C. Engineered Wood Products: Acceptable to authorities having jurisdiction and for which current model code research or evaluation reports exist that show compliance with building code in effect for Project.
  - 1. Allowable design stresses, as published by manufacturer, shall meet or exceed those indicated. Manufacturer's published values shall be determined from empirical data or by rational engineering analysis and demonstrated by comprehensive testing performed by a qualified independent testing agency.

2.2 WOOD-PRESERVATIVE-TREATED LUMBER

- A. Preservative Treatment by Pressure Process: AWPA U1; Use Category UC2 for interior construction not in contact with ground, Use Category UC3b for exterior construction not in contact with ground, and Use Category UC4a for items in contact with ground.
  - 1. Preservative Chemicals: Acceptable to authorities having jurisdiction and containing no arsenic or chromium. Do not use inorganic boron (SBX) for sill plates.
- B. Kiln-dry lumber after treatment to a maximum moisture content of 19 percent. Do not use material that is warped or that does not comply with requirements for untreated material.
- C. Mark lumber with treatment quality mark of an inspection agency approved by the ALSC Board of Review.

D. Application: Treat items indicated on Drawings, and the following:

1. Wood cants, nailers, curbs, equipment support bases, blocking, stripping, and similar members in connection with roofing, flashing, vapor barriers, and waterproofing.
2. Wood sills, sleepers, blocking, and similar concealed members in contact with masonry or concrete.
3. Wood framing and furring attached directly to the interior of below-grade exterior masonry or concrete walls.
4. Wood framing members that are less than 18 inches (460 mm) above the ground in crawlspaces or unexcavated areas.
5. Wood floor plates that are installed over concrete slabs-on-grade.

2.3 DIMENSION LUMBER FRAMING

A. Non-Load-Bearing Interior Partitions: No. 2 grade.

1. Application: All interior partitions.
2. Species:
  - a. Douglas fir-larch (north); NLGA.

B. Load-Bearing Partitions: No. 2 grade.

1. Application: Exterior walls and interior load-bearing partitions.
2. Species:
  - a. Douglas fir-larch (north); NLGA.

C. Ceiling Joists: No. 2 grade.

1. Species:
  - a. Douglas fir-larch (north); NLGA.

D. Joists, Rafters, and Other Framing Not Listed Above: No. 2 grade.

1. Species:
  - a. Douglas fir-larch (north); NLGA.

E. Exposed Framing Indicated to Receive a Stained or Natural Finish: Hand-select material for uniformity of appearance and freedom from characteristics, on exposed surfaces and edges, that would impair finish appearance, including decay, honeycomb, knot-holes, shake, splits, torn grain, and wane.

1. Species and Grade: Douglas fir-larch (north); No. 2 grade; NLGA.

2.4 ENGINEERED WOOD PRODUCTS

A. Source Limitations: Obtain each type of engineered wood product from single source from a single manufacturer.

- B. Laminated-Veneer Lumber: Structural composite lumber made from wood veneers with grain primarily parallel to member lengths, evaluated and monitored according to ASTM D 5456 and manufactured with an exterior-type adhesive complying with ASTM D 2559.
  - 1. RedBuilt, Red-Lam per ICC Report ESR-2993
  - 2. Extreme Fiber Stress in Bending, Edgewise: 2445 psi for 12-inch nominal- (286-mm actual-) depth members.
  - 3. Modulus of Elasticity, Edgewise: 1,800,000 psi (12 400 MPa).
- C. Wood I-Joists: Prefabricated units, I-shaped in cross section, made with solid or structural composite lumber flanges and wood-based structural panel webs, let into and bonded to flanges. Comply with material requirements of and with structural capacities established and monitored according to ASTM D 5055.
  - 1. Red-Built
  - 2. Web Material: Either OSB or plywood, complying with DOC PS 1 or DOC PS 2, Exposure 1.
  - 3. Structural Properties: Depths and design values not less than those indicated.
  - 4. Comply with APA PRI-400. Factory mark I-joists with APA-EWS trademark indicating nominal joist depth, joist class, span ratings, mill identification, and compliance with APA-EWS standard.
- D. Rim Boards: Product designed to be used as a load-bearing member and to brace wood I-joists at bearing ends, complying with research or evaluation report for I-joists.
  - 1. Manufacturer: Provide products by same manufacturer as I-joists.
  - 2. Material: product made from any combination solid lumber, wood strands, and veneers.
  - 3. Thickness: 1-1/4 inches (32 mm).
  - 4. Comply with APA PRR-401, rim board plus grade. Factory mark rim boards with APA-EWS trademark indicating thickness, grade, and compliance with APA-EWS standard.

## 2.5 MISCELLANEOUS LUMBER

- A. General: Provide miscellaneous lumber indicated and lumber for support or attachment of other construction, including the following:
  - 1. Blocking.
  - 2. Nailers.
  - 3. Rooftop equipment bases and support curbs.
  - 4. Cants.
  - 5. Furring.
  - 6. Grounds.
- B. Dimension Lumber Items: Construction or No. 2 grade lumber of any of the following species:
  - 1. Hem-fir (north); NLGA.
  - 2. Hem-fir; WCLIB or WWPA.
  - 3. Western woods; WCLIB or WWPA.
  - 4. Northern species; NLGA.

- C. Concealed Boards: 19 percent maximum moisture content and any of the following species and grades:
  - 1. Hem-fir or hem-fir (north); Construction or No. 2 Common grade; NLGA, WCLIB, or WWPA.
  - 2. Northern species; No. [2] [3] Common grade; NLGA.
  - 3. Western woods; Construction or No. 2 Common grade; WCLIB or WWPA.
- D. For blocking not used for attachment of other construction, Utility, Stud, or No. 3 grade lumber of any species may be used provided that it is cut and selected to eliminate defects that will interfere with its attachment and purpose.
- E. For blocking and nailers used for attachment of other construction, select and cut lumber to eliminate knots and other defects that will interfere with attachment of other work.
- F. For furring strips for installing plywood or hardboard paneling, select boards with no knots capable of producing bent-over nails and damage to paneling.

## 2.6 PLYWOOD BACKING PANELS

- A. Equipment Backing Panels: Plywood, DOC PS 1, Exposure 1, C-D Plugged, in thickness indicated or, if not indicated, not less than 3/4-inch (19-mm) nominal thickness.

Plywood, where required by code, shall be fire-retardant treated to result in a flame spread rating of 25 or less with no evidence of significant progressive combustion when tested for 30 minutes duration under ASTM E-84 and shall bear the testing laboratory mark on the surface to be concealed.

## 2.7 FASTENERS

- A. General: Fasteners shall be of size and type indicated and shall comply with requirements specified in this article for material and manufacture.
  - 1. Where rough carpentry is exposed to weather, in ground contact, pressure-preservative treated, or in area of high relative humidity, provide fasteners with hot-dip zinc coating complying with ASTM A 153/A 153M.
- B. Nails, Brads, and Staples: ASTM F 1667.
- C. Power-Driven Fasteners: Fastener systems with an evaluation report acceptable to authorities having jurisdiction, based on ICC-ES AC70.
- D. Post-Installed Anchors: Fastener systems with an evaluation report acceptable to authorities having jurisdiction, based on ICC-ES AC01, ICC-ES AC58, ICC-ES AC193 or ICC-ES AC308 as appropriate for the substrate.
  - 1. Material: Carbon-steel components, zinc plated to comply with ASTM B 633, Class Fe/Zn 5.

2. Material: Stainless steel with bolts and nuts complying with ASTM F 593 and ASTM F 594, Alloy Group 1 or 2 (ASTM F 738M and ASTM F 836M, Grade A1 or A4).

## 2.8 METAL FRAMING ANCHORS

- A. Simpson Strong-Tie is the approved connector manufacture.
- B. Allowable design loads, as published by manufacturer, shall meet or exceed those of products of manufacturers listed. Manufacturer's published values shall be determined from empirical data or by rational engineering analysis and demonstrated by comprehensive testing performed by a qualified independent testing agency. Framing anchors shall be punched for fasteners adequate to withstand same loads as framing anchors.
- C. Galvanized-Steel Sheet: Hot-dip, zinc-coated steel sheet complying with ASTM A 653/A 653M, G60 (Z180) coating designation.
  1. Use for interior locations unless otherwise indicated.
- D. Hot-Dip, Heavy-Galvanized Steel Sheet: ASTM A 653/A 653M; structural steel (SS), high-strength low-alloy steel Type A (HSLAS Type A), or high-strength low-alloy steel Type B (HSLAS Type B); G185 (Z550) coating designation; and not less than 0.036 inch (0.9 mm) thick.
  1. Use for wood-preserved-treated lumber and where indicated.

## 2.9 MISCELLANEOUS MATERIALS

- A. Sill-Sealer Gaskets: Closed-cell neoprene foam, 1/4 inch (6.4 mm) thick, selected from manufacturer's standard widths to suit width of sill members indicated.
- B. Flexible Flashing: Composite, self-adhesive, flashing product consisting of a pliable, butyl rubber or rubberized-asphalt compound, bonded to a high-density polyethylene film, aluminum foil, or spunbonded polyolefin to produce an overall thickness of not less than 0.025 inch (0.6 mm).
- C. Water-Repellent Preservative: NWWDA-tested and -accepted formulation containing 3-iodo-2-propynyl butyl carbamate, combined with an insecticide containing chloropyrifos as its active ingredient.

## PART 3 - EXECUTION

### 3.1 INSTALLATION, GENERAL

- A. Framing Standard: Comply with AF&PA's WCD 1, "Details for Conventional Wood Frame Construction," unless otherwise indicated.

- B. Framing with Engineered Wood Products: Install engineered wood products to comply with manufacturer's written instructions.
- C. Set rough carpentry to required levels and lines, with members plumb, true to line, cut, and fitted. Fit rough carpentry accurately to other construction. Locate furring, nailers, blocking, grounds, and similar supports to comply with requirements for attaching other construction.
- D. Install plywood backing panels by fastening to studs; coordinate locations with utilities requiring backing panels.
- E. Install metal framing anchors to comply with manufacturer's written instructions. Install fasteners through each fastener hole.
- F. Install sill sealer gasket to form continuous seal between sill plates and foundation walls.
- G. Do not splice structural members between supports unless otherwise indicated.
- H. Provide blocking and framing as indicated and as required to support facing materials, fixtures, specialty items, and trim.
  - 1. Provide metal clips for fastening gypsum board or lath at corners and intersections where framing or blocking does not provide a surface for fastening edges of panels. Space clips not more than 16 inches (406 mm) o.c.
- I. Provide fire blocking in furred spaces, stud spaces, and other concealed cavities as indicated and as follows:
  - 1. Fire block furred spaces of walls, at each floor level, at ceiling, and at not more than 96 inches (2438 mm) o.c. with solid wood blocking or noncombustible materials accurately fitted to close furred spaces.
  - 2. Fire block concealed spaces of wood-framed walls and partitions at each floor level, at ceiling line of top story, and at not more than 96 inches (2438 mm) o.c. Where fire blocking is not inherent in framing system used, provide closely fitted solid wood blocks of same width as framing members and 2-inch nominal (38-mm actual) thickness.
  - 3. Fire block concealed spaces between floor sleepers with same material as sleepers to limit concealed spaces to not more than 100 sq. ft. (9.3 sq. m) and to solidly fill space below partitions.
  - 4. Fire block concealed spaces behind combustible cornices and exterior trim at not more than 20 feet (6 m) o.c.
- J. Sort and select lumber so that natural characteristics do not interfere with installation or with fastening other materials to lumber. Do not use materials with defects that interfere with function of member or pieces that are too small to use with minimum number of joints or optimum joint arrangement.
- K. Comply with AWWA M4 for applying field treatment to cut surfaces of preservative-treated lumber.
  - 1. Use copper naphthenate for items not continuously protected from liquid water.

- L. Where wood-preservative-treated lumber is installed adjacent to metal decking, install continuous flexible flashing separator between wood and metal decking.
- M. Securely attach rough carpentry work to substrate by anchoring and fastening as indicated, complying with the following:
  - 1. See Fastening Schedule on the Drawings.
  - 2. ICC-ES evaluation report for fastener.
- N. Use steel common nails unless otherwise indicated. Select fasteners of size that will not fully penetrate members where opposite side will be exposed to view or will receive finish materials. Make tight connections between members. Install fasteners without splitting wood. Drive nails snug but do not countersink nail heads unless otherwise indicated.
- O. For exposed work, arrange fasteners in straight rows parallel with edges of members, with fasteners evenly spaced, and with adjacent rows staggered.
  - 1. Comply with indicated fastener patterns where applicable
  - 2. Use finishing nails unless otherwise indicated. Countersink nail heads and fill holes with wood filler.
  - 3. Use common nails unless otherwise indicated. Drive nails snug but do not countersink nail heads.

### 3.2 WOOD BLOCKING, AND NAILER INSTALLATION

- A. Install where indicated and where required for attaching other work. Form to shapes indicated and cut as required for true line and level of attached work. Coordinate locations with other work involved.
- B. Attach items to substrates to support applied loading. Recess bolts and nuts flush with surfaces unless otherwise indicated.
- C. Provide permanent grounds of dressed, pressure-preservative-treated, key-beveled lumber not less than 1-1/2 inches (38 mm) wide and of thickness required to bring face of ground to exact thickness of finish material. Remove temporary grounds when no longer required.

### 3.3 WOOD FURRING INSTALLATION

- A. Install level and plumb with closure strips at edges and openings. Shim with wood as required for tolerance of finish work.
- B. Furring to Receive Plywood or Hardboard Paneling: Install 1-by-3-inch nominal- (19-by-63-mm actual-) size furring horizontally at 24 inches (610 mm) o.c.
- C. Furring to Receive Gypsum Board: Install 1-by-2-inch nominal- (19-by-38-mm actual-) size furring vertically at 16 inches (406 mm) o.c.

### 3.4 WALL AND PARTITION FRAMING INSTALLATION

- A. General: Provide single bottom plate and double top plates using members of 2-inch nominal (38-mm actual) thickness whose widths equal that of studs, except single top plate may be used for non-load-bearing partitions. Fasten plates to supporting construction unless otherwise indicated.
1. For exterior walls, provide 2-by-6-inch nominal- (38-by-140-mm actual-) size wood studs spaced 16 inches (406 mm) o.c. unless otherwise indicated.
  2. For interior partitions and walls, provide 2-by-6-inch nominal- (38-by-140-mm actual-) size wood studs spaced 16 inches (406 mm)o.c. unless otherwise indicated.
  3. Provide continuous horizontal blocking at midheight of partitions more than 96 inches (2438 mm) high, using members of 2-inch nominal (38-mm actual) thickness and of same width as wall or partitions.
- B. Construct corners and intersections with three or more studs, except that two studs may be used for interior non-load-bearing partitions.
- C. Frame openings with multiple studs and headers. Provide nailed header members of thickness equal to width of studs. Support headers on jamb studs.
1. For non-load-bearing partitions, provide double-jamb studs and headers not less than 4-inch nominal (89-mm actual) depth for openings 48 inches (1200 mm) and less in width, 6-inch nominal (140-mm actual) depth for openings 48 to 72 inches (1200 to 1800 mm) in width, 8-inch nominal (184-mm actual) depth for openings 72 to 120 inches (1800 to 3000 mm) in width, and not less than 10-inch nominal (235-mm actual) depth for openings 10 to 12 feet (3 to 3.6 m) in width.
  2. For load-bearing walls, as indicated on the drawings.

### 3.5 FLOOR JOIST FRAMING INSTALLATION

- A. General: Install floor joists with crown edge up and support ends of each member with not less than 1-1/2 inches (38 mm) of bearing on wood or metal, or 3 inches (76 mm) on masonry. Attach floor joists as follows:
1. Where supported on wood members, by using metal framing anchors.
  2. Where framed into wood supporting members, by using wood ledgers as indicated or, if not indicated, by using metal joist hangers.
- B. Frame openings with headers and trimmers supported by metal joist hangers; double headers and trimmers where span of header exceeds 48 inches (1200 mm).
- C. Do not notch in middle third of joists; limit notches to one-sixth depth of joist, one-third at ends. Do not bore holes larger than one-third depth of joist; do not locate closer than 2 inches (50 mm) from top or bottom.
- D. Provide solid blocking of 2-inch nominal (38-mm actual) thickness by depth of joist at ends of joists unless nailed to header or band.



- E. Lap members framing from opposite sides of beams, girders, or partitions not less than 4 inches (102 mm) or securely tie opposing members together. Provide solid blocking of 2-inch nominal (38-mm actual) thickness by depth of joist over supports.
- F. Provide solid blocking between joists under jamb studs for openings.
- G. Under non-load-bearing partitions, provide double joists separated by solid blocking equal to depth of studs above.
  - 1. Provide triple joists separated as above, under partitions receiving ceramic tile and similar heavy finishes or fixtures.
- H. Provide bridging of type indicated below, at intervals of 96 inches (2438 mm) o.c., between joists.
  - 1. Diagonal wood bridging formed from bevel-cut, 1-by-3-inch nominal- (19-by-64-mm actual-) size lumber, double-crossed and nailed at both ends to joists.
  - 2. Steel bridging installed to comply with bridging manufacturer's written instructions.

### 3.6 CEILING JOIST AND RAFTER FRAMING INSTALLATION

- A. Ceiling Joists: Install with crown edge up and complying with requirements specified above for floor joists. Face nail to ends of parallel rafters.
  - 1. Where ceiling joists are at right angles to rafters, provide additional short joists parallel to rafters from wall plate to first joist; nail to ends of rafters and to top plate, and nail to first joist or anchor with framing anchors or metal straps. Provide 1-by-8-inch nominal- (19-by-184-mm actual-) size or 2-by-4-inch nominal- (38-by-89-mm actual-) size stringers spaced 48 inches (1200 mm) o.c. crosswise over main ceiling joists.
- B. Rafters: Notch to fit exterior wall plates and[ toe nail or] use metal framing anchors. Double rafters to form headers and trimmers at openings in roof framing, if any, and support with metal hangers. Where rafters abut at ridge, place directly opposite each other and nail to ridge member or use metal ridge hangers.
  - 1. At valleys, provide double-valley rafters of size indicated or, if not indicated, of same thickness as regular rafters and 2 inches (50 mm) deeper. Bevel ends of jack rafters for full bearing against valley rafters.
  - 2. At hips, provide hip rafter of size indicated or, if not indicated, of same thickness as regular rafters and 2 inches (50 mm) deeper. Bevel ends of jack rafters for full bearing against hip rafter.
- C. Provide collar beams (ties) as indicated or, if not indicated, provide 1-by-6-inch nominal- (19-by-140-mm actual-) size boards between every third pair of rafters, but not more than 48 inches (1219 mm) o.c. Locate below ridge member, at third point of rafter span. Cut ends to fit roof slope and nail to rafters.
- D. Provide special framing as indicated for eaves, overhangs, dormers, and similar conditions if any.

3.7 TIMBER FRAMING INSTALLATION

- A. Install timber beams with crown edge up and provide not less than 4 inches (102 mm) of bearing on supports. Provide continuous members unless otherwise indicated; tie together over supports as indicated if not continuous.
- B. Install wood posts using metal anchors indicated.
- C. Treat ends of timber beams and posts exposed to weather by dipping in water-repellent preservative for 15 minutes.

3.8 STAIR FRAMING INSTALLATION

- A. Provide stair framing members of size, space, and configuration indicated or, if not indicated, to comply with the following requirements:
  - 1. Size: 2-by-12-inch nominal (38-by-286-mm actual) size, minimum.
  - 2. Material: solid lumber.
  - 3. Notching: Notch rough carriages to receive treads, risers, and supports; leave at least 5-1/2 inches (89 mm) of effective depth.
- B. Provide stair framing with no more than 3/16-inch (4.7-mm) variation between adjacent treads and risers and no more than 3/8-inch (9.5-mm) variation between largest and smallest treads and risers within each flight.

3.9 PROTECTION

- A. Protect rough carpentry from weather. If, despite protection, rough carpentry becomes wet enough that moisture content exceeds that specified, apply EPA-registered borate treatment. Apply borate solution by spraying to comply with EPA-registered label.

END OF SECTION 061000



SECTION 061323 - HEAVY TIMBER FRAMING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes framing using timbers.
- B. Related Requirements:
  - 1. Section 061516 "Wood Roof Decking."
  - 2. Section 061800 "Glued-Laminated Construction."

1.3 DEFINITIONS

- A. Timbers: Lumber of 5 inches nominal (114 mm actual) or greater in least dimension.
- B. Poles: Round wood members, called either "poles" or "posts" in the referenced standards.
- C. Inspection agencies, and the abbreviations used to reference them, include the following:
  - 1. NeLMA: Northeastern Lumber Manufacturers' Association.
  - 2. NHLA: National Hardwood Lumber Association.
  - 3. NLGA: National Lumber Grades Authority.
  - 4. SPIB: Southern Pine Inspection Bureau (The).
  - 5. WCLIB: West Coast Lumber Inspection Bureau.
  - 6. WWPA: Western Wood Products Association.

1.4 ACTION SUBMITTALS

- A. Product Data: For timber connectors.
  - 1. For timber connectors. Include installation instructions.
- B. Shop Drawings: For heavy timber framing. Show layout, dimensions of each member, and details of connections.

1.5 INFORMATIONAL SUBMITTALS

- A. Material Certificates:

1. For timbers specified to comply with minimum allowable unit stresses. Indicate species and grade selected for each use and design values approved by ALSC's Board of Review.
- B. Certificates of Inspection: Issued by lumber-grading agency for exposed timber not marked with grade stamp.

#### 1.6 QUALITY ASSURANCE

- A. Timber Manufacturer Qualifications: A qualified manufacturer that is certified for chain of custody by an FSC-accredited certification body.
- B. Timber Vendor Qualifications: A vendor that is certified for chain of custody by an FSC-accredited certification body.

#### 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Schedule delivery of materials to avoid extended on-site storage and to avoid delaying the Work.
- B. Store materials under cover and protected from weather and contact with damp or wet surfaces. Provide for air circulation within and around stacks and under temporary coverings.

### PART 2 - PRODUCTS

#### 2.1 WOOD MATERIALS, GENERAL

- A. Regional Materials: Timbers shall be milled within 500 miles (800 km) of Project site from wood that has been harvested within 500 miles (800 km) of Project site.
- B. Certified Wood: Timbers shall be certified as "FSC Pure" according to FSC STD-01-001, "FSC Principles and Criteria for Forest Stewardship," and to FSC STD-40-004, "FSC Standard for Chain of Custody Certification."

#### 2.2 TIMBER

- A. Comply with DOC PS 20 and with grading rules of lumber-grading agencies certified by ALSC's Board of Review as applicable.
  1. Factory mark each item of timber with grade stamp of grading agency.
  2. For exposed timber indicated to receive a stained or natural finish, apply grade stamps to surfaces that are not exposed to view, or omit grade stamps and provide certificates of grade compliance issued by grading agency.
- B. Timber Species and Grade: Douglas fir-larch or Douglas fir-larch (North); No. 2 or better , NLGA, WCLIB, or WWPA.

- C. Structural Properties: Provide any species and grade that, for moisture content provided, complies with required structural properties.
- D. Moisture Content: Provide timber with 19 percent maximum moisture content at time of dressing
- E. Dressing: Provide dressed timber (S4S) unless otherwise indicated.

### 2.3 TIMBER CONNECTORS

- A. Manufacturers: Subject to compliance with requirements, provide products by Simpson Strong Tie. All connectors shall be provided as shown on the drawings.
- B. Materials: Unless otherwise indicated, fabricate from the following materials:
  - 1. Structural-steel shapes, plates, and flat bars complying with ASTM A 36/A 36M.
- C. Hot-dip galvanize steel assemblies and fasteners after fabrication to comply with ASTM A 123/A 123M or ASTM A 153/A 153M.

### 2.4 FABRICATION

- A. Shop fabricate members by cutting and restoring exposed surfaces to match specified surfacing. Finish exposed surfaces to remove planing or surfacing marks, and to provide a finish equivalent to that produced by machine sanding with No. 120 grit sandpaper.
- B. Predrill for fasteners and assembly of units.
- C. Where preservative-treated members are indicated, fabricate (cut, drill, surface, and sand) before treatment to greatest extent possible. Where fabrication must be done after treatment, apply a field-treatment preservative to comply with AWPA M4.
  - 1. Use inorganic boron (SBX) treatment for members not in contact with the ground and continuously protected from liquid water.
  - 2. Use copper naphthenate treatment for members in contact with the ground or not continuously protected from liquid water.
- D. Coat crosscuts with end sealer.
- E. Seal Coat: After fabricating and surfacing each unit, apply a saturation coat of penetrating sealer on surfaces of each unit except for treated wood where the treatment included a water repellent.

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- A. General: Erect heavy timber framing true and plumb. Provide temporary bracing to maintain lines and levels until permanent supporting members are in place.

1. Install horizontal and sloping members with crown edge up, and provide not less than 4 inches (102 mm) of bearing on supports. Provide continuous members unless otherwise indicated; tie together over supports with metal strap ties if not continuous.
  2. Handle and temporarily support heavy timber framing to prevent surface damage, compression, and other effects that might interfere with indicated finish.
- B. Framing Built into Masonry: Provide 1/2-inch (13-mm) clearance at tops, sides, and ends of members built into masonry, and bevel cut ends 3 inches (76 mm); do not embed more than 4 inches (102 mm) unless otherwise indicated.
- C. Cutting: Avoid extra cutting after fabrication. Where field fitting is unavoidable, comply with requirements for shop fabrication.
- D. Fitting: Fit members by cutting and restoring exposed surfaces to match specified surfacing.
1. Predrill for fasteners using timber connectors as templates.
  2. Finish exposed surfaces to remove planing or surfacing marks, and to provide a finish equivalent to that produced by machine sanding with No. 120 grit sandpaper.
  3. Coat crosscuts with end sealer.
  4. Where preservative-treated members must be cut during erection, apply a field-treatment preservative to comply with AWPAC M4.
    - a. Use inorganic boron (SBX) treatment for members not in contact with the ground and continuously protected from liquid water.
    - b. Use copper naphthenate treatment for members in contact with the ground or not continuously protected from liquid water.
- E. Install timber connectors as indicated.
1. Unless otherwise indicated, install bolts with same orientation within each connection and in similar connections.
  2. Install bolts with orientation as indicated or, if not indicated, as directed by Architect.
- 3.2 ADJUSTING
- A. Repair damaged surfaces and finishes after completing erection. Replace damaged heavy timber framing if repairs are not approved by Architect.

END OF SECTION 061323

SECTION 061516 - WOOD ROOF DECKING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes solid-sawn wood roof decking
- B. Related Requirements:
  - 1. Section 061800 "Glued-Laminated Construction".
  - 2. Section 061323 "Heavy Timber Construction"

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. For preservative-treated wood products, include chemical treatment manufacturer's written instructions for handling, storing, installing, and finishing treated material.

1.4 QUALITY ASSURANCE

- A. Manufacturer Qualifications: A qualified manufacturer that is certified for chain of custody by an FSC-accredited certification body.
- B. Vendor Qualifications: A vendor that is certified for chain of custody by an FSC-accredited certification body.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Schedule delivery of wood roof decking to avoid extended on-site storage and to avoid delaying the Work.
- B. Store materials under cover and protected from weather and contact with damp or wet surfaces. Provide for air circulation within and around stacks and under temporary coverings. Stack wood roof decking with surfaces that are to be exposed in the final Work protected from exposure to sunlight.



## PART 2 - PRODUCTS

### 2.1 WOOD ROOF DECKING, GENERAL

- A. General: Comply with DOC PS 20 and with applicable grading rules of inspection agencies certified by ALSC's Board of Review.
- B. Regional Materials: Wood roof decking shall be manufactured within 500 miles (800 km) of Project site from wood that has been harvested and milled within 500 miles (800 km) of Project site.
- C. Regional Materials: Wood roof decking shall be manufactured within 500 miles (800 km) of Project site.
- D. Certified Wood: Wood roof decking shall be certified as "FSC Pure" according to FSC STD-01-001, "FSC Principles and Criteria for Forest Stewardship," and to FSC STD-40-004, "FSC Standard for Chain of Custody Certification."

### 2.2 SOLID-SAWN WOOD ROOF DECKING

- A. Standard for Solid-Sawn Wood Roof Decking: Comply with AITC 112.
- B. Roof Decking Species and size per plans.
- C. Grade Stamps: Factory mark each item with grade stamp of grading agency. Apply grade stamp to surfaces that are not exposed to view.
- D. Moisture Content: Provide wood roof decking with 15 percent maximum moisture content at time of dressing.

### 2.3 ACCESSORY MATERIALS

- A. Nails: Common; complying with ASTM F 1667, Type I, Style 10.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine support framing in areas to receive wood roof decking for compliance with installation tolerances and other conditions affecting performance of wood roof decking.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. Install solid-sawn wood roof decking to comply with AITC 112.

1. Locate end joints for two-span continuous lay-up.

B. Anchor wood roof decking, where supported on walls with nails.

3.3 ADJUSTING

A. Repair damaged surfaces and finishes after completing erection. Replace damaged roof decking if repairs are not approved by Architect.

3.4 PROTECTION

A. Provide water-resistive barrier over roof decking as the Work progresses to protect roof decking until roofing is applied.

B. If, despite protection, roof decking becomes wet, apply EPA-registered borate treatment. Apply borate solution by spraying to comply with EPA-registered label.

END OF SECTION 061516

SECTION 061800 - GLUED-LAMINATED CONSTRUCTION

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes framing using structural glued-laminated timber.
- B. Related Requirements:
  - 1. Section 061323 "Heavy Timber Construction" for framing using timbers
  - 2. Section 061516 "Wood Roof Decking" for glued-laminated wood roof decking.

1.3 DEFINITIONS

- A. Structural Glued-Laminated (Glulam) Timber: An engineered, stress-rated timber product assembled from selected and prepared wood laminations bonded together with adhesives and with the grain of the laminations approximately parallel longitudinally.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. Include data on lumber, adhesives, fabrication, and protection.
  - 2. For preservative-treated wood products. Include chemical treatment manufacturer's written instructions for handling, storing, installing, and finishing treated material.
  - 3. For connectors. Include installation instructions.
- B. Shop Drawings:
  - 1. Show layout of structural glued-laminated timber system and full dimensions of each member.
  - 2. Indicate species and laminating combination.
  - 3. Include large-scale details of connections.

1.5 INFORMATIONAL SUBMITTALS

- A. Certificates of Conformance: Issued by a qualified testing and inspecting agency indicating that structural glued-laminated timber complies with requirements in AITC A190.1.

- B. Material Certificates: For preservative-treated wood products, from manufacturer. Indicate type of preservative used and net amount of preservative retained.
- C. Research/Evaluation Reports: For structural glued-laminated timber, from ICC-ES.

#### 1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: An AITC- or APA-EWS-licensed firm.

#### 1.7 DELIVERY, STORAGE, AND HANDLING

- A. General: Comply with provisions in AITC 111.
- B. Individually wrap members using plastic-coated paper covering with water-resistant seams.

### PART 2 - PRODUCTS

#### 2.1 STRUCTURAL GLUED-LAMINATED TIMBER

- A. General: Provide structural glued-laminated timber that complies with AITC A190.1 and AITC 117 or research/evaluation reports acceptable to authorities having jurisdiction.
  - 1. Factory mark each piece of structural glued-laminated timber with AITC Quality Mark or APA-EWS trademark. Place mark on surfaces that are not exposed in the completed Work.
  - 2. Provide structural glued-laminated timber made from single species.
  - 3. Provide structural glued-laminated timber made from solid lumber laminations; do not use laminated veneer lumber.
  - 4. Provide structural glued-laminated timber made with wet-use adhesive complying with AITC A190.1.
  - 5. Adhesive shall not contain urea-formaldehyde resins.
  - 6. Adhesives shall comply with the testing and product requirements of the California Department of Public Health's (formerly, the California Department of Health Services') "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers."
- B. Regional Materials: Glued-laminated timber shall be manufactured within 500 miles (800 km) of Project site from wood that has been harvested and milled within 500 miles (800 km) of Project site.
- C. Certified Wood: Glued-laminated timber shall be certified as "FSC Pure" according to FSC STD-01-001, "FSC Principles and Criteria for Forest Stewardship," and to FSC STD-40-004, "FSC Standard for Chain of Custody Certification."
- D. Species and Grades for Structural Glued-Laminated Timber: Douglas fir-larch in grades needed to comply with "Performance Requirements" Article.

## 2.2 PRESERVATIVE TREATMENT

- A. Preservative Treatment: Where preservative-treated structural glued-laminated timber is indicated, comply with AWWA U1, Use Category 1.
  - 1. Use preservative solution without water repellents or substances that might interfere with application of indicated finishes.
  - 2. Do not incise structural glued-laminated timber or wood used to produce structural glued-laminated timber.
- B. Preservative ( One of the following):
  - 1. Oxine copper (copper-8-quinolinolate) in a light petroleum solvent.
  - 2. Pentachlorophenol in light petroleum solvent.
  - 3. Copper naphthenate in a light petroleum solvent.
  - 4. Ammoniacal zinc copper arsenate (ACZA) in a water solution.
  - 5. Chromated copper arsenate (CCA) in a water solution.
  - 6. Ammoniacal copper quat Type A (ACQ-C) in a water solution.
  - 7. Propiconazole tebuconazole imidacloprid (PTI) in a water emulsion.
- C. After dressing members, apply a copper naphthenate field-treatment preservative to comply with AWWA M4 to surfaces cut to a depth of more than 1/16 inch (1.5 mm).

## 2.3 TIMBER CONNECTORS

- A. Manufacturers: Simpson Strong Tie or as detailed on contract documents.
- B. Materials: Unless otherwise indicated, fabricate from the following materials:
  - 1. Structural-steel shapes, plates, and flat bars complying with ASTM A 36/A 36M.
- C. Finish steel assemblies and fasteners with rust-inhibitive primer, 2-mil (0.05-mm) dry film thickness.
  - 1. Primer shall comply with the testing and product requirements of the California Department of Public Health's (formerly, the California Department of Health Services') "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers."
- D. Hot-dip galvanize steel assemblies and fasteners after fabrication to comply with ASTM A 123/A 123M or ASTM A 153/A 153M.

## 2.4 MISCELLANEOUS MATERIALS

- A. End Sealer: Manufacturer's standard, transparent, colorless wood sealer that is effective in retarding the transmission of moisture at cross-grain cuts and is compatible with indicated finish.

- B. Penetrating Sealer: Manufacturer's standard, transparent, penetrating wood sealer that is compatible with indicated finish.
- C. Sealers shall comply with the testing and product requirements of the California Department of Public Health's (formerly, the California Department of Health Services') "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers."

## 2.5 FABRICATION

- A. Shop fabricate for connections to greatest extent possible, including cutting to length and drilling bolt holes.
  - 1. Dress exposed surfaces as needed to remove planing and surfacing marks.
- B. Camber: Fabricate horizontal and inclined members of less than 1:1 slope with either circular or parabolic camber equal to 1/500 of span.
- C. Where preservative-treated members are indicated, fabricate (cut, drill, surface, and sand) before treatment to greatest extent possible. Where fabrication must be done after treatment, apply a field-treatment preservative to comply with AWPA M4.
  - 1. Use inorganic boron (SBX) treatment for members not in contact with the ground and continuously protected from liquid water.
  - 2. Use copper naphthenate treatment for members in contact with the ground or not continuously protected from liquid water.
- D. End-Cut Sealing: Immediately after end cutting each member to final length, apply a saturation coat of end sealer to ends and other cross-cut surfaces, keeping surfaces flood coated for not less than 10 minutes.
- E. Seal Coat: After fabricating, sanding, and end-coat sealing, apply a heavy saturation coat of penetrating sealer on surfaces of each unit.

## 2.6 FACTORY FINISHING

- A. Wiped Stain Finish: Manufacturer's standard, dry-appearance, penetrating acrylic stain and sealer; oven dried and resistant to mildew and fungus.
  - 1. Color: [As indicated by manufacturer's designations] [Match Architect's sample] [As selected by Architect from manufacturer's full range] <Insert color>.
- B. Clear Finish: Manufacturer's standard, two-coat, clear varnish finish; resistant to mildew and fungus.
- C. Finishing materials shall comply with the testing and product requirements of the California Department of Public Health's (formerly, the California Department of Health Services') "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers."

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates in areas to receive structural glued-laminated timber, with Installer present, for compliance with requirements, installation tolerances, and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. General: Erect structural glued-laminated timber true and plumb and with uniform, close-fitting joints. Provide temporary bracing to maintain lines and levels until permanent supporting members are in place.
  - 1. Handle and temporarily support glued-laminated timber to prevent surface damage, compression, and other effects that might interfere with indicated finish.
- B. Framing Built into Masonry: Provide 1/2-inch (13-mm) clearance at tops, sides, and ends of members built into masonry; bevel cut ends 3 inches (76 mm); and do not embed more than 4 inches (102 mm) unless otherwise indicated.
- C. Cutting: Avoid extra cutting after fabrication. Where field fitting is unavoidable, comply with requirements for shop fabrication.
- D. Fit structural glued-laminated timber by cutting and restoring exposed surfaces to match specified surfacing and finishing.
  - 1. Predrill for fasteners using timber connectors as templates.
  - 2. Finish exposed surfaces to remove planing or surfacing marks and to provide a finish equivalent to that produced by machine sanding with No. 120 grit sandpaper.
  - 3. Coat cross cuts with end sealer.
  - 4. Where preservative-treated members must be cut during erection, apply a field-treatment preservative to comply with AWWA M4.
    - a. Use inorganic boron (SBX) treatment for members not in contact with the ground and continuously protected from liquid water.
    - b. Use copper naphthenate treatment for members in contact with the ground or not continuously protected from liquid water.
- E. Install timber connectors as indicated.
  - 1. Unless otherwise indicated, install bolts with same orientation within each connection and in similar connections.
  - 2. Install bolts with orientation as indicated or, if not indicated, as directed by Architect.



3.3 ADJUSTING

- A. Repair damaged surfaces and finishes after completing erection. Replace damaged structural glued-laminated timber if repairs are not approved by Architect.

3.4 PROTECTION

- A. Do not remove wrappings on individually wrapped members until they no longer serve a useful purpose, including protection from weather, sunlight, soiling, and damage from work of other trades.
  - 1. Coordinate wrapping removal with finishing work. Retain wrapping where it can serve as a painting shield.
  - 2. Slit underside of wrapping to prevent accumulation of moisture inside the wrapping.

END OF SECTION 061800

SECTION 06 4023 - INTERIOR ARCHITECTURAL WOODWORK

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Plastic-laminate cabinets.
  - 2. Plastic-laminate countertops.

1.3 DEFINITIONS

- A. Interior architectural woodwork includes wood furring, blocking, shims, and hanging strips for installing woodwork items unless concealed within other construction before woodwork installation.

1.4 SUBMITTALS

- A. Product Data: For each type of product indicated, including cabinet hardware and accessories-
- B. Shop Drawings: Show location of each item, dimensioned plans and elevations, large-scale details, attachment devices, and other components.
  - 1. Show locations and sizes of furring, blocking, and hanging strips, including concealed blocking and reinforcement specified in other Sections.
  - 2. Show locations and sizes of cutouts and holes for plumbing fixtures faucets and other items installed in architectural woodwork.
- C. Samples for Verification:
  - 1. Plastic laminates.
  - 2. Exposed cabinet hardware and accessories, one unit for each type and finish.

1.5 QUALITY ASSURANCE

- A. Fabricator Qualifications: Shop that employs skilled workers who custom-fabricate products similar to those required for this Project and whose products have a record of successful in-service performance. Shop is a certified participant in W.I. or AWI's Quality Certification Program.

- B. Quality Standard: Unless otherwise indicated, comply with W.I. and AWI's "Architectural Woodwork Quality Standards" for grades of interior architectural woodwork indicated for construction, finishes, installation, and other requirements.
- C. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination."

#### 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Do not deliver woodwork until painting and similar operations that could damage woodwork have been completed in installation areas. If woodwork must be stored in other than installation areas, store only in areas where environmental conditions comply with requirements specified in "Project Conditions" Article.

#### 1.7 PROJECT CONDITIONS

- A. Environmental Limitations: Do not deliver or install woodwork until building is enclosed, wet work is complete, and HVAC system is operating and maintaining temperature and relative humidity at occupancy levels during the remainder of the construction period.
- B. Field Measurements: Where woodwork is indicated to fit to other construction, verify dimensions of other construction by field measurements before fabrication, and indicate measurements on Shop Drawings. Coordinate fabrication schedule with construction progress to avoid delaying the Work.
  - 1. Locate concealed framing, blocking, and reinforcements that support woodwork by field measurements before being enclosed, and indicate measurements on Shop Drawings.
  - 2. Established Dimensions: Where field measurements cannot be made without delaying the Work, establish dimensions and proceed with fabricating woodwork without field measurements. Provide allowance for trimming at site, and coordinate construction to ensure that actual dimensions correspond to established dimensions.

#### 1.8 COORDINATION

- A. Coordinate sizes and locations of framing, blocking, furring, reinforcements, and other related units of Work specified in other Sections to ensure that interior architectural woodwork can be supported and installed as indicated.

### PART 2 - PRODUCTS

#### 2.1 MATERIALS

- A. General: Provide materials that comply with requirements of AWI's quality standard for each type of woodwork and quality grade specified, unless otherwise indicated.
- B. Wood Products: Comply with the following:
  - 1. Hardboard: AHA A135.4.

2. Medium-Density Fiberboard: ANSI A208.2, Grade MD, made with binder containing no urea formaldehyde.
  3. Softwood Plywood: DOC PS 1.
  4. Veneer-Faced Panel Products (Hardwood Plywood): HPVA HP-1, made with adhesive containing no urea formaldehyde.
- C. High-Pressure Decorative Laminate: NEMA LD 3, grades as indicated or, if not indicated, as required by woodwork quality standard.
1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering high-pressure decorative laminates that may be incorporated into the Work include, but are not limited to, the following:
  2. Manufacturer: Subject to compliance with requirements, provide high-pressure decorative laminates by one of the following:
    - a. Formica Corporation.
    - b. Lamin-Art, Inc.
    - c. Nevamar Company, LLC; Decorative Products Div.
    - d. Panolam Industries International Incorporated.
    - e. Wilsonart International; Div. of Premark International, Inc.

## 2.2 CABINET HARDWARE AND ACCESSORIES

- A. General: Provide cabinet hardware and accessory materials associated with architectural cabinets, except for items specified in Division 08 Section "Door Hardware (Scheduled by Describing Products)."
- B. Frameless Concealed Hinges (European Type): BHMA A156.9, B01602, 170 degrees of opening. (Blum Clip top 170 Hinges)
- C. Wire Pulls: Back mounted, solid metal, 4 inches (100 mm) long, 5/16 inch (8 mm) in diameter.
  1. Match Hafele 116.07.220
- D. Catches: Ball friction catches, BHMA A156.9, B03013.
  1. Match Hafele, 244.20.102
- E. Shelf Rests: BHMA A156.9, B04013; plastic, two-pin type with shelf hold-down clip.
  1. Match Hafele, 282.47.402
- F. Drawer Slides: BHMA A156.9, B05091. (Accuride 3832 series)
  1. Standard Duty (Grade 1, Grade 2, and Grade 3): Side mounted; full-extension type; zinc-plated steel with polymer rollers.
  2. Heavy Duty (Grade 1HD-100 and Grade 1HD-200): Side mounted; full-overtravel-extension type; zinc-plated steel ball-bearing slides.
  3. Box Drawer Slides: Grade 1HD-100; for drawers not more than 6 inches (150 mm) high and 24 inches (600 mm) wide.
  4. File Drawer Slides: Grade 1HD-100; for drawers more than 6 inches (150 mm) high or 24 inches (600 mm) wide.
- G. Door Locks: BHMA A156.11, E07121. (Comp National C8173)
- H. Drawer Locks: BHMA A156.11, E07041. (Comp National C8177)

- I. Grommets for Cable Passage through Countertops: 2-inch (51-mm) OD, black, molded-plastic grommets and matching plastic caps with slot for wire passage.
  - 1. Product: Subject to compliance with requirements, provide "OG series" by Doug Mockett & Company, Inc. (SP Flip Top series by Mockett)
- J. Exposed Hardware Finishes: For exposed hardware, provide finish that complies with BHMA A156.18 for BHMA finish number indicated.
  - 1. Satin Chromium Plated: BHMA 626 for brass or bronze base; BHMA 652 for steel base.
- K. For concealed hardware, provide manufacturer's standard finish that complies with product class requirements in BHMA A156.9.

## 2.3 MISCELLANEOUS MATERIALS

- A. Adhesives, General: Do not use adhesives that contain urea formaldehyde.
- B. Adhesive for Bonding Plastic Laminate: Unpigmented contact cement.
  - 1. Adhesive for Bonding Edges: Hot-melt adhesive or adhesive specified above for faces. (3M Fastbond 30-NF)
- C. T. Moulding: Plastic T cap moulding with flat face, color as selected.

## 2.4 FABRICATION, GENERAL

- A. Interior Woodwork Grade: Unless otherwise indicated, provide Custom grade interior woodwork complying with referenced quality standard.
- B. Wood Moisture Content: Comply with requirements of referenced quality standard for wood moisture content in relation to ambient relative humidity during fabrication and in installation areas.
- C. Fabricate woodwork to dimensions, profiles, and details indicated. Ease edges to radius indicated for the following:
  - 1. Corners of Cabinets and Edges of Solid-Wood (Lumber) Members 3/4 Inch (19 mm) Thick or Less: 1/16 inch (1.5 mm).
  - 2. Edges of Rails and Similar Members More Than 3/4 Inch Thick: 1/8 inch.
  - 3. Corners of Cabinets and Edges of Solid-Wood (Lumber) Members and Rails: 1/16 inch.
- D. Complete fabrication, including assembly, finishing, and hardware application, to maximum extent possible before shipment to Project site. Disassemble components only as necessary for shipment and installation. Where necessary for fitting at site, provide ample allowance for scribing, trimming, and fitting.
- E. Shop-cut openings to maximum extent possible to receive hardware, appliances, plumbing fixtures, electrical work, and similar items. Locate openings accurately and use templates or roughing-in diagrams to produce accurately sized and shaped openings. Sand edges of cutouts to remove splinters and burrs.
  - 1. Seal edges of openings in countertops with a coat of varnish.

2.5 PLASTIC-LAMINATE CABINETS

- A. Grade: Custom.
- B. AWS Type of Cabinet Construction: Flush overlay.
- C. Laminate Cladding for Exposed Surfaces: High-pressure decorative laminate complying with the following requirements:
  - 1. Horizontal Surfaces Other Than Tops: Grade HGS.
  - 2. Postformed Surfaces: Grade HGP.
  - 3. Vertical Surfaces: Grade HGS.
  - 4. Edges: PVC edge banding, 0.12 inch (3 mm).
- D. Materials for Semiexposed Surfaces:
  - 1. Woodwork manufacturer's standard low pressure laminate.
  - 2. Surfaces Other Than Drawer Bodies: High-pressure decorative laminate, Grade VGS.
  - 3. Drawer Sides and Backs: Solid-hardwood lumber.
- E. Concealed Backs of Panels with Exposed Plastic Laminate Surfaces: High-pressure decorative laminate, Grade BKL.
- F. Colors, Patterns, and Finishes: Provide materials and products that result in colors and textures of exposed laminate surfaces to match the following requirements:
  - 1. PL-1
    - a. Manufacturer: Wilsonart
    - b. Product: 7921-38 Tuscan Walnut
  - 2. PVC edge.
    - a. Manufacturer: Doeliken-Woodtape (Use 3mm PVC product)
    - b. Provide Samples for architect's selection

2.6 PLASTIC-LAMINATE COUNTERTOPS

- A. Grade: Custom.
- B. High-Pressure Decorative Laminate Grade: HGS.
- C. Colors, Patterns, and Finishes: Provide materials and products that result in colors and textures of exposed laminate surfaces to match the following requirements:
  - 1. PL-2
    - a. Manufacturer: Wilsonart
    - b. Product: AT981 Suede Coriander Fiber
  - 2. T-Molding
    - a. Manufacturer: Doeliken-Woodtape (Use 3mm PVC product)
    - b. Product: Provide Samples for architect's selection
- D. Edge Treatment: T-moulding.
- E. Core Material: Medium-density fiberboard.
- F. Paper Backing: Provide paper backing on underside of countertop substrate.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Before installation, condition woodwork to average prevailing humidity conditions in installation areas.
- B. Before installing architectural woodwork, examine shop-fabricated work for completion and complete work as required, including removal of packing and backpriming.

3.2 INSTALLATION

- A. Grade: Install woodwork to comply with requirements for the same grade specified in Part 2 for fabrication of type of woodwork involved.
- B. Assemble woodwork and complete fabrication at Project site to comply with requirements for fabrication in Part 2, to extent that it was not completed in the shop.
- C. Install woodwork level, plumb, true, and straight. Shim as required with concealed shims. Install level and plumb (including tops) to a tolerance of 1/8 inch in 96 inches (3 mm in 2400 mm).
- D. Scribe and cut woodwork to fit adjoining work, refinish cut surfaces, and repair damaged finish at cuts.
- E. Anchor woodwork to anchors or blocking built in or directly attached to substrates. Secure with countersunk, concealed fasteners and blind nailing as required for complete installation. Use fine finishing nails or finishing screws for exposed fastening, countersunk and filled flush with woodwork and matching final finish if transparent finish is indicated.
- F. Cabinets: Install without distortion so doors and drawers fit openings properly and are accurately aligned. Adjust hardware to center doors and drawers in openings and to provide unencumbered operation. Complete installation of hardware and accessory items as indicated.
  - 1. Install cabinets with no more than 1/8 inch in 96-inch (3 mm in 2400-mm) sag, bow, or other variation from a straight line.
  - 2. Maintain veneer sequence matching of cabinets with transparent finish.
  - 3. Fasten wall cabinets through back, near top and bottom, at ends and not more than 16 inches (400 mm) o.c. with No. 10 wafer-head sheet metal screws through metal backing or metal framing behind wall finish.
- G. Countertops: Anchor securely by screwing through corner blocks of base cabinets or other supports into underside of countertop.
  - 1. Align adjacent solid-surfacing-material countertops and form seams to comply with manufacturer's written recommendations using adhesive in color to match countertop. Carefully dress joints smooth, remove surface scratches, and clean entire surface.
  - 2. Install countertops with no more than 1/8 inch in 96-inch (3 mm in 2400-mm) sag, bow, or other variation from a straight line.
  - 3. Secure backsplashes to walls with adhesive.

4. Calk space between backsplash and wall with sealant specified in Division 07 Section "Joint Sealants."

H. Touch up finishing work specified in this Section after installation of woodwork. Fill nail holes with matching filler where exposed.

### 3.3 ADJUSTING AND CLEANING

A. Repair damaged and defective woodwork, where possible, to eliminate functional and visual defects; where not possible to repair, replace woodwork. Adjust joinery for uniform appearance.

B. Clean, lubricate, and adjust hardware.

C. Clean woodwork on exposed and semiexposed surfaces. Touch up shop-applied finishes to restore damaged or soiled areas.



END OF SECTION 06 4023

**DIVISION 07 – THERMAL AND MOISTURE PROTECTION**



SECTION 07 2100 - THERMAL INSULATION

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.
  
- B. Refer to Division 075400 Section "Thermoplastic Membrane Roofing" for roof insulation.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Extruded polystyrene foam-plastic board.
  - 2. Blanket/batt insulation.
  - 3. Fire safing insulation.

1.3 SUBMITTALS

- A. Product Data: For each type of insulation product specified.

1.4 QUALITY ASSURANCE

- A. Fire Performance Characteristics: Provide insulation materials identical to those whose indicated fire performance characteristics have been determined per the ASTM test method indicated below, by UL or other testing and inspecting organizations acceptable to authorities having jurisdiction. Identify products with appropriate markings of applicable testing and inspecting organization.
  - 1. Surface Burning Characteristic: ASTM E 84, 2007 edition.
  - 2. Fire Resistance Ratings: ASTM E 119, 2007 edition.
  - 3. Combustion Characteristics: ASTM E 136, 2007 edition.
  
- B. Single-Source Responsibility for Insulation Products: Obtain each type of building insulation from a single source with resources to provide products of consistent quality in appearance and physical properties without delaying progress of the Work.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Protect insulation materials from physical damage and from deterioration by moisture, soiling, and other sources. Store inside and in a dry location. Comply with manufacturer's recommendations for handling, storage, and protection during installation.

## PART 2 - PRODUCTS

### 2.2 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide insulation products of one of the following:
  - 1. Manufacturers of Glass Fiber Insulation:
    - a. CertainTeed Corp.
    - b. Johns Manville Insulations.
    - c. Owens-Corning Fiberglas Corp.
  - 2. Manufacturer of Fire Safing Insulation:
    - a. Thermafiber, Inc.

### 2.3 EXTRUDED POLYSTYRENE FOAM-PLASTIC BOARD

- A. Extruded polystyrene boards in this article are also called "XPS boards." Roman numeral designators in ASTM C 578 are assigned in a fixed random sequence, and their numeric order does not reflect increasing strength or other characteristics.
- B. Extruded Polystyrene Board, Type IV: ASTM C 578, Type IV, 25-psi minimum compressive strength; unfaced; maximum flame-spread and smoke-developed indexes of 25 and 450, respectively, per ASTM E 84.
  - 1. Fire Propagation Characteristics: Passes NFPA 285 testing as part of an approved assembly.

### 2.4 GLASS-FIBER BLANKET

- A. General: Provide insulating materials that comply with requirements and with referenced standards.
  - 1. Preformed Units: Sizes to fit applications indicated, selected from manufacturer's standard thicknesses, widths, and lengths.
  - 2. Typical R-values:
    - a. Batts at exterior stud walls shall be 6 inches thick, R-19, typically unfaced unless otherwise specified, required by code or shown.
- B. Glass-Fiber Blanket, Unfaced: ASTM C 665, Type I; with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively, per ASTM E 84; passing ASTM E 136 for combustion characteristics.
- C. Glass-Fiber Blanket, Polypropylene-Scrim-Kraft Faced: ASTM C 665, Type II (nonreflective faced), Class A (faced surface with a flame-spread index of 25 or less); Category 1 (membrane is a vapor barrier).

### 2.5 SAFING INSULATION AND ACCESSORIES

- A. Safing insulation shall be Thermafiber, Inc. mineral fiber safing insulation, unfaced. Insulation shall comply with ASTM C 612, Types 1A and 1B; and have nominal 4.0 pcf density.
- B. Sealant shall be as approved by manufacturer of safing insulation for conditions shown.

PART 3 - EXECUTION

3.2 EXAMINATION

- A. Examine substrates and conditions with Installer present, for compliance with requirements of the Sections in which substrates and related work are specified and to determine if other conditions affecting performance of insulation are satisfactory. Do not proceed with installation of insulation until unsatisfactory conditions have been corrected.

3.3 PREPARATION

- A. Clean substrates of substances harmful to insulations or vapor retarders, including removal of projections that might puncture vapor retarders.

3.4 INSTALLATION, GENERAL

- A. Comply with insulation manufacturer's instructions applicable to products and application indicated. If printed instructions are not available or do not apply to project conditions, consult manufacturer's technical representative for specific recommendations before proceeding with installation of insulation.
- B. Extend insulation full thickness as indicated to envelop entire area to be insulated. Cut and fit tightly around obstructions, and fill voids with insulation. Remove projections that interfere with placement.
- C. Apply a single layer of insulation of required thickness, unless otherwise shown or required to make up total thickness.

3.5 INSTALLATION OF SLAB INSULATION

- A. On vertical slab edge and foundation surfaces, set insulation units using manufacturer's recommended adhesive according to manufacturer's written instructions.
  - 1. If not otherwise indicated, extend insulation a minimum of 24 inches below exterior grade line.
- B. On horizontal surfaces, loosely lay insulation units according to manufacturer's written instructions. Stagger end joints and tightly abut insulation units.
  - 1. If not otherwise indicated, extend insulation a minimum of 24 inches in from exterior walls.

3.6 INSTALLATION OF FOUNDATION WALL INSULATION

- A. Butt panels together for tight fit.
- B. Adhesive Installation: Install with adhesive or press into tacky waterproofing or dampproofing according to manufacturer's written instructions.

3.7 INSTALLATION OF GENERAL BUILDING INSULATION

- A. Apply insulation units to substrate / bays by method complying with manufacturer's recommendations. If no specific method is indicated, use mechanical anchorage to provide permanent placement and support of units. Place insulation on soffits, at roof framing, at exterior wall construction, and where shown on Drawings in manner to insure continuous thermal barrier.
- B. Install faced batts and boards in wall framing where shown. Friction fit.
  - 1. Install batts above termination of wall sheathing utilizing 18 gauge wire perpendicular to the batt at 18 inches on center, or attach pin anchor at intervals required by insulation manufacturer.

3.8 INSTALLATION OF SAFING INSULATION

- A. Install safing insulation to fill gap between top of partition and horizontal material above, to fill hollow metal frames, to fill gaps between floor framing and exterior walls and windows, or as otherwise shown on Drawings. Apply sealant to complete safing assembly, as shown in Gypsum Association Fire Resistance Design Manual (18th Edition), Section II (Requirements for Fire Protection).
- B. TESTING
  - 1. Thermographic Insulation Inspection:
  - 2. ASTM C 1060-90 Standard Practice for Thermographic Inspection of Insulation Installations in Envelope Cavities of Framed Buildings.
  - 3. Using a FLIR Systems B20 thermal imaging camera, insulation within envelope cavities shall be inspected for thermal anomalies. Perform imaging test when the outside temperature is at least 15 degrees different from interior temperatures. Field image 20% of the total insulated framed exterior wall area. Document locations of tests and include with test report. If CxA doesn't perform this test provide test report to CxA for review and comment.

3.9 PROTECTION

- A. General: Protect installed insulation from damage due to harmful weather exposures, physical abuse, and other causes. Provide temporary coverings or enclosures where insulation will be subject to abuse and cannot be concealed and protected by permanent construction immediately after installation.

END OF SECTION 07 2100

SECTION 07 2600 - VAPOR BARRIER

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. Section Includes:
  - 1. Under slab vapor barrier system.
  - 2. Accessories.
- B. Related Sections:
  - 1. Division 033000 Section "Cast-In-Place Concrete".
  - 2. Division 312000 Section "Earth Moving".

1.3 REFERENCES

- A. ASTM E96/E96M - Water Vapor Transmission of Materials.
- B. ASTM E 154 – Standard Test Methods for Water Vapor Retarders Used in Contact with Earth Under Concrete Slabs, on Walls, or as Ground Cover.
- C. ASTM E1745 - Water Vapor Retarders Used in Contact with Soil or Granular Fill under Concrete Slabs.
- D. ACI 302.1R – Guide for Concrete Floor and Slab Construction.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product. Indicate conformance to specified requirements.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Minimum 15-mil thick polyolefin geomembrane.
- B. Manufactured with ISO certified virgin resins.
- C. Membrane Properties:
  - 1. Water Vapor Barrier: ASTM E1745 Meets or exceeds Class B.
  - 2. Water Vapor Transmission Rate: ASTM E96 0.006 gr./ft<sup>2</sup>/hr. or lower
  - 3. Permeance Rating: ASTM E96 0.01 gr./ft<sup>2</sup>/hr. or lower.



- 4. Puncture Resistance: ASTM E1745 minimum 1700 grams.
- 5. Tensile Strength: ASTM E1745 minimum 45.0 lbf/in.

## 2.2 MANUFACTURERS

- A. Stego industries LLC; Stego Wrap (15 mil) Vapor Barrier.
- B. Raven Industries, VaporBlock (15 mils) Underslab Vapor Retarder.
- C. Insulation Solutions, Viper II 15-mil Vapor Barrier.
- D. Or approved equal.

## 2.3 ACCESSORIES

- A. Seam Tape:
  - 1. Manufacturer's standard High Density Polyethylene Tape with pressure sensitive adhesive. Minimum width 4 inches.
- B. Pipe Boots:
  - 1. Manufacturer's pre-fabricated construct pipe boots from vapor barrier material.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Verify that conditions are acceptable and are ready to receive the Work. Notify the CDCR Representative, in writing, of any conditions requiring corrective action.
- B. If unsatisfactory conditions exist, do not commence installation until such conditions have been corrected. Beginning installation means acceptance of existing conditions.

### 3.2 INSTALLATION

- A. Install after substrate construction and penetrating work has been completed, and defective work is corrected.
- B. Place vapor barrier using widest practical width of film.
  - 1. Use vapor barrier over base material.
  - 2. Install proprietary products in accordance with manufacturer's instructions.
  - 3. Where laps are required, lap not less than 24 inches, and seal with vapor barrier tape.
  - 4. Extend to extremities of area.
  - 5. Vapor barrier shall be draped down the side of all footings at least 12 inches.
  - 6. Turn up 2 inches at perimeter walls, apply adhesive and tape in place. Box fold at inside corners; do not cut.
  - 7. Repair damage to film with vapor barrier tape. Cut film around pipes and conduit piercing barrier with undersized holes and apply vapor barrier tape to ensure maximum barrier effectiveness.
- C. Protect vapor barriers so that other trades do not puncture, damage or otherwise cause deterioration of vapor barrier.

- D. Coordinate with other Sections for the placement of welded wire fabric, reinforcing steel, pipes, conduits, and other items on top over vapor barrier to prevent punctures.
- E. Trim off excess material after slab is placed.

END OF SECTION 07 2600

SECTION 07 5400 - THERMOPLASTIC MEMBRANE ROOFING

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Adhered membrane roofing system.
  - 2. Roof insulation.
  - 3. Walkway pads.
- B. Related Sections include the following:
  - 1. Division 06 1000 Section "Rough Carpentry" for wood nailers, curbs, and blocking.
  - 2. Division 07 2100 Section "Thermal Insulation" for insulation beneath the roof deck.
  - 3. Division 07 7100 Section "Roof Specialties" for metal roof penetration flashings, flashings, and counterflashings.
  - 4. Division 07 9200 Section "Joint Sealants."

1.3 DEFINITIONS

- A. Roofing Terminology: Refer to ASTM D 1079 and glossary of NRCA's "The NRCA Roofing and Waterproofing Manual" for definition of terms related to roofing work in this Section.
- B. Design Uplift Pressure: The uplift pressure, calculated according to procedures in SPRI's "Wind Load Design Guide for Fully Adhered and Mechanically Fastened Roofing Systems," before multiplication by a safety factor.
- C. Factored Design Uplift Pressure: The uplift pressure, calculated according to procedures in SPRI's "Wind Load Design Guide for Fully Adhered and Mechanically Fastened Roofing Systems," after multiplication by a safety factor.

1.4 PERFORMANCE REQUIREMENTS

- A. General: Provide installed roofing membrane and base flashings that remain watertight; do not permit the passage of water; and resist specified uplift pressures, thermally induced movement, and exposure to weather without failure.
- B. Material Compatibility: Provide roofing materials that are compatible with one another under conditions of service and application required, as demonstrated by roofing membrane manufacturer based on testing and field experience.

- C. FMG Listing: Provide roofing membrane, base flashings, and component materials that comply with requirements in FMG 4450 and FMG 4470 as part of a membrane roofing system and that are listed in FMG's "Approval Guide" for Class 1 or noncombustible construction, as applicable. Identify materials with FMG markings.
  - 1. Fire/Windstorm Classification: Class 1A-60.
  - 2. Hail Resistance: SH.
  - 3. Ground Roughness: C.
  - 4. Wind Speed:
    - a. Basic Speed: 90mph
    - b. Three Second Gust: 110mph

## 1.5 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: For roofing system. Include plans, elevations, sections, details, and attachments to other Work.
  - 1. Base flashings and membrane terminations.
  - 2. Tapered insulation, including slopes.
  - 3. Insulation fastening patterns.
- C. Samples for Verification: For the following products:
  - 1. 12-by-12-inch (300-by-300-mm) square of sheet roofing, of color specified, including T-shaped side and end lap seam.
  - 2. 12-by-12-inch (300-by-300-mm) square of roof insulation.
  - 3. 12-by-12-inch (300-by-300-mm) square of walkway pads or rolls.
- D. Installer Certificates: Signed by roofing system manufacturer certifying that Installer is approved, authorized, or licensed by manufacturer to install roofing system.
- E. Manufacturer Certificates: Signed by roofing manufacturer certifying that roofing system complies with requirements specified in "Performance Requirements" Article.
  - 1. Submit evidence of meeting performance requirements.
- F. Test Reports: Submit manufacturer's FM Global "RoofNAV" report, compiled with materials to be used for this Project, showing roofing system meets requirements of Factory Mutual Approval Standard 4450 without use of substrate board (thermal barrier) as required by CBC 2013, Section 2603.4.1.5.
- G. Qualification Data: For Installer and manufacturer.
- H. Product Test Reports: Based on evaluation of comprehensive tests performed by manufacturer and witnessed by a qualified testing agency, for components of roofing system.
- I. Research/Evaluation Reports: For components of membrane roofing system.
- J. Maintenance Data: For roofing system to include in maintenance manuals.
- K. Warranties: Special warranties specified in this Section.

- L. Inspection Report: Copy of roofing system manufacturer's inspection report of completed roofing installation.

#### 1.6 QUALITY ASSURANCE

- A. Installer Qualifications: A qualified firm that is approved, authorized, or licensed by roofing system manufacturer to install manufacturer's product and that is eligible to receive manufacturer's warranty.
- B. Manufacturer Qualifications: A qualified manufacturer that has FMG approval for membrane roofing system identical to that used for this Project.
- C. Testing Agency Qualifications: An independent testing agency with the experience and capability to conduct the testing indicated, as documented according to ASTM E 548 and ASTM D 5957.
- D. Source Limitations: Obtain components for membrane roofing system from or approved by roofing membrane manufacturer.
- E. Fire-Test-Response Characteristics: Provide membrane roofing materials with the fire-test-response characteristics indicated as determined by testing identical products per test method below by UL, FMG, or another testing and inspecting agency acceptable to authorities having jurisdiction. Materials shall be identified with appropriate markings of applicable testing and inspecting agency.
  - 1. Exterior Fire-Test Exposure: Class B ; ASTM E 108, 2007 edition , for application and roof slopes indicated.
- F. Preinstallation Conference: Conduct conference at Project site. Comply with requirements in Division 013100 Section "Project Management and Coordination." Review methods and procedures related to roofing system including, but not limited to, the following:
  - 1. Meet with Owner, Architect, Owner's insurer if applicable, testing and inspecting agency representative, roofing Installer, roofing system manufacturer's representative, deck Installer, and installers whose work interfaces with or affects roofing including installers of roof accessories and roof-mounted equipment.
  - 2. Review methods and procedures related to roofing installation, including manufacturer's written instructions.
  - 3. Review and finalize construction schedule and verify availability of materials, Installer's personnel, equipment, and facilities needed to make progress and avoid delays.
  - 4. Examine deck substrate conditions and finishes for compliance with requirements, including flatness and fastening.
  - 5. Review structural loading limitations of roof deck during and after roofing.
  - 6. Review base flashings, special roofing details, roof drainage, roof penetrations, equipment curbs, and condition of other construction that will affect roofing system.
  - 7. Review governing regulations and requirements for insurance and certificates if applicable.
  - 8. Review temporary protection requirements for roofing system during and after installation.
  - 9. Review roof observation and repair procedures after roofing installation.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Deliver roofing materials to Project site in original containers with seals unbroken and labeled with manufacturer's name, product brand name and type, date of manufacture, and directions for storing and mixing with other components.
- B. Store liquid materials in their original undamaged containers in a clean, dry, protected location and within the temperature range required by roofing system manufacturer. Protect stored liquid material from direct sunlight.
  - 1. Discard and legally dispose of liquid material that cannot be applied within its stated shelf life.
- C. Protect roof insulation materials from physical damage and from deterioration by sunlight, moisture, soiling, and other sources. Store in a dry location. Comply with insulation manufacturer's written instructions for handling, storing, and protecting during installation.
- D. Handle and store roofing materials and place equipment in a manner to avoid permanent deflection of deck.

1.8 PROJECT CONDITIONS

- A. Weather Limitations: Proceed with installation only when existing and forecasted weather conditions permit roofing system to be installed according to manufacturer's written instructions and warranty requirements.

1.9 WARRANTY

- A. Special Warranty: Manufacturer's standard form, without monetary limitation, in which manufacturer agrees to repair or replace components of membrane roofing system that fail in materials or workmanship within specified warranty period. Failure includes roof leaks.
  - 1. Special warranty includes roofing membrane, base flashings, roofing membrane accessories roof insulation fasteners cover boards walkway products and other components of membrane roofing system.
  - 2. Total System Warranty: 15 years from date of Substantial Completion.
  - 3. Membrane Warranty: 20 years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply for product selection:
  - 1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, the products specified.
  - 2. Manufacturers: Subject to compliance with requirements, provide products by the manufacturers specified.

2.2 THERMOPLASTIC POLYOLEFIN ROOFING MEMBRANE

- A. Fabric-Reinforced Thermoplastic Polyolefin Sheet: Uniform, flexible sheet formed from a thermoplastic polyolefin, internally fabric or scrim reinforced, and as follows:
- B. Basis-of-Design Product: Subject to compliance with requirements, provide Firestone Building Products; UltraPly TPO or a comparable product by one of the following:
  - a. Carlisle SynTec Incorporated.
  - b. GAF Materials Corporation.
  - c. GenFlex Roofing Systems.
  - d. Johns Manville International, Inc.
  - e. Sarnafil Inc.
  - f. Stevens Roofing Systems; Div. of JPS Elastomerics.
  - g. Versico Inc.
- 2. Thickness: 60 mils (1.5 mm), nominal.
- 3. Exposed Face Color: White.
- 4. Physical Properties:
  - a. Breaking Strength: 225 lbf (1 kN); ASTM D 751, grab method.
  - b. Elongation at Break: 15 percent; ASTM D 751.
  - c. Tearing Strength: 55 lbf (245 N) minimum; ASTM D 751, Procedure B.
  - d. Brittleness Point: Minus 22 deg F (30 deg C).
  - e. Ozone Resistance: No cracks after sample, wrapped around a 3-inch- (75-mm-) diameter mandrel, is exposed for 166 hours to a temperature of 104 deg F (40 deg C) and an ozone level of 100 pphm (100 mPa); ASTM D 1149.
  - f. Resistance to Heat Aging: 90 percent minimum retention of breaking strength, elongation at break, and tearing strength after 166 hours at 240 deg F (116 deg C); ASTM D 573.
  - g. Water Absorption: Less than 4 percent mass change after 166 hours' immersion at 158 deg F (70 deg C); ASTM D 471.
  - h. Linear Dimension Change: Plus or minus 2 percent; ASTM D 1204.

2.3 AUXILIARY MATERIALS

- A. General: Auxiliary materials recommended by roofing system manufacturer for intended use and compatible with membrane roofing.
  - 1. Liquid-type auxiliary materials shall meet VOC limits of authorities having jurisdiction.
- B. Sheet Flashing: Manufacturer's standard sheet flashing of same material, type, reinforcement, thickness, and color as PVC sheet membrane. (Sure-weld)
- C. Bonding Adhesive: Manufacturer's standard bonding adhesive for membrane, and solvent-based bonding adhesive for base flashings. (sure-weld Bonding adhesive)
- D. Slip Sheet: Manufacturer's recommended slip sheet, of type required for application.
- E. Metal Termination Bars: Manufacturer's standard predrilled stainless-steel or aluminum bars, approximately 1 by 1/8 inch (25 by 3 mm) thick; with anchors. (Sure-seal)
- F. Metal Battens: Manufacturer's standard aluminum-zinc-alloy-coated or zinc-coated steel sheet, approximately 1 inch (25 mm) wide by 0.05 inch (1.3 mm) thick, prepunched.



- G. Fasteners: Factory-coated steel fasteners and metal or plastic plates meeting corrosion-resistance provisions in FMG 4470, designed for fastening membrane to substrate, and acceptable to membrane roofing system manufacturer. (HP-X and Piranha plate)
- H. Miscellaneous Accessories: Provide pourable sealers, preformed cone and vent sheet flashings, preformed inside and outside corner sheet flashings, T-joint covers, termination reglets, cover strips, and other accessories. (Sure-weld and Sure-seal)

## 2.4 ROOF INSULATION

- A. General: Provide preformed roof insulation boards that comply with requirements and referenced standards, selected from manufacturer's standard sizes and of thicknesses indicated.
- B. Polyisocyanurate Board Insulation: ASTM C 1289, 2007 edition , Type II, felt or glass-fiber mat facer on both major surfaces.
  - 1. Manufacturers:
    - a. AlliedSignal Inc.; Commercial Roofing Systems.
    - b. Apache Products Company.
    - c. Atlas Roofing Corporation. (HP-H Polysio)
    - d. Carlisle SynTec Incorporated.
    - e. Celotex Corporation.
    - f. Firestone Building Products Company.
    - g. GAF Materials Corporation.
    - h. GenFlex Roofing Systems.
    - i. Hunter Panels, LLC.
    - j. Johns Manville International, Inc.
    - k. Koppers Industries.
- C. Tapered Insulation: Provide factory-tapered insulation boards fabricated to slope of 1/4 inch per 12 inches (1:48), unless otherwise indicated.
- D. Provide preformed saddles, crickets, tapered edge strips, and other insulation shapes where indicated for sloping to drain. Fabricate to slopes indicated.

## 2.5 INSULATION ACCESSORIES

- A. General: Roof insulation accessories recommended by insulation manufacturer for intended use and compatible with membrane roofing.
- B. Fasteners: Factory-coated steel fasteners and metal or plastic plates meeting corrosion-resistance provisions in FMG 4470, designed for fastening roof insulation to substrate, and acceptable to roofing system manufacturer.
- C. Cold Fluid-Applied Adhesive: Manufacturer's standard cold fluid-applied adhesive formulated to adhere roof insulation to substrate.
- D. Cover Board: ASTM C 208, Type II, Grade 2, cellulosic-fiber insulation board, 1/2 inch (13 mm) thick.

## 2.6 WALKWAYS

- A. Flexible Walkways: Factory-formed, nonporous, heavy-duty, solid-rubber, slip-resisting, surface-textured walkway pads or rolls, approximately 3/16 inch (5 mm) thick, and acceptable to membrane roofing system manufacturer. (Sure-weld)

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with the following requirements and other conditions affecting performance of roofing system:
  - 1. Verify that roof openings and penetrations are in place and set and braced.
  - 2. Verify that wood blocking, curbs, and nailers are securely anchored to roof deck at penetrations and terminations and nailers match thicknesses of insulation.
  - 3. Verify that surface plane flatness and fastening of steel roof deck comply with requirements in Division 05 Section "Steel Decking."
  - 4. Verify that minimum concrete drying period recommended by roofing system manufacturer has passed.
  - 5. Verify that concrete substrate is visibly dry and free of moisture. Test for capillary moisture by plastic sheet method according to ASTM D 4263.
  - 6. Verify that concrete curing compounds that will impair adhesion of roofing components to roof deck have been removed.
  - 7. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. Clean substrate of dust, debris, moisture, and other substances detrimental to roofing installation according to roofing system manufacturer's written instructions. Remove sharp projections.
- B. Prevent materials from entering and clogging conductors and from spilling or migrating onto surfaces of other construction.
- C. Complete terminations and base flashings and provide temporary seals to prevent water from entering completed sections of roofing system at the end of the workday or when rain is forecast. Remove and discard temporary seals before beginning work on adjoining roofing.

### 3.3 INSULATION INSTALLATION

- A. Coordinate installing membrane roofing system components so insulation is not exposed to precipitation or left exposed at the end of the workday.
- B. Comply with membrane roofing system manufacturer's written instructions for installing roof insulation.
- C. Install tapered insulation under area of roofing to conform to slopes indicated.

- D. Install two or more layers of base insulation under area of roofing to achieve a minimum "R" value of 30.
  - 1. Install 2 or more layers with joints of each succeeding layer staggered from joints of previous layer a minimum of 6 inches (150 mm) in each direction.
- E. Trim surface of insulation where necessary at roof scuppers so completed surface is flush and does not restrict flow of water.
- F. Install insulation with long joints of insulation in a continuous straight line with end joints staggered between rows, abutting edges and ends between boards. Fill gaps exceeding 1/4 inch (6 mm) with insulation.
  - 1. Cut and fit insulation within 1/4 inch (6 mm) of nailers, projections, and penetrations.
- G. Adhered Insulation: Install each layer of insulation and secure first layer of insulation to deck using mechanical fasteners specifically designed and sized for fastening specified board-type roof insulation to deck type.
  - 1. Fasten first layer of insulation according to requirements in FMG's "Approval Guide" for specified Windstorm Resistance Classification.
  - 2. Install subsequent layers of insulation in a cold fluid-applied adhesive.
- H. Install cover boards over insulation with long joints in continuous straight lines with end joints staggered between rows. Stagger joints from joints in insulation below a minimum of 6 inches (150 mm) in each direction. Loosely butt cover boards together and fasten to roof deck.
  - 1. Fasten according to requirements in FMG's "Approval Guide" for specified Windstorm Resistance Classification.
  - 2. Fasten to resist uplift pressure at corners, perimeter, and field of roof.

### 3.4 ADHERED ROOFING MEMBRANE INSTALLATION

- A. Install roofing membrane over area to receive roofing according to membrane roofing system manufacturer's written instructions. Unroll roofing membrane and allow to relax before installing.
- B. Start installation of roofing membrane in presence of membrane roofing system manufacturer's technical personnel.
- C. Accurately align roofing membrane and maintain uniform side and end laps of minimum dimensions required by manufacturer. Stagger end laps.
- D. Bonding Adhesive: Apply solvent-based bonding adhesive to substrate and underside of roofing membrane at rate required by manufacturer and allow to partially dry before installing roofing membrane. Do not apply bonding adhesive to splice area of roofing membrane.
- E. Mechanically or adhesively fasten roofing membrane securely at terminations, penetrations, and perimeter of roofing.
- F. Apply roofing membrane with side laps shingled with slope of roof deck where possible.

- G. Seams: Clean seam areas, overlap roofing membrane, and hot-air weld side and end laps of roofing membrane according to manufacturer's written instructions to ensure a watertight seam installation.
  - 1. Test lap edges with probe to verify seam weld continuity. Apply lap sealant to seal cut edges of roofing membrane.
  - 2. Verify field strength of seams a minimum of twice daily and repair seam sample areas.
  - 3. Repair tears, voids, and lapped seams in roofing membrane that does not meet requirements.
- H. Install roofing membrane and auxiliary materials to tie in to existing roofing.

### 3.5 BASE FLASHING INSTALLATION

- A. Install sheet flashings and preformed flashing accessories and adhere to substrates according to membrane roofing system manufacturer's written instructions.
- B. Apply solvent-based bonding adhesive to substrate and underside of sheet flashing at required rate and allow to partially dry. Do not apply bonding adhesive to seam area of flashing.
- C. Flash penetrations and field-formed inside and outside corners with sheet flashing.
- D. Clean seam areas and overlap and firmly roll sheet flashings into the adhesive. Weld side and end laps to ensure a watertight seam installation.
- E. Terminate and seal top of sheet flashings and mechanically anchor to substrate through termination bars.

### 3.6 WALKWAY INSTALLATION

- A. Flexible Walkways: Install walkway products in locations indicated. Heat weld to substrate or adhere walkway products to substrate with compatible adhesive according to roofing system manufacturer's written instructions.

### 3.7 FIELD QUALITY CONTROL

- A. Final Roof Inspection: Arrange for roofing system manufacturer's technical personnel to inspect roofing installation on completion and submit report to Architect.
- B. Testing:
  - 1. Horizontal Waterproofing Installation Flood Testing:
    - a. ASTM D 5957 – Standard Guide for Flood Testing Horizontal Waterproofing Insulation
    - b. Perform flood testing of a 20% section of roof area by constructing containment assemblies to plug off drains. Flood contained roof area with water to a depth as recommended by roofing manufacturer. Do not exceed structural design loads. Inspect the underside of flooded roof area for water leakage throughout testing. Document locations of tests and include with test report. Provide test report to CxA for review and comment.

2. Infrared Roof Survey:
  - a. ASTM D 1153, Standard Practice for Location of Wet Insulation in Roofing Systems Using Infrared Imaging
  - b. Perform infrared roof imaging shortly after sunset when the surface temperature of the roof drops quickly. Use a FLIR Systems B20 thermal imaging camera to identify areas containing water within the roof system and or insulation. Test 20% of the entire roof area including previously flood tested roof area and identify anomalies. Mark these areas on the roof surface for future repair and evaluation. Document locations of the tests and include with test report. If CxA doesn't perform this test provide test report to CxA for review and comment.
- C. Repair or remove and replace components of membrane roofing system where test results or inspections indicate that they do not comply with specified requirements.
- D. Additional testing and inspecting, at Contractor's expense, will be performed to determine compliance of replaced or additional work with specified requirements.

### 3.8 PROTECTING AND CLEANING

- A. Protect membrane roofing system from damage and wear during remainder of construction period. When remaining construction will not affect or endanger roofing, inspect roofing for deterioration and damage, describing its nature and extent in a written report, with copies to Architect and Owner.
- B. Correct deficiencies in or remove membrane roofing system that does not comply with requirements, repair substrates, and repair or reinstall membrane roofing system to a condition free of damage and deterioration at time of Substantial Completion and according to warranty requirements.
- C. Clean overspray and spillage from adjacent construction using cleaning agents and procedures recommended by manufacturer of affected construction.

END OF SECTION 07 5400

SECTION 07 7100 - ROOF SPECIALTIES

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following manufactured roof specialties:
  - 1. Copings.
  - 2. Roof edge flashings.
  - 3. Roof edge drainage systems.
  - 4. Counterflashings and reglets.
- B. Related Sections include the following:
  - 1. Division 033000 Section "Cast-in-Place Concrete" for installing reglets.
  - 2. Division 042200 Section "Unit Masonry" for installing reglets.
  - 3. Division 061000 Section "Rough Carpentry" for wood nailers, curbs, and blocking.
  - 4. Division 077200 Section "Roof Accessories" for set-on-type curbs, equipment supports, roof hatches, vents, and other manufactured roof accessory units.
  - 5. Division 079200 Section "Joint Sealants" for field-applied sealants.

1.3 PERFORMANCE REQUIREMENTS

- A. General: Manufacture and install manufactured roof specialties to resist thermally induced movement and exposure to weather without failing, rattling, leaking, and fastener disengagement.
- B. FMG Listing: Manufacture and install copings and roof edge flashings that are listed in FMG's "Approval Guide" and approved for Windstorm Classification, Class 1-60. Identify materials with FMG markings.
  - 1. Ground Roughness: C.
  - 2. Wind Speed:
    - a. Basic Speed: 90mph
    - b. Three Second Gust: 110mph
- C. Thermal Movements: Provide manufactured roof specialties that allow for thermal movements resulting from the following maximum change (range) in ambient and surface temperatures by preventing buckling, opening of joints, hole elongation, overstressing of components, failure of joint sealants, failure of connections, and other detrimental effects. Provide clips that resist rotation and avoid shear stress as a result of thermal movements. Base engineering calculation on surface temperatures of materials due to both solar heat gain and nighttime-sky heat loss.

1. Temperature Change (Range): 120 deg F (67 deg C), ambient; 180 deg F (100 deg C), material surfaces.

- D. Water Infiltration: Provide manufactured roof specialties that do not allow water infiltration to building interior.

#### 1.4 SUBMITTALS

- A. Product Data: For each type of product indicated. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes.
- B. Shop Drawings: Show layouts of manufactured roof specialties, including plans and elevations. Identify factory- vs. field-assembled work. Include the following:
  1. Details for fastening, joining, supporting, and anchoring manufactured roof specialties including fasteners, clips, cleats, and attachments to adjoining work.
  2. Details for expansion and contraction.
- C. Fabrication Samples: For copings roof edge flashings roof edge drainage systems counterflashings and reglets made from 12-inch (300-mm) lengths of full-size components including fasteners, cover joints, accessories, and attachments.
- D. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency, verifying compliance of copings roof edge flashings with performance requirements.
- E. Warranty: Special warranty specified in this Section.

#### 1.5 QUALITY ASSURANCE

- A. Product Options: Information on Drawings and in Specifications establishes requirements for system's aesthetic effects and performance characteristics. Aesthetic effects are indicated by dimensions, arrangements, alignment, and profiles of components and assemblies as they relate to sightlines, to one another, and to adjoining construction. Performance characteristics are indicated by criteria subject to verification by one or more methods including preconstruction testing, field testing, and in-service performance.
  1. Do not modify intended aesthetic effects, as judged solely by Architect, except with Architect's approval. If modifications are proposed, submit comprehensive explanatory data to Architect for review.

#### 1.6 COORDINATION

- A. Coordinate installation of manufactured roof specialties with interfacing and adjoining construction to provide a leakproof, secure, and noncorrosive installation.

1.7 WARRANTY

- A. Special Warranty on Painted Finishes: Manufacturer's standard form in which manufacturer agrees to repair finish or replace manufactured roof specialties that show evidence of deterioration of factory-applied finishes within specified warranty period.
1. Fluoropolymer Finish: Deterioration includes, but is not limited to, the following:
    - a. Color fading more than 5 Hunter units when tested according to ASTM D 2244.
    - b. Chalking in excess of a No. 8 rating when tested according to ASTM D 4214.
    - c. Cracking, checking, peeling, or failure of paint to adhere to bare metal.
  2. Finish Warranty Period: 20 years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, products specified. (Fire-stone Uniclاد)

2.2 EXPOSED METALS

- A. Aluminum Sheet: ASTM B 209 (ASTM B 209M), alloy and temper recommended by manufacturer for use and finish indicated, finished as follows:
1. Surface: Smooth, flat finish.
  2. High-Performance Organic Finish: AA-C12C42R1x (Chemical Finish: cleaned with inhibited chemicals; Chemical Finish: acid-chromate-fluoride-phosphate conversion coating; Organic Coating: as specified below). Prepare, pretreat, and apply coating to exposed metal surfaces to comply with coating and resin manufacturers' written instructions.
    - a. Fluoropolymer 2-Coat System: Manufacturer's standard 2-coat, thermocured system consisting of specially formulated inhibitive primer and fluoropolymer color topcoat containing not less than 70 percent polyvinylidene fluoride resin by weight; complying with AAMA 2605.
  3. Anodic Finish: Apply the following finish:
    - a. Class II, Clear Anodic Finish: AA-M12C22A31 (Mechanical Finish: nonspecular as fabricated; Chemical Finish: etched, medium matte; Anodic Coating: Architectural Class II, clear coating 0.010 mm or thicker) complying with AAMA 611.
- B. Aluminum Extrusions: ASTM B 221 (ASTM B 221M), alloy and temper recommended by manufacturer for type of use and finish indicated, finished as follows:
1. High-Performance Organic Finish: AA-C12C42R1x (Chemical Finish: cleaned with inhibited chemicals; Chemical Finish: acid-chromate-fluoride-phosphate conversion coating; Organic Coating: as specified below). Prepare, pretreat, and apply coating to exposed metal surfaces to comply with coating and resin manufacturers' written instructions.



- a. Fluoropolymer 2-Coat System: Manufacturer's standard 2-coat, thermocured system consisting of specially formulated inhibitive primer and fluoropolymer color topcoat containing not less than 70 percent polyvinylidene fluoride resin by weight; complying with AAMA 2605.
2. Anodic Finish: Apply the following finish:
  - a. Class II, Clear Anodic Finish: AA-M12C22A31 (Mechanical Finish: nonspecular as fabricated; Chemical Finish: etched, medium matte; Anodic Coating: Architectural Class II, clear coating 0.010 mm or thicker) complying with AAMA 611.
- C. Prepainted, Zinc-Coated Steel Sheet: ASTM A 653/A 653M, G90 (Z275) coating designation, structural quality, and prepainted by the coil-coating process to comply with ASTM A 755/A 755M.
  1. Surface: Smooth, flat finish.
  2. High-Performance Organic Finish: Prepare, pretreat, and apply coating to exposed metal surfaces to comply with coating and resin manufacturers' written instructions.
    - a. Fluoropolymer 2-Coat System: Manufacturer's standard 2-coat, thermocured system consisting of specially formulated inhibitive primer and fluoropolymer color topcoat containing not less than 70 percent polyvinylidene fluoride resin by weight; complying with physical properties and coating performance requirements of AAMA 2605, except as modified below:
      - 1) Humidity Resistance: 2000 hours.

### 2.3 CONCEALED METALS

- A. Aluminum Sheet: ASTM B 209 (ASTM B 209M), alloy and temper recommended by manufacturer for use and structural performance indicated, mill finished.
- B. Aluminum Extrusions: ASTM B 221 (ASTM B 221M), alloy and temper recommended by manufacturer for type of use and structural performance indicated, mill finished.
- C. Stainless-Steel Sheet: ASTM A 240/A 240M, Type 304.
- D. Zinc-Coated (Galvanized) Steel Sheet: ASTM A 653/A 653M, G90 (Z275) coating designation; structural quality.

### 2.4 MISCELLANEOUS MATERIALS

- A. General: Provide materials and types of fasteners, protective coatings, separators, sealants, and other miscellaneous items required by manufacturer for a complete installation.
- B. Fasteners: Manufacturer's recommended fasteners, suitable for application and designed to withstand design loads.
  1. Exposed Penetrating Fasteners: Gasketed screws with hex washer heads matching color of sheet metal.
- C. Sealing Tape: Pressure-sensitive, 100 percent solids, polyisobutylene compound sealing tape with release-paper backing. Provide permanently elastic, nonsag, nontoxic, nonstaining tape.

- D. Elastomeric Sealant: ASTM C 920, elastomeric silicone polymer sealant; of type, grade, class, and use classifications required to seal joints in sheet metal flashing and trim and remain watertight.
- E. Butyl Sealant: ASTM C 1311, single-component, solvent-release butyl rubber sealant, polyisobutylene plasticized, heavy bodied for hooked-type expansion joints with limited movement.
- F. Epoxy Seam Sealer: Two-part, noncorrosive, aluminum seam-cementing compound, recommended by aluminum manufacturer for exterior nonmoving joints, including riveted joints.
- G. Bituminous Coating: Cold-applied asphalt mastic, SSPC-Paint 12, compounded for 15-mil (0.4-mm) dry film thickness per coat. Provide inert-type noncorrosive compound free of asbestos fibers, sulfur components, and other deleterious impurities.
- H. Asphalt Roofing Cement: ASTM D 4586, asbestos free, of consistency required for application.
- I. Polyethylene Sheet: 6-mil- (0.15-mm-) thick polyethylene sheet complying with ASTM D 4397.
- J. Felt: ASTM D 226, Type II (No. 30), asphalt-saturated organic felt, nonperforated.
  - 1. Slip Sheet: Rosin-sized paper, minimum 3 lb/100 sq. ft. (0.16 kg/sq. m).

## 2.5 COPINGS

- A. Copings: Manufactured coping system consisting of formed-metal coping cap in section lengths not exceeding 12 feet (3.6 m), concealed anchorage, concealed splice plates with same finish as coping caps, mitered corner units, and end cap units.
  - 1. Available Manufacturers:
    - a. Architectural Products Co.
    - b. ATAS International, Inc.
    - c. Castle Metal Products.
    - d. Cheney Flashing Company.
    - e. Hickman, W. P. Company.
    - f. Merchant & Evans, Inc.
    - g. Metal-Era, Inc.
    - h. Metal-Fab Manufacturing LLC.
    - i. MM Systems Corporation.
    - j. Perimeter Systems, a division of Southern Aluminum Finishing Co.
    - k. Petersen Aluminum Corp.
  - 2. Coping Caps: Snap-on, fabricated from the following exposed metal:
    - a. Aluminum: 0.040 inch (1.0 mm) thick.
    - b. Prepainted, Zinc-Coated Steel: 0.040 inch (1.0 mm) thick.
  - 3. Coping Cap Color: Match paint colors as indicated on drawings.
  - 4. Corners: Continuously welded.
  - 5. Snap-on Coping Anchor Plates: Concealed, galvanized steel sheet, 12 inches (300 mm) wide, 0.028 inch (0.7 mm) thick, with integral cleats.
  - 6. Face Leg Cleats: Concealed, continuous galvanized steel sheet.
  - 7. As selected by architect from mfr. Full list to match existing building.

## 2.6 ROOF EDGE FLASHING

- A. Gravel Stops: Manufactured, one-piece, formed-metal gravel stop in section lengths not exceeding 12 feet (3.6 m), with a horizontal flange and vertical leg fascia terminating in a drip edge, continuous hold-down cleat, and concealed splice plates of same material, finish, and shape as gravel stop. Provide mitered and welded or soldered corner units.
1. Available Manufacturers:
    - a. Architectural Products Co.
    - b. ATAS International, Inc.
    - c. Castle Metal Products.
    - d. Cheney Flashing Company.
    - e. Hickman, W. P. Company.
    - f. Merchant & Evans, Inc.
    - g. Metal-Era, Inc.
    - h. MM Systems Corporation.
    - i. Perimeter Systems, a division of Southern Aluminum Finishing Co.
    - j. Petersen Aluminum Corp.
  2. Fabricate from the following exposed metal:
    - a. Aluminum: 0.040 inch (1.0 mm) thick.
    - b. Prepainted, Zinc-Coated Steel: 0.040 inch (1.0 mm) thick.
  3. Color: As indicated.

## 2.7 ROOF EDGE DRAINAGE SYSTEMS

- A. Available Manufacturers:
1. Architectural Products Co.
  2. ATAS International, Inc.
  3. Berger Bros. Co.
  4. Castle Metal Products.
  5. Cheney Flashing Company.
  6. Hickman, W. P. Company.
  7. Merchant & Evans, Inc.
  8. Metal-Era, Inc.
  9. Metal-Fab Manufacturing LLC.
  10. MM Systems Corporation.
  11. Obdyke, Benjamin Incorporated.
  12. Perimeter Systems, a division of Southern Aluminum Finishing Co.
  13. Petersen Aluminum Corp.
- B. Gutters and Downspouts: Manufactured formed gutter in uniform section lengths not exceeding 12 feet, with mitered and welded or soldered corner units, end caps, outlet tubes, and other accessories. Elevate back edge at least 1 inch above front gutter rim. Furnish with flat-stock gutter straps and gutter support brackets and expansion joints and expansion-joint covers fabricated from same metal as gutters.
1. Fabricate gutter from the following exposed metal:
    - a. Aluminum: 0.040 inch (1.0 mm) thick.
    - b. Prepainted, Zinc-Coated Steel: 0.040 inch (1.0 mm) thick.
  2. Gutter Style: A according to SMACNA's "Architectural Sheet Metal Manual."
  3. Downspouts: Fabricated Hanger Style: SMACNA figure designation 1-35A.
    - a. Galvanized Steel: 0.022 inch (0.56 mm) thick.

- b. Aluminum-Zinc Alloy-Coated Steel: 0.022 inch (0.56 mm) thick.

## 2.8 COUNTERFLASHINGS AND REGLETS

- A. Available Manufacturers:
  - 1. Castle Metal Products.
  - 2. Cheney Flashing Company.
  - 3. Fry Reglet Corporation.
  - 4. Hickman, W. P. Company.
  - 5. Keystone Flashing Company.
  - 6. Merchant & Evans, Inc.
  - 7. Metal-Era, Inc.
  - 8. MM Systems Corporation.
  
- B. Counterflashings: Manufactured units in lengths not exceeding 12 feet (3.6 m) < designed to snap into reglets and compress against base flashings with joints lapped, from the following exposed metal in thickness indicated:
  - 1. Aluminum: 0.024 inch (0.6 mm) thick.
  - 2. Prepainted, Zinc-Coated Steel: 0.028 inch (0.7 mm) thick.
  
- C. Reglets: Manufactured units formed to provide secure interlocking of separate reglet and counterflashing pieces, and compatible with flashings indicated with factory-mitered and -welded corners and junctions, from the following exposed metal in thickness indicated:
  - 1. Aluminum: 0.050 inch (1.2 mm) thick.
  - 2. Prepainted, Zinc-Coated Steel: 0.028 inch (0.7 mm) thick.
  - 3. Type: For concrete application with temporary closure tape to keep reglet free of concrete materials, special fasteners for attaching reglet to concrete forms, and guides to ensure alignment of reglet section ends.
  - 4. Type: For masonry application, with offset top flange for embedment in masonry mortar joint.
  - 5. Type: Multiuse, for embedment in masonry mortar joints.
  
- D. Accessories: Counterflashing wind-restraint clips.

## 2.9 FINISHES

- A. Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
  
- B. Protect mechanical and painted finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.
  
- C. Appearance of Finished Work: Variations in appearance of abutting or adjacent pieces are acceptable if they are within one-half of the range of approved Samples. Noticeable variations in the same piece are not acceptable. Variations in appearance of other components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.

- D. See exterior building elevations for location of metal fascia flashing. All fascia to be factory finished. Contractor to provide touch up as required. Provide paint samples for architectural review prior to painting.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, to verify actual locations, dimensions, and other conditions affecting performance of work.
  - 1. Examine walls, roof edges, and parapets for suitable conditions for manufactured roof specialties.
  - 2. Verify that substrate is sound, dry, smooth, clean, sloped for drainage, and securely anchored.
  - 3. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 INSTALLATION

- A. General: Install manufactured roof specialties according to manufacturer's written instructions. Anchor manufactured roof specialties securely in place and capable of resisting forces specified in performance requirements. Use fasteners, separators, sealants, and other miscellaneous items as required to complete manufactured roof specialty systems.
  - 1. Install manufactured roof specialties with provisions for thermal and structural movement.
  - 2. Torch cutting of manufactured roof specialties is not permitted.
- B. Metal Protection: Where dissimilar metals will contact each other or corrosive substrates, protect against galvanic action by painting contact surfaces with bituminous coating or by other permanent separation as recommended by manufacturer.
  - 1. Coat concealed side of uncoated aluminum manufactured roof specialties with bituminous coating where in contact with wood, ferrous metal, or cementitious construction.
  - 2. Underlayment: Where installing exposed-to-view components of manufactured roof specialties directly on cementitious or wood substrates, install a course of felt underlayment and cover with a slip sheet, or install a course of polyethylene underlayment.
  - 3. Bed flanges in thick coat of asphalt roofing cement where required by manufacturers of roof specialties for waterproof performance.
- C. Install manufactured roof specialties level, plumb, true to line and elevation, and without warping, jogs in alignment, excessive oil-canning, buckling, or tool marks.
- D. Install manufactured roof specialties to fit substrates and to result in watertight performance. Verify shapes and dimensions of surfaces to be covered before manufacture.
- E. Expansion Provisions: Provide for thermal expansion of exposed manufactured roof specialties. Space movement joints at a maximum of 12 feet (3.6 m) with no unplanned joints within 24 inches (600 mm) of corners or intersections.

- F. Fasteners: Use fasteners of type and size recommended by manufacturer but of sizes that will penetrate substrate not less than 1-1/4 inches for nails and not less than 3/4 inch for screws.
- G. Seal joints with elastomeric or butyl sealant as required by manufacturer of roofing specialties.

### 3.3 COPING INSTALLATION

- A. Install cleats, anchor plates, and other anchoring and attachment accessories and devices with concealed fasteners.
- B. Anchor copings to resist uplift and outward forces according to performance requirements.
  - 1. Interlock face and back leg drip edges of snap-on coping cap into cleated anchor plates anchored to substrate at 30-inch (760-mm) centers.

### 3.4 ROOF EDGE FLASHING INSTALLATION

- A. Install cleats, cant dams, and other anchoring and attachment accessories and devices with concealed fasteners.
- B. Anchor roof edgings to resist uplift and outward forces according to performance requirements.

### 3.5 ROOF EDGE DRAINAGE SYSTEM INSTALLATION

- A. General: Install gutters and downspouts to produce a complete roof drainage system according to manufacturer's written instructions. Coordinate installation of roof perimeter flashing with installation of roof drainage system.
- B. Gutters: Join and seal gutter lengths. Attach gutters to firmly anchored gutter brackets spaced not more than 36 inches (900 mm) apart. Slope gutters to downspouts.
  - 1. Install gutter with expansion joints at locations indicated but not exceeding 50 feet (15.2 m) apart. Install expansion joint caps.
- C. Downspouts: Join sections with manufacturer's standard telescoping joints. Provide fasteners designed to hold downspouts securely to walls; locate fasteners at top and bottom and at approximately 48 inches (1200 mm) o.c. in between.
  - 1. Provide elbows at base of downspout to direct water away from building.

### 3.6 COUNTERFLASHING AND REGLET INSTALLATION

- A. Counterflashings: Coordinate installation of counterflashings with installation of base flashings. Insert counterflashings in reglets or receivers and fit tightly to base flashings. Extend counterflashings 4 inches (100 mm) over base flashings. Lap counterflashing joints a minimum of 4 inches (100 mm) and bed with elastomeric or butyl sealant.

3.7 CLEANING AND PROTECTION

- A. Clean exposed metal surfaces of substances that interfere with uniform oxidation and weathering.
- B. Clean and neutralize flux materials. Clean off excess solder and sealants.
- C. Remove temporary protective coverings and strippable films as manufactured roof specialties are installed. On completion of installation, clean finished surfaces, including removing unused fasteners, metal filings, pop rivet stems, and pieces of flashing. Maintain in a clean condition during construction.
- D. Replace manufactured roof specialties that have been damaged or that cannot be successfully repaired by finish touchup or similar minor repair procedures.

END OF SECTION 07 7100

SECTION 07 7200 - ROOF ACCESSORIES

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Roof curbs.
  - 2. Equipment supports.
- B. Related Sections include the following:
  - 1. Division 055000 Section "Metal Fabrications" for metal vertical ladders, ships' ladders, and stairs for access to roof hatches.
  - 2. Division 061000 Section "Rough Carpentry" for roof sheathing, wood cants, and wood nailers and pressure-treated wood walkways.
  - 3. Division 077200 Section "Roof Accessories" for shop- and field-fabricated metal flashing and counterflashing, roof expansion-joint covers, and miscellaneous sheet metal trim and accessories.

1.3 SUBMITTALS

- A. Product Data: For each type of roof accessory indicated. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes.
- B. Shop Drawings: Show fabrication and installation details for roof accessories. Show layouts of roof accessories including plans and elevations. Indicate dimensions, weights, loadings, required clearances, method of field assembly, and components. Include plans, elevations, sections, details, and attachments to other work.
- C. Coordination Drawings: Roof plans, drawn to scale, and coordinating penetrations and roof-mounted items. Show the following:
  - 1. Size and location of roof accessories specified in this Section.
  - 2. Method of attaching roof accessories to roof or building structure.
  - 3. Other roof-mounted items including mechanical and electrical equipment, ductwork, piping, and conduit.
- D. Warranty: Provide manufacturer's standard warranty.



1.4 QUALITY ASSURANCE

- A. Sheet Metal Standard: Comply with SMACNA's "Architectural Sheet Metal Manual" details for fabrication of units, including flanges and cap flashing to coordinate with type of roofing indicated.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Pack, handle, and ship roof accessories properly labeled in heavy-duty packaging to prevent damage.

1.6 PROJECT CONDITIONS

- A. Field Measurements: Verify required openings for each type of roof accessory by field measurements before fabrication and indicate measurements on Shop Drawings.

1.7 COORDINATION

- A. Coordinate layout and installation of roof accessories with roofing membrane and base flashing and interfacing and adjoining construction to provide a leakproof, weathertight, secure, and noncorrosive installation.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the manufacturers listed in other Part 2 articles.

2.2 METAL MATERIALS

- A. Galvanized Steel Sheet: ASTM A 653/A 653M, G90 (Z275) coated.
- B. Aluminum-Zinc Alloy-Coated Steel Sheet: ASTM A 792/A 792M, AZ50 (AZM150) coated.
- C. Aluminum Sheet: ASTM B 209 (ASTM B 209M), alloy and temper recommended by manufacturer for type of use and mill finish.
- D. Aluminum Extrusions and Tubes: ASTM B 221 (ASTM B 221M), alloy and temper recommended by manufacturer for type of use, mill finished.
- E. Stainless-Steel Shapes or Sheet: ASTM A 240/A 240M or ASTM A 666, Type 304 or Type 316, No. 2D finish.
- F. Steel Shapes: ASTM A 36/A 36M, hot-dip galvanized to comply with ASTM A 123/A 123M, unless otherwise indicated.

- G. Steel Tube: ASTM A 500, round tube, baked-enamel finished.
- H. Galvanized Steel Tube: ASTM A 500, round tube, hot-dip galvanized to comply with ASTM A 123/A 123M.
- I. Galvanized Steel Pipe: ASTM A 53/A 53M.

### 2.3 MISCELLANEOUS MATERIALS

- A. Glass-Fiber Board Insulation: ASTM C 726, 1 inch (25 mm) thick.
- B. Polyisocyanurate Board Insulation: ASTM C 1289, 1 inch (25 mm) thick.
- C. Wood Nailers: Softwood lumber, pressure treated with waterborne preservatives for aboveground use, complying with AWPA C2; not less than 1-1/2 inches (38 mm) thick.
- D. Bituminous Coating: Cold-applied asphalt mastic, SSPC-Paint 12, compounded for 15-mil (0.4-mm) dry film thickness per coat. Provide inert-type noncorrosive compound free of asbestos fibers, sulfur components, and other deleterious impurities.
- E. Fasteners: Same metal as metals being fastened, or nonmagnetic stainless steel or other noncorrosive metal as recommended by roof accessory manufacturer. Match finish of exposed fasteners with finish of material being fastened. Provide nonremovable fastener heads to exterior exposed fasteners.
- F. Gaskets: Manufacturer's standard tubular or fingered design of neoprene, EPDM, or PVC; or flat design of foam rubber, sponge neoprene, or cork.
- G. Elastomeric Sealant: ASTM C 920, polyurethane sealant; of type, grade, class, and use classifications required to seal joints in sheet metal flashing and trim and remain watertight.
- H. Butyl Sealant: ASTM C 1311, single-component, solvent-release butyl rubber sealant, polyisobutylene plasticized, and heavy bodied for hooked-type expansion joints with limited movement.
- I. Roofing Cement: ASTM D 4586, nonasbestos, fibrated asphalt cement designed for trowel application or other adhesive compatible with roofing system.

### 2.4 ROOF CURBS

- A. Roof Curbs: Provide metal roof curbs, internally reinforced and capable of supporting superimposed live and dead loads, including equipment loads and other construction to be supported on roof curbs. Fabricate with welded or sealed mechanical corner joints, with and integral formed mounting flange at perimeter bottom. Coordinate dimensions with rough-in information or Shop Drawings of equipment to be supported.
  - 1. Manufacturers: (Butler IF Curb)
    - a. Colony Custom Curbs.
    - b. Commodity Products Company, Inc.
    - c. Conn-Fab Sales, Inc.

- d. Curbs Plus Inc.
  - e. Custom Curb, Inc.
  - f. LM Curbs.
  - g. Loren Cook Company.
  - h. Metallic Products Corporation.
  - i. Pate Company (The).
  - j. Roof Products & Systems Corporation.
  - k. Roof Products, Inc.
  - l. Thaler Metal Industries Ltd.
  - m. ThyCurb; Div. of Thybar Corporation.
  - n. Uni-Curb, Inc.
  - o. Vent Products Company, Inc.
2. Load Requirements: Provide roof curbs capable of supporting superimposed live and dead loads, including equipment loads and other construction to be supported on roof curbs. Coordinate dimension with rough-in information or Shop Drawings of equipment to be supported.
  3. Material: Galvanized or Aluminum-zinc alloy-coated steel sheet, 0.052 inch (1.32 mm) thick.
  4. Liner: Same material as curb, of manufacturer's standard thickness and finish.
  5. Factory install wood nailers at tops of curbs.
  6. On ribbed or fluted metal roofs, form flange at perimeter bottom to conform to roof profile.
  7. Factory insulate curbs with manufacturer's standard rigid or semi-rigid insulation.
  8. Curb height may be determined by adding thickness of roof insulation and minimum base flashing height recommended by roofing membrane manufacturer. Fabricate units to minimum height of 16 inches (400 mm), unless otherwise indicated.
  9. Sloping Roofs: Where slope of roof deck exceeds 1:48, fabricate curb units with water diverter or cricket and with height tapered to match slope to level tops of units.

## 2.5 EQUIPMENT SUPPORTS

- A. Equipment Supports: Provide metal equipment supports, internally reinforced and capable of supporting superimposed live and dead loads, including equipment loads and other construction to be supported. Fabricate with welded or sealed mechanical corner joints, with and integral formed mounting flange at perimeter bottom. Coordinate dimensions with rough-in information or Shop Drawings of equipment to be supported.
  1. Manufacturers:
    - a. Colony Custom Curbs.
    - b. Commodity Products Company, Inc.
    - c. Conn-Fab Sales, Inc.
    - d. Curbs Plus Inc.
    - e. Custom Curb, Inc.
    - f. LM Curbs.
    - g. Loren Cook Company.
    - h. Metallic Products Corporation.
    - i. Pate Company (The).
    - j. Roof Products & Systems Corporation.
    - k. Roof Products, Inc.
    - l. Thaler Metal Industries Ltd.
    - m. ThyCurb; Div. of Thybar Corporation.

- n. Uni-Curb, Inc.
- o. Vent Products Company, Inc.
- 2. Load Requirements: Provide roof curbs capable of supporting superimposed live and dead loads, including equipment loads and other construction to be supported on roof curbs. Coordinate dimension with rough-in information or Shop Drawings of equipment to be supported.
- 3. Material: Galvanized or Aluminum-zinc alloy-coated steel sheet, 0.052 inch (1.32 mm) thick.
- 4. Factory-install continuous wood nailers 3-1/2 inches (90 mm) wide at tops of equipment supports.
- 5. Metal Counterflashing: Manufacturer's standard removable counterflashing, fabricated of same metal and finish as equipment support.
- 6. On ribbed or fluted metal roofs, form flange at perimeter bottom to conform to roof profile.
- 7. Fabricate units to minimum height of 12 inches (300 mm), unless otherwise indicated.
- 8. Sloping Roofs: Where slope of roof deck exceeds 1:48, fabricate curb units with water diverter or cricket and with height tapered to match slope to level tops of units.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, to verify actual locations, dimensions, and other conditions affecting performance of work.
  - 1. Verify that substrate is sound, dry, smooth, clean, sloped for drainage, and securely anchored and is ready to receive roof accessories.
  - 2. Verify dimensions of roof openings for roof accessories.
  - 3. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 INSTALLATION

- A. General: Install roof accessories according to manufacturer's written instructions. Anchor roof accessories securely in place and capable of resisting forces specified. Use fasteners, separators, sealants, and other miscellaneous items as required for completing roof accessory installation. Install roof accessories to resist exposure to weather without failing, rattling, leaking, and fastener disengagement.
- B. Install roof accessories to fit substrates and to result in watertight performance.
- C. Metal Protection: Where dissimilar metals will contact each other or corrosive substrates, protect against galvanic action by painting contact surfaces with bituminous coating or by other permanent separation as recommended by manufacturer.
  - 1. Coat concealed side of uncoated aluminum and stainless-steel roof accessories with bituminous coating where in contact with wood, ferrous metal, or cementitious construction.
  - 2. Underlayment: Where installing exposed-to-view components of roof accessories directly on cementitious or wood substrates, install a course of felt underlayment and cover with a slip sheet, or install a course of polyethylene underlayment.

3. Bed flanges in thick coat of asphalt roofing cement where required by roof accessory manufacturers for waterproof performance.
- D. Install roof accessories level, plumb, true to line and elevation, and without warping, jogs in alignment, excessive oil canning, buckling, or tool marks.
- E. Roof Curb Installation:
  1. Set roof curb so top surface of roof curb is level.
- F. Equipment Support Installation:
  1. Set equipment support so top surface of equipment support is level.
- G. Seal joints with elastomeric sealant as required by manufacturer of roof accessories.

### 3.3 TOUCH UP

- A. Touch up factory-primed surfaces with compatible primer ready for field painting in accordance with Division 09 painting Sections.
- B. Galvanized Surfaces: Clean field welds, bolted connections, and abraded areas and repair galvanizing to comply with ASTM A 780.

### 3.4 CLEANING

- A. Clean exposed surfaces according to manufacturer's written instructions.

END OF SECTION 07 7200

SECTION 078120 – INTUMESCENT FIRE RESISTIVE MATERIALS

PART 1 - GENERAL

1.1 SCOPE

1.1.1 This specification covers labor, materials, equipment, and application necessary for, and incidental to, the complete and proper installation of intumescent fire protection for application to steel structures and supports in accordance with all applicable requirements of contract documents.

1.1.2 This specification shall be supplemented by the applicable requirements of building codes, insurance rating organizations and all other authorities having jurisdiction.

1.2 SECTION INCLUDES

1.2.1 Intumescent fire protection material.

1.2.2 Topcoat protective decorative finish.

1.3 RELATED SECTIONS

1.3.1 Section 051000: Structural Steel.

1.3.2 Section 051200 - 055000: Structural steel and metal fabrications with reference to primer receiving fire protection materials.

1.3.3 Section 078100 Spray-Applied Fire Resistive Material.

1.3.4 Section 072700: Firestopping and Smoke Seals.

1.3.5 Section 099000: Painting.

1.4 REFERENCES

1.4.1 Underwriters Laboratories (UL) Fire Resistance Directory.

1.4.2 Underwriters Laboratories of Canada (ULC) - List of Equipment and Materials.

1.4.3 Third Party Evaluation Services Report

- 1.4.3 Test Standards and Practices
- a) ANSI/UL 263 (ASTM E119) - Fire Tests of Building Construction and Materials
  - b) CAN/ULC-S101 - Standard Methods of Fire Endurance Tests of Building Construction and Materials
  - c) ASTM E84 (UL723, CAN/ULC-S102) - Surface Burning Characteristics of Building Materials. Flame Spread Maximum: 5 and Smoke Developed Maximum: 35
  - d) ASTM D2240 – Durometer Hardness (Shore D Only). Minimum: 67 Shore D
  - e) ASTM D2794 – Impact Resistance. Intrusion minimum: 152 inch-lb. (17.17 Nm)
  - f) ASTM D4060 – Abrasion Resistance. Maximum 0.2600 grams/1000 cycles
  - g) ASTM D4541 – Bond Strength. Minimum: 340 psi. (2344 k Pa.)
  - h) ASTM E2924 – Standard Practice for Intumescent Coatings

1.4.4 Steel Structures Painting Council (SSPC) Surface Preparation Standards.

1.4.5 Material manufacturer's current published information including, but not limited to, application guide.

1.4.6 AWCI Technical Manual 12-B "Standard Practice for the Testing and Inspection of Field Applied Thin-Film Intumescent Fire-Resistive Materials; an Annotated Guide", Latest Edition.

## 1.5 SYSTEM DESCRIPTION

1.5.1 The intumescent fire protection materials shall be applied at the required thickness to provide the UL fire resistive ratings.

## 1.6 SUBMITTALS

1.6.1 Manufacturer's Data: Submit manufacturer's specifications, including independent laboratory physical property test reports and certifications as may be required to show material compliance with contract documents.

## 1.7 QUALITY ASSURANCE

1.7.1 Comply with ASTM E2924 for the testing, labeling, transportation, delivery, storage, shelf life, application and inspection of intumescent coatings.

1.7.2 Manufacturer - Company specializing in manufacturing fire protection products.

1.7.3 The intumescent fire resistive material shall be manufactured under the Follow-Up Service program of UL or ULC and bear the UL and/or ULC label (mark).

1.7.4 Applicator - A firm with expertise in the installation of fire resistive or similar materials.

1.7.5 Product - The product shall be approved by the architect and applicable authorities having jurisdiction.

1.8 DELIVERY, STORAGE AND HANDLING

1.8.1 Deliver materials to the project in manufacturer's unopened packages, fully identified as to trade name, type and other identifying data. Packaged materials shall bear the appropriate labels, seals and UL label (mark) for fire resistive ratings and shall be stored at temperatures in compliance with manufacturer instructions in a dry interior location away from direct sunlight.  
DO NOT FREEZE.

1.9 PROJECT/SITE CONDITIONS

1.9.1 When the temperature at the job site is less than 50° F (10° C), a minimum substrate and ambient temperature of 50° F (10° C) shall be maintained prior to, during, and a minimum of 72 hours after application. If necessary for job schedule, the General Contractor shall provide enclosures and heat to maintain proper temperatures and humidity levels in the application areas.

1.9.2 In enclosed areas, ventilation shall not be less than 4 complete air exchanges per hour until the material is dry.

1.9.3 Relative humidity shall not exceed 85% throughout the total period of application and drying for the intumescent fire resistive material, and must not exceed 85% throughout the application and drying for the protective decorative topcoat.

1.10 SEQUENCING AND SCHEDULING

1.10.1 Applicator shall cooperate in the coordination and scheduling of fire protection work to avoid delays in job progress.

1.10.2 The installation of piping, ducts, conduit or other suspended equipment shall not commence until the application of the thin-film fire resistive material is complete in that area.

PART 2 - PRODUCTS

2.1 COMPATIBLE METAL PRIMER

2.1.1 Primer shall be approved by manufacturer and applied in full accordance with the primer manufacturer's written instructions.

2.2 INTUMESCENT FIRE PROTECTION SYSTEM

2.2.1 The intumescent fire resistive material shall be CAFCO® SprayFilm® WB 5™ or CAFCO® SprayFilm® WB 3™ as supplied by Isolatek International or CAFCO INDUSTRIES.

2.2.2 Intumescent fire resistive material shall be applied in accordance with drawings and/or specifications, and shall have been tested in accordance with the procedures of ANSI/UL 263 or ASTM E119 or CAN/ULC-S101, and reported by Underwriters Laboratories, Inc. or Underwriters Laboratories of Canada only.



- 2.2.3. Thin-Film Fire-Resistive Intumescent Mastic Coating: Factory-mixed formulation.
- a) Water-Based Formulation: Approved by manufacturer and authorities having jurisdiction for indicated use.
  - b) Verify with manufacturer that products selected are suitable for use indicated.
  - c) UL Fire Tested Designs Only based on ANSI/UL 263 (ASTM E119).
  - d) Current Third Party Evaluation Service Report
  - e) To assure an acceptable Architectural finish, no mesh is allowed.
  - f) A representative mock-up sprayed Architectural finish sample must be submitted, reviewed, and accepted by the architect in advance.

## 2.3 DECORATIVE TOPCOATING

- 2.3.1 Topcoat materials shall be as required for color-coding, aesthetics or additional surface protection, approved by the thin-film fire resistive material manufacturer and applied in full accordance with the coating manufacturer's written instructions.

## PART 3 - EXECUTION

### 3.1 PREPARATION

- 3.1.1 All surfaces to receive thin-film fire resistive material shall be clean, dry and free of oil, grease, loose mill scale, dirt, dust or other materials which would impair bond of the thin-film fire resistive material to the surface. Any cleaning of the surfaces to receive fire resistive material shall be the responsibility of the General Contractor or steel erector, as outlined in the structural steel section.
- 3.1.2 Confirm compatibility of surfaces to receive thin-film fire resistive material. Steel surfaces shall be primed with a compatible primer approved by the thin-film fire resistive material manufacturer.
- 3.1.3 Provide masking, drop cloths or other suitable coverings to prevent overspray onto surfaces not intended to be coated with intumescent coating.

### 3.2 APPLICATION

- 3.2.1 The thin-film fire resistive material shall be applied at the required dry film thickness per the appropriate UL design number guidelines and manufacturers written application instructions.

### 3.3 MOCK UP

3.3.1 Before proceeding with the work, the applicator shall apply the thin-film fire resistive material to a section witnessed by the architect's or owner's representative. The application shall be subject to their approval and shall be used as a guide for texture and thickness of the finished work.

#### 3.4 CLEAN UP AND REPAIR

3.4.1 Upon completion of installation, all excess material, overspray and debris shall be cleared and removed from the job site.

3.4.2 All patching of and repair to thin-film fire resistive material, due to damage by other trades, shall be performed under this section and paid for by the trade responsible for the damage. Patching shall be performed by an applicator with expertise in the installation of fire resistive or similar materials. Repair shall be in accordance with UL design number guidelines and manufacturers written application instructions.

#### 3.5 INSPECTION AND TESTING

3.5.1 In addition to continuous Wet Film Thickness checks performed by applicator during application, the installed intumescent material shall be inspected by a qualified independent testing laboratory for thickness in accordance with the AWCi Technical Manual 12-B "Standard Practice For The Testing and Inspection Of Field Applied Thin-Film Intumescent Fire-Resistive Materials; an Annotated Guide", Latest Edition, before application of the topcoat.

3.5.2 The results of the above tests shall be made available to all parties at the completion of each area and approved prior to the application of topcoat.

#### Note:

The performance data herein is based upon our experience and knowledge and reflect our expectations based on tests conducted in accordance with recognized standard methods under controlled conditions. Isolatek International makes no claim that these tests, or any other tests, accurately reflect all environments as application, environmental and design factors can vary significantly. The sale of these products shall be subject to the Terms and Conditions of Sale set forth in the Company's Invoices. The applicator, general contractor, property owner and/or user MUST read, understand and follow the directions, specifications and/or recommendations set forth in Isolatek International's publications concerning use and application of these products, and should not rely merely on the information contained in this guide specification. ISOLATEK INTERNATIONAL DISCLAIMS ALL WARRANTIES, WHETHER EXPRESS OR IMPLIED, INCLUDING WARRANTIES OF FITNESS FOR A PARTICULAR PURPOSE OR MERCHANTABILITY. ISOLATEK INTERNATIONAL SHALL NOT BE RESPONSIBLE FOR ANY DAMAGES (INCLUDING, BUT NOT LIMITED TO, INCIDENTAL OR CONSEQUENTIAL DAMAGES, DAMAGES FOR LOST PROFITS, DAMAGES FOR LOST SALES, AND/OR DAMAGES FOR INJURY TO PERSON OR PROPERTY). ISOLATEK INTERNATIONAL SHALL NOT BE RESPONSIBLE FOR ANY DAMAGES ARISING FROM OR RELATED TO THE FAILURE BY THE APPLICATOR, GENERAL CONTRACTOR, PROPERTY OWNER AND/OR USER TO FOLLOW THE DIRECTIONS, SPECIFICATIONS AND/OR RECOMMENDATIONS SET FORTH IN ISOLATEK INTERNATIONAL'S PUBLICATIONS. No agent, employee or representative of Isolatek International, its subsidiary or affiliated companies is authorized to modify this statement.



SECTION 07 8413 - PENETRATION FIRESTOPPING

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes through-penetration firestop systems for penetrations through fire-resistance-rated constructions, including both empty openings and openings containing penetrating items.
- B. Related Sections include the following:
  - 1. Division 078446 Section "Fire-Resistive Joint Systems."

1.3 PERFORMANCE REQUIREMENTS

- A. General: For penetrations through fire-resistance-rated constructions, including both empty openings and openings containing penetrating items, provide through-penetration firestop systems that are produced and installed to resist spread of fire according to requirements indicated, resist passage of smoke and other gases, and maintain original fire-resistance rating of construction penetrated.
  - 1. Fire-resistance-rated walls including fire partitions, fire barriers and smoke barriers.
  - 2. Fire-resistance-rated horizontal assemblies including floor/ceiling assemblies and ceiling membranes of roof/ceiling assemblies.
- B. Rated Systems: Provide through-penetration firestop systems with the following ratings determined per ASTM E 814, 2007 edition or UL 1479:
  - 1. F-Rated Systems: Provide through-penetration firestop systems with F-ratings indicated, but not less than that equaling or exceeding fire-resistance rating of constructions penetrated.
  - 2. T-Rated Systems: For the following conditions, provide through-penetration firestop systems with T-ratings indicated, as well as F-ratings, where systems protect penetrating items exposed to potential contact with adjacent materials in occupiable floor areas:
    - a. Penetrations located outside wall cavities.
    - b. Penetrations located outside fire-resistance-rated shaft enclosures.

- C. For through-penetration firestop systems exposed to view, traffic, moisture, and physical damage, provide products that, after curing, do not deteriorate when exposed to these conditions both during and after construction.
  - 1. For piping penetrations for plumbing and wet-pipe sprinkler systems, provide moisture-resistant through-penetration firestop systems.
  - 2. For floor penetrations with annular spaces exceeding 4 inches (100 mm) in width and exposed to possible loading and traffic, provide firestop systems capable of supporting floor loads involved, either by installing floor plates or by other means.
  - 3. For penetrations involving insulated piping, provide through-penetration firestop systems not requiring removal of insulation.
- D. For through-penetration firestop systems exposed to view, provide products with flame-spread and smoke-developed indexes of less than 25 and 450, respectively, as determined per ASTM E 84, 2007 edition.

#### 1.4 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: For each through-penetration firestop system, show each type of construction condition penetrated, relationships to adjoining construction, and type of penetrating item. Include firestop design designation of qualified testing and inspecting agency that evidences compliance with requirements for each condition indicated.
  - 1. Submit documentation, including illustrations, from a qualified testing and inspecting agency that is applicable to each through-penetration firestop system configuration for construction and penetrating items.
  - 2. Where Project conditions require modification to a qualified testing and inspecting agency's illustration for a particular through-penetration firestop condition, submit illustration, with modifications marked, approved by through-penetration firestop system manufacturer's fire-protection engineer as an engineering judgment or equivalent fire-resistance-rated assembly.
- C. Through-Penetration Firestop System Schedule: Indicate locations of each through-penetration firestop system, along with the following information:
  - 1. Types of penetrating items.
  - 2. Types of constructions penetrated, including fire-resistance ratings and, where applicable, thicknesses of construction penetrated.
  - 3. Through-penetration firestop systems for each location identified by firestop design designation of qualified testing and inspecting agency.
- D. Qualification Data: For Installer.
- E. Product Certificates: For through-penetration firestop system products, signed by product manufacturer.
- F. Product Test Reports: From a qualified testing agency indicating through-penetration firestop system complies with requirements, based on comprehensive testing of current products.

1.5 QUALITY ASSURANCE

- A. Installer Qualifications: A firm that has been approved by FMG according to FMG 4991, "Approval of Firestop Contractors."
- B. Installer Qualifications: A firm experienced in installing through-penetration firestop systems similar in material, design, and extent to that indicated for this Project, whose work has resulted in construction with a record of successful performance. Qualifications include having the necessary experience, staff, and training to install manufacturer's products per specified requirements. Manufacturer's willingness to sell its through-penetration firestop system products to Contractor or to Installer engaged by Contractor does not in itself confer qualification on buyer.
- C. Installation Responsibility: Assign installation of through-penetration firestop systems and fire-resistive joint systems in Project to a single qualified installer.
- D. Source Limitations: Obtain through-penetration firestop systems, for each kind of penetration and construction condition indicated, through one source from a single manufacturer.
- E. Fire-Test-Response Characteristics: Provide through-penetration firestop systems that comply with the following requirements and those specified in Part 1 "Performance Requirements" Article:
  - 1. Firestopping tests are performed by a qualified testing and inspecting agency. A qualified testing and inspecting agency is UL, or another agency performing testing and follow-up inspection services for firestop systems acceptable to authorities having jurisdiction.
  - 2. Through-penetration firestop systems are identical to those tested per testing standard referenced in "Part 1 Performance Requirements" Article. Provide rated systems complying with the following requirements:
    - a. Through-penetration firestop system products bear classification marking of qualified testing and inspecting agency.
    - b. Through-penetration firestop systems correspond to those indicated by reference to through-penetration firestop system designations listed by the following:
      - 1) UL in its "Fire Resistance Directory."
- F. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 013100 Section "Project Management and Coordination."

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Deliver through-penetration firestop system products to Project site in original, unopened containers or packages with intact and legible manufacturers' labels identifying product and manufacturer, date of manufacture, lot number, shelf life if applicable, qualified testing and inspecting agency's classification marking applicable to Project, curing time, and mixing instructions for multicomponent materials.
- B. Store and handle materials for through-penetration firestop systems to prevent their deterioration or damage due to moisture, temperature changes, contaminants, or other causes.

1.7 PROJECT CONDITIONS

- A. Environmental Limitations: Do not install through-penetration firestop systems when ambient or substrate temperatures are outside limits permitted by through-penetration firestop system manufacturers or when substrates are wet due to rain, frost, condensation, or other causes.
- B. Ventilate through-penetration firestop systems per manufacturer's written instructions by natural means or, where this is inadequate, forced-air circulation.

1.8 COORDINATION

- A. Coordinate construction of openings and penetrating items to ensure that through-penetration firestop systems are installed according to specified requirements.
- B. Coordinate sizing of sleeves, openings, core-drilled holes, or cut openings to accommodate through-penetration firestop systems.
- C. Notify Owner's inspecting agency at least seven days in advance of through-penetration firestop system installations; confirm dates and times on days preceding each series of installations.
- D. Do not cover up through-penetration firestop system installations that will become concealed behind other construction until each installation has been examined by Owner's inspecting agency and building inspector, if required by authorities having jurisdiction.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Available Products: Subject to compliance with requirements, through-penetration firestop systems that may be incorporated into the Work include, but are not limited to, those systems indicated that are produced by one of the following manufacturers:
  - 1. A/D Fire Protection Systems Inc.
  - 2. Grace, W. R. & Co. - Conn.
  - 3. Hilti, Inc.
  - 4. Johns Manville.
  - 5. Nelson Firestop Products.
  - 6. NUCO Inc.
  - 7. RectorSeal Corporation (The).
  - 8. Specified Technologies Inc.
  - 9. 3M; Fire Protection Products Division.
  - 10. Tremco; Sealant/Weatherproofing Division.
  - 11. USG Corporation.
  - 12. Pecora.

## 2.2 FIRESTOPPING, GENERAL

- A. **Compatibility:** Provide through-penetration firestop systems that are compatible with one another; with the substrates forming openings; and with the items, if any, penetrating through-penetration firestop systems, under conditions of service and application, as demonstrated by through-penetration firestop system manufacturer based on testing and field experience.
- B. **Accessories:** Provide components for each through-penetration firestop system that are needed to install fill materials and to comply with Part 1 "Performance Requirements" Article. Use only components specified by through-penetration firestop system manufacturer and approved by qualified testing and inspecting agency for firestop systems indicated. Accessories include, but are not limited to, the following items:
  - 1. Permanent forming/damming/backing materials, including the following:
    - a. Slag-/rock-wool-fiber insulation.
    - b. Sealants used in combination with other forming/damming/backing materials to prevent leakage of fill materials in liquid state.
    - c. Fire-rated form board.
    - d. Fillers for sealants.
  - 2. Temporary forming materials.
  - 3. Substrate primers.
  - 4. Collars.
  - 5. Steel sleeves.

## 2.3 FILL MATERIALS

- A. **General:** Provide through-penetration firestop systems containing the types of fill materials indicated in the Through-Penetration Firestop System Schedule at the end of Part 3 by referencing the types of materials described in this Article. Fill materials are those referred to in directories of referenced testing and inspecting agencies as "fill," "void," or "cavity" materials.
- B. **Cast-in-Place Firestop Devices:** Factory-assembled devices for use in cast-in-place concrete floors and consisting of an outer metallic sleeve lined with an intumescent strip, a radial extended flange attached to one end of the sleeve for fastening to concrete formwork, and a neoprene gasket.
- C. **Latex Sealants:** Single-component latex formulations that after cure do not re-emulsify during exposure to moisture.
- D. **Firestop Devices:** Factory-assembled collars formed from galvanized steel and lined with intumescent material sized to fit specific diameter of penetrant.
- E. **Intumescent Composite Sheets:** Rigid panels consisting of aluminum-foil-faced elastomeric sheet bonded to galvanized steel sheet.
- F. **Intumescent Putties:** Nonhardening dielectric, water-resistant putties containing no solvents, inorganic fibers, or silicone compounds.
- G. **Intumescent Wrap Strips:** Single-component intumescent elastomeric sheets with aluminum foil on one side.



- H. Mortars: Prepackaged dry mixes consisting of a blend of inorganic binders, hydraulic cement, fillers, and lightweight aggregate formulated for mixing with water at Project site to form a nonshrinking, homogeneous mortar.
- I. Pillows/Bags: Reusable heat-expanding pillows/bags consisting of glass-fiber cloth cases filled with a combination of mineral-fiber, water-insoluble expansion agents, and fire-retardant additives.
- J. Silicone Foams: Multicomponent, silicone-based liquid elastomers that, when mixed, expand and cure in place to produce a flexible, nonshrinking foam.
- K. Silicone Sealants: Single-component, silicone-based, neutral-curing elastomeric sealants of grade indicated below:
  - 1. Grade: Pourable (self-leveling) formulation for openings in floors and other horizontal surfaces, and nonsag formulation for openings in vertical and other surfaces requiring a nonslumping, gunnable sealant, unless indicated firestop system limits use to nonsag grade for both opening conditions.
  - 2. Grade for Horizontal Surfaces: Pourable (self-leveling) formulation for openings in floors and other horizontal surfaces.
  - 3. Grade for Vertical Surfaces: Nonsag formulation for openings in vertical and other surfaces.

## 2.4 MIXING

- A. For those products requiring mixing before application, comply with through-penetration firestop system manufacturer's written instructions for accurate proportioning of materials, water (if required), type of mixing equipment, selection of mixer speeds, mixing containers, mixing time, and other items or procedures needed to produce products of uniform quality with optimum performance characteristics for application indicated.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates and conditions, with Installer present, for compliance with requirements for opening configurations, penetrating items, substrates, and other conditions affecting performance of work.
  - 1. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. Surface Cleaning: Clean out openings immediately before installing through-penetration firestop systems to comply with firestop system manufacturer's written instructions and with the following requirements:

1. Remove from surfaces of opening substrates and from penetrating items foreign materials that could interfere with adhesion of through-penetration firestop systems.
  2. Clean opening substrates and penetrating items to produce clean, sound surfaces capable of developing optimum bond with through-penetration firestop systems. Remove loose particles remaining from cleaning operation.
  3. Remove laitance and form-release agents from concrete.
- B. Priming: Prime substrates where recommended in writing by through-penetration firestop system manufacturer using that manufacturer's recommended products and methods. Confine primers to areas of bond; do not allow spillage and migration onto exposed surfaces.
- C. Masking Tape: Use masking tape to prevent through-penetration firestop systems from contacting adjoining surfaces that will remain exposed on completion of Work and that would otherwise be permanently stained or damaged by such contact or by cleaning methods used to remove smears from firestop system materials. Remove tape as soon as possible without disturbing firestop system's seal with substrates.

### 3.3 THROUGH-PENETRATION FIRESTOP SYSTEM INSTALLATION

- A. General: Install through-penetration firestop systems to comply with Part 1 "Performance Requirements" Article and with firestop system manufacturer's written installation instructions and published drawings for products and applications indicated.
- B. Install forming/damming/backing materials and other accessories of types required to support fill materials during their application and in the position needed to produce cross-sectional shapes and depths required to achieve fire ratings indicated.
1. After installing fill materials and allowing them to fully cure, remove combustible forming materials and other accessories not indicated as permanent components of firestop systems.
- C. Install fill materials for firestop systems by proven techniques to produce the following results:
1. Fill voids and cavities formed by openings, forming materials, accessories, and penetrating items as required to achieve fire-resistance ratings indicated.
  2. Apply materials so they contact and adhere to substrates formed by openings and penetrating items.
  3. For fill materials that will remain exposed after completing Work, finish to produce smooth, uniform surfaces that are flush with adjoining finishes.

### 3.4 IDENTIFICATION

- A. Identify through-penetration firestop systems with preprinted metal or plastic labels. Attach labels permanently to surfaces adjacent to and within 6 inches (150 mm) of edge of the firestop systems so that labels will be visible to anyone seeking to remove penetrating items or firestop systems. Use mechanical fasteners for metal labels. For plastic labels, use self-adhering type with adhesives capable of permanently bonding labels to surfaces on which labels are placed and, in combination with label material, will result in partial destruction of label if removal is attempted. Include the following information on labels:

1. The words "Warning - Through-Penetration Firestop System - Do Not Disturb. Notify Building Management of Any Damage."
2. Contractor's name, address, and phone number.
3. Through-penetration firestop system designation of applicable testing and inspecting agency.
4. Date of installation.
5. Through-penetration firestop system manufacturer's name.
6. Installer's name.

### 3.5 FIELD QUALITY CONTROL

- A. Inspecting Agency: Owner will engage a qualified, independent inspecting agency to inspect through-penetration firestops. Independent inspecting agency shall comply with ASTM E 2174 requirements including those related to qualifications, conducting inspections, and preparing test reports.
- B. Where deficiencies are found, repair or replace through-penetration firestop systems so they comply with requirements.
- C. Proceed with enclosing through-penetration firestop systems with other construction only after inspection reports are issued and firestop installations comply with requirements.

### 3.6 CLEANING AND PROTECTING

- A. Clean off excess fill materials adjacent to openings as Work progresses by methods and with cleaning materials that are approved in writing by through-penetration firestop system manufacturers and that do not damage materials in which openings occur.
- B. Provide final protection and maintain conditions during and after installation that ensure that through-penetration firestop systems are without damage or deterioration at time of Substantial Completion. If, despite such protection, damage or deterioration occurs, cut out and remove damaged or deteriorated through-penetration firestop systems immediately and install new materials to produce systems complying with specified requirements.

### 3.7 THROUGH-PENETRATION FIRESTOP SYSTEM SCHEDULE

- A. Where UL-classified systems are indicated, they refer to alpha-alpha-numeric designations listed in UL's "Fire Resistance Directory" under product Category XHEZ.
- B. Firestop Systems with No Penetrating Items:
  1. Available UL-Classified Systems: C-AJ, C-BJ, F-A, W-J and W-L.
  2. Type of Fill Materials: One or more of the following:
    - a. Latex sealant.
    - b. Silicone sealant.
    - c. Intumescent putty.
    - d. Mortar.
- C. Firestop Systems for Metallic Pipes, Conduit, or Tubing:

1. Available UL-Classified Systems: C-AJ, C-BJ, C-BK, F-A, F-B, F-C, W-J, W-K, and W-L.
  2. Type of Fill Materials: One or more of the following:
    - a. Latex sealant.
    - b. Silicone sealant.
    - c. Intumescent putty.
    - d. Mortar.
- D. Firestop Systems for Nonmetallic Pipe, Conduit, or Tubing:
1. Available UL-Classified Systems: C-AJ, C-BJ, F-A, F-B, F-C, W-J, and W-L.
  2. Type of Fill Materials: One or more of the following:
    - a. Latex sealant.
    - b. Silicone sealant.
    - c. Intumescent putty.
    - d. Intumescent wrap strips.
    - e. Firestop device.
- E. Firestop Systems for Electrical Cables:
1. Available UL-Classified Systems: C-AJ, C-BJ, F-A, F-B, F-C, W-J, and W-L.
  2. Type of Fill Materials: One or more of the following:
    - a. Latex sealant.
    - b. Silicone sealant.
    - c. Intumescent putty.
    - d. Silicone foam.
    - e. Pillows/bags.
- F. Firestop Systems for Cable Trays:
1. Available UL-Classified Systems: C-AJ, C-BJ, F-A, F-B, F-C, W-J, W-K, and W-L.
  2. Type of Fill Materials: One or more of the following:
    - a. Latex sealant.
    - b. Intumescent putty.
    - c. Silicone foam.
    - d. Pillows/bags.
    - e. Mortar.
- G. Firestop Systems for Insulated Pipes:
1. Available UL-Classified Systems: C-AJ, C-BJ, F-A, F-C, W-J, and W-L.
  2. Type of Fill Materials: One or more of the following:
    - a. Latex sealant.
    - b. Intumescent putty.
    - c. Silicone foam.
    - d. Intumescent wrap strips.
- H. Firestop Systems for Miscellaneous Electrical Penetrants:
1. Available UL-Classified Systems: C-AJ, F-A, and W-L.
  2. Type of Fill Materials: One or more of the following:
    - a. Latex sealant.
    - b. Intumescent putty.
    - c. Mortar.
- I. Firestop Systems for Miscellaneous Mechanical Penetrants:

1. Available UL-Classified Systems: C-AJ, F-C, W-J, and W-L.
2. Type of Fill Materials: One or both of the following:
  - a. Latex sealant.
  - b. Mortar.
3. Firestop Systems for Groupings of Penetrants:
4. Available UL-Classified Systems: C-AJ, C-BJ, F-A, F-C, W-J, and W-L.
5. Type of Fill Materials: One or more of the following:
  - a. Latex sealant.
  - b. Mortar.
  - c. Intumescent wrap strips.
  - d. Firestop device.
  - e. Intumescent composite sheet.

END OF SECTION 07 8413

SECTION 07 8446 - FIRE-RESISTIVE JOINT SYSTEMS

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. Section Includes:

- 1. Joints in or between fire-resistance-rated constructions.

- B. Related Sections:

- 1. Division 078413 section "Penetration Firestopping" for penetrations in fire-resistance-rated walls, horizontal assemblies, and smoke barriers.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.

- B. Product Schedule: For each fire-resistive joint system. Include location and design designation of qualified testing agency.

- 1. Where Project conditions require modification to a qualified testing agency's illustration for a particular fire-resistive joint system condition, submit illustration, with modifications marked, approved by fire-resistive joint system manufacturer's fire-protection engineer as an engineering judgment or equivalent fire-resistance-rated assembly.

1.4 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For qualified Installer.

- B. Installer Certificates: From Installer indicating fire-resistive joint systems have been installed in compliance with requirements and manufacturer's written recommendations.

- C. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency, for fire-resistive joint systems.

## 1.5 QUALITY ASSURANCE

- A. Installer Qualifications: A firm that has been approved by FM Global according to FM Global 4991, "Approval of Firestop Contractors," or been evaluated by UL and found to comply with UL's "Qualified Firestop Contractor Program Requirements."
- B. Installer Qualifications: A firm experienced in installing fire-resistive joint systems similar in material, design, and extent to that indicated for this Project, whose work has resulted in construction with a record of successful performance. Qualifications include having the necessary experience, staff, and training to install manufacturer's products per specified requirements. Manufacturer's willingness to sell its fire-resistive joint system products to Contractor or to Installer engaged by Contractor does not in itself confer qualification on buyer.
- C. Fire-Test-Response Characteristics: Fire-resistive joint systems shall comply with the following requirements:
  - 1. Fire-resistive joint system tests are performed by a qualified testing agency acceptable to authorities having jurisdiction.
  - 2. Fire-resistive joint systems are identical to those tested per testing standard referenced in "Fire-Resistive Joint Systems" Article. Provide rated systems complying with the following requirements:
    - a. Fire-resistive joint system products bear classification marking of qualified testing agency.
    - b. Fire-resistive joint systems correspond to those indicated by reference to designations listed by the following:
      - 1) UL in its "Fire Resistance Directory."
      - 2) Intertek ETL SEMKO in its "Directory of Listed Building Products."
- D. Preinstallation Conference: Conduct conference at Project site.

## 1.6 PROJECT CONDITIONS

- A. Environmental Limitations: Do not install fire-resistive joint systems when ambient or substrate temperatures are outside limits permitted by fire-resistive joint system manufacturers or when substrates are wet due to rain, frost, condensation, or other causes.
- B. Install and cure fire-resistive joint systems per manufacturer's written instructions using natural means of ventilation or, where this is inadequate, forced-air circulation.

## 1.7 COORDINATION

- A. Coordinate construction of joints to ensure that fire-resistive joint systems are installed according to specified requirements.
- B. Coordinate sizing of joints to accommodate fire-resistive joint systems.
- C. Notify Owner's testing agency at least seven days in advance of fire-resistive joint system installations; confirm dates and times on day preceding each series of installations.

PART 2 - PRODUCTS

2.1 FIRE-RESISTIVE JOINT SYSTEMS

- A. Where required, provide fire-resistive joint systems that are produced and installed to resist spread of fire according to requirements indicated, resist passage of smoke and other gases, and maintain original fire-resistance rating of assemblies in or between which fire-resistive joint systems are installed. Fire-resistive joint systems shall accommodate building movements without impairing their ability to resist the passage of fire and hot gases.
- B. Joints in or between Fire-Resistance-Rated Construction: Provide fire-resistive joint systems with ratings determined per ASTM E 1966, 2001 edition or UL 2079:
1. Joints include those installed in or between fire-resistance-rated walls.
  2. Fire-Resistance Rating: Equal to or exceeding the fire-resistance rating of construction they will join.
  3. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. A/D Fire Protection Systems Inc.
    - b. CEMCO.
    - c. Fire Trak Corp.
    - d. Grace Construction Products.
    - e. Hilti, Inc.
    - f. Johns Manville.
    - g. Nelson Firestop Products.
    - h. NUCO Inc.
    - i. Passive Fire Protection Partners.
    - j. RectorSeal Corporation.
    - k. Specified Technologies Inc.
    - l. 3M Fire Protection Products.
    - m. Tremco, Inc.; Tremco Fire Protection Systems Group.
    - n. USG Corporation.
- C. Exposed Fire-Resistive Joint Systems: Provide products with flame-spread and smoke-developed indexes of less than 25 and 450, respectively, as determined per ASTM E 84, 2007 edition .
- D. VOC Content: Fire-resistive joint system sealants shall comply with the following limits for VOC content when calculated according to 40 CFR 59, Subpart D (EPA Method 24):
1. Architectural Sealants: 250 g/L.
  2. Sealant Primers for Nonporous Substrates: 250 g/L.
  3. Sealant Primers for Porous Substrates: 775 g/L.
- E. Low-Emitting Materials: Fire-resistive joint system sealants shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."



- F. Accessories: Provide components of fire-resistive joint systems, including primers and forming materials, that are needed to install fill materials and to maintain ratings required. Use only components specified by fire-resistive joint system manufacturer and approved by the qualified testing agency for systems indicated.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine substrates and conditions, with Installer present, for compliance with requirements for joint configurations, substrates, and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 PREPARATION

- A. Surface Cleaning: Clean joints immediately before installing fire-resistive joint systems to comply with fire-resistive joint system manufacturer's written instructions and the following requirements:
  - 1. Remove from surfaces of joint substrates foreign materials that could interfere with adhesion of fill materials.
  - 2. Clean joint substrates to produce clean, sound surfaces capable of developing optimum bond with fill materials. Remove loose particles remaining from cleaning operation.
  - 3. Remove laitance and form-release agents from concrete.
- B. Priming: Prime substrates where recommended in writing by fire-resistive joint system manufacturer using that manufacturer's recommended products and methods. Confine primers to areas of bond; do not allow spillage and migration onto exposed surfaces.
- C. Masking Tape: Use masking tape to prevent fill materials of fire-resistive joint system from contacting adjoining surfaces that will remain exposed on completion of the Work and that would otherwise be permanently stained or damaged by such contact or by cleaning methods used to remove stains. Remove tape as soon as possible without disturbing fire-resistive joint system's seal with substrates.

#### 3.3 INSTALLATION

- A. General: Install fire-resistive joint systems to comply with manufacturer's written installation instructions and published drawings for products and applications indicated.
- B. Install forming materials and other accessories of types required to support fill materials during their application and in position needed to produce cross-sectional shapes and depths required to achieve fire ratings indicated.
  - 1. After installing fill materials and allowing them to fully cure, remove combustible forming materials and other accessories not indicated as permanent components of fire-resistive joint system.

- C. Install fill materials for fire-resistive joint systems by proven techniques to produce the following results:
  - 1. Fill voids and cavities formed by joints and forming materials as required to achieve fire-resistance ratings indicated.
  - 2. Apply fill materials so they contact and adhere to substrates formed by joints.
  - 3. For fill materials that will remain exposed after completing the Work, finish to produce smooth, uniform surfaces that are flush with adjoining finishes.

### 3.4 IDENTIFICATION

- A. Identify fire-resistive joint systems with preprinted metal or plastic labels. Attach labels permanently to surfaces adjacent to and within 6 inches (150 mm) of joint edge so labels will be visible to anyone seeking to remove or penetrate joint system. Use mechanical fasteners or self-adhering-type labels with adhesives capable of permanently bonding labels to surfaces on which labels are placed. Include the following information on labels:
  - 1. The words "Warning - Fire-Resistive Joint System - Do Not Disturb. Notify Building Management of Any Damage."
  - 2. Contractor's name, address, and phone number.
  - 3. Designation of applicable testing agency.
  - 4. Date of installation.
  - 5. Manufacturer's name.
  - 6. Installer's name.

### 3.5 FIELD QUALITY CONTROL

- A. Inspecting Agency: Owner will engage a qualified testing agency to perform tests and inspections.
- B. Where deficiencies are found or fire-resistive joint systems are damaged or removed due to testing, repair or replace fire-resistive joint systems so they comply with requirements.
- C. Proceed with enclosing fire-resistive joint systems with other construction only after inspection reports are issued and installations comply with requirements.

### 3.6 CLEANING AND PROTECTING

- A. Clean off excess fill materials adjacent to joints as the Work progresses by methods and with cleaning materials that are approved in writing by fire-resistive joint system manufacturers and that do not damage materials in which joints occur.
- B. Provide final protection and maintain conditions during and after installation that ensure fire-resistive joint systems are without damage or deterioration at time of Substantial Completion. If damage or deterioration occurs despite such protection, cut out and remove damaged or deteriorated fire-resistive joint systems immediately and install new materials to produce fire-resistive joint systems complying with specified requirements.

3.7 FIRE-RESISTIVE JOINT SYSTEM SCHEDULE

- A. Designation System for Joints in or between Fire-Resistance-Rated Constructions: Alphanumeric systems listed in UL's "Fire Resistance Directory" under Product Category XHBN.
  
- B. Head-of-Wall Fire-Resistive Joint Systems:
  - 1. Available UL-Classified Systems: Provide one of the systems listed in the UL Fire Resistance Directory for HW-D and HW-S, applicable for the type of wall and roof assembly.
  - 2. Assembly Rating: As required to meet the rating of the wall assembly.
  - 3. Nominal Joint Width: As indicated.
  - 4. Type of Fill Materials: One or more of the following subject to compliance with requirements:
    - a. Sprayable coating:
      - 1) Fire Dam Spray; EM.
      - 2) Fire Temp SI; Johns Manville.
      - 3) Spec Seal AS Elastomeric Spray; Specified Technologies, Inc.
      - 4) Metacaulk 1100; The Rectorseal Corp.
      - 5) CP-672 Sprayable Firestop Hilti
    - b. Latex sealant.
    - c. Urethane sealant.
    - d. Flexible Polyurethane Security Sealant.
    - e. Backer Rod.
    - f. Mineral Wool.
  
- C. Wall-to-Wall Fire-Resistive Joint Systems:
  - 1. Available UL-Classified Systems: Provide one of the systems listed in the UL Fire Resistance Directory for WW-D and WW-S, applicable for the type of wall assembly.
  - 2. Assembly Rating: As required to meet the rating of the wall assembly.
  - 3. Nominal Joint Width: As indicated.
  - 4. Type of Fill Materials: One or more of the following subject to compliance with requirements:
    - a. Latex sealant.
    - b. Urethane sealant.
    - c. Flexible Polyurethane Security Sealant.
    - d. Backer Rod.
    - e. Mineral Wool.

END OF SECTION 07 8446

SECTION 07 9200 - JOINT SEALANTS

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes joint sealants for the applications indicated in the Joint-Sealant Schedule at the end of Part 3.
- B. Related Sections include the following:
  - 1. Division 042200 Section "Unit Masonry" for masonry control and expansion joint fillers and gaskets.
  - 2. Division 078446 Section "Fire-Resistive Joint Systems" for sealing joints in fire-resistance-rated construction.
  - 3. Division 088000 Section "Glazing" for glazing sealants.
  - 4. Division 092900 Section "Gypsum Board" for sealing perimeter joints of gypsum board partitions to reduce sound transmission.
  - 5. Division 095113 Section "Acoustical Panel Ceilings" for sealing edge moldings at perimeters of acoustical ceilings.
  - 6. Division 321313 Section "Concrete Paving Joint Sealants" for sealing joints in pavements, walkways, and curbing.

1.3 DEFINITIONS

- A. Non-Security Rated Areas: Any surface located outside the confines of the security areas as defined by the security plans and not typically used by inmates.
- B. Security Rated Areas: Any surface located within the confines of security areas, including security rated walls, floors, ceiling and roof as defined by the security plans and other areas typical for inmate use.
  - 1. On vertical surfaces, security rating ends at 10 feet (3 M) above any floor surface, or at ceiling or roof line lower than 10 feet (3 M).

1.4 PERFORMANCE REQUIREMENTS

- A. Provide elastomeric joint sealants that establish and maintain watertight and airtight continuous joint seals without staining or deteriorating joint substrates.
- B. Provide joint sealants for interior applications that establish and maintain airtight and water-resistant continuous joint seals without staining or deteriorating joint substrates.

1.5 SUBMITTALS

- A. Product Data: For each joint-sealant product indicated.
- B. Samples for Initial Selection: Manufacturer's color charts consisting of strips of cured sealants showing the full range of colors available for each product exposed to view.
- C. Samples for Verification: For each type and color of joint sealant required, provide Samples with joint sealants in 1/2-inch- (13-mm-) wide joints formed between two 6-inch- (150-mm-) long strips of material matching the appearance of exposed surfaces adjacent to joint sealants.
- D. Compatibility and Adhesion Test Reports: From sealant manufacturer, indicating the following:
  - 1. Materials forming joint substrates and joint-sealant backings have been tested for compatibility and adhesion with joint sealants.
  - 2. Interpretation of test results and written recommendations for primers and substrate preparation needed for adhesion.
- E. Warranties: Special warranties specified in this Section.

1.6 QUALITY ASSURANCE

- A. Installer Qualifications: Manufacturer's authorized Installer who is approved or licensed for installation of elastomeric sealants required for this Project.
- B. Source Limitations: Obtain each type of joint sealant through one source from a single manufacturer.
- C. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination."

1.7 PROJECT CONDITIONS

- A. Do not proceed with installation of joint sealants under the following conditions:
  - 1. When ambient and substrate temperature conditions are outside limits permitted by joint-sealant manufacturer or are below 40 deg F (5 deg C).
  - 2. When joint substrates are wet.
  - 3. Where joint widths are less than those allowed by joint-sealant manufacturer for applications indicated.
  - 4. Contaminants capable of interfering with adhesion have not yet been removed from joint substrates.

1.8 WARRANTY

- A. Special Installer's Warranty: Installer's standard form in which Installer agrees to repair or replace elastomeric joint sealants that do not comply with performance and other requirements specified in this Section within specified warranty period.
  - 1. Warranty Period: Five (5) years from date of Substantial Completion.

- B. Special Manufacturer's Warranty: Manufacturer's standard form in which elastomeric sealant manufacturer agrees to furnish elastomeric joint sealants to repair or replace those that do not comply with performance and other requirements specified in this Section within specified warranty period.
  - 1. Warranty Period: Five (5) years from date of Substantial Completion.
- C. Special warranties specified in this Article exclude deterioration or failure of elastomeric joint sealants from the following:
  - 1. Movement of the structure resulting in stresses on the sealant exceeding sealant manufacturer's written specifications for sealant elongation and compression caused by structural settlement or errors attributable to design or construction.
  - 2. Disintegration of joint substrates from natural causes exceeding design specifications.
  - 3. Mechanical damage caused by individuals, tools, or other outside agents.
  - 4. Changes in sealant appearance caused by accumulation of dirt or other atmospheric contaminants.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, products listed in other Part 2 articles.

### 2.2 MATERIALS, GENERAL

- A. Compatibility: Provide joint sealants, backings, and other related materials that are compatible with one another and with joint substrates under conditions of service and application, as demonstrated by sealant manufacturer, based on testing and field experience.
- B. Colors of Exposed Joint Sealants: As selected by Architect from manufacturer's full range.
  - 1. Refer to Joint Sealant Schedule in Part 3 article.

### 2.3 ELASTOMERIC JOINT SEALANTS

- A. Elastomeric Sealants: Comply with ASTM C 920 and other requirements indicated for each liquid-applied chemically curing sealant specified, including those referencing ASTM C 920 classifications for type, grade, class, and uses related to exposure and joint substrates.
- B. Stain-Test-Response Characteristics: Where elastomeric sealants are specified to be nonstaining to porous substrates, provide products that have undergone testing according to ASTM C 1248 and have not stained porous joint substrates indicated for Project.
- C. Suitability for Contact with Food: Where elastomeric sealants are indicated for joints that will come in repeated contact with food, provide products that comply with 21 CFR 177.2600.

- D. Single-Component Pourable Neutral-Curing Silicone Sealant:
1. Available Products:
    - a. Dow Corning Corporation; 890-SL.
    - b. Pecora Corporation; 300 Pavement Sealant (Self Leveling).
    - c. Dow Corning Corporation; SL Parking Structure Sealant.
  2. Type and Grade: S (single component) and P (pourable).
  3. Class: 100/50.
  4. Uses Related to Exposure: NT and T (traffic).
  5. Uses Related to Joint Substrates: M and O, as applicable to joint substrates indicated.
    - a. Use O Joint Substrates: Concrete and asphaltic concrete.
- E. Single-Component Low-Modulus Neutral-Curing Silicone Sealant:
1. Available Products:
    - a. Dow Corning Corporation; 790.
    - b. GE Silicones; SilPruf LM SCS2700.
    - c. GE Silicones; SilPruf SCS2000.
    - d. Pecora Corporation; 864.
    - e. Pecora Corporation; 890.
    - f. Polymeric Systems Inc.; PSI-641.
    - g. Sonneborn, Division of ChemRex Inc.; Omniseal.
    - h. Tremco; Spectrem 3.
  2. Type and Grade: S (single component) and NS (nonsag).
  3. Class: 50 or 100/50.
  4. Use Related to Exposure: NT (nontraffic).
  5. Uses Related to Joint Substrates: M, G, A, and O as applicable to joint substrates indicated.
    - a. Use O Joint Substrates: color or clear anodic aluminum, galvanized steel, stainless steel, concrete and masonry.
  6. Stain-Test-Response Characteristics: Nonstaining to porous substrates per ASTM C 1248.
- F. Single-Component Medium-Modulus Neutral-Curing Silicone Sealant:
1. Available Products:
    - a. Dow Corning Corporation; 799.
    - b. GE Silicones; UltraGlaze SSG4000.
    - c. Polymeric Systems Inc.; PSI-631.
    - d. Tremco; Proglaze SG.
    - e. Tremco; Spectrem 2.
    - f. Tremco; Tremsil 600.
  2. Type and Grade: S (single component) and NS (nonsag).
  3. Class: 25.
  4. Use Related to Exposure: NT (nontraffic).
  5. Uses Related to Joint Substrates: G, A, and O as applicable to joint substrates indicated.
    - a. Use O Joint Substrates: Coated glass, color or clear anodic aluminum, galvanized steel and stainless steel.
- G. Single-Component Mildew-Resistant Neutral-Curing or Acid-Curing Silicone Sealant:
1. Available Products:
    - a. Pecora Corporation; 898.
    - b. Tremco; Tremsil 600 or Tremsil 200 White.
    - c. Dow Corning Corporation; 786 Mildew Resistant.

- d. GE Silicones; Sanitary SCS1700.
2. Type and Grade: S (single component) and NS (nonsag).
3. Class: 25.
4. Use Related to Exposure: NT (nontraffic).
5. Uses Related to Joint Substrates: G, A, and O as applicable to joint substrates indicated.
  - a. Use O Joint Substrates: Stainless steel, porcelain ceramic, concrete, masonry, plastic laminate and gypsum wall board.

H. Multicomponent Nonsag Urethane Sealant:

1. Available Products:
  - a. Pecora Corporation; Dynatrol II.
  - b. Tremco; Dymeric 511.
  - c. Sika Corporation, Inc.; Sikaflex - 2c NS TG.
  - d. Sonneborn, Division of ChemRex Inc.; NP 2.
2. Type and Grade: M (multicomponent) and NS (nonsag).
3. Class: 25 or 50.
4. Use Related to Exposure: NT (nontraffic).
5. Uses Related to Joint Substrates: M, A, and O as applicable to joint substrates indicated.
  - a. Use O Joint Substrates: Color or clear anodic aluminum, galvanized steel, stainless steel, concrete and masonry.

I. Multicomponent Pourable Urethane Sealant:

1. Available Products:
  - a. Pecora Corporation; Urexpam NR-200.
  - b. Tremco; THC-900 or THC-901.
  - c. Sika Corporation, Inc.; Sikaflex - 2c SL.
  - d. Sonneborn, Division of ChemRex Inc.; SL 2.
2. Type and Grade: M (multicomponent) and P (pourable).
3. Class: 25.
4. Use Related to Exposure: T (traffic).
5. Uses Related to Joint Substrates: M, A, and O as applicable to joint substrates indicated.
  - a. Use O Joint Substrates: Concrete, quarry tile and ceramic tile.

2.4 LATEX JOINT SEALANTS

A. Latex Sealant: Comply with ASTM C 834, Type P, Grade NF.

B. Available Products:

1. Pecora Corporation; AC-20+.
2. Sonneborn, Division of ChemRex Inc.; Sonolac.
3. Tremco; Tremflex 834.

2.5 SECURITY JOINT SEALANTS

A. Flexible Polyurethane Security Sealant:

1. Available Products:
  - a. Pecora; Dynaflex.
  - b. Sonneborn, Division of ChemRex, Inc.; Ultra.
2. Type and Grade: S (Single component) Grade NS.



3. Class: 12-1/2.
  4. Uses related to exposure: T (traffic) and NT (non-traffic).
  5. Hardness, Shore A: 55 minimum.
  6. Uses related to joint substrates: M, G, A and O as applicable to joint substrates indicated.
    - a. Use O Joint Substrates: Galvanized steel, steel, stainless steel, ceramic, concrete, and masonry.
- B. Rigid Epoxy Security Sealant:
1. Available Products:
    - a. Pecora; Dynapoxy EP-1100.
    - b. Pecora; Dynapoxy EP-1200.
    - c. Sika Corporation, Inc.; Sakador 31-Hi-Mod Gel.
    - d. Sonneborn, Division of ChemRex, Inc.; Epolith (R)-Por-G.
  2. Type and grade: M (multi-component) Grade NS.
  3. Uses related to exposure: T (traffic) and NT (non-traffic).
  4. Hardness, Shore D: 70 minimum.
  5. Uses related to joint substrates: M, A and O as applicable to joint substrates indicated.
    - a. Use O Substrates: Galvanized steel, steel and stainless steel.

## 2.6 JOINT-SEALANT BACKING

- A. General: Provide sealant backings of material and type that are nonstaining; are compatible with joint substrates, sealants, primers, and other joint fillers; and are approved for applications indicated by sealant manufacturer based on field experience and laboratory testing.
- B. Cylindrical Sealant Backings: ASTM C 1330, Type C (closed-cell material with a surface skin), O (open-cell material), B (bicellular material with a surface skin), or any of the preceding types, as approved in writing by joint-sealant manufacturer for joint application indicated, and of size and density to control sealant depth and otherwise contribute to producing optimum sealant performance:
- C. Bond-Breaker Tape: Polyethylene tape or other plastic tape recommended by sealant manufacturer for preventing sealant from adhering to rigid, inflexible joint-filler materials or joint surfaces at back of joint where such adhesion would result in sealant failure. Provide self-adhesive tape where applicable.

## 2.7 MISCELLANEOUS MATERIALS

- A. Primer: Material recommended by joint-sealant manufacturer where required for adhesion of sealant to joint substrates indicated, as determined from preconstruction joint-sealant-substrate tests and field tests.
- B. Cleaners for Nonporous Surfaces: Chemical cleaners acceptable to manufacturers of sealants and sealant backing materials, free of oily residues or other substances capable of staining or harming joint substrates and adjacent nonporous surfaces in any way, and formulated to promote optimum adhesion of sealants to joint substrates.
- C. Masking Tape: Nonstaining, nonabsorbent material compatible with joint sealants and surfaces adjacent to joints.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine joints indicated to receive joint sealants, with Installer present, for compliance with requirements for joint configuration, installation tolerances, and other conditions affecting joint-sealant performance.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Surface Cleaning of Joints: Clean out joints immediately before installing joint sealants to comply with joint-sealant manufacturer's written instructions and the following requirements:
  - 1. Remove all foreign material from joint substrates that could interfere with adhesion of joint sealant, including dust, paints (except for permanent, protective coatings tested and approved for sealant adhesion and compatibility by sealant manufacturer), old joint sealants, oil, grease, waterproofing, water repellents, water, surface dirt, and frost.
  - 2. Clean porous joint substrate surfaces by brushing, grinding, blast cleaning, mechanical abrading, or a combination of these methods to produce a clean, sound substrate capable of developing optimum bond with joint sealants. Remove loose particles remaining after cleaning operations above by vacuuming or blowing out joints with oil-free compressed air. Porous joint substrates include the following:
    - a. Concrete.
    - b. Masonry.
    - c. Unglazed surfaces of ceramic tile.
  - 3. Remove laitance and form-release agents from concrete.
  - 4. Clean nonporous surfaces with chemical cleaners or other means that do not stain, harm substrates, or leave residues capable of interfering with adhesion of joint sealants. Nonporous joint substrates include the following:
    - a. Metal.
    - b. Glass.
    - c. Porcelain enamel.
    - d. Glazed surfaces of ceramic tile.
- B. Joint Priming: Prime joint substrates, where recommended in writing by joint-sealant manufacturer, based on preconstruction joint-sealant-substrate tests or prior experience. Apply primer to comply with joint-sealant manufacturer's written instructions. Confine primers to areas of joint-sealant bond; do not allow spillage or migration onto adjoining surfaces.
- C. Masking Tape: Use masking tape where required to prevent contact of sealant with adjoining surfaces that otherwise would be permanently stained or damaged by such contact or by cleaning methods required to remove sealant smears. Remove tape immediately after tooling without disturbing joint seal.

### 3.3 INSTALLATION OF JOINT SEALANTS

- A. General: Comply with joint-sealant manufacturer's written installation instructions for products and applications indicated, unless more stringent requirements apply.
- B. Sealant Installation Standard: Comply with recommendations in ASTM C 1193 for use of joint sealants as applicable to materials, applications, and conditions indicated.
- C. Install sealant backings of type indicated to support sealants during application and at position required to produce cross-sectional shapes and depths of installed sealants relative to joint widths that allow optimum sealant movement capability.
  - 1. Do not leave gaps between ends of sealant backings.
  - 2. Do not stretch, twist, puncture, or tear sealant backings.
  - 3. Remove absorbent sealant backings that have become wet before sealant application and replace them with dry materials.
- D. Install bond-breaker tape behind sealants where sealant backings are not used between sealants and backs of joints.
- E. Install sealants using proven techniques that comply with the following and at the same time backings are installed:
  - 1. Place sealants so they directly contact and fully wet joint substrates.
  - 2. Completely fill recesses in each joint configuration.
  - 3. Produce uniform, cross-sectional shapes and depths relative to joint widths that allow optimum sealant movement capability.
- F. Tooling of Nonsag Sealants: Immediately after sealant application and before skinning or curing begins, tool sealants according to requirements specified below to form smooth, uniform beads of configuration indicated; to eliminate air pockets; and to ensure contact and adhesion of sealant with sides of joint.
  - 1. Remove excess sealant from surfaces adjacent to joints.
  - 2. Use tooling agents that are approved in writing by sealant manufacturer and that do not discolor sealants or adjacent surfaces.
  - 3. Provide concave joint configuration per Figure 5A in ASTM C 1193, unless otherwise indicated.
  - 4. Provide flush joint configuration where indicated per Figure 5B in ASTM C 1193.
  - 5. Provide recessed joint configuration of recess depth and at locations indicated per Figure 5C in ASTM C 1193.
    - a. Use masking tape to protect surfaces adjacent to recessed tooled joints.
- G. Installation of Preformed Foam Sealants: Install each length of sealant immediately after removing protective wrapping, taking care not to pull or stretch material, producing seal continuity at ends, turns, and intersections of joints. For applications at low ambient temperatures where expansion of sealant requires acceleration to produce seal, apply heat to sealant in compliance with sealant manufacturer's written instructions.

### 3.4 FIELD QUALITY CONTROL

- A. Field-Adhesion Testing: Field test joint-sealant adhesion to joint substrates as follows:
  - 1. Extent of Testing: Test completed elastomeric sealant joints as follows:

- a. Perform 10 tests for the first 1000 feet (300 m) of joint length for each type of elastomeric sealant and joint substrate.
- b. Perform 1 test for each 1000 feet (300 m) of joint length thereafter or 1 test per each floor per elevation.
2. Test Method: Test joint sealants according to Method A, Field-Applied Sealant Joint Hand Pull Tab in Appendix X1 in ASTM C 1193.
  - a. For joints with dissimilar substrates, verify adhesion to each substrate separately; do this by extending cut along one side, verifying adhesion to opposite side. Repeat procedure for opposite side.
3. Inspect joints for complete fill, for absence of voids, and for joint configuration complying with specified requirements. Record results in a field-adhesion-test log.
4. Inspect tested joints and report on the following:
  - a. Whether sealants in joints connected to pulled-out portion failed to adhere to joint substrates or tore cohesively. Include data on pull distance used to test each type of product and joint substrate. Compare these results to determine if adhesion passes sealant manufacturer's field-adhesion hand-pull test criteria.
  - b. Whether sealants filled joint cavities and are free of voids.
  - c. Whether sealant dimensions and configurations comply with specified requirements.
5. Record test results in a field-adhesion-test log. Include dates when sealants were installed, names of persons who installed sealants, test dates, test locations, whether joints were primed, adhesion results and percent elongations, sealant fill, sealant configuration, and sealant dimensions. Provide test report to CxA for review and comment.
6. Repair sealants pulled from test area by applying new sealants following same procedures used originally to seal joints. Ensure that original sealant surfaces are clean and that new sealant contacts original sealant.

- B. Evaluation of Field Test Results: Sealants not evidencing adhesive failure from testing or noncompliance with other indicated requirements will be considered satisfactory. Remove sealants that fail to adhere to joint substrates during testing or to comply with other requirements. Retest failed applications until test results prove sealants comply with indicated requirements.

### 3.5 CLEANING

- A. Clean off excess sealant or sealant smears adjacent to joints as the Work progresses by methods and with cleaning materials approved in writing by manufacturers of joint sealants and of products in which joints occur.

### 3.6 PROTECTION

- A. Protect joint sealants during and after curing period from contact with contaminating substances and from damage resulting from construction operations or other causes so sealants are without deterioration or damage at time of Substantial Completion. If, despite such protection, damage or deterioration occurs, cut out and remove damaged or deteriorated joint sealants immediately so installations with repaired areas are indistinguishable from original work.

### 3.7 JOINT-SEALANT SCHEDULE

- A. Sealants systems for non-security rated areas.
1. Exterior concrete unit masonry control joints.
    - a. Joint Sealant: Single-component low-modulus neutral-curing silicone sealant.
    - b. Joint-Sealant Color: Match Color of finish paint.
  2. Exterior vertical control and expansion joints in EIFS
    - a. Joint Sealant: Single-component low-modulus neutral-curing silicone sealant.
    - b. Joint-Sealant Color: Match Color of finish paint.
  3. Exterior perimeter joints between different materials listed above and frames of doors, windows and louvers.
    - a. Joint Sealant: Single-component medium-modulus neutral-curing silicone sealant.
    - b. Joint-Sealant Color: Match Color of finish paint.
  4. Exterior perimeter joints of surface mounted items, including surface mounted lights, enclosures, housings, intercoms, etc. with a gap that exceeds 1/32 inch (1.0mm) wide.
    - a. Joint Sealant: Single-component medium-modulus neutral-curing silicone sealant.
    - b. Joint-Sealant Color: Match Color of finish paint.
  5. Other exterior joints.
    - a. Joint Sealant: Single-component low-modulus neutral-curing silicone sealant.
    - b. Joint-Sealant Color: Match Color of surface on which they occur.
  6. Interior vertical control and expansion joints in unit masonry on interior surfaces of exterior walls.
    - a. Joint Sealant: Multicomponent nonsag urethane sealant.
    - b. Joint-Sealant Color: Match Color of finish paint.
  7. Interior perimeter joints of door and window frames in unit masonry and concrete walls.
    - a. Joint Sealant: Multicomponent nonsag urethane sealant.
    - b. Joint-Sealant Color: Match Color of finish paint.
  8. Interior joints between plumbing fixtures and adjoining walls, floors, and counters.
    - a. Joint Sealant: Single-component mildew-resistant neutral or acid-curing silicone sealant.
    - b. Joint-Sealant Color: Match Color of finish paint.
  9. Interior perimeter joints between wall finish and door and window frames in metal stud framed walls.
    - a. Joint Sealant: Latex sealant.
    - b. Joint-Sealant Color: Match Color of finish paint.
  10. Interior control and casing bead joints in gypsum board walls and ceilings.
    - a. Joint Sealant: Latex sealant.
    - b. Joint-Sealant Color: Match Color of finish paint.
  11. Interior control, expansion, and isolation joints in horizontal traffic surfaces of exposed concrete floor, quarry tile flooring and resilient tile flooring.
    - a. Joint Sealant: Multicomponent pourable urethane sealant.
    - b. Joint-Sealant Color:
      - 1) Match color of exposed concrete.
      - 2) Match color of tile grout
      - 3) Match field color of resilient tile flooring.
- B. Sealant Systems for Security Rated Areas.
1. Exterior vertical control and expansion joints in unit masonry to 10 feet (3M) above finish grade.
    - a. Joint Sealant: Flexible polyurethane security sealant.
    - b. Joint Sealant Color: Match Color of finish paint.

2. Exterior perimeter joints between different materials listed above and frames of doors, windows and louvers located within 10 feet (3M) above finish grade.
  - a. Joint Sealant: Flexible polyurethane security sealant.
  - b. Joint Sealant Color: Match Color of finish paint.
3. Exterior perimeter joints of surface mounted items on concrete, unit masonry walls, located at 10 feet (3M) or less above finish grade, including surface mounted lights, enclosures, housings, intercoms, etc. with a gap that exceeds 1/32 inch (1.0mm) wide.
  - a. Joint Sealant: Flexible polyurethane security sealant.
  - b. Joint Sealant Color: Match Color of finish paint.
4. Interior vertical control and expansion joints in unit masonry on interior surfaces of exterior walls.
  - a. Joint Sealant: Flexible polyurethane security sealant.
  - b. Joint Sealant Color: Match Color of finish paint.
5. Interior perimeter joints of door and window frames in unit masonry and concrete walls.
  - a. Joint Sealant: Flexible polyurethane security sealant.
  - b. Joint Sealant Color: Match Color of finish paint.
6. Interior joints between plumbing fixtures and adjoining walls, floors and counters.
  - a. Joint Sealant: Flexible polyurethane security sealant.
  - b. Joint Sealant Color: Match Color of finish paint.
7. Interior floor joints.
  - a. Joint Sealant: Flexible polyurethane security sealant.
  - b. Joint Sealant Color: Match color of exposed concrete.
8. Interior perimeter joints of surface mounted items on concrete, unit masonry walls, floors or ceilings, including surface mounted lights, grilles, registers, wall mounted furniture, enclosures, housings, mirrors, shelves, intercoms, sprinkler escutcheons, etc. with a gap that exceeds 1/32 inch (1.0mm) wide.
  - a. Joint Sealant: Flexible polyurethane security sealant.
  - b. Joint Sealant Color: Match Color of finish paint.
9. Nylon electrical, data and communication device cover plates. Seal back side perimeter of cover plate to wall with sealant.
  - a. Joint Sealant: Flexible polyurethane security sealant.
  - b. Joint Sealant Color: Match Color of finish paint.
10. Floor joint between second level walkway slab and steel edge plate.
  - a. Joint Sealant: Flexible polyurethane security sealant.
  - b. Joint Sealant Color: Match color of exposed concrete.
11. Joint between modular metal detention wall panels and concrete or unit masonry surfaces.
  - a. Joint Sealant: Flexible polyurethane security sealant.
  - b. Joint Sealant Color: Match Color of finish paint.
12. Joints in modular metal detention wall panels.
  - a. Joint Sealant: Rigid epoxy security sealant.
  - b. Joint Sealant Color: Match Color of finish paint.
13. Interior perimeter joints of door and window frames in modular metal detention wall panels.
  - a. Joint Sealant: Rigid epoxy security sealant.
  - b. Joint Sealant Color: Match Color of finish paint.

END OF SECTION 07 9200

**DIVISION 08 – OPENINGS**





SECTION 08 1113 - HOLLOW METAL DOORS AND FRAMES

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. Section Includes:
  - 1. Standard hollow metal doors and frames.
- B. Related Sections:
  - 1. Division 044200 Section "Unit Masonry" for embedding anchors for hollow metal work into masonry construction.
  - 2. Division 083463 Section "Detention Doors and Frames" for hollow metal doors and frames for detention facilities.
  - 3. Division 087100 Section "Door Hardware for door hardware for hollow metal doors.
  - 4. Division 09 Sections "Exterior Painting" and "Interior Painting" for field painting hollow metal doors and frames.
  - 5. Division 26 Sections for electrical connections including conduit and wiring for door controls and operators.

1.3 DEFINITIONS

- A. Minimum Thickness: Minimum thickness of base metal without coatings.
- B. Standard Hollow Metal Work: Hollow metal work fabricated according to ANSI/SDI A250.8.

1.4 SUBMITTALS

- A. Product Data: For each type of product indicated. Include construction details, material descriptions, core descriptions, fire-resistance rating, and finishes.
- B. Shop Drawings: Include the following:
  - 1. Elevations of each door design.
  - 2. Details of doors, including vertical and horizontal edge details and metal thicknesses.
  - 3. Frame details for each frame type, including dimensioned profiles and metal thicknesses.
  - 4. Locations of reinforcement and preparations for hardware.
  - 5. Details of each different wall opening condition.
  - 6. Details of anchorages, joints, field splices, and connections.
  - 7. Details of accessories.
  - 8. Details of moldings, removable stops, and glazing.
  - 9. Details of conduit and preparations for power, signal, and control systems.

- C. Other Action Submittals:
  - 1. Schedule: Provide a schedule of hollow metal work prepared by or under the supervision of supplier, using same reference numbers for details and openings as those on Drawings. Coordinate with door hardware schedule.
- D. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency, for each type of hollow metal door and frame assembly.

#### 1.5 QUALITY ASSURANCE

- A. Source Limitations: Obtain hollow metal work from single source from single manufacturer.
- B. Fire-Rated Door Assemblies: Assemblies complying with NFPA 80, 2007 edition that are listed and labeled by a qualified testing agency, for fire-protection ratings indicated, based on testing at as close to neutral pressure as possible according to NFPA 252, 2003 edition.
- C. Fire-Rated, Borrowed-Light Frame Assemblies: Assemblies complying with NFPA 80 that are listed and labeled, by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire-protection ratings indicated, based on testing according to NFPA 257, 2007 edition or UL 9. Label each individual glazed lite.
- D. Smoke-Control Door Assemblies: Comply with NFPA 105, 2007 edition or UL 1784.
- E. Preinstallation Conference: Conduct conference at Project site.

#### 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Deliver hollow metal work palletized, wrapped, or crated to provide protection during transit and Project-site storage. Do not use nonvented plastic.
  - 1. Provide additional protection to prevent damage to finish of factory-finished units.
- B. Deliver welded frames with two removable spreader bars across bottom of frames, tack welded to jambs and mullions.
- C. Store hollow metal work under cover at Project site. Place in stacks of five units maximum in a vertical position with heads up, spaced by blocking, on minimum 4-inch- (102-mm-) high wood blocking. Do not store in a manner that traps excess humidity.
  - 1. Provide minimum 1/4-inch (6-mm) space between each stacked door to permit air circulation.

#### 1.7 PROJECT CONDITIONS

- A. Field Measurements: Verify actual dimensions of openings by field measurements before fabrication.

1.8 COORDINATION

- A. Coordinate installation of anchorages for hollow metal frames. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors. Deliver such items to Project site in time for installation.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Amweld Building Products, LLC.
  - 2. Benchmark; a division of Therma-Tru Corporation.
  - 3. Ceco Door Products; an Assa Abloy Group company.
  - 4. Curries Company; an Assa Abloy Group company.
  - 5. Deansteel Manufacturing Company, Inc.
  - 6. Firedoor Corporation.
  - 7. Fleming Door Products Ltd.; an Assa Abloy Group company.
  - 8. Habersham Metal Products Company.
  - 9. Kewanee Corporation (The).
  - 10. Mesker Door Inc.
  - 11. Pioneer Industries, Inc.
  - 12. Security Metal Products Corp.
  - 13. Steelcraft; an Ingersoll-Rand company.
  - 14. Windsor Republic Doors.
  - 15. Chief Industries, Inc.

2.2 MATERIALS

- A. Cold-Rolled Steel Sheet: ASTM A 1008/A 1008M, Commercial Steel (CS), Type B; suitable for exposed applications.
- B. Hot-Rolled Steel Sheet: ASTM A 1011/A 1011M, Commercial Steel (CS), Type B; free of scale, pitting, or surface defects; pickled and oiled.
- C. Metallic-Coated Steel Sheet: ASTM A 653/A 653M, Commercial Steel (CS), Type B; with minimum A40 (ZF120) metallic coating.
- D. Frame Anchors: ASTM A 591/A 591M, Commercial Steel (CS), 40Z (12G) coating designation; mill phosphatized.
  - 1. For anchors built into exterior walls, steel sheet complying with ASTM A 1008/A 1008M or ASTM A 1011/A 1011M, hot-dip galvanized according to ASTM A 153/A 153M, Class B.
- E. Inserts, Bolts, and Fasteners: Hot-dip galvanized according to ASTM A 153/A 153M.

- F. Grout: ASTM C 476, except with a maximum slump of 4 inches (102 mm), as measured according to ASTM C 143/C 143M.
- G. Mineral-Fiber Insulation: ASTM C 665, Type I (blankets without membrane facing); consisting of fibers manufactured from slag or rock wool with 6- to 12-lb/cu. ft. (96- to 192-kg/cu. m) density; with maximum flame-spread and smoke-development indexes of 25 and 50, respectively; passing ASTM E 136, 2007 edition for combustion characteristics.
- H. Glazing: Comply with requirements in Division 08 Section "Glazing."
- I. Bituminous Coating: Cold-applied asphalt mastic, SSPC-Paint 12, compounded for 15-mil (0.4-mm) dry film thickness per coat. Provide inert-type noncorrosive compound free of asbestos fibers, sulfur components, and other deleterious impurities.

## 2.3 STANDARD HOLLOW METAL DOORS

- A. General: Provide doors of design indicated, not less than thickness indicated; fabricated with smooth surfaces, without visible joints or seams on exposed faces unless otherwise indicated. Comply with ANSI/SDI A250.8.
  - 1. Design: Flush panel.
  - 2. Core Construction: Manufacturer's standard kraft-paper honeycomb, polystyrene, polyurethane, polyisocyanurate, mineral-board, or vertical steel-stiffener core.
    - a. Fire Door Core: As required to provide fire-protection ratings indicated.
    - b. Thermal-Rated (Insulated) Doors: Where indicated, provide doors fabricated with thermal-resistance value (R-value) of not less than 6.0 deg F x h x sq. ft./Btu (1.057 K x sq. m/W) when tested according to ASTM C 1363.
      - 1) Locations: Exterior doors.
  - 3. Vertical Edges for Single-Acting Doors: Square edge.
  - 4. Vertical Edges for Double-Acting Doors: Round vertical edges with 2-1/8-inch (54-mm) radius.
  - 5. Top and Bottom Edges: Closed with flush or inverted 0.042-inch- (1.0-mm-) thick, end closures or channels of same material as face sheets.
  - 6. Tolerances: Comply with SDI 117, "Manufacturing Tolerances for Standard Steel Doors and Frames."
- B. Exterior Doors: Face sheets fabricated from metallic-coated steel sheet. Provide doors complying with requirements indicated below by referencing ANSI/SDI A250.8 for level and model and ANSI/SDI A250.4 for physical performance level:
  - 1. Level 3 and Physical Performance Level A (Extra Heavy Duty), Model 1 (Full Flush).
- C. Interior Doors: Face sheets fabricated from cold-rolled steel sheet unless metallic-coated sheet is indicated. Provide doors complying with requirements indicated below by referencing ANSI/SDI A250.8 for level and model and ANSI/SDI A250.4 for physical performance level:
  - 1. Level 2 and Physical Performance Level B (Heavy Duty), Model 1 (Full Flush).
- D. Hardware Reinforcement: Fabricate according to ANSI/SDI A250.6 with reinforcing plates from same material as door face sheets.
- E. Fabricate concealed stiffeners and hardware reinforcement from either cold- or hot-rolled steel sheet.

## 2.4 STANDARD HOLLOW METAL FRAMES

- A. General: Comply with ANSI/SDI A250.8 and with details indicated for type and profile.
- B. Exterior Frames: Fabricated from metallic-coated steel sheet.
  - 1. Fabricate frames with mitered or coped corners.
  - 2. Frames for Level 3 Steel Doors: 0.053-inch-thick steel sheet.
- C. Interior Frames: Fabricated from cold-rolled steel sheet unless metallic-coated sheet is indicated.
  - 1. Fabricate frames with mitered or coped corners.
  - 2. Fabricate knocked-down, drywall slip-on frames for in-place gypsum board partitions.
  - 3. Frames for Level 2 Steel Doors: 0.053-inch-thick steel sheet.
  - 4. Frames for Wood Doors: 0.053-inch-thick steel sheet.
  - 5. Frames for Borrowed Lights: 0.053-inch-thick steel sheet.
- D. Hardware Reinforcement: Fabricate according to ANSI/SDI A250.6 with reinforcement plates from same material as frames.

## 2.5 FRAME ANCHORS

- A. Jamb Anchors:
  - 1. Masonry Type: Adjustable strap-and-stirrup or T-shaped anchors to suit frame size, not less than 0.042 inch (1.0 mm) thick, with corrugated or perforated straps not less than 2 inches (50 mm) wide by 10 inches (250 mm) long; or wire anchors not less than 0.177 inch (4.5 mm) thick.
  - 2. Stud-Wall Type: Designed to engage stud, welded to back of frames; not less than 0.042 inch (1.0 mm) thick.
  - 3. Compression Type for Drywall Slip-on Frames: Adjustable compression anchors.
  - 4. Postinstalled Expansion Type for In-Place Concrete or Masonry: Minimum 3/8-inch- (9.5-mm-) diameter bolts with expansion shields or inserts. Provide pipe spacer from frame to wall, with throat reinforcement plate, welded to frame at each anchor location.
- B. Floor Anchors: Formed from same material as frames, not less than 0.042 inch (1.0 mm) thick, and as follows:
  - 1. Monolithic Concrete Slabs: Clip-type anchors, with two holes to receive fasteners.

## 2.6 STOPS AND MOLDINGS

- A. Moldings for Glazed Lites in Doors: Minimum 0.032 inch (0.8 mm) thick, fabricated from same material as door face sheet in which they are installed.
- B. Fixed Frame Moldings: Formed integral with hollow metal frames, a minimum of 5/8 inch (16 mm) high unless otherwise indicated.
- C. Loose Stops for Glazed Lites in Frames: Minimum 0.032 inch (0.8 mm) thick, fabricated from same material as frames in which they are installed.

2.7 ACCESSORIES

- A. Mullions and Transom Bars: Join to adjacent members by welding or rigid mechanical anchors.
- B. Ceiling Struts: Minimum 1/4-inch-thick by 1-inch- (6.4-mm-thick by 25.4-mm-) wide steel.
- C. Grout Guards: Formed from same material as frames, not less than 0.016 inch (0.4 mm) thick.

2.8 FABRICATION

- A. Fabricate hollow metal work to be rigid and free of defects, warp, or buckle. Accurately form metal to required sizes and profiles, with minimum radius for thickness of metal. Where practical, fit and assemble units in manufacturer's plant. To ensure proper assembly at Project site, clearly identify work that cannot be permanently factory assembled before shipment.
- B. Tolerances: Fabricate hollow metal work to tolerances indicated in SDI 117.
- C. Hollow Metal Doors:
  - 1. Exterior Doors: Provide weep-hole openings in bottom of exterior doors to permit moisture to escape. Seal joints in top edges of doors against water penetration.
  - 2. Glazed Lites: Factory cut openings in doors.
  - 3. Astragals: Provide overlapping astragal on one leaf of pairs of doors where required by NFPA 80 for fire-performance rating or where indicated. Extend minimum 3/4 inch (19 mm) beyond edge of door on which astragal is mounted.
- D. Hollow Metal Frames: Where frames are fabricated in sections due to shipping or handling limitations, provide alignment plates or angles at each joint, fabricated of same thickness metal as frames.
  - 1. Welded Frames: Weld flush face joints continuously; grind, fill, dress, and make smooth, flush, and invisible.
  - 2. Sidelight and Transom Bar Frames: Provide closed tubular members with no visible face seams or joints, fabricated from same material as door frame. Fasten members at crossings and to jambs by butt welding.
  - 3. Provide countersunk, flat- or oval-head exposed screws and bolts for exposed fasteners unless otherwise indicated.
    - a. Provide pinned Torx-Plus or pinned Torx drive type fasteners at door hardware for doors and frames located in inmate accessible areas. Administration and Visitation areas are the only areas not accessible to inmates.
  - 4. Grout Guards: Weld guards to frame at back of hardware mortises in frames to be grouted.
  - 5. Floor Anchors: Weld anchors to bottom of jambs and mullions with at least four spot welds per anchor.
  - 6. Jamb Anchors: Provide number and spacing of anchors as follows:
    - a. Masonry Type: Locate anchors not more than 18 inches (457 mm) from top and bottom of frame. Space anchors not more than 32 inches (813 mm) o.c. and as follows:
      - 1) Two anchors per jamb up to 60 inches (1524 mm) high.
      - 2) Three anchors per jamb from 60 to 90 inches (1524 to 2286 mm) high.
      - 3) Four anchors per jamb from 90 to 120 inches (2286 to 3048 mm) high.

- 4) Four anchors per jamb plus 1 additional anchor per jamb for each 24 inches (610 mm) or fraction thereof above 120 inches (3048 mm) high.
    - b. Stud-Wall Type: Locate anchors not more than 18 inches (457 mm) from top and bottom of frame. Space anchors not more than 32 inches (813 mm) o.c. and as follows:
      - 1) Three anchors per jamb up to 60 inches (1524 mm) high.
      - 2) Four anchors per jamb from 60 to 90 inches (1524 to 2286 mm) high.
      - 3) Five anchors per jamb from 90 to 96 inches (2286 to 2438 mm) high.
      - 4) Five anchors per jamb plus 1 additional anchor per jamb for each 24 inches (610 mm) or fraction thereof above 96 inches (2438 mm) high.
      - 5) Two anchors per head for frames above 42 inches (1066 mm) wide and mounted in metal-stud partitions.
    - c. Compression Type: Not less than two anchors in each jamb.
    - d. Postinstalled Expansion Type: Locate anchors not more than 6 inches (152 mm) from top and bottom of frame. Space anchors not more than 26 inches (660 mm) o.c.
  7. Door Silencers: Except on weather-stripped doors, drill stops to receive door silencers as follows. Keep holes clear during construction.
    - a. Single-Door Frames: Drill stop in strike jamb to receive three door silencers.
    - b. Double-Door Frames: Drill stop in head jamb to receive two door silencers.
- E. Fabricate concealed stiffeners, edge channels, and hardware reinforcement from either cold- or hot-rolled steel sheet.
- F. Hardware Preparation: Factory prepare hollow metal work to receive templated mortised hardware; include cutouts, reinforcement, mortising, drilling, and tapping according to the Door Hardware Schedule and templates furnished as specified in Division 08 Section "Door Hardware."
  1. Locate hardware as indicated, or if not indicated, according to ANSI/SDI A250.8.
  2. Reinforce doors and frames to receive nontemplated, mortised and surface-mounted door hardware.
  3. Comply with applicable requirements in ANSI/SDI A250.6 and ANSI/DHI A115 Series specifications for preparation of hollow metal work for hardware.
  4. Coordinate locations of conduit and wiring boxes for electrical connections with Division 26 Sections.
- G. Stops and Moldings: Provide stops and moldings around glazed lites where indicated. Form corners of stops and moldings with butted or mitered hairline joints.
  1. Single Glazed Lites: Provide fixed stops and moldings welded on secure side of hollow metal work.
  2. Multiple Glazed Lites: Provide fixed and removable stops and moldings so that each glazed lite is capable of being removed independently.
  3. Provide fixed frame moldings on outside of exterior and on secure side of interior doors and frames.
  4. Provide loose stops and moldings on inside of hollow metal work.
  5. Coordinate rabbet width between fixed and removable stops with type of glazing and type of installation indicated.
  6. Provide pinned Torx-Plus or pinned Torx drive type fasteners at stops and moldings located in inmate accessible areas. Administration and Visitation areas are the only areas not accessible to inmates.

2.9 STEEL FINISHES

- A. Prime Finish: Apply manufacturer's standard primer immediately after cleaning and pretreating.
  - 1. Shop Primer: Manufacturer's standard, fast-curing, lead- and chromate-free primer complying with ANSI/SDI A250.10 acceptance criteria; recommended by primer manufacturer for substrate; compatible with substrate and field-applied coatings despite prolonged exposure.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Examine roughing-in for embedded and built-in anchors to verify actual locations before frame installation.
- C. For the record, prepare written report, endorsed by Installer, listing conditions detrimental to performance of the Work.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Remove welded-in shipping spreaders installed at factory. Restore exposed finish by grinding, filling, and dressing, as required to make repaired area smooth, flush, and invisible on exposed faces.
- B. Prior to installation, adjust and securely brace welded hollow metal frames for squareness, alignment, twist, and plumbness to the following tolerances:
  - 1. Squareness: Plus or minus 1/16 inch (1.6 mm), measured at door rabbet on a line 90 degrees from jamb perpendicular to frame head.
  - 2. Alignment: Plus or minus 1/16 inch (1.6 mm), measured at jambs on a horizontal line parallel to plane of wall.
  - 3. Twist: Plus or minus 1/16 inch (1.6 mm), measured at opposite face corners of jambs on parallel lines, and perpendicular to plane of wall.
  - 4. Plumbness: Plus or minus 1/16 inch (1.6 mm), measured at jambs on a perpendicular line from head to floor.
- C. Drill and tap doors and frames to receive nontemplated, mortised, and surface-mounted door hardware.

3.3 INSTALLATION

- A. General: Install hollow metal work plumb, rigid, properly aligned, and securely fastened in place; comply with Drawings and manufacturer's written instructions.



- B. Hollow Metal Frames: Install hollow metal frames of size and profile indicated. Comply with ANSI/SDI A250.11.
1. Set frames accurately in position, plumbed, aligned, and braced securely until permanent anchors are set. After wall construction is complete, remove temporary braces, leaving surfaces smooth and undamaged.
    - a. At fire-protection-rated openings, install frames according to NFPA 80, 2007 edition
    - b. Where frames are fabricated in sections because of shipping or handling limitations, field splice at approved locations by welding face joint continuously; grind, fill, dress, and make splice smooth, flush, and invisible on exposed faces.
    - c. Install frames with removable glazing stops located on secure side of opening.
    - d. Install door silencers in frames before grouting.
    - e. Remove temporary braces necessary for installation only after frames have been properly set and secured.
    - f. Check plumbness, squareness, and twist of frames as walls are constructed. Shim as necessary to comply with installation tolerances.
    - g. Field apply bituminous coating to backs of frames that are filled with grout containing antifreezing agents. (RFI #327 – This is required)
  2. Floor Anchors: Provide floor anchors for each jamb and mullion that extends to floor, and secure with postinstalled expansion anchors.
  3. Metal-Stud Partitions: Solidly pack mineral-fiber insulation behind frames.
  4. Masonry Walls: Coordinate installation of frames to allow for solidly filling space between frames and masonry with grout.
  5. Concrete Walls: Solidly fill space between frames and concrete with grout. Take precautions, including bracing frames, to ensure that frames are not deformed or damaged by grout forces.
  6. In-Place Concrete or Masonry Construction: Secure frames in place with postinstalled expansion anchors. Countersink anchors, and fill and make smooth, flush, and invisible on exposed faces.
  7. Installation Tolerances: Adjust hollow metal door frames for squareness, alignment, twist, and plumb to the following tolerances:
    - a. Squareness: Plus or minus 1/16 inch (1.6 mm), measured at door rabbet on a line 90 degrees from jamb perpendicular to frame head.
    - b. Alignment: Plus or minus 1/16 inch (1.6 mm), measured at jambs on a horizontal line parallel to plane of wall.
    - c. Twist: Plus or minus 1/16 inch (1.6 mm), measured at opposite face corners of jambs on parallel lines, and perpendicular to plane of wall.
    - d. Plumbness: Plus or minus 1/16 inch (1.6 mm), measured at jambs at floor.
- C. Hollow Metal Doors: Fit hollow metal doors accurately in frames, within clearances specified below. Shim as necessary.
1. Non-Fire-Rated Standard Steel Doors:
  2. Fire-Rated Doors: Install doors with clearances according to NFPA 80.
  3. Smoke-Control Doors: Install doors according to NFPA 105.
- D. Glazing: Comply with installation requirements in Division 08 Section "Glazing" and with hollow metal manufacturer's written instructions.
1. Secure stops with countersunk flat- or oval-head machine screws spaced uniformly not more than 9 inches (230 mm) o.c. and not more than 2 inches (50 mm) o.c. from each corner.

- a. Provide pinned Torx-Plus or pinned Torx drive type fasteners at stops located in inmate accessible areas. Administration and Visitation areas are the only areas not accessible to inmates.

### 3.4 ADJUSTING AND CLEANING

- A. Final Adjustments: Check and readjust operating hardware items immediately before final inspection. Leave work in complete and proper operating condition. Remove and replace defective work, including hollow metal work that is warped, bowed, or otherwise unacceptable.
- B. Remove grout and other bonding material from hollow metal work immediately after installation.
- C. Prime-Coat Touchup: Immediately after erection, sand smooth rusted or damaged areas of prime coat and apply touchup of compatible air-drying, rust-inhibitive primer.
- D. Metallic-Coated Surfaces: Clean abraded areas and repair with galvanizing repair paint according to manufacturer's written instructions.

END OF SECTION 08 1113

## SECTION 08 1416 - FLUSH WOOD DOORS

### PART 1 - GENERAL

#### 1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Solid-core doors with wood faces.
  - 2. Hollow-core doors with wood-veneer faces.
  - 3. Shop priming and Factory finishing flush wood doors.
  - 4. Factory fitting flush wood doors to frames and factory machining for hardware.
- B. Related Sections:
  - 1. Division 088853 Section "Glazing" for glass view panels in flush wood doors.

#### 1.3 SUBMITTALS

- A. Product Data: For each type of door indicated. Include details of core and edge construction and trim for openings. Include factory-finishing specifications.
- B. Shop Drawings: Indicate location, size, and hand of each door; elevation of each kind of door; construction details not covered in Product Data; location and extent of hardware blocking; and other pertinent data.
  - 1. Indicate dimensions and locations of mortises and holes for hardware.
  - 2. Indicate dimensions and locations of cutouts.
  - 3. Indicate requirements for veneer matching.
  - 4. Indicate doors to be factory finished and finish requirements.
  - 5. Indicate fire-protection ratings for fire-rated doors.
- C. Samples for Verification:
  - 1. Factory finishes applied to actual door face materials, approximately 8 by 10 inches (200 by 250 mm), for each material and finish. For each wood species and transparent finish, provide set of three samples showing typical range of color and grain to be expected in the finished work.
- D. Warranty: Sample of special warranty.

#### 1.4 QUALITY ASSURANCE

- A. Manufacturer Qualifications: A qualified manufacturer that is certified for chain of custody by an FSC-accredited certification body.

- B. Source Limitations: Obtain flush wood doors from single manufacturer.
- C. Quality Standard: In addition to requirements specified, comply with AWI's "Architectural Woodwork Quality Standards Illustrated."
  - 1. Provide AWI Quality Certification Labels or an AWI letter of licensing for Project indicating that doors comply with requirements of grades specified.
- D. Fire-Rated Wood Doors: Doors complying with NFPA 80, 2007 edition that are listed and labeled by a qualified testing agency, for fire-protection ratings indicated, based on testing at as close to neutral pressure as possible according to NFPA 252, 2003 edition .
- E. Preinstallation Conference: Conduct conference at Project site.

#### 1.5 DELIVERY, STORAGE, AND HANDLING

- A. Comply with requirements of referenced standard and manufacturer's written instructions.
- B. Package doors individually in cardboard cartons and wrap bundles of doors in plastic sheeting.
- C. Mark each door on top and bottom rail with opening number used on Shop Drawings.

#### 1.6 PROJECT CONDITIONS

- A. Environmental Limitations: Do not deliver or install doors until spaces are enclosed and weathertight, wet work in spaces is complete and dry, and HVAC system is operating and maintaining ambient temperature and humidity conditions at occupancy levels during the remainder of the construction period.

#### 1.7 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace doors that fail in materials or workmanship within specified warranty period.
  - 1. Failures include, but are not limited to, the following:
    - a. Warping (bow, cup, or twist) more than 1/4 inch in a 42-by-84-inch section.
    - b. Telegraphing of core construction in face veneers exceeding 0.01 inch in a 3-inch span.
  - 2. Warranty shall also include installation and finishing that may be required due to repair or replacement of defective doors.
  - 3. Warranty Period for Solid-Core Interior Doors: Life of installation.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements.
  - 1. Algoma Hardwoods, Inc.
  - 2. Ampco, Inc.

3. Buell Door Company Inc.
4. Chappell Door Co.
5. Eagle Plywood & Door Manufacturing, Inc.
6. Eggers Industries.
7. Graham; an Assa Abloy Group company.
8. Haley Brothers, Inc.
9. Ideal Architectural Doors & Plywood.
10. Ipik Door Company.
11. Lambton Doors.
12. Marlite.
13. Marshfield Door Systems, Inc.
14. Mohawk Flush Doors, Inc.; a Masonite company.
15. Oshkosh Architectural Door Company.
16. Poncraft Door Company.
17. Vancouver Door Company.
18. VT Industries Inc.

## 2.2 DOOR CONSTRUCTION, GENERAL

- A. WDMA I.S.1-A Performance Grade: Heavy Duty.
- B. Particleboard-Core Doors:
  1. Particleboard: ANSI A208.1, Grade LD-2.
  2. Blocking: Provide wood blocking in particleboard-core as follows:
    - a. 5-inch (125-mm) top-rail blocking, in doors indicated to have closers.
    - b. 5-inch (125-mm) bottom-rail blocking, in exterior doors and doors indicated to have kick, mop, or armor plates.
    - c. 5-inch (125-mm) midrail blocking, in doors indicated to have exit devices.
- C. Structural-Composite-Lumber-Core Doors:
  1. Structural Composite Lumber: WDMA I.S.10.
    - a. Screw Withdrawal, Face: 700 lbf (3100 N).
    - b. Screw Withdrawal, Edge: 400 lbf (1780 N).
- D. Fire-Protection-Rated Doors: Provide core specified or mineral core as needed to provide fire-protection rating indicated.
  1. Edge Construction: Provide edge construction with intumescent seals concealed by outer stile. Comply with specified requirements for exposed edges.
  2. Pairs: Provide formed-steel edges and astragals with intumescent seals.
    - a. Finish steel edges and astragals to match door hardware (locksets or exit devices).

## 2.3 VENEERED-FACED DOORS FOR TRANSPARENT FINISH

- A. Interior Solid-Core Doors:
  1. Grade: Premium, with Grade A faces.
  2. Species: Red oak .
  3. Cut: Plain sliced (flat sliced).
  4. Match between Veneer Leaves: Book match.
  5. Assembly of Veneer Leaves on Door Faces: Balance match.

6. Pair and Set Match: Provide for doors hung in same opening or separated only by mullions.
7. Room Match: Provide door faces of compatible color and grain within each separate room or area of building.
8. Exposed Vertical and Top Edges: Same species as faces.
9. Core: Structural composite.
10. Construction: Five plies. Stiles and rails are bonded to core, then entire unit abrasive planed before veneering. Faces are bonded to core using a hot press.

## 2.4 LIGHT FRAMES

- A. Wood Beads for Light Openings in Wood Doors: Provide manufacturer's standard wood beads as follows unless otherwise indicated.
- B. Metal Frames for Light Openings and Fire-Rated Doors: Manufacturer's standard frame formed of 0.048-inch- (1.2-mm-) thick, cold-rolled steel sheet; with baked-enamel- or powder-coated finish; and approved for use in doors of fire-protection rating indicated.

## 2.5 FABRICATION

- A. Factory fit doors to suit frame-opening sizes indicated. Comply with clearance requirements of referenced quality standard for fitting unless otherwise indicated.
  1. Comply with requirements in NFPA 80 for fire-rated doors.
- B. Factory machine doors for hardware that is not surface applied. Locate hardware to comply with DHI-WDHS-3. Comply with final hardware schedules, door frame Shop Drawings, DHI A115-W series standards, and hardware templates.
  1. Coordinate with hardware mortises in metal frames to verify dimensions and alignment before factory machining.
  2. Metal Astragals: Factory machine astragals and formed-steel edges for hardware for pairs of fire-rated doors.
- C. Openings: Cut and trim openings through doors in factory.
  1. Light Openings: Trim openings with moldings of material and profile indicated.
  2. Glazing: Factory install glazing in doors indicated to be factory finished. Comply with applicable requirements in Division 08 Section "Glazing."

## 2.6 FACTORY FINISHING

- A. General: Comply with referenced quality standard for factory finishing. Complete fabrication, including fitting doors for openings and machining for hardware that is not surface applied, before finishing.
  1. Finish faces, all four edges, edges of cutouts, and mortises. Stains and fillers may be omitted on bottom edges, edges of cutouts, and mortises.
- B. Finish doors at factory.

- C. Transparent Finish:
  - 1. Grade: Custom.
  - 2. Finish: AWI catalyzed polyurethane system.
  - 3. Staining: Match Submit Samples for architect selection to match Wilsonart Plastic Laminate 7921-38 Tuscan Walnut
  - 4. Effect: Filled finish.
  - 5. Sheen: Semigloss.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine doors and installed door frames before hanging doors.
  - 1. Verify that frames comply with indicated requirements for type, size, location, and swing characteristics and have been installed with level heads and plumb jambs.
  - 2. Reject doors with defects.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 INSTALLATION

- A. Hardware: For installation, see Division 08 Section "Door Hardware."
- B. Installation Instructions: Install doors to comply with manufacturer's written instructions and the referenced quality standard, and as indicated.
  - 1. Install fire-rated doors in corresponding fire-rated frames according to NFPA 80.
- C. Factory-Fitted Doors: Align in frames for uniform clearance at each edge.
- D. Factory-Finished Doors: Restore finish before installation if fitting or machining is required at Project site.

#### 3.3 ADJUSTING

- A. Operation: Rehang or replace doors that do not swing or operate freely.
- B. Finished Doors: Replace doors that are damaged or that do not comply with requirements. Doors may be repaired or refinished if work complies with requirements and shows no evidence of repair or refinishing.

END OF SECTION 08 1416





SECTION 08 3113 - ACCESS DOORS AND FRAMES

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Access doors and frames for walls and ceilings.
- B. Related Sections include the following:
  - 1. Division 033000 Section "Cast-in-Place Concrete" for blocking out openings for access doors and frames in concrete.
  - 2. Division 042200 Section "Unit Masonry" for anchoring and grouting access door frames set in masonry construction.
  - 3. Division 087100 Section "Door Hardware" for mortise or rim cylinder locks and master keying.
  - 4. Division 095113 Section "Acoustical Panel Ceilings" for suspended acoustical tile ceilings.
  - 5. Division 233300 Section "Air Duct Accessories" for heating and air-conditioning duct access doors.

1.3 SUBMITTALS

- A. Product Data: For each type of access door and frame indicated. Include construction details, fire ratings, materials, individual components and profiles, and finishes.
- B. Shop Drawings: Show fabrication and installation details of access doors and frames for each type of substrate. Include plans, elevations, sections, details, and attachments to other work.
- C. Access Door and Frame Schedule: Provide complete access door and frame schedule, including types, locations, sizes, latching or locking provisions, and other data pertinent to installation.
- D. Ceiling Coordination Drawings: Reflected ceiling plans, drawn to scale, on which ceiling-mounted items including access doors and frames, lighting fixtures, diffusers, grilles, speakers, sprinklers, and special trim are shown and coordinated with each other.

1.4 QUALITY ASSURANCE

- A. Source Limitations: Obtain access doors and frames through one source from a single manufacturer.

- B. Fire-Rated Access Doors and Frames: Units complying with NFPA 80, 2007 edition that are identical to access door and frame assemblies tested for fire-test-response characteristics per the following test method and that are listed and labeled by UL or another testing and inspecting agency acceptable to authorities having jurisdiction:
  - 1. NFPA 252, 2003 edition for vertical access doors and frames.
  - 2. ASTM E 119, 2007 edition for horizontal access doors and frames.
- C. Size Variations: Obtain Architect's acceptance of manufacturer's standard-size units, which may vary slightly from sizes indicated.

## 1.5 COORDINATION

- A. Verification: Determine specific locations and sizes for access doors needed to gain access to concealed plumbing, mechanical, or other concealed work, and indicate in the schedule specified in "Submittals" Article.

## PART 2 - PRODUCTS

### 2.1 STEEL MATERIALS

- A. Steel Plates, Shapes, and Bars: ASTM A 36/A 36M.
  - 1. ASTM A 123/A 123M, for galvanizing steel and iron products.
  - 2. ASTM A 153/A 153M, for galvanizing steel and iron hardware.
- B. Steel Sheet: Uncoated or electrolytic zinc-coated, ASTM A 591/A 591M with cold-rolled steel sheet substrate complying with ASTM A 1008/A 1008M, Commercial Steel (CS), exposed.
- C. Metallic-Coated Steel Sheet: ASTM A 653/A 653M, Commercial Steel (CS) with A60 (ZF180) zinc-iron-alloy (galvannealed) coating or G60 (Z180) mill-phosphatized zinc coating; stretcher-leveled standard of flatness; with minimum thickness indicated representing specified thickness according to ASTM A 924/A 924M.
- D. Steel Finishes: Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
  - 1. Surface Preparation for Steel Sheet: Clean surfaces to comply with SSPC-SP 1, "Solvent Cleaning," to remove dirt, oil, grease, or other contaminants that could impair paint bond. Remove mill scale and rust, if present, from uncoated steel, complying with SSPC-SP 5/NACE No. 1, "White Metal Blast Cleaning," or SSPC-SP 8, "Pickling."
  - 2. Surface Preparation for Metallic-Coated Steel Sheet: Clean surfaces with nonpetroleum solvent so surfaces are free of oil and other contaminants. After cleaning, apply a conversion coating suited to the organic coating to be applied over it. Clean welds, mechanical connections, and abraded areas, and apply galvanizing repair paint specified below to comply with ASTM A 780.
    - a. Galvanizing Repair Paint: High-zinc-dust-content paint for regalvanizing welds in steel, complying with SSPC-Paint 20.
  - 3. Factory-Primed Finish: Apply shop primer immediately after cleaning and pretreating.

- E. Drywall Beads: Edge trim formed from 0.0299-inch (0.76-mm) zinc-coated steel sheet formed to receive joint compound and in size to suit thickness of gypsum board.

## 2.2 ACCESS DOORS AND FRAMES FOR WALLS AND CEILINGS

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Acudor Products, Inc.
  - 2. Babcock-Davis; A Cierra Products Co.
  - 3. Bar-Co, Inc. Div.; Alfab, Inc.
  - 4. Cendrex Inc.
  - 5. Dur-Red Products.
  - 6. Elmdor/Stoneman; Div. of Acorn Engineering Co.
  - 7. Jensen Industries.
  - 8. J. L. Industries, Inc.
  - 9. Karp Associates, Inc.
  - 10. Larsen's Manufacturing Company.
  - 11. MIFAB, Inc.
  - 12. Milcor Inc.
  - 13. Nystrom, Inc.
  - 14. Williams Bros. Corporation of America (The).
- C. Flush Access Doors and Frames with Exposed Trim: Fabricated from metallic-coated steel sheet.
  - 1. Locations: Concrete and masonry wall and ceiling surfaces.
  - 2. Door: Minimum 0.060-inch- (1.5-mm-) thick sheet metal, set flush with exposed face flange of frame.
  - 3. Frame: Minimum 0.060-inch- (1.5-mm-) thick sheet metal with manufacturer's standard 1-inch- (25-mm-) or 1-1/4-inch- (32-mm-) wide, surface-mounted trim.
  - 4. Hinges: Continuous piano.
  - 5. Latch: Self-latching bolt operated by flush key with interior release.
  - 6. Lock: Cylinder.
- D. Flush Access Doors and Trimless Frames: Fabricated from metallic-coated steel sheet.
  - 1. Locations: Gypsum board wall and ceiling surfaces.
  - 2. Door: Minimum 0.060-inch- (1.5-mm-) thick sheet metal, set flush with surrounding finish surfaces.
  - 3. Frame: Minimum 0.060-inch- (1.5-mm-) thick sheet metal with drywall bead flange.
  - 4. Hinges: Continuous piano.
  - 5. Latch: Self-latching bolt operated by flush key with interior release.
  - 6. Lock: Cylinder.
- E. Fire-Rated, Insulated, Flush Access Doors and Frames with Exposed Trim: Fabricated from metallic-coated steel sheet.
  - 1. Locations: Concrete and masonry wall and ceiling surfaces.
  - 2. Fire-Resistance Rating: Not less than that of wall installed in.
  - 3. Temperature Rise Rating: 250 deg F (139 deg C) at the end of 30 minutes.

4. Door: Flush panel with a core of mineral-fiber insulation enclosed in sheet metal with a minimum thickness of 0.036 inch (0.9 mm).
  5. Frame: Minimum 0.060-inch- (1.5-mm-) thick sheet metal with manufacturer's standard 1-inch- (25-mm-) or 1-1/4-inch- (32-mm-) wide, surface-mounted trim.
  6. Hinges: Continuous piano.
  7. Automatic Closer: Spring type.
  8. Latch: Self-latching device operated by flush key with interior release.
  9. Lock: Self-latching device with cylinder lock.
- F. Fire-Rated, Insulated, Flush Access Doors and Trimless Frames: Fabricated from metallic-coated steel sheet.
1. Locations: Gypsum board wall and ceiling surfaces.
  2. Fire-Resistance Rating: Not less than that of wall installed in.
  3. Temperature Rise Rating: 250 deg F (139 deg C) at the end of 30 minutes.
  4. Door: Flush panel with a core of mineral-fiber insulation enclosed in sheet metal with a minimum thickness of 0.036 inch (0.9 mm).
  5. Frame: Minimum 0.060-inch- (1.5-mm-) thick sheet metal with drywall bead.
  6. Hinges: Continuous piano.
  7. Automatic Closer: Spring type.
  8. Latch: Self-latching device operated by flush key with interior release.
  9. Lock: Self-latching device with cylinder lock.
- G. Medium-Security, Flush Access Doors and Frames with Exposed Trim: Fabricated from metallic-coated steel sheet.
1. Locations: Typical wall and ceiling surfaces with security rating.
  2. Door: Minimum 0.105-inch- (2.7-mm-) thick sheet metal, flush construction.
  3. Frame: Minimum 0.105-inch- (2.7-mm-) thick sheet metal with manufacturer's standard 1-inch- (25-mm-) or 1-1/4-inch- (32-mm-) wide, surface-mounted trim.
  4. Hinges: Concealed continuous piano.
  5. Lock: Detention.
    - a. Lock Preparation: Prepare door panel to accept lock specified in Division 08 Section "Detention Door Hardware."
- H. Fire-Rated, Insulated, Medium-Security, Flush Access Doors and Frames with Exposed Trim: Fabricated from metallic-coated steel sheet.
1. Locations: Typical wall surfaces with security and fire rating.
  2. Fire-Resistance Rating: Not less than that of wall installed in.
  3. Temperature Rise Rating: 250 deg F (139 deg C) at the end of 30 minutes.
  4. Door: Flush panel with a core of 2-inch- (50-mm-) thick, mineral-fiber insulation enclosed in sheet metal with a minimum thickness of 0.075 inch (1.9 mm).
  5. Frame: Minimum 0.060-inch- (1.5-mm-) thick sheet metal with manufacturer's standard 1-inch- (25-mm-) or 1-1/4-inch- (32-mm-) wide, surface-mounted trim.
  6. Hinges: Continuous piano.
  7. Automatic Closer: Spring type.
  8. Lock: Self-latching device with detention lock.
    - a. Lock Preparation: Prepare door panel to accept lock specified in Division 08 Section "Detention Door Hardware."
- I. Maximum-Security, insulated Flush Access Doors and Frames with Exposed Trim: Fabricated from steel sheet and angles.
1. Locations: Sleeping rooms wall surfaces.

2. Door: Minimum 0.180-inch- (4.55-mm-) thick sheet metal, flush construction.
3. Frame: Minimum 3/16-by-2-by-2-inch (4.7-by-50-by-50-mm) angle welded with joints ground smooth.
  - a. Provide continuous stop all four sides of frame.
  - b. Provide continuous smoke gasket between door and continuous stop all four sides of frame
4. Hinges: Continuous heavy-duty steel welded to door and frame
  - a. With non-removable hinge pin.
5. Lock: Heavy-duty, detention deadbolt.
  - a. Lock Preparation: Prepare door panel to accept lock specified in Division 08 Section "Detention Door Hardware."

## 2.3 FABRICATION

- A. General: Provide access door and frame assemblies manufactured as integral units ready for installation.
- B. Metal Surfaces: For metal surfaces exposed to view in the completed Work, provide materials with smooth, flat surfaces without blemishes. Do not use materials with exposed pitting, seam marks, roller marks, rolled trade names, or roughness.
- C. Doors and Frames: Grind exposed welds smooth and flush with adjacent surfaces. Furnish attachment devices and fasteners of type required to secure access panels to types of supports indicated.
  1. Exposed Flanges: As indicated.
  2. For trimless frames with drywall bead, provide edge trim for gypsum board securely attached to perimeter of frames.
  3. Provide mounting holes in frames for attachment of units to metal framing.
  4. Provide mounting holes in frame for attachment of masonry anchors. Furnish adjustable metal masonry anchors.
- D. Latching Mechanisms: Furnish number required to hold doors in flush, smooth plane when closed.
  1. For cylinder lock, furnish two keys per lock and key all locks alike.

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- A. Comply with manufacturer's written instructions for installing access doors and frames.
- B. Set frames accurately in position and attach securely to supports with plane of face panels aligned with adjacent finish surfaces.
- C. Install doors flush with adjacent finish surfaces or recessed to receive finish material.

3.2 ADJUSTING AND CLEANING

- A. Adjust doors and hardware after installation for proper operation.
- B. Remove and replace doors and frames that are warped, bowed, or otherwise damaged.

END OF SECTION 08 3113

SECTION 083323 - OVERHEAD COILING DOORS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes the following types of manually operated overhead coiling doors:
  - 1. Fire-rated counter doors.
  - 2. Service Doors
- B. Related Sections include the following:
  - 1. Division 055000 Section "Metal Fabrications" for miscellaneous steel supports.
  - 2. Division 087100 Section "Door Hardware" for lock cylinders and keying.
  - 3. Division 099123 Section "Interior Painting".
  - 4. Division 26 Sections for electrical service and connections for powered operators and accessories.

1.3 DEFINITIONS

- A. Operation Cycle: One cycle of a door is complete when it is moved from the closed position to the fully open position and returned to the closed position.

1.4 PERFORMANCE REQUIREMENTS

- A. Operation-Cycle Requirements: Provide overhead coiling door components and operators capable of operating for not less than 20,000 cycles and for 10 cycles per day.
  - 1. Include tamperproof cycle counter.

1.5 SUBMITTALS

- A. Product Data: For each type and size of overhead coiling door and accessory. Include the following:
  - 1. Summary of forces and loads on walls and jambs.
  - 2. Fire-Rated Doors: Include description of fire-release system including testing and resetting instructions.
- B. Shop Drawings: For special components and installations not dimensioned or detailed in manufacturer's product data.

- C. Samples for Initial Selection: Manufacturer's color charts showing full range of colors available for units with factory-applied finishes.
- D. Qualification Data: For Installer.

## 1.6 QUALITY ASSURANCE

- A. Installer Qualifications: Manufacturer's authorized representative who is trained and approved for both installation and maintenance of units required for this Project.
- B. Source Limitations: Obtain overhead coiling doors through one source from a single manufacturer.
- C. Fire-Test-Response Characteristics: Provide assemblies complying with NFPA 80, 2010 edition that are identical to door and frame assemblies tested for fire-test-response characteristics per UL 10b and NFPA 252, 2008 edition, and that are listed and labeled for fire ratings indicated by UL, FMG, ITS, or another testing and inspecting agency acceptable to authorities having jurisdiction.
- D. Listing and Labeling: Provide electrically operated fixtures specified in this Section that are listed and labeled.
  - 1. The Terms "Listed" and "Labeled": As defined in NFPA 70, 2008 edition Article 100.
  - 2. Listing and Labeling Agency Qualifications: A "Nationally Recognized Testing Laboratory" as defined in OSHA Regulation 1910.7.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. Manufacturer: Subject to compliance with requirements, provide products by one of the following:
  - 1. Alpine Overhead Doors, Inc.
  - 2. Atlas Door; Div. of Clopay Building Products Company, Inc.
  - 3. Cookson Company.
  - 4. Cornell Iron Works Inc.
  - 5. Dynamic Closures Corporation.
  - 6. Mahon Door Corporation.
  - 7. McKeon Rolling Steel Door Company, Inc.
  - 8. Metro Door.
  - 9. Overhead Door Corp.
  - 10. Pacific Rolling Doors Co.
  - 11. Raynor.
  - 12. Southwestern Steel Rolling Door Co.
  - 13. Wayne-Dalton Corp.
  - 14. Windsor Door, a MAGNATRAX Corporation.



## 2.2 DOOR CURTAIN MATERIALS AND CONSTRUCTION

- A. Door Curtains: Fabricate overhead coiling door curtain of interlocking slats, designed to withstand wind loading indicated, in a continuous length for width of door without splices. Unless otherwise indicated, provide slats of thickness and mechanical properties recommended by door manufacturer for performance, size, and type of door indicated, and as follows:
  - 1. Steel Door Curtain Slats: Zinc-coated (galvanized), cold-rolled structural steel (SS) sheet; complying with ASTM A 653/A 653M, G90 (Z275) coating designation.
    - a. Minimum Base-Metal (Uncoated) Thickness: 0.0209 inch (0.55 mm).
    - b. Flat profile slats.
    - c. Exterior Door Insulated-Slat Interior Facing: Metal.
    - d. Gasket Seal. Manufacturer's standard continuous gaskets between slats.
- B. Endlocks for Counter Doors: Manufacturer's standard locks on not less than alternate curtain slats for curtain alignment and resistance against lateral movement.
- C. Bottom Bar for Counter Doors: Manufacturer's standard continuous channel or tubular shape, either stainless-steel or aluminum extrusions to suit type of curtain slats.
  - 1. Astragal: Provide a replaceable, adjustable, continuous, compressible gasket of flexible vinyl, rubber, or neoprene; for placement between angles or fitted to shape, as a cushion bumper for interior door.
- D. Curtain Jamb Guides for Counter Doors: Fabricate curtain jamb guides of angles or channels and angles of material and finish to match curtain slats, with sufficient depth and strength to retain curtain, to allow curtain to operate smoothly, and to withstand loading. Provide continuous integral wear strips to prevent metal-to-metal contact and to minimize operational noise; with removable stops on guides to prevent over travel of curtain.
- E. Air Infiltration: Maximum rate of 0.08 cfm/sq. ft. (0.406 L/s per sq. m) at 15 and 25 mph (24.1 and 40.2 km/h) when tested according to ASTM E 283.
- F. Curtain R-Value: 6.0 deg F x h x sq. ft./Btu (1.057 K x sq. m/W).

## 2.3 HOODS AND ACCESSORIES

- A. Hood: Form to act as weather seal and entirely enclose coiled curtain and operating mechanism at opening head. Contour to fit end brackets to which hood is attached. Roll and reinforce top and bottom edges for stiffness. Provide closed ends for surface-mounted hoods and provide fascia for any portion of between-jamb mounting projecting beyond wall face. Provide intermediate support brackets as required to prevent sagging.
  - 1. Fabricate hoods for steel doors of minimum 0.028-inch- (0.7-mm-) thick, hot-dip galvanized steel sheet with G90 (Z275) zinc coating, complying with ASTM A 653/A 653M.
  - 2. Fabricate hoods for stainless-steel doors of minimum 0.025-inch- (0.65-mm-) thick stainless-steel sheet, Type 304, complying with ASTM A 666.
  - 3. Include automatic drop baffle to guard against passage of smoke or flame.
  - 4. Shape: Round.
- B. Smoke Seals: Provide UL-listed and -tested smoke-seal perimeter gaskets.

- C. Push/Pull Handles: For push-up-operated or emergency-operated doors, provide galvanized steel lifting handles on each side of door.
  - 1. Provide pull-down straps or pole hooks for doors more than 84 inches (2130 mm) high.
- D. Slide Bolt: Fabricate with side-locking bolts to engage through slots in tracks for locking by padlock, located on both left and right jamb sides, operable from coil side.
- E. Provide automatic-closing device that is inoperative during normal door operations, with oscillating governor unit complying with requirements of NFPA 80, 2010 edition and with an easily tested and reset release mechanism, and designed to be activated by the following:
  - 1. Replaceable fusible links with temperature rise and melting point of 165 deg F (74 deg C); interconnected and mounted on both sides of door opening.
  - 2. Building fire alarm and detection system and door-holder-release devices.

#### 2.4 COUNTERBALANCING MECHANISM

- A. General: Counterbalance doors by means of adjustable-tension, steel helical torsion spring mounted around a steel shaft and contained in a spring barrel connected to door curtain with barrel rings. Use grease-sealed bearings or self-lubricating graphite bearings for rotating members.
- B. Counterbalance Barrel: Fabricate spring barrel of hot-formed, structural-quality, welded or seamless carbon-steel pipe, of sufficient diameter and wall thickness to support rolled-up curtain without distortion of slats and to limit barrel deflection to not more than 0.03 in./ft. (2.5 mm/m) of span under full load.
- C. Provide spring balance of one or more oil-tempered, heat-treated steel helical torsion springs. Size springs to counterbalance weight of curtain, with uniform adjustment accessible from outside barrel. Provide cast-steel barrel plugs to secure ends of springs to barrel and shaft.
- D. Fabricate torsion rod for counterbalance shaft of cold-rolled steel, sized to hold fixed spring ends and carry torsional load.
- E. Brackets: Provide mounting brackets of manufacturer's standard design, either cast iron or cold-rolled steel plate.

#### 2.5 MANUAL DOOR OPERATORS

- A. Provide manual operators unless electric door operators are indicated.
- B. Push-up Operation:
  - 1. Counter Doors: Design counterbalance mechanism so required lift or pull for door operation does not exceed 25 lbf (111 N).
  - 2. Service Doors: Chain-Hoist Operator

2.6 FINISHES, GENERAL

- A. General: Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Appearance of Finished Work: Variations in appearance of abutting or adjacent pieces are acceptable if they are within one-half of the range of approved Samples. Noticeable variations in the same piece are not acceptable. Variations in appearance of other components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.

2.7 STEEL AND GALVANIZED STEEL FINISHES

- A. Factory Primer for Field Finish: Manufacturer's standard primer, compatible with field-applied finish according to coating manufacturer's written instructions for cleaning, pretreatment, application, and minimum dry film thickness.
  - 1. Apply to ferrous surfaces except zinc-coated metal.
- B. Baked Finish: Manufacturer's standard baked finish consisting of primer and topcoat according to coating manufacturer's written instructions for cleaning, pretreatment, application, thermosetting, and minimum dry film thickness.
- C. Powder-Coat Finish: Manufacturer's standard powder-coat finish consisting of primer and topcoat according to coating manufacturer's written instructions for cleaning, pretreatment, application, thermosetting, and minimum dry film thickness.
  - 1. Color and Gloss: Match adjacent window frame color.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. General: Install coiling doors and operating equipment complete with necessary hardware, jamb and head molding strips, anchors, inserts, hangers, and equipment supports.
  - 1. Install fire-rated doors to comply with NFPA 80, 2010 edition.

3.2 ADJUSTING

- A. Lubricate bearings and sliding parts; adjust doors to operate easily, free of warp, twist, or distortion and with weather tight fit around entire perimeter.

3.3 STARTUP SERVICES

- A. Engage a factory-authorized service representative to perform startup service.
  - 1. Complete installation and startup checks according to manufacturer's written instructions.

2. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
  - a. Test door closing when activated by detector or alarm-connected fire-release system. Reset door-closing mechanism after successful test.

3.4 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain overhead coiling doors. Refer to 017900 Section "Demonstration and Training."

END OF SECTION 083323

SECTION 083463 – DETENTION DOORS AND FRAMES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.
- B. Division 01 Section “Sustainable Design Requirements” for additional LEED requirements.
- C. Section 013513.16, “Special Project Procedures for Detention Facilities”.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Swinging steel detention doors.
  - 2. Steel detention door frames.
  - 3. Steel detention sidelight frames.
  - 4. Steel detention borrowed-light frames.
  - 5. Detention door accessories.

1.3 SCOPE AND RESPONSIBILITIES

- A. Under the requirements of this specification, the DEC shall be responsible for furnishing and installing all security hollow metal doors, frames and door accessories, as specified, in all locations.

1.4 DEFINITIONS

- A. Uncoated Steel Sheet Thicknesses: Indicated as the minimum thicknesses.
- B. Metallic-Coated Steel Sheet Thicknesses: Indicated as the minimum thicknesses of uncoated base metals.
- C. Stainless-Steel Sheet Thicknesses: Indicated as the specified thicknesses for which over- and under-thickness tolerances apply, according to ASTM A 480/A 480M.
- D. Nominal Surface of Floor Covering: Top surface of floor; for resilient tile and carpet, nominal surface of floor covering is defined as top of concrete slab.

1.5 REFERENCES

- A. ASTM A366/A 366M-97 Standard Specification for Commercial Steel (CS), Carbon (0.15 Maximum Percent), Cold Rolled
- B. ASTM A569A 569M-97 Standard Specification for Steel, Carbon, (0.15 Maximum Percent), Hot Rolled Sheet and Strip, Commercial Quality
- C. ASTM A653/A, 653M-96, Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by Hot Dip Process, Commercial Quality
- D. ASTM A 666-96b Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate and Flat Bar
- E. ASTM B 117-95 Standard Practice for Operation salt Spray (Fog) Apparatus
- F. ASTM 143-90a (1990) Standard Test Method for Slump of Hydraulic Cement Concrete
- G. ASTM D610-95 Standard Test Method for Evaluating Degree of Rusting on Painted Steel Surfaces
- H. ASTM D 714-87 (1994), Standard Test Method for Evaluating Degree of Blistering of Paints
- I. ASTM D 1735-92, Standard Practice for Testing Water Resistance of Coatings Using Water Fog Apparatus
- J. ASTM E 152-81a Method for Fire Tests of Door Assemblies
- K. ASTM F1450-97, Standard Test Methods for Hollow Metal Swinging Door Assemblies for Detention Facilities
- L. ASTM 1577-96, Standard Test Methods for Detention Locks for Swinging Doors
- M. ASTM A167 and A240, Stainless Steel Type 304
- N. NAAAM Hollow Metal Manual, all sections.
- O. NAAAM HMMA 850-83 Fire-Rated Hollow Metal Doors and Frames, Second Edition
- P. ANSI / NFPA 80-95 Fire Door and Windows
- Q. ANSI / NFPA 252-95 Standard Methods for Fire Test of Door Assemblies
- R. ANSI / NFPA 257-96 Methods for Fire Test of Window Assemblies
- S. ANSI/UL 10 (B) 10 (C) 8<sup>th</sup> Edition, Fire Tests of Window Assemblies
- T. ANSI / UL 752 Bullet-Resistance Equipment

#### 1.6 PERFORMANCE REQUIREMENTS

- A. Detention Doors: Provide detention doors and frames that comply with Security Grade 1, or Security Grade 3, whichever applies, according to the latest edition of ASTM F 1450, as

determined by testing manufacturer's standard products representing those indicated for this Project.

- B. Detention Sidelight and Borrowed-Light Frames: Provide detention vision frames that comply with ASTM F 1592 and removable glazing stop test according to HMMA 863, based on testing manufacturer's standard units.

#### 1.7 SUBMITTALS

- A. Product Data: Include construction details, material descriptions, core descriptions, label compliance, fire-resistance rating, and finishes for each type of detention door, frame and access panel, as specified.
- B. Provide performance testing reports which support the testing requirements specified.
- C. Shop Drawings: For detention doors and frames. Include conditions at openings, details of construction, dimensions of profiles, and details of joints and connections. Show anchorage and accessories. Include fastener types, sizes and spacing. Identify each detention door and frame using same reference numbers for openings as those on Drawings.
- D. It is the DEC's responsibility to coordinate detention/security items in this scope of work, and to answer all manufacturer questions or concerns that are not strictly design related. The DEC shall redline the manufacturers' individual shop drawings and/or schedules, and note corrections prior to submittal for Architectural/Consultant review. When multiple items are submitted by the manufacturer on a single cutsheet, the DEC shall note with an arrow, circle or note cloud, to show which product on the sheet is submitted for this scope of work. DEC submittals not reviewed and redlined prior to submittal to Architect/Consultant for final review, will be returned rejected.
- E. Shop Drawings: For access panels.
  - 1. Door and panel units: Show types, elevations, lock type, thickness of metals, and full size profiles of door members.
  - 2. General: Show connections of units and hardware to other Work. Include schedules showing location of each type and size of door and panel units.
- F. Coordination Drawings: Drawings of each opening, including detention door and frame, drawn to scale and coordinating detention door hardware. Show the following:
  - 1. Locations, dimensions, and profiles of detention door hardware reinforcements.
  - 2. Locations and installation details of detention door hardware.
  - 3. Elevations of each detention door design type showing dimensions, locations of detention door hardware, and preparations for power, signal, and electrified and pneumatic control systems.
  - 4. Details of each detention frame type.
  - 5. Details of mortar boxes in detention frames for hardware and communication devices.
- G. Oversize Construction Certification: For detention door assemblies required to be fire rated and exceeding limitations of labeled assemblies, submit certification of a testing agency acceptable to authorities having jurisdiction that each detention door and frame assembly has been

constructed to comply with design, materials, and construction equivalent to requirements for labeled construction.

## 1.8 QUALIFICATION OF MANUFACTURERS

A. Qualifications of Security Hollow Metal Manufacturers: Security hollow metal manufacturing firms who have not been pre-qualified, shall have not less than five (5) years continuous successful experience with manufacturing hollow metal. These firms shall now be actively engaged in the manufacture of security hollow metal doors and frames of the type required for this project. Fabrication methods and product quality shall meet or exceed standards set by the Hollow Metal Manufacturers Association, (HMMA), a division of the National Association of Architectural Metal Manufacturers (NAAMM), and be tested in accordance with ASTM F 1450.

1. Submittal Requirements: In addition to a written request for substitutions, a full size corner sample of each type door and frame showing door construction, face stiffening, insulation, and top hinge reinforcements shall be provided. Provide details of each type of door and frame. Provide a list of 10 facilities of similar scope and size where the product has been installed for a minimum of 5 years. Provide the following information on the 10 facilities:

- a. List name and location of installation.
- b. Date of occupancy by Owner.
- c. Owner's representative to contact and telephone number.
- d. Name of DEC, Construction Manager or General Contractor, and Architect including names of contacts and phone numbers.
- e. The manufacturer shall also submit an audited and certified financial statement indicating a consolidated net worth of \$1,000,000.
- f. Provide performance data and tests: All security hollow-metal door manufacturers shall submit to the Architect / Consultant evidence of compliance with ASTM F 1450 and HMMA 863. Test reports and documentation shall be in accordance with ASTM F 1450.

- 1) Test Specimens: Test doors shall be 3'-0" W x 7'-0" H with 100 square inch vision panel, 4" x 25" clear opening, positioned generally as shown in ASTM F 1450, figure 3. Test doors and frames shall be prepared for hardware as specified in ASTM F 1450, Section 6 "Specimen Preparation".
- 2) Testing Procedures: Test doors and frames shall be furnished with hardware in accordance ASTM F 1450, Section 6 – "Specimen Preparation". Latch throw of the lock shall not exceed 1". Assemblies shall be tested in accordance with procedures outlined in ASTM F 1450, 7.2 – "Door Assembly Impact Test".
- 3) Door Static Load Test: Doors shall be tested in accordance with procedures outlined in ASTM F 1450, 7.3 – "Door Static Load Test".
- 4) Door Rack Test: Doors shall be tested in accordance with procedures outlined in ASTM F 1450, 7.4 – "Door Rack Test".
- 5) Performance Criteria for load testing shall be in accordance with applicable paragraphs of ASTM F 1450, Section 7 – "Procedures".
- 6) Glass Stop Test: A rectangular view window test frame shall be constructed with a glass opening size of 28" x 33" ( $\pm 1$ "). The frame shall be constructed



of commercial quality steel meeting ASTM standard A366 or A569, 12-gauge maximum. Refer to HMMA 863, Figure 5, for test frame configuration.

- 7) A steel plate of 3/8" minimum thickness shall be glazed in place using the specified glass stop.
  - 8) The test frame assembly shall then be rigidly fixed in the vertical position with the removable glass stop on the opposite side of the 3/8" plate from the impact ram.
  - 9) A target on the side of the 3/8" plate shall be marked in one corner no more than 6" away from the stops.
  - 10) Using the door ram pendulum system specified in ASTM F 1450, Figure 2 deliver four hundred (400) impacts of 200 Ft-lbs. each, on the target area. Removable glass stops and the 3/8" plate shall remain firmly in place so that removal cannot be accomplished without removing the retaining screws. There shall be no more than one (1) broken screw in the assembly after impact test.
  - 11) Fire rated doors and frames shall be provided for those openings indicated in the schedule as requiring fire protection ratings. Such doors and frames shall be constructed as tested in accordance with ASTM E-152, UL-10B or NFPA-252 and labeled by a recognized testing agency having a factory inspection service.
- g. Substitution after the bid date will not be allowed.
- h. Approval of a Hollow Metal Manufacturer does not relieve that company from fully complying with the product as specified.

#### 1.9 QUALITY ASSURANCE

- A. Installer Qualifications: An authorized representative of detention door and frame manufacturer for installation of units required for this Project.
- B. Source Limitations: Obtain detention doors and frames through one source from a single manufacturer.
- C. Welding: Qualify procedures and personnel according to the following:
  1. AWS D1.3, "Structural Welding Code--Sheet Steel."
- D. Fire-Rated Detention Door Assemblies: Assemblies complying with NFPA 80 that are listed and labeled, by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire ratings indicated, based on testing according to NFPA 252 or UL 10B.
  1. Test Pressure: Test at atmospheric pressure.
  2. Oversize Fire-Rated Detention Door Assemblies: For units exceeding sizes of tested assemblies, provide certification by a testing agency acceptable to authorities having jurisdiction that detention doors comply with standard construction requirements for tested and labeled, fire-rated detention door assemblies except for size.
  3. Temperature-Rise Rating: If indicated, provide detention doors that have a temperature-rise rating of 450 deg F (250 deg C) maximum in 30 minutes of fire exposure.

- E. Fire-Rated Detention Sidelight and Borrowed-Light Frames: Assemblies complying with NFPA 80 that are listed and labeled, by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire ratings indicated, based on testing according to NFPA 257.
- F. Fire-Resistance Ratings for Access Panels: Wherever a fire-resistance classification is indicated, provide access door and panel assemblies with panel door, frame, hinge, and latch from manufacturer listed in Underwriter's Laboratories (UL), "Building Materials Directory" for rating shown.
  - 1. Provide 90 minute UL label at 2-hour rated partitions.
- G. Smoke-Control Detention Door Assemblies: Comply with NFPA 105.

#### 1.10 DELIVERY, STORAGE, AND HANDLING

- A. Deliver detention doors and frames palletized, wrapped, or crated to provide protection during transit and Project-site storage. Do not use non-vented plastic.
- B. Deliver detention frames with two removable spreader bars across bottom of frames, tack welded to jambs and mullions.
  - 1. Where frames are to be cast into precast concrete modules, take additional precautions, including bracing for detention frames, to ensure that detention frames are not deformed or damaged by concrete forces.
- C. Inspect detention doors and frames, on delivery, for damage. Minor damage may be repaired provided refinished items match new work and are approved by Architect; otherwise, remove and replace damaged items as directed.
- D. Store detention doors and frames under cover at building site. Place units in a vertical position with heads up, spaced by blocking, on minimum 4-inch- (100-mm-) high wood blocking. Avoid using non-vented plastic or canvas shelters that could create a humidity chamber.
  - 1. If wrappers on detention doors become wet, remove cartons immediately. Provide minimum 1/4-inch (6-mm) space between each stacked detention door to permit air circulation.

#### 1.11 COORDINATION

- A. Coordinate installation of anchorages for detention frames. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors, that are to be embedded in concrete or masonry. Deliver such items to Project site in time for installation.

#### 1.12 MAINTENANCE TOOLS

- A. Tool Kit: Provide twelve (12) bits for use with security fasteners, each packaged in a compartmented kit configured for easy handling and storage.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Security Hollow Metal Manufacturers: Unless pre-approved prior to bidding, provide products by one of the following:
1. Habersham Metal Products Company, Inc.; Cornelia, GA
  2. Trussbilt, LLC: Vadnais Heights, MN
  3. American Steel Products: Swainsboro, GA
  4. Slate Steel Door Industries: Hartselle, AL

2.2 MATERIALS

- A. Hot-Rolled Steel Sheet: ASTM A 1011/A 1011M, CS (Commercial Steel), Type B: Free of scale, pitting or surface defects: Pickled and oiled.
- B. Cold-Rolled Steel Sheet: ASTM A 1008/A 1008M, CS (Commercial Steel), Type B.
- C. Metallic-Coated Steel Sheet: ASTM A 653/A 653M CS (Commercial Steel), Type B; G60 (Z180) zinc galvanized or A60 (ZF180) zinc-iron-alloy glavannealed coating by hot dipped Process.
- D. Stainless-Steel Sheet: ASTM A 240/A 240M, austenitic stainless steel, Type 304, No. 3 finish unless otherwise indicated.
- E. Steel Plates, Shapes, and Bars: ASTM A 36/A 36M.
- F. Concealed Bolts: ASTM A 307, Grade A, unless otherwise indicated.
- G. Post-installed Expansion Anchors in Concrete: With capability to sustain, without failure, a load equal to 4 times the load imposed, as determined by testing per ASTM E 488, conducted by a qualified independent testing agency.
1. Corrosion Protection: Carbon-steel components zinc plated to comply with ASTM B 633, Class Fe/Zn 5 (0.005 mm) for Class SC 1 service condition (mild).
  2. Corrosion Protection: Stainless-steel components complying with ASTM F 593 and ASTM F 594, Alloy Group 1 or 2 (ASTM F 738M and ASTM F 836M, Alloy Group 1 or 4) for bolts and nuts; ASTM A 666 or ASTM A 276, Type 304 or 316, for anchors.
  3. Corrosion Protection: Components fabricated from nickel-copper-alloy rods complying with ASTM B 164 for UNS No. N04400 alloy.
- H. Powder-Actuated Fasteners in Concrete: Fastener system of type suitable for application indicated, fabricated from corrosion-resistant materials, with clips or other accessory devices for attaching detention frames of type indicated.
- I. Cast-in-Place Anchors in Concrete: Anchors of type indicated below, fabricated from corrosion-resistant materials capable of sustaining, without failure, a load equal to 4 times the load imposed, as determined by testing per ASTM E 488, conducted by a qualified independent testing agency.

1. Threaded or wedge type; galvanized ferrous castings, either ASTM A 47 (ASTM A 47M) malleable iron or ASTM A 27/A 27M cast steel. Provide bolts, washers, and shims as needed, hot-dip galvanized per ASTM A 153/A 153M.
- J. Embedded Plate Anchors: Fabricated from mild steel shapes and plates, minimum 3/16 inch (4.8 mm) thick; with minimum 1/2-inch- (12.7-mm-) diameter headed studs welded to back of plate.
- K. Welding Rods and Bare Electrodes: Select according to AWS specifications for metal alloy welded.
- L. Detention Door, Sidelight and Borrowed-Light Glazing: Comply with Section 088853 "Security Glazing."
- M. Grout-field installed by general contractor: Comply with ASTM C 476, with a slump of 4 inches (102 mm) for detention frames built into masonry, 8 to 11 inches (200 to 280 mm) for detention frames installed in concrete as measured according to ASTM C 143/C 143M.
- N. Epoxy Filler: Bondo or other substitution acceptable to the Architect.
- O. Electrical Conduit:
  1. Raceways: Circular raceways shall be 3/4" diameter U.L. approved rigid steel conduit, intermediate metal conduit (IMC) or electrical metallic tubing (EMT), galvanized inside and outside.
  2. Raceway Fittings: Fittings and couplings for conduit shall be galvanized or cadmium plated compatible with conduit materials. Fittings for rigid conduit and IMC shall be threaded.

## 2.3 DETENTION DOORS

- A. General: Provide flush-design detention doors, 2 inches (50 mm) thick, of seamless hollow construction, unless otherwise indicated. Construct detention doors with smooth, flush surfaces without visible joints or seams on exposed faces or stile edges.
  1. Visible joints or seams around glazed, louvered panel inserts are permitted.
  2. For single-acting swinging detention doors, bevel both vertical edges 1/8 inch in 2 inches (3 mm in 50 mm).
  3. For sliding detention doors, square both vertical edges.
- B. Metallic Core Construction: Provide the following core construction welded to both detention door faces:
  1. Steel-Stiffened Core: 0.042-inch- (1.0-mm-) thick, steel vertical stiffeners extending full-door height, with vertical webs spaced not more than 4 inches (102 mm) apart, spot welded to face sheets a maximum of 3 inches (76 mm) o.c. Fill spaces between stiffeners with insulation of minimum 0.6-lb/cu. ft. (9.6-kg/cu. m) density.

2. Truss-Stiffened Core: 0.013-inch- (0.3-mm-) thick steel, truncated triangular stiffeners extending between face sheets and for full height and width of door; with stiffeners welded to face sheets not more than 3 inches (76 mm) o.c. vertically and 2-3/4 inches (70 mm) horizontally. Fill spaces between stiffeners with insulation of minimum 0.8-lb/cu. ft. density.
  3. Fire Detention Door Cores: As required to provide fire-protection and temperature-rise ratings indicated.
- C. Vertical Edge Channels: 0.123-inch- (3.1-mm-) thick, continuous steel channel extending full-door height at each vertical edge, with webs of channels flush with door edges; welded to top and bottom channels to create a fully welded perimeter channel.
- D. Top and Bottom Channels: 0.123-inch- (3.1-mm-) thick metal channel spot welded, not more than 4 inches (102 mm) o.c., to face sheets.
1. Reinforce tops and bottoms of detention doors with inverted horizontal channels of same material as face sheet so flanges of channels are even with bottom and top edges of face sheets.
  2. Close top edge with 0.074-inch- (1.8-mm-) thick closing channel of same material as face sheet; welded so webs of channels are flush with top door edges.
  3. Close bottom edge with 0.074-inch- (1.8-mm-) thick closing channel of same material as face sheet; welded so webs of channels are flush with bottom door edges.
- E. Hardware Reinforcement: Fabricate reinforcing plates from same material as detention door face sheets to comply with the following minimum thickness:
1. Full-Mortise Hinges and Pivots: 0.187 inch (4.7 mm) thick.
  2. Maximum-Security Surface Hinges: 12 Ga. 10"channel with 3/8" x 1" x 6" back-up at each hinge.
  3. Strike Reinforcements: 10 ga. thick.
  4. Slide-Device Hanger Attachments: As recommended by device manufacturer.
  5. Lock Fronts, Concealed Holders, and Surface-Mounted Closers: 0.093 inch (2.3 mm) thick.
  6. All Other Surface-Mounted Hardware: 0.093 inch (2.3 mm) thick.
  7. Lock Pockets: 0.123 inch (3.1 mm) thick at secure side; welded to face sheet.
- F. Frames shall be reinforced, drilled and tapped for all templated mortised hardware only, in accordance with the final approved hardware schedule and templates provided by the hardware supplier.
- G. Loose Glazing Stops: Loose glazing stops shall be pressed steel angles, no less than 1 1/4" X 1 1/4" X 10 gauge.
1. Angle tops shall be butt and notch and tight fitting at the corner joints, and secured in place with 1/4-28 special hardened tamperproof button head Torx security screws spaced 8" o.c. maximum and not more than 2 inches from each corner.
  2. The frame underneath the glazing stops and the inside of the glazing stop shall be chemically treated for maximum paint adhesion and painted with a rust-inhibitive primer prior to installation in the frame.

- H. Hardware Enclosures: Provide enclosures and junction boxes for electrically operated detention door hardware, interconnected with UL-approved, 1/2-inch- (12.7-mm-) diameter conduit and connectors.
  - 1. Enclosures for mechanical paracentric locks with lock mountings. Provide unitized pocket preparation, which after fabrication forms a one-piece box that provides for the lock mounting plate to be recessed into the door such that, when secured in place, the mounting plate outside surface is flush with the door face sheet.
    - a. Lock preparation shall be constructed from 0.123 inch (3.1 mm) steel, punched for keying options as required, and drilled and tapped to receive lock mounting plate.
    - b. Finished preparation shall be a unitized lock pocket, which completely surrounds the lock and is securely welded to both face sheets and the perimeter edge channel.
  - 2. Provide 0.067 inch (1.7 mm) enclosed lock bolt keeper in edge of door for jamb-mounted locks.
- I. Interior Steel Detention Door Face Sheets: Fabricated from hot-rolled steel sheets, metallic-coated steel sheets where indicated and stainless steel sheets where indicated and other metal components from hot- or cold-rolled steel sheets.
  - 1. Security Grade 1: 12 gauge thick steel, – provided at Segregation Cell doors only. Provide galvanealed material where noted on architectural door schedule.
  - 2. Security Grade 3: 14 gauge thick steel – provided at all other Security Hollow Metal (SHM) doors. Provide galvanealed material where noted on architectural door schedule.
- J. Exterior Steel Detention Door Face Sheets: Fabricated from metallic-coated steel sheets, and other metal components from hot- or cold-rolled steel sheets.
  - 1. Security Grade 3: 14 gauge thick steel, galvanealed.
- K. Astragals: As required by NFPA 80 to provide fire ratings indicated.

## 2.4 DETENTION FRAMES

- A. General: Fabricate detention frames of full-welded unit construction, with corners mitered, reinforced, and continuously welded full depth and width of detention frame. Knockdown frames are not acceptable.
- B. Interior Steel Detention Frames: Fabricated from hot-rolled steel sheets, metallic-coated steel sheets where indicated and stainless steel sheets for stainless-steel detention doors, and other metal components from hot- or cold-rolled steel sheets.
  - 1. Security Grade 1: 12 gauge thick steel. Provide galvanealed material where noted on architectural door schedule.
- C. Exterior Steel Detention Frames: Fabricated from metallic-coated steel sheets, and other metal components from hot- or cold-rolled steel sheets.
  - 1. Security Grade 1: 12 gauge thick steel, galvanealed.

- D. Hardware Reinforcement: Fabricate reinforcing plates from same material as detention frame to comply with the following minimum thickness:
1. Full-Mortise Hinges and Pivots: 3/16" x full width of jamb x 10" in length. The top hinge shall be additionally reinforced with 3/16" formed angle welded both to hinge reinforcing and frame face.
  2. Strikes, Flush Bolts, and Closers: 0.187 inch (4.7 mm) thick.
  3. Surface-Mounted Hardware: 12 ga. (2.66 mm) thick.
  4. Provide a key cylinder protection pipe extension on both sides of the frame for all wide jamb electric locks. Where a recessed pocket is provided on the stop side of the frame, the cylinder protection pipe will only be required on the side of the frame with the lock cover plate. Provide a 3/16" steel pipe that extends 1/4" beyond the face of the key cylinder. Weld attach the 3" diameter pipe extension to the cover plate at four locations.
- E. Hardware Enclosures: Provide enclosures and junction boxes for electrically operated detention door hardware, and frame mounted communication devices interconnected with UL-approved, 1/2 inch diameter conduit and connectors.
1. Provide enclosures with access for conduit, tapped holes for hardware and internal fastener protection so fasteners will seat after frame is grouted full.
  2. Electrical access boxes will not be permitted except at hardware pockets or communication mortar boxes. Provide knockout at top and bottom of each box to accept conduit.
  3. Lock pockets for jamb mounted locks: Provide 0.123 inch (3.1 mm) thick steel enclosure with:
    - a. Surface mounted cover, minimum 10 ga. thick steel plate with uniform beveled edges on the side closest to the lock strike or frame rabbet, secured with a minimum of 8 flathead Torx security screws.
    - b. Secure lock to frame or pocket in accordance with lock manufacturer's recommendations for each lock type.
    - c. Provide concealed lock front preparation with frame rabbet cutout only to allow passage of latch bolt and deadbolt actuator. Lock front and case are not exposed.
    - d. Provide key access ports at locks keyed two sides or side opposite the door swing. Size key access port to accommodate paracentric keys on a key ring.
  4. Provide conduit between electric lock pocket and door position switch and between back-to-back communication boxes where scheduled for each frame. All other conduit will be field installed.
- F. Mullions and Transom Bars: Provide closed or tubular mullions and transom bars where indicated. Fasten mullions and transom bars at crossings and to jambs by butt-welding. Reinforce joints between detention frame members with concealed clip angles or sleeves of same metal and thickness as detention frame.
- G. Head Reinforcement: Leave vertical mullions in detention frames open at top for grouting.
- H. Grout Holes: Provide grout holes in frames to be installed in existing wall or concrete wall openings. Weld 0.093-inch back reinforcing plate with 1-3/8" diameter hole to inside of frame. Flush cover plate, same gauge as frame, to be shipped loose for field installation after frame is grouted full. Weld cover plate to frame and grind smooth for a seamless finish.

- I. Supports and Anchors: After fabricating, galvanize units to be built into exterior walls according to ASTM A 153/A 153M, Class B.
  - J. Jamb Anchors: Weld jamb anchors to detention frames near hinges and directly opposite on strike jamb as required to secure detention frames to adjacent construction. Locate jamb anchors at 16" on center and as follows:
    - 1. Detention Door Frames: One additional anchor for each 16 inches (406 mm) or fraction thereof more than 40 inches (1016 mm) in height.
    - 2. Detention Sidelight and Borrowed-Light Frames: One additional anchor for each 16 inches (406 mm) or fraction thereof more than 40 inches (1016 mm) in height.
    - 3. Masonry Type: Adjustable, corrugated or perforated, strap-and-stirrup anchors to suit detention frame size; formed of same material and thickness as detention frame; with strap not less than 2 inches (50 mm) wide by 10 inches (250 mm) long with hole in strap for vertical wall reinforcing.
    - 4. Embedment Type for Precast Concrete Walls: 0.187 inch (4.7 mm) thick x 6 inch long embed, plates with two 0.375 inch diameter x 4" headed studs per embed.
      - a. Width of plate to be 1/2" greater than the depth of the frame.
      - b. Provide shims and weld both sides of frame to embed.
    - 5. Post-installed Expansion Anchors for In-Place Concrete or Masonry: Minimum 1/2-inch- (12.7-mm-) diameter concealed bolts with expansion shields or inserts. Provide conduit spacer from detention frame to wall, welded to detention frame. Reinforce detention frames at anchor locations.
  - K. Floor Anchors: Provide floor anchors for each jamb and mullion that extends to floor, formed of same material and thickness as detention frame, and as follows:
    - 1. Monolithic Concrete Slabs: Clip-type anchors, with two holes to receive fasteners, welded to bottom of jambs and mullions with at least four spot welds per anchor.
    - 2. Separate Topping Concrete Slabs: Adjustable-type anchors with extension clips, allowing not less than 2-inch (50-mm) height adjustment, welded to jambs and mullions with at least 4 spot welds per anchor. Terminate bottom of detention frames at finish floor surface.
  - L. Rubber Door Silencers: Except on weather-stripped detention doors, drill stops in strike jambs to receive three silencers on single-detention-door frames and drill head jamb stop to receive two silencers on double-detention-door frames. Install plastic plugs to keep holes clear during construction.
  - M. Grout Guards: Provide grout guards of same material as detention frame, welded to detention frame at back of hardware cutouts and glazing-stop screw and silencer preparations to close off interior of openings and prevent mortar or other materials from obstructing hardware operation or installation.
- 2.5 BAR GRILLS IN DETENTION DOORS AND FRAMES – N/A
- 2.6 WOVEN ROD MESH IN DETENTION DOORS – N/A



2.7 PERFORATED PLATE IN DETENTION FRAMES – N/A

2.8 STOPS AND MOLDINGS

- A. General: Provide stops and moldings around glazed panels where indicated.
  - 1. Frame Stops for Detention Doors: Minimum 5/8 inch high, unless otherwise indicated.
  - 2. Frame Stops for Detention Sidelights and Borrowed Lights: Minimum 5/8 inch high, unless otherwise indicated.
  - 3. Glazing stops shall be 1 1/4" X 1 1/4" X 10 gauge.
- B. Fixed Detention Door Moldings: Formed from 12 ga. thick sheet reinforcing 'Z', of same material as detention door face sheets, spot-welded to face sheets a maximum of 5 inches o.c.
- C. Fixed Detention Frame Moldings: Formed integral with detention frames, unless otherwise indicated. Form corners with butted or mitered hairline joints.
- D. Stops for Security Glazing: Formed from 0.123-inch thick, pressed-steel angle. Form corners with butt and notch ends to be tight fitting at the corner joints. Secure with minimum 1/4-28 pinned torx button head security machine screws spaced uniformly not more than 8 inches o.c. and not more than 2 inches from each corner.
- E. Deliver frames to project site with stops temporarily secured with 2 Torx 1/4-28 security screws. Ship security screws (plus 10% spare) in appropriate containers labeled and tagged to match detention frames.
- F. Coordinate rabbet width between fixed and removable stops with type of glass or panel and type of installation indicated.

2.9 ACCESSORIES

- A. Food Pass / Cuff Port Openings: N/A

2.10 FABRICATION

- A. Fabricate detention doors and frames rigid, neat in appearance, and free of defects, warp, or buckle. Accurately form metal to required sizes and profiles, with minimum radius for thickness of metal. Weld exposed joints continuously; grind, fill, dress, and make smooth, flush, and invisible. Where practical, fit and assemble units in manufacturer's plant. To ensure proper assembly at Project site, clearly identify work that cannot be permanently factory assembled before shipment.
  - 1. Exterior Detention Doors: Provide weep-hole openings in bottom of detention doors to permit entrapped moisture to escape. Seal joints in top edges of detention doors against water penetration.
  - 2. Fabricate detention doors and frames to comply with manufacturing tolerances indicated in HMMA 863.
- B. Continuously weld detention frame corners, with contact edges closed tight and faces mitered.

- C. Fabricate multiple-opening detention frames with mullions that have closed tubular shapes and with no visible seams or joints.
- D. Exposed Fasteners: Provide countersunk security fasteners for exposed screws and bolts, unless otherwise indicated.
- E. Hardware Preparation: Factory-prepare detention doors and frames to receive mortised hardware, including cutouts, reinforcement, mortising, drilling, and tapping, according to final door hardware schedule and templates provided by detention door hardware supplier. Comply with applicable requirements in DHI A115 Series for detention door and frame preparation for door hardware.
  - 1. Reinforce detention doors and frames to receive surface-mounted door hardware. Drilling and tapping may be done at Project site.
  - 2. Locate door hardware as indicated or, if not indicated, according to HMMA 863, "Guide Specifications for Detention Security Hollow Metal Doors and Frames."
- F. Factory-cut openings in detention doors for accessories.
- G. Welding: Weld components to comply with referenced AWS standard. Weld before finishing components to greatest extent possible. Remove weld spatter and welding oxides from exposed surfaces by descaling or grinding.
- H. Glazing Channels: Provide minimum clearances for thickness and type of glass indicated, according to GANA's "Glazing Manual."
- I. Security Fasteners: Fabricate detention doors and frames using security fasteners with head style appropriate for fabrication requirements, strength, and finish of adjacent materials, except that a maximum of two different sets of tools shall be required to operate security fasteners for Project. Provide stainless-steel security fasteners in stainless-steel materials, exterior doors and frames and interior doors and frames located in wet areas.

## 2.11 FINISHES, GENERAL

- A. Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Finish detention doors and frames after assembly.

## 2.12 METALLIC-COATED STEEL FINISHES

- A. Surface Preparation: Clean surfaces with non-petroleum solvent so surfaces are free of oil and other contaminants. After cleaning, apply a conversion coating suited to organic coating to be applied over it. Clean welds, mechanical connections, and abraded areas and apply galvanizing repair paint specified below to comply with ASTM A 780.
  - 1. Galvanizing Repair Paint: High-zinc-dust-content paint for regalvanizing welds in steel, complying with SSPC-Paint 20.

2. Factory Priming for Field-Painted Finish: Apply shop primer specified below immediately after surface preparation and pretreatment. Apply a smooth coat of even consistency to provide a uniform dry film thickness of not less than 0.7 mils (0.02 mm).
3. Shop Primer: Manufacturer's or fabricators standard, fast-curing, lead- and chromate-free primer complying with ANSI A224.1 acceptance criteria; recommended by primer manufacturer for zinc-coated steel; compatible with substrate and field-applied finish paint system indicated; and providing a sound foundation for field-applied topcoats despite prolonged exposure.

B. Steel Sheet Finishes

1. Surface Preparation: Clean surfaces to comply with SSPC-SP 1, "Solvent Cleaning"; remove dirt, oil, grease, or other contaminants that could impair paint bond. Remove mill scale and rust, if present, from uncoated steel, complying with SSPC-SP 3, "Power Tool Cleaning," or SSPC-SP 6/NACE No. 3, "Commercial Blast Cleaning."
2. Factory Priming for Field-Painted Finish: Apply shop primer specified below immediately after surface preparation and pretreatment. Apply a smooth coat of even consistency to provide a uniform dry film thickness of not less than 0.7 mils (0.02 mm).
3. Shop Primer: Manufacturer's or fabricators standard, fast-curing, corrosion-inhibiting, lead- and chromate-free, universal primer complying with ANSI A224.1 acceptance criteria; compatible with substrate and field-applied finish paint system indicated; and providing a sound foundation for field-applied topcoats despite prolonged exposure.

2.13 STAINLESS-STEEL FINISHES (WHERE SCHEDULED)

- A. General: Remove tool and die marks and stretch lines or blend into finish. Grind and polish surfaces to produce uniform, directionally textured, polished finish indicated, free of cross scratches. Run grain with long dimension of each piece.
  1. Bright, Directional Polish: No. 3 finish, unless otherwise indicated.
- B. When polishing is completed, passivate and rinse surfaces. Remove embedded foreign matter and leave surfaces chemically clean.

2.14 SOURCE QUALITY CONTROL

- A. Owner may select one detention door at random from detention doors delivered to Project and have it cut in half or otherwise taken apart for verification that construction complies with requirements.
  1. Should examination disclose door construction at variance from that specified, the door manufacturer shall, upon direction of the Architect-Engineer, replace all doors shipped to the project, as of the date of inspection, with doors constructed in conformance with project specifications. Under conditions of non-conformity, the door manufacturer shall pay for the destroyed door, replacement doors and related labor.
  2. Should examination prove the door was constructed in conformance with the specifications, the Owner will pay to replace the destroyed door and related labor.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of detention doors and frames.
  - 1. Examine rough-ins for embedded and built-in anchors to verify actual locations of detention frame connections before detention frame installation.
  - 2. For the record, prepare written report, endorsed by Installer, listing conditions detrimental to performance of detention doors and frames.
- B. Inspect built-in and cast-in anchor installations before installing detention frames to verify that anchor installations comply with requirements. Prepare inspection reports.
  - 1. Remove and replace anchors where inspections indicate that they do not comply with specified requirements. Reinspect after repairs or replacements are made.
  - 2. Perform additional inspections to determine compliance of replaced or additional work. Prepare inspection reports.
- C. Verify locations of detention doors and frames with those indicated on Coordination Drawings.
- D. For material whose orientation is critical for its performance as a ballistic barrier, verify installation orientation.
- E. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 PREPARATION

- A. Prior to installation and with spreaders removed, adjust detention frames for squareness, alignment, twist, and plumb to the following tolerances:
  - 1. Squareness: Plus or minus 1/16 inch (1.6 mm), measured at door rabbet on a line 90 degrees from jamb and perpendicular to frame head.
  - 2. Alignment: Plus or minus 1/16 inch (1.6 mm), measured at jambs on a horizontal line parallel to plane of face.
  - 3. Twist: Plus or minus 1/16 inch (1.6 mm), measured at opposite face corners of jambs on parallel lines, and perpendicular to plane of door rabbet.
  - 4. Plumbness: Plus or minus 1/16 inch (1.6 mm), measured at jambs on a perpendicular line from head to floor.

#### 3.3 INSTALLATION

- A. General: Install detention doors and frames plumb, rigid, properly aligned, and securely fastened in place, complying with Drawings, Coordination Drawings, DHI A115.IG, and manufacturer's written recommendations.

- B. Detention Frames: Install detention frames for detention doors, transoms, sidelights, borrowed lights and other openings, of sizes and profiles indicated.
1. Set masonry anchorage devices where required for securing detention frames to in-place concrete or masonry construction.
    - a. Set anchorage devices opposite each anchor location according to details on Shop Drawings and anchorage device manufacturer's written instructions. Leave drilled holes rough, not reamed, and free of dust and debris.
  2. Embedment-Masonry-Type Jamb Anchors: Weld wall angle anchors to embedded steel plates to match locations of detention frame angle anchors. Remove jamb faces from detention frames and set detention frames into opening until detention frame anchors contact and match embedded anchors. Weld detention frame anchors to embedded anchors with 1-inch- (25-mm-) long welds at each end of angle. Reinstall jamb faces of detention frames.
  3. Post-installed Expansion Jamb Anchors: After bolt is tightened, weld bolt head to provide non-removable condition. Grind, dress, and finish smooth welded bolt head.
  4. Floor anchors may be set with powder-actuated fasteners instead of post-installed expansion anchors if so indicated on Shop Drawings.
  5. Placing Detention Frames: Set detention frames accurately in position; plumbed, aligned, and braced securely until permanent anchors are set. After wall construction is complete, remove temporary braces and spreaders, leaving surfaces smooth and undamaged.
    - a. At fire-rated openings, install detention frames according to NFPA 80.
    - b. Field splice only at approved locations. Weld, grind, and finish as required to conceal evidence of splicing on exposed faces.
    - c. Install detention frames with removable stops located on secure (non-offender) side of opening.
  6. Assemble detention frames fabricated in sections. Install angle splices at each corner, of same material and thickness as detention frame, and extend at least 4 inches (102 mm) on both sides of joint.
  7. Continuously weld and finish smooth joints between faces of abutted, multiple-opening, detention frame members.
  8. Field Welding: Comply with the following requirements:
    - a. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
    - b. Obtain fusion without undercut or overlap.
    - c. Remove welding flux immediately.
    - d. At exposed connections, finish exposed welds and surfaces smooth and blended so no roughness shows after finishing and contour of welded surface matches that of adjacent surface.
  9. Grout-field installed by general contractor: Fill space between detention frames and concrete or masonry with grout. Install grout in lifts and take other precautions, including bracing detention frames, to ensure that detention frames are not deformed or damaged by grout forces. If a light consistency grout (greater than 5.0 inch slump in accordance with ASTM C 143) is to be used, special precautions shall be taken in the

field by the Installer to protect tapped holes, electrical knock-outs, lock pockets, grout guards, junction boxes, etc., in the frames.

- C. Swinging Detention Doors: Fit non-fire-rated detention doors accurately in their respective detention frames, with the following clearances:
  - 1. Between Doors and Frames at Jambs and Head: 1/8 inch (3.2 mm).
  - 2. Between Edges of Pairs of Doors: 1/8 inch (3.2 mm).
  - 3. At Door Sills with Threshold: 1/8 inch over threshold.
  - 4. At Door Sills without Threshold: 5/8 inch (15.9 mm).
- D. Fire-Rated Detention Doors: Install with clearances as specified in NFPA 80.
- E. Smoke-Control Detention Doors: Install according to NFPA 105.
- F. Comply with installation tolerances indicated in HMMA 863.
- G. Glazing: Comply with installation requirements in Division 8 Section "Security Glazing," unless otherwise indicated.

### 3.4 FIELD QUALITY CONTROL

- A. Inspect installed products to verify compliance with requirements. Prepare inspection reports and indicate compliance with and deviations from the Contract Documents.
- B. Remove and replace detention work where inspections indicate that work does not comply with specified requirements.
- C. Perform additional inspections to determine compliance of replaced or additional work. Prepare inspection reports.
- D. Prepare field quality-control certification that states installed products and their installation comply with requirements in the Contract Documents.

### 3.5 ADJUSTING AND CLEANING

- A. Final Adjustments: Check and readjust operating hardware items just before final inspection. Leave work in complete and proper operating condition. Remove and replace defective work, including detention doors, frames, steel grating, and door accessories, that are warped, bowed, or otherwise unacceptable.
- B. Clean grout and other bonding material off detention doors and frames immediately after installation.
- C. Prime-Coat Touchup: Immediately after erection, sand smooth rusted or damaged areas of prime coat and apply touchup of compatible air-drying primer.
  - 1. After finishing smooth field welds, apply air-drying primer.

- D. Galvanized Surfaces: Clean field welds, bolted connections, and abraded areas and repair galvanizing to comply with ASTM A 780.

END OF SECTION 083463

SECTION 08 4113 - ALUMINUM-FRAMED ENTRANCES AND STOREFRONTS

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. Section Includes:
  - 1. Exterior storefront framing.
  - 2. Storefront framing for punched openings.
  - 3. Exterior manual-swing entrance doors and door-frame units.

1.3 DEFINITIONS

- A. ADA/ABA Accessibility Guidelines: California Accessibility Code (CAC), U.S. Architectural & Transportation Barriers Compliance Board's "Americans with Disability Act (ADA) and Architectural Barriers Act (ABA) Accessibility Guidelines for Buildings and Facilities."

1.4 PERFORMANCE REQUIREMENTS

- A. General Performance: Aluminum-framed systems shall withstand the effects of the following performance requirements without exceeding performance criteria or failure due to defective manufacture, fabrication, installation, or other defects in construction:
  - 1. Movements of supporting structure indicated on Drawings including, but not limited to, story drift and deflection from uniformly distributed and concentrated live loads.
  - 2. Dimensional tolerances of building frame and other adjacent construction.
  - 3. Failure includes the following:
    - a. Deflection exceeding specified limits.
    - b. Thermal stresses transferring to building structure.
    - c. Framing members transferring stresses, including those caused by thermal and structural movements to glazing.
    - d. Noise or vibration created by wind and by thermal and structural movements.
    - e. Loosening or weakening of fasteners, attachments, and other components.
    - f. Sealant failure.
    - g. Failure of operating units.
- B. Delegated Design: Design aluminum-framed systems, including comprehensive engineering analysis by a qualified professional engineer, using performance requirements and design criteria indicated.
- C. Structural Loads:
  - 1. Wind Loads: Refer to Sheet S0.1.



- D. Deflection of Framing Members:
1. Deflection Normal to Wall Plane: Limited to edge of glass in a direction perpendicular to glass plane shall not exceed  $L/175$  of the glass edge length for each individual glazing lite or an amount that restricts edge deflection of individual glazing lites to 3/4 inch (19 mm), whichever is less.
  2. Deflection Parallel to Glazing Plane: Limited to  $L/360$  of clear span or 1/8 inch (3.2 mm), whichever is smaller.
- E. Air Infiltration: Provide aluminum-framed systems with maximum air leakage through fixed glazing and framing areas of 0.06 cfm/sq. ft. (0.03 L/s per sq. m) of fixed wall area when tested according to ASTM E 283 at a minimum static-air-pressure difference of 1.57 lbf/sq. ft. (75 Pa).
- F. Water Penetration under Static Pressure: Provide aluminum-framed systems that do not evidence water penetration through fixed glazing and framing areas when tested according to ASTM E 331 at a minimum static-air-pressure difference of 20 percent of positive wind-load design pressure, but not less than 6.24 lbf/sq. ft. (300 Pa).
- G. Water Penetration under Dynamic Pressure: Provide aluminum-framed systems that do not evidence water leakage through fixed glazing and framing areas when tested according to AAMA 501.1 under dynamic pressure equal to 20 percent of positive wind-load design pressure, but not less than 6.24 lbf/sq. ft. (300 Pa).
1. Maximum Water Leakage: No uncontrolled water penetrating aluminum-framed systems or water appearing on systems' normally exposed interior surfaces from sources other than condensation. Water leakage does not include water controlled by flashing and gutters that is drained to exterior and water that cannot damage adjacent materials or finishes.
- H. Thermal Movements: Provide aluminum-framed systems that allow for thermal movements resulting from the following maximum change (range) in ambient and surface temperatures. Base engineering calculation on surface temperatures of materials due to both solar heat gain and nighttime-sky heat loss.
1. Temperature Change (Range): 120 deg F (67 deg C), ambient; 180 deg F (100 deg C), material surfaces.
- I. Condensation Resistance: Provide aluminum-framed systems with fixed glazing and framing areas having condensation-resistance factor (CRF) of not less than 45 when tested according to AAMA 1503.
- J. Thermal Conductance: Provide aluminum-framed systems with fixed glazing and framing areas having an average U-factor of not more than 0.69 Btu/sq. ft. x h x deg F (3.92 W/sq. m x K) when tested according to AAMA 1503.
- K. Sound Transmission: Provide aluminum-framed systems with fixed glazing and framing areas having the following sound-transmission characteristics:
1. Outdoor-Indoor Transmission Class (OITC): Minimum 26 OITC when tested for laboratory sound transmission loss according to ASTM E 90 and determined by ASTM E 1332.

## 1.5 SUBMITTALS

- A. Product Data: For each type of product indicated. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for aluminum-framed systems.
- B. Shop Drawings: For aluminum-framed systems. Include plans, elevations, sections, details, and attachments to other work.
  - 1. Include details of provisions for system expansion and contraction and for drainage of moisture in the system to the exterior.
- C. Samples for Verification: For each type of exposed finish required, in manufacturer's standard sizes.
- D. Delegated-Design Submittal: For aluminum-framed systems indicated to comply with performance requirements and design criteria, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation.
  - 1. Detail fabrication and assembly of aluminum-framed systems.
  - 2. Include design calculations.
- E. Qualification Data: For qualified Installer and testing agency.
- F. Seismic Qualification Certificates: For aluminum-framed systems, accessories, and components, from manufacturer.
  - 1. Basis for Certification: Indicate whether withstand certification is based on actual test of assembled components or on calculation.
- G. Welding certificates.
- H. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency, for aluminum-framed systems, indicating compliance with performance requirements.
- I. Source quality-control reports.
- J. Field quality-control reports.
- K. Maintenance Data: For aluminum-framed systems to include in maintenance manuals.
- L. Warranties: Sample of special warranties.

## 1.6 QUALITY ASSURANCE

- A. Installer Qualifications: Manufacturer's authorized representative who is trained and approved for installation of units required for this Project.
- B. Testing Agency Qualifications: Qualified according to ASTM E 699 for testing indicated.

- C. Engineering Responsibility: Prepare data for aluminum-framed systems, including Shop Drawings, based on testing and engineering analysis of manufacturer's standard units in systems similar to those indicated for this Project.
- D. Product Options: Information on Drawings and in Specifications establishes requirements for systems' aesthetic effects and performance characteristics. Aesthetic effects are indicated by dimensions, arrangements, alignment, and profiles of components and assemblies as they relate to sightlines, to one another, and to adjoining construction. Performance characteristics are indicated by criteria subject to verification by one or more methods including preconstruction testing, field testing, and in-service performance.
  - 1. Do not revise intended aesthetic effects, as judged solely by Architect, except with Architect's approval. If revisions are proposed, submit comprehensive explanatory data to Architect for review.
- E. Accessible Entrances: Comply with applicable provisions in the U.S. Architectural & Transportation Barriers Compliance Board's ADA-ABA Accessibility Guidelines.
- F. Source Limitations for Aluminum-Framed Systems: Obtain from single source from single manufacturer.
- G. Welding Qualifications: Qualify procedures and personnel according to AWS D1.2, "Structural Welding Code - Aluminum."
- H. Mockups: Build mockups to verify selections made under sample submittals and to demonstrate aesthetic effects and set quality standards for fabrication and installation.
  - 1. Approval of mockups does not constitute approval of deviations from the Contract Documents contained in mockups unless Architect specifically approves such deviations in writing.
  - 2. Approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.
- I. Preinstallation Conference: Conduct conference at Project site .

#### 1.7 PROJECT CONDITIONS

- A. Field Measurements: Verify actual locations of structural supports for aluminum-framed systems by field measurements before fabrication and indicate measurements on Shop Drawings.

#### 1.8 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of aluminum-framed systems that do not comply with requirements or that fail in materials or workmanship within specified warranty period.
  - 1. Failures include, but are not limited to, the following:
    - a. Structural failures including, but not limited to, excessive deflection.
    - b. Noise or vibration caused by thermal movements.
    - c. Deterioration of metals, metal finishes, and other materials beyond normal weathering.

- d. Adhesive or cohesive sealant failures.
- e. Water leakage through fixed glazing and framing areas.
- f. Failure of operating components.
2. Warranty Period: Two years from date of Substantial Completion.

B. Special Finish Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components on which finishes do not comply with requirements or that fail in materials or workmanship within specified warranty period. Warranty does not include normal weathering.

1. Warranty Period: Five years from date of Substantial Completion.

## 1.9 MAINTENANCE SERVICE

A. Entrance Door Hardware:

1. Maintenance Tools and Instructions: Furnish a complete set of specialized tools and maintenance instructions as needed for Owner's continued adjustment, maintenance, and removal and replacement of entrance door hardware.
2. Initial Maintenance Service: Beginning at Substantial Completion, provide six months' full maintenance by skilled employees of entrance door hardware Installer. Include quarterly preventive maintenance, repair or replacement of worn or defective components, lubrication, cleaning, and adjusting as required for proper entrance door hardware operation at rated speed and capacity. Provide parts and supplies the same as those used in the manufacture and installation of original equipment.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
1. Arch Aluminum & Glass Co., Inc.
  2. CMI Architectural.
  3. Commercial Architectural Products, Inc.
  4. EFCO Corporation.
  5. Kawneer North America; an Alcoa company.
    - a. Basis of Design
      - 1) Kawneer 451 Storefront system at administration offices and entrance in area D.
  6. Pittco Architectural Metals, Inc.
  7. Tubelite.
  8. YKK AP America Inc.

### 2.2 MATERIALS

- A. Aluminum: Alloy and temper recommended by manufacturer for type of use and finish indicated.
1. Sheet and Plate: ASTM B 209 (ASTM B 209M).

2. Extruded Bars, Rods, Profiles, and Tubes: ASTM B 221 (ASTM B 221M).
  3. Extruded Structural Pipe and Tubes: ASTM B 429.
  4. Structural Profiles: ASTM B 308/B 308M.
  5. Welding Rods and Bare Electrodes: AWS A5.10/A5.10M.
- B. Steel Reinforcement: Manufacturer's standard zinc-rich, corrosion-resistant primer, complying with SSPC-PS Guide No. 12.00; applied immediately after surface preparation and pretreatment. Select surface preparation methods according to recommendations in SSPC-SP COM and prepare surfaces according to applicable SSPC standard.
1. Structural Shapes, Plates, and Bars: ASTM A 36/A 36M.
  2. Cold-Rolled Sheet and Strip: ASTM A 1008/A 1008M.
  3. Hot-Rolled Sheet and Strip: ASTM A 1011/A 1011M.

## 2.3 FRAMING SYSTEMS

- A. Framing Members: Manufacturer's standard extruded-aluminum framing members of thickness required and reinforced as required to support imposed loads.
1. Construction: Thermally broken.
  2. Glazing System: Retained mechanically with gaskets on four sides.
  3. Glazing Plane: Center.
- B. Brackets and Reinforcements: Manufacturer's standard high-strength aluminum with nonstaining, nonferrous shims for aligning system components.
- C. Fasteners and Accessories: Manufacturer's standard corrosion-resistant, nonstaining, nonbleeding fasteners and accessories compatible with adjacent materials.
1. Use self-locking devices where fasteners are subject to loosening or turning out from thermal and structural movements, wind loads, or vibration.
  2. Reinforce members as required to receive fastener threads.
  3. Use exposed fasteners with countersunk Phillips screw heads, finished to match framing system.
- D. Concrete and Masonry Inserts: Hot-dip galvanized cast-iron, malleable-iron, or steel inserts, complying with ASTM A 123/A 123M or ASTM A 153/A 153M.
- E. Concealed Flashing: Manufacturer's standard corrosion-resistant, nonstaining, nonbleeding flashing compatible with adjacent materials.
- F. Framing System Gaskets and Sealants: Manufacturer's standard, recommended by manufacturer for joint type.

## 2.4 GLAZING SYSTEMS

- A. Glazing: As specified in Division 08 Section "Glazing."
- B. Glazing Gaskets: Manufacturer's standard compression types; replaceable, molded or extruded, of profile and hardness required to maintain watertight seal.
- C. Spacers and Setting Blocks: Manufacturer's standard elastomeric type.

## 2.5 ENTRANCE DOOR SYSTEMS

- A. Entrance Doors: Manufacturer's standard glazed entrance doors for manual-swing operation.
  - 1. Door Construction: 1-3/4-inch (44.5-mm) overall thickness, with minimum 0.125-inch (3.2-mm-) thick, extruded-aluminum tubular rail and stile members. Mechanically fasten corners with reinforcing brackets that are deeply penetrated and fillet welded or that incorporate concealed tie rods.
  - 2. Door Design: As indicated.
    - a. Accessible Doors: Smooth surfaced for width of door in area within 10 inches (255 mm) above floor or ground plane.
  - 3. Glazing Stops and Gaskets: Square, snap-on, extruded-aluminum stops and preformed gaskets.
    - a. Provide nonremovable glazing stops on outside of door.
- B. Entrance Door Hardware: As specified in Division 08 Section "Door Hardware."

## 2.6 ENTRANCE DOOR HARDWARE

- A. General: Provide entrance door hardware and entrance door hardware sets indicated in door and frame schedule for each entrance door to comply with requirements in this Section.
- B. Opening-Force Requirements:
  - 1. Latches and Exit Devices: Not more than 15 lbf (67 N) required to release latch.
- C. Continuous-Gear Hinges: Manufacturer's standard with stainless-steel bearings between knuckles, fabricated to full height of door and frame. (Hager 780-111)
- D. Mortise Auxiliary Locks: As specified in Division 8 Section "Door Hardware".
- E. Panic Exit Devices: BHMA A156.3, Grade 1, listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for panic protection, based on testing according to UL 305. (Von Duprin XP98/99)
- F. Cylinders: As specified in Division 087100 Section "Door Hardware"
- G. Closers: As provided by division 087100 Section "Door Hardware". (LCN 4110 series)
- H. Door Stops: BHMA A156.16, Grade 1, floor or wall mounted, as appropriate for door location indicated, with integral rubber bumper. (Ives FS436)
- I. Weather Stripping: Manufacturer's standard replaceable components.
  - 1. Compression Type: Made of ASTM D 2000, molded neoprene, or ASTM D 2287, molded PVC.
  - 2. Sliding Type: AAMA 701, made of wool, polypropylene, or nylon woven pile with nylon-fabric or aluminum-strip backing.
- J. Weather Sweeps: Manufacturer's standard exterior-door bottom sweep with concealed fasteners on mounting strip.
- K. Silencers: BHMA A156.16, Grade 1.

- L. Thresholds: BHMA A156.21, raised thresholds beveled with a slope of not more than 1:2, with maximum height of 1/2 inch (13 mm). (PEMKO 170)

## 2.7 ACCESSORY MATERIALS

- A. Joint Sealants: For installation at perimeter of aluminum-framed systems, as specified in Division 079200 Section "Joint Sealants."
- B. Bituminous Paint: Cold-applied, asphalt-mastic paint complying with SSPC-Paint 12 requirements except containing no asbestos; formulated for 30-mil (0.762-mm) thickness per coat.

## 2.8 FABRICATION

- A. Form or extrude aluminum shapes before finishing.
- B. Weld in concealed locations to greatest extent possible to minimize distortion or discoloration of finish. Remove weld spatter and welding oxides from exposed surfaces by descaling or grinding.
- C. Framing Members, General: Fabricate components that, when assembled, have the following characteristics:
  - 1. Profiles that are sharp, straight, and free of defects or deformations.
  - 2. Accurately fitted joints with ends coped or mitered.
  - 3. Means to drain water passing joints, condensation within framing members, and moisture migrating within the system to exterior.
  - 4. Physical and thermal isolation of glazing from framing members.
  - 5. Accommodations for thermal and mechanical movements of glazing and framing to maintain required glazing edge clearances.
  - 6. Provisions for field replacement of glazing from exterior.
  - 7. Fasteners, anchors, and connection devices that are concealed from view to greatest extent possible.
- D. Entrance Door Frames: Reinforce as required to support loads imposed by door operation and for installing entrance door hardware.
  - 1. At exterior doors, provide compression weather stripping at fixed stops.
- E. Entrance Doors: Reinforce doors as required for installing entrance door hardware.
  - 1. At pairs of exterior doors, provide sliding-type weather stripping retained in adjustable strip and mortised into door edge.
  - 2. At exterior doors, provide weather sweeps applied to door bottoms.
- F. Entrance Door Hardware Installation: Factory install entrance door hardware to the greatest extent possible. Cut, drill, and tap for factory-installed entrance door hardware before applying finishes.
- G. After fabrication, clearly mark components to identify their locations in Project according to Shop Drawings.

2.9 ALUMINUM FINISHES

- A. Clear Anodic Finish: AAMA 611, AA-M12C22A41, Class I, 0.018 mm or thicker.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. General:
  - 1. Comply with manufacturer's written instructions.
  - 2. Do not install damaged components.
  - 3. Fit joints to produce hairline joints free of burrs and distortion.
  - 4. Rigidly secure nonmovement joints.
  - 5. Install anchors with separators and isolators to prevent metal corrosion and electrolytic deterioration.
  - 6. Seal joints watertight unless otherwise indicated.
- B. Metal Protection:
  - 1. Where aluminum will contact dissimilar metals, protect against galvanic action by painting contact surfaces with primer or applying sealant or tape, or by installing nonconductive spacers as recommended by manufacturer for this purpose.
  - 2. Where aluminum will contact concrete or masonry, protect against corrosion by painting contact surfaces with bituminous paint.
- C. Install components to drain water passing joints, condensation occurring within framing members, and moisture migrating within the system to exterior.
- D. Set continuous sill members and flashing in full sealant bed as specified in Division 07 Section "Joint Sealants" to produce weathertight installation.
- E. Install components plumb and true in alignment with established lines and grades, and without warp or rack.
- F. Install glazing as specified in Division 08 Section "Glazing."
- G. Entrance Doors: Install doors to produce smooth operation and tight fit at contact points.
  - 1. Exterior Doors: Install to produce weathertight enclosure and tight fit at weather stripping.
  - 2. Field-Installed Entrance Door Hardware: Install surface-mounted entrance door hardware according to entrance door hardware manufacturers' written instructions using concealed fasteners to greatest extent possible.



- H. Install perimeter joint sealants as specified in Division 07 Section "Joint Sealants" to produce weathertight installation.

### 3.3 ERECTION TOLERANCES

- A. Install aluminum-framed systems to comply with the following maximum erection tolerances:
  - 1. Location and Plane: Limit variation from true location and plane to 1/8 inch in 12 feet (3 mm in 3.7 m); 1/4 inch (6 mm) over total length.
  - 2. Alignment:
    - a. Where surfaces abut in line, limit offset from true alignment to 1/16 inch (1.5 mm).
    - b. Where surfaces meet at corners, limit offset from true alignment to 1/32 inch (0.8 mm).
- B. Diagonal Measurements: Limit difference between diagonal measurements to 1/8 inch (3 mm).

### 3.4 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified independent testing and inspecting agency to perform field tests and inspections.
- B. Field Water Spray Testing:
  - 1. AAMA 501.2, Quality Assurance and Diagnostic Water Leakage Field Check of Installed Storefronts, Curtain Walls, and Sloped Glazing Systems
  - 2. Perform nozzle water testing by applying water using a hand held spray assembly employing a Type B2 #6.030 nozzle, pressure gauge, control valve, and a 3/4" garden hose. Adjust water flow to the nozzle to produce 30 psi at the nozzle. Direct water at the joint under test perpendicular to the face of the storefront. Move the nozzle slowly back and forth above the joint, at a distance of 1'-0" for a period of five minutes for each 5'-0" of joint. An observer on the inside checks for water leakage. Perform field water spray testing on 20% of the total area of installed storefront. Document locations of tests and include with test report. Provide test report to CxA for review and comment.
- C. Repair or remove work if test results and inspections indicate that it does not comply with specified requirements.
- D. Additional testing and inspecting, at Contractor's expense, will be performed to determine compliance of replaced or additional work with specified requirements.
- E. Aluminum-framed assemblies will be considered defective if they do not pass tests and inspections.
- F. Prepare test and inspection reports.

### 3.5 ADJUSTING

- A. Adjust operating entrance door hardware to function smoothly as recommended by manufacturer.

1. For entrance doors accessible to people with disabilities, adjust closers to provide a 3-second closer sweep period for doors to move from a 70-degree open position to 3 inches (75 mm) from the latch, measured to the leading door edge.

END OF SECTION 08 4113

SECTION 085123.13 - HOT-ROLLED STEEL WINDOWS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes steel windows from hot-rolled members.
- B. Related Requirements:
  - 1. Section 08 8000 "Glazing" for requirements for glass and glazing.

1.3 PREINSTALLATION MEETINGS

- A. Preinstallation Conference: Conduct conference at Project site.
  - 1. Review requirements for hot-rolled steel windows, including, but not limited to, the following:
    - a. Coordinating finishing of hot-rolled steel windows with other work where color and finish matching is indicated.
    - b. Coordinating hot-rolled steel windows with other exterior wall components, including anchorage, glazing, flashing, weeping, air barriers, sealants, and protection of finishes.
    - c. Sequencing work to construct a watertight and weathertight exterior building enclosure.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. Include construction details, material descriptions, fabrication methods, dimensions of individual components and profiles, hardware, finishes, and operating instructions.
- B. Shop Drawings:
  - 1. Include plans, elevations, sections, and details.
  - 2. Detail attachments to other work, and between units, if any.
  - 3. Include hardware and required clearances.
  - 4. Mullion details, including reinforcement and stiffeners.
  - 5. Flashing details.
  - 6. Glazing details.
  - 7. Accessories.
- C. Samples for Verification: For each type of hot-rolled steel window.

1. Main Framing and Sash Members: Full-sized sections 12 inches long, with factory-applied finish and glazing bead.

D. Product Schedule: For hot-rolled steel windows. Use same designations indicated on Drawings.

#### 1.5 INFORMATIONAL SUBMITTALS

A. Qualification Data: For Installer and manufacturer.

B. Product test reports indicating conformance with performance requirements specified in Part 2.

#### 1.6 CLOSEOUT SUBMITTALS

A. Maintenance Data: For hot-rolled steel windows to include in maintenance manuals.

#### 1.7 QUALITY ASSURANCE

A. Manufacturer Qualifications: A manufacturer capable of fabricating hot-rolled steel windows that meet performance requirements indicated and of documenting performance by labels, test reports, and calculations.

B. Installer Qualifications: An installer acceptable to window manufacturer for installation of units required for this Project.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

A. Basis-of-Design Product: Subject to compliance with requirements, provide Hope's Windows, Inc.; S10 or a comparable product by one of the following:

1. A&S Window Associates, Inc.
2. Crittall Windows Ltd.
3. Optimum Window Manufacturing Corp.
4. Torrance Steel Window Co., Inc.

#### 2.2 PERFORMANCE REQUIREMENTS

A. SWI Standards: Comply with applicable requirements in SWI's "The Architect's Guide to Steel Windows and Doors" and "Specifications: Hot-Rolled," except where more stringent requirements are indicated.

B. Structural Wind Loads: As indicated on Drawings.

C. Deflection Limits: Design glass framing system to limit lateral deflections of glass edges to less than 1/175 of glass-edge length or 3/4 inch, whichever is less, at design pressures.

- D. Structural: Test according to ASTM E 330 as follows:
  - 1. When tested at positive and negative wind-load design pressures, hot-rolled steel windows do not evidence deflection exceeding specified limits.
  - 2. When tested at 150 percent of positive and negative wind-load design pressures, assemblies, including anchorage, do not evidence material failures, structural distress, or permanent deformation of main framing members exceeding 0.2 percent of span.
  - 3. Test Durations: As required by design wind velocity, but not less than 10 seconds.
- E. Air Infiltration for Weather-Stripped Sash: Not more than 0.37 cfm/ft. of sash crack length at an inward test pressure of 6.24 lbf/sq. ft. when tested according to ASTM E 283.
- F. Water Penetration: No leakage for 15 minutes when window is subjected to a rate of flow of 5 gal./h/sq. ft. with a differential pressure across the window of 2.86 lbf/sq. ft. when tested according to ASTM E 331.
- G. Tool-Resistance: Units shall meet or exceed Grade 4 as tested per ASTM A627.
- H. Impact Resistance: Units shall meet or exceed Grade 3 as tested per ASTM F 1592.
- I. Thermal Movements: Provide hot-rolled steel windows, including anchorage, that allow for thermal movements resulting from the following maximum change (range) in ambient and surface temperatures by preventing buckling, opening of joints, overstressing of components, failure of joint sealants, failure of connections, and other detrimental effects. Base engineering calculation on surface temperatures of materials due to both solar heat gain and nighttime-sky heat loss.
  - 1. Temperature Change: 120 deg F, ambient; 180 deg F material surfaces] <Insert temperature change>.

### 2.3 HOT-ROLLED STEEL WINDOWS

- A. Operating Types: Provide the following operating types in locations indicated on Drawings:
  - 1. Fixed and operable (awning).
- B. Hot-Rolled Steel Windows: Provide frame and sash members formed from hot-rolled, new billet steel sections. Provide combined weight of frame and sash members and depth of frame or sash members according to the SWI specifications category for Heavy Intermediate hot-rolled steel windows.
- C. Window Finish: High performance (epoxy with polyurethane topcoat).
  - 1. Color and Gloss: As selected by Architect from manufacturer's full range of standard colors.
- D. Units shall have horizontal steel detention bars, concealed within the head rail of each operable portion of unit and in the sill of frame. Horizontal bars shall penetrate vertical steel detention bars concealed in the jambs of the frame to form an integral detention grid. Operable units shall be linked together to operate in unison by concealed operating mechanism.
- E. Mullions: Formed of hot-rolled steel matching window units; with anchors for support to structure and for installation of window units and having sufficient strength to withstand design pressure indicated. Provide mullions of profile indicated and with cover plates. Allow for

erection tolerances and provide for movement of window units due to thermal expansion and building deflections.

- F. Glazing Stops: Provide manufacturer's standard screw-applied stops fabricated from formed steel or stainless steel; coordinate with Section 08 8000 "Glazing" for glazing system indicated. Finish glazing stops with same finish as window units if fabricated of steel; otherwise, provide manufacturer's standard finish. Match color to window units.
- G. Weather Stripping: Manufacturer's standard compressible weather stripping, complying with AAMA 701/702, ASTM C 509, or ASTM C 864 and designed for permanently resilient sealing under compression and for complete concealment when sash is closed.

## 2.4 GLAZING

- A. Glass and Glazing System: See Section 08 8000 "Glazing" for glass units and glazing requirements for hot-rolled steel windows.

## 2.5 ACCESSORIES

- A. Security and Detention Screens:
  - 1. Fixed Angle Frame:
    - a. Frames shall be steel angles, fabricate from 12 gauge galvanized steel, minimum.
    - b. Steel clamp strip shall be fabricated from 12 gauge galvanized steel, minimum.
    - c. Screen cloth shall be 18/8 Type 304, woven 12 mesh to the inch from 0.047-inch diameter wire, double crimped.
- B. Fasteners: Provide fasteners of bronze, brass, stainless steel, or other metal that are warranted by manufacturer to be noncorrosive and compatible with trim, hardware, anchors, and other components of hot-rolled steel windows.
  - 1. Exposed Fasteners: Exposed fasteners shall be tamper resistant truss-head plated steel.
- C. Anchors, Clips, and Window Accessories: Provide units of stainless steel, hot-dip zinc-coated steel, bronze, brass, or iron complying with ASTM A 123/A 123M. Provide units with sufficient strength to withstand design pressure indicated.
- D. Sealant: For sealants required within fabricated windows, provide manufacturer's standard, permanently elastic, nonshrinking, and nonmigrating type recommended by sealant manufacturer for joint size and movement.

## 2.6 FABRICATION

- A. General: Fabricate hot-rolled steel windows of type and in sizes indicated to comply with SWI standards and reviewed Shop Drawings. Include a complete system for assembly of components and anchorage of window units.
- B. Provide units that are reglazable without dismantling framing.

- C. Frame members shall be coped and welded at corners, full depth of frame for maximum strength and weather tightness. All exposed welds shall be dressed smooth to match adjacent frame.
- D. Horizontal detention bars (7/8-inch diameter, minimum) shall penetrate vertical detention bars (1/4- by 2-inch flat stock). All detention bars shall be fully concealed within framing members as indicated in Part 2.
- E. Operable unit jamb and sill detention bars shall be solidly welded and exposed faces and contact surfaces shall be dressed smooth to match adjacent surfaces. Jamb and head bars shall be welded to pivotal bars.
- F. Operating Hardware:
  - 1. The 7/8" round pivotal bars shall be continuous and have a welded linkage near each end. The linkage arms at each jamb shall be attached to a flat connecting bar by a pivot pin controlling the ventilators in unison to a maximum opening of 50 degrees.
  - 2. The linkage arms of the lower ventilator shall be connected to bell cranks by means of an adjustable link, which provides for adjustment of the ventilators.
  - 3. A bell crank shall be welded to each end of the 3/4" diameter power shaft.
  - 4. The 3/4" power shaft shall be connected to the power with an overload safety device.
  - 5. The power unit shall be located and concealed within the sub frame of the window.
  - 6. Opening and closing of the ventilators shall be accomplished by rotating the operating cone or crank in either direction.
  - 7. The 3/4" diameter shaft, power unit, bell cranks and adjuster links shall be removable from the window.
- G. Weatherstripping shall be factory applied for all operable units.
- H. Prepare windows for site glazing.
- I. Subframes and Sash: Formed of hot-rolled steel of profile indicated. Miter or cope corners, and weld and dress joints smooth.
- J. Weather Stripping: Provide full-perimeter weather stripping for each operable sash unless otherwise indicated.
- K. Provide weep holes and internal water passages to conduct infiltrating water to the exterior.
- L. Security and Detention Screens:
  - 1. Fixed angle frame
  - 2. Frames shall be welded solid at corners and welds dressed smooth.
  - 3. Secure screen cloth to frame using special security screws spaced 4" on centers, which penetrate the frame, screen cloth and clamp strip.
  - 4. The screen frame and clamp strip shall be factory finished to match the window finish.

## 2.7 STEEL FINISHES

- A. High-Performance Coating Finish: Manufacturer's standard epoxy coating with polyurethane topcoat (. Prepare, pretreat, and apply coating to exposed metal surfaces to comply with coating and resin manufacturers' written instructions.



PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine openings, substrates, structural support, anchorage, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work. Verify rough-opening dimensions, levelness of sill plate, and clearances. Examine wall flashings, vapor retarders, water and weather barriers, and other built-in components to ensure a coordinated, weathertight window installation.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. SWI Publication: Comply with applicable requirements in SWI's "General Guidelines on the Installation of Steel Windows," except where more stringent requirements are indicated.
- B. Comply with manufacturer's written instructions for installing windows, hardware, operators, accessories, and other components.
- C. Install windows level, plumb, square, true to line, without distortion or impediment to thermal movement, anchored securely in place to structural support, and in proper relation to wall flashing and other adjacent construction.
- D. Set sill members in bed of sealant or with gaskets, as indicated, to provide weathertight construction.
- E. Install windows and components to drain condensation, water-penetrating joints, and moisture migrating within windows to the exterior.
- F. Separate corrodible surfaces from sources of corrosion or electrolytic action at points of contact with other materials according to ASTM E 2112.
- G. Install security screens per manufacturer's written instructions on interior side of frame.

3.3 ADJUSTING, CLEANING, AND PROTECTION

- A. Adjust operating sashes, screens, hardware, and accessories for a tight fit at contact points and weather stripping for smooth operation and weathertight closure. Lubricate hardware and moving parts.
- B. Clean factory-finished steel surfaces immediately after installing windows. Comply with manufacturer's written recommendations for final cleaning and maintenance. Avoid damaging protective coatings and finishes.
- C. Protect window surfaces from contact with contaminating substances resulting from construction operations. Remove contaminants immediately according to manufacturer's written recommendations.

- D. Refinish or replace windows with damaged finish.

END OF SECTION

SECTION 086200 - UNIT SKYLIGHTS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Unit skylights mounted on fabricated curbs.
- B. Related Sections:
  - 1. Division 06 1000 Section "Rough Carpentry " for wood framing and blocking at unit skylights.
  - 2. Division 07 7200 Section "Roof Accessories" for curbs and flashing at unit skylights.

1.3 PERFORMANCE REQUIREMENTS

- A. AAMA/WDMA Performance Requirements: Provide unit skylights of performance class and grade indicated that comply with AAMA/WDMA 101/I.S.2/NAFS.
  - 1. Performance Class and Grade: SKP-HC40/40-1200x2500.
- B. Skylights must conform to all federal, state and local code bodies having jurisdiction, and be design to withstand all forces of nature deemed necessary by those code bodies for the specified project location.
- C. Plastic unit skylights shall conform to recommendations of the AA Specifications for Aluminum Structures
- D. Skylights must be designed to carry a minimum 30 psf tributary roof load or greater per site as specified in the current International Building Code or prevailing model code.
- E. Drop Test:
  - 1. A 200 lb (91 kg) drop test from a height of 24 inches (610mm) above the center (highest point) of dome shape and at mid points of both the 5 foot (1524mm) and 6 foot (1829mm) side (approximately 15 inches (381mm) and 18 inches (457mm) from center).
  - 2. The 200 lb (91 kg) load must be contained within a flexible bladder or sack having approximate dimensions no larger than 30 inches long, 20 inches wide, and 8 inches high (762mm x 508mm x 203mm), filled with coarse sand or pea gravel.
  - 3. The dome must withstand the sack drop without inverting or breaking.
  - 4. Finished skylight domes sealed in frame must also handle 500 lb (227 kg) on 1 square foot (.09 sm) point loading without inverting.

5. The drop test must be witnessed and certified by the test laboratory which provides the NAFS certification.

F. Skylights must be certified by the NFRC, NAFS and be Factory Mutual approved.

#### 1.4 SUBMITTALS

A. Product Data: For each type of unit skylight indicated. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for unit skylights.

B. Shop Drawings: For unit skylight work. Include plans, elevations, sections, details, and connections to supporting structure and other adjoining work.

C. Product Test Reports: Based on evaluation of comprehensive tests performed within the last four years by a qualified testing agency for each type, performance class, performance grade, and size of unit skylight. Test results based on use of downsized test units will not be accepted.

D. Maintenance Data: For unit skylights to include in maintenance manuals.

E. Warranty: Sample of special warranty.

#### 1.5 QUALITY ASSURANCE

A. Manufacturer Qualifications: A manufacturer capable of fabricating unit skylights that meet or exceed performance requirements indicated and of documenting this performance by inclusion in lists and by labels, test reports, and calculations.

B. Installer Qualifications: An installer acceptable to unit skylight manufacturer for installation of units required for this Project.

C. Source Limitations: Obtain unit skylights from single source from single manufacturer.

D. Surface-Burning Characteristics of Plastic Glazing: Provide plastic glazing sheets identical to those tested for fire-exposure behavior per test method indicated below by a testing and inspecting agency acceptable to authorities having jurisdiction. Identify materials with appropriate markings of applicable testing and inspecting agency.

1. Self-Ignition Temperature: 650 deg F (343 deg C) or more for plastic sheets in thickness indicated when tested per ASTM D 1929.

2. Smoke-Production Characteristics: Comply with either requirement below:

a. Smoke-Developed Index: 450 or less when tested per ASTM E 84 on plastic sheets in manner indicated for use.

b. Smoke Density: 75 or less when tested per ASTM D 2843 on plastic sheets in thickness indicated for use.

3. Burning Characteristics: Tested per ASTM D 635.

a. Acrylic Glazing: Class CC2, burning rate of 2-1/2 inches (64 mm) per minute or less for nominal thickness of 0.060 inch (1.5 mm) or thickness indicated for use.

- E. Unit Skylight Standard: Comply with AAMA/WDMA 101/LS.2/NAFS, "North American Fenestration Standard Voluntary Performance Specification for Windows, Skylights and Glass Doors," for minimum standards of performance, materials, components, accessories, and fabrication. Comply with more stringent requirements if indicated.
- F. Preinstallation Conference: Conduct conference at Project site.
- G. Mock-Up: Provide a mock-up for evaluation of surface preparation techniques and application of workmanship.
  - 1. Mockup to include roof curb, anchorage, flashing, roof material and interior trim.
  - 2. Mockup is to be part of the final roof installation.

## 1.6 COORDINATION

- A. Coordinate unit skylight flashing requirements with roofing system.
- B. Coordinate sizes and locations of fabricated curbs with actual unit skylights provided.
- C. Provide anchors and inserts to be placed in adjacent construction in proper sequence so as not to delay the Work.

## 1.7 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of unit skylights that fail in materials or workmanship within specified warranty period.
  - 1. Failures include, but are not limited to, the following:
    - a. Uncontrolled water leakage.
    - b. Deterioration of metals, metal finishes, and other materials beyond normal weathering.
    - c. Yellowing of acrylic glazing.
    - d. Deterioration of insulating-glass hermetic seal.
  - 2. Warranty Period: Five years from date of Substantial Completion.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Sunoptics Prismatic Skylights: Basis of Design
  - 2. Bristolite Skylights.
  - 3. Fox Lite, Inc.; Skymaster Skylights.

## 2.2 MATERIALS

- A. Aluminum Components:
1. Sheets: ASTM B 209 (ASTM B 209M), alloy and temper to suit forming operations and finish requirements but with not less than the strength and durability of alclad Alloy 3005-H25.
  2. Extruded Shapes: ASTM B 221 (ASTM B 221M), alloy and temper to suit structural and finish requirements but with not less than the strength and durability of Alloy 6063-T52.
- B. Fasteners: Same metal as metal being fastened, nonmagnetic stainless steel, or other noncorrosive metal as recommended by manufacturer. Finish exposed fasteners to match material being fastened.
1. Fasteners (For anchorage of skylight to roof curb): #12 x 1 1/2 inch (38mm) 300 series stainless steel screws with washers. Provide fasteners in sufficient quantity for complete installation.
- C. Frame:
1. ASTM B 221 alloy 6063-T5 extruded aluminum frame with extruded aluminum dome retaining angle, Insulated thermal break, and integral condensate gutter.
  2. Finish: Manufacturer's standard mill finish.
  3. Provide pre-installed 1 1/2 inch (38mm) x 1/4 inch (6mm) foam rubber gasket between frame and curb.
  4. Provide weather sweep attached to frame.

## 2.3 GLAZING

- A. Glazing Panels: Configuration: Double Hip – Double Glazed.
1. Outer Lens: SR 60 - 100 percent impact modified clear prismatic acrylic of sufficient thickness recommended to meet the specified performance requirements.
  2. Inner lens: SR25 White Prismatic Acrylic Lens.
  3. Outer Lens: Clear Armor™ Polycarbonate (Lexan SLX) Prismatic Lens.
  4. Inner lens: SR25 White Prismatic Acrylic Lens.
  5. Energy Requirements: Glazing material must have a maximum light distribution characteristic that maximizes the shading factor. Per Addendum D of ASHRAE 90.1 – 2007, the diffusing qualities of glazing must have a minimum haze factor of 90 percent or greater. The combined inner/outer lens target values shall be as follows:
    - a. Light Transmittance: 67.8 percent minimum – 100 percent Class 1 and Class 3 Acrylic outer dome.
    - b. Light Transmittance: 60.0 percent minimum – Clear Armor™ Polycarbonate (LEXAN SLX) outer dome.
    - c. Diffusion / Haze Factor: 100 percent min.
    - d. Solar Heat Gain Coefficient (SHGC): 0.52 maximum. NFRC 200
    - e. “U” Value: 0.82 or lower (glazing and framing) in accordance with NFRC 100 or “unlabeled skylight” default requirements of ASHRAE 90.1 - 2004
  6. Hail Resistance Level: Class 3 as tested by certified engineering firm.
- B. Glazing Gaskets: Manufacturer's standard.

## 2.4 INSTALLATION MATERIALS

- A. Bituminous Coating: SSPC-Paint 12, solvent-type, bituminous mastic, nominally free of sulfur and containing no asbestos fibers, formulated for 15-mil (0.4-mm) dry film thickness per coating.
- B. Joint Sealants: As specified in Division 07 Section "Joint Sealants."
- C. Mastic Sealant: Polyisobutylene; nonhardening, nonskinning, nondrying, nonmigrating sealant.
- D. Roofing Cement: ASTM D 4586, asbestos free, designed for trowel application or other adhesive compatible with roofing system.

## 2.5 UNIT SKYLIGHTS

- A. General: Provide factory-assembled unit skylights that include glazing, extruded-aluminum glazing retainers, gaskets, and inner frames and that are capable of withstanding performance requirements indicated.
- B. Prefabricated Curb: As specified in Division 07 7200 Section "Roof Accessories."
- C. Unit Shape and Size: As indicated on Drawings.
- D. Condensation Control: Fabricate unit skylights with integral internal gutters and nonclogging weeps to collect and drain condensation to the exterior.
- E. Thermal Break: Fabricate unit skylights with thermal barrier separating exterior and interior metal framing.

## 2.6 GENERAL FINISH REQUIREMENTS

- A. Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Appearance of Finished Work: Noticeable variations in same piece are not acceptable. Variations in appearance of adjoining components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.

## 2.7 ALUMINUM FINISHES

- A. Clear Anodic Finish: AAMA 611, AA-M12C22A41, Class I, 0.018 mm or thicker.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine openings, substrates, structural support, anchorage, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Proceed with unit skylight installation only after unsatisfactory conditions have been corrected.

#### 3.2 INSTALLATION

- A. Coordinate installation of unit skylight with installation of substrates, vapor retarders, roof insulation, roofing membrane, and flashing as required to ensure that each element of the Work performs properly and that combined elements are waterproof and weathertight.
- B. Comply with recommendations in AAMA 1607 and with manufacturer's written instructions for installing unit skylights.
- C. Install unit skylights level, plumb, and true to line, without distortion.
- D. Anchor unit skylights securely to supporting substrates.
- E. Where metal surfaces of unit skylights will contact incompatible metal or corrosive substrates, including preservative-treated wood, apply bituminous coating on concealed metal surfaces, or provide other permanent separation recommended in writing by unit skylight manufacturer.
- F. Set unit skylight flanges in thick bed of roofing cement to form a seal unless otherwise indicated.
- G. Where cap flashing is indicated, install to produce waterproof overlap with roofing or roof flashing. Seal with thick bead of mastic sealant except where overlap is indicated to be left open for ventilation.

#### 3.3 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. After completion of installation and nominal curing of sealant and glazing compounds but before installation of interior finishes, test for water leaks according to AAMA 501.2.
- C. Perform test for total area of each unit skylight.
- D. Work will be considered defective if it does not pass tests and inspections.
- E. Additional testing and inspections, at Contractor's expense, will be performed to determine compliance of replaced or additional work with specified requirements.



3.4 CLEANING

- A. Clean exposed unit skylight surfaces according to manufacturer's written instructions. Touch up damaged metal coatings and finishes.
- B. Remove excess sealants, glazing materials, dirt, and other substances.
- C. Remove and replace glazing that has been broken, chipped, cracked, abraded, or damaged during construction period.
- D. Protect unit skylight surfaces from contact with contaminating substances resulting from construction operations.

END OF SECTION 086200

SECTION 08 7100 - DOOR HARDWARE

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Commercial door hardware for the following:
    - a. Swinging doors.
    - b. Other doors to the extent indicated.
  - 2. Cylinders for doors specified in other Sections.
- B. Related Sections include the following:
  - 1. Division 081416 Section "Flush Wood Doors" for astragals and integral intumescent seals provided as part of fire-rated labeled assemblies.
  - 2. Division 083113 Section "Access Doors and Frames" for access door hardware, except cylinders.
  - 3. Division 083463 Section "Detention Doors and Frames".
  - 4. Division 041138 Section "Aluminum-Framed Entrances and Storefronts" for entrance door hardware not included in this section.
  - 5. Division 087163 Section "Detention Door Hardware" for hardware for detention doors.
  - 6. Division 102213 Section "Wire Mesh Partitions" for door hardware for doors in wire mesh-partitions, except cylinders.
  - 7. Division 26 Sections for connections to electrical power system and for low-voltage wiring work.
  - 8. Division 281300 Section "Access Control System" for access control devices installed at door openings and provided as part of a security access system.
  - 9. Division 283111 Section "Digital Addressable Fire Alarm System" for connections to building fire alarm system.
- C. Products furnished, but not installed, under this Section include the following. Coordinating, purchasing, delivering, and scheduling remain requirements of this Section.
  - 1. Thresholds, weather stripping and cylinders for locks specified in other Sections.
  - 2. Permanent cores to be installed by Owner.

1.3 SUBMITTALS

- A. Product Data: Include construction and installation details, material descriptions, dimensions of individual components and profiles, and finishes.
- B. Product Test Reports: Based on evaluation of comprehensive tests performed by manufacturer and witnessed by a qualified testing agency, for locks, latches, delayed-egress locks and closers.

- C. Maintenance Data: For each type of door hardware to include in maintenance manuals. Include final hardware schedule.
- D. Warranty: Special warranty specified in this Section.
- E. Other Action Submittals:
  - 1. Door Hardware Sets: Prepared by or under the supervision of Architectural Hardware Consultant, detailing fabrication and assembly of door hardware, as well as procedures and diagrams. Coordinate the final door hardware sets with doors, frames, and related work to ensure proper size, thickness, hand, function, and finish of door hardware.
    - a. Format: Comply with scheduling sequence and vertical format in DHI's "Sequence and Format for the Hardware Schedule." Double space entries, and number and date each page.
    - b. Format: Use same scheduling sequence and format and use same door numbers as in the Contract Documents.
    - c. Content: Include the following information:
      - 1) Identification number, location, hand, fire rating, and material of each door and frame.
      - 2) Type, style, function, size, quantity, and finish of each door hardware item. Include description and function of each lockset and exit device.
      - 3) Complete designations of every item required for each door or opening including name and manufacturer.
      - 4) Fastenings and other pertinent information.
      - 5) Location of each door hardware set, cross-referenced to Drawings, both on floor plans and in door and frame schedule.
      - 6) Explanation of abbreviations, symbols, and codes contained in schedule.
      - 7) Mounting locations for door hardware.
      - 8) Door and frame sizes and materials.
      - 9) List of related door devices specified in other Sections for each door and frame.
    - d. Submittal Sequence: Submit the final door hardware sets at earliest possible date, particularly where approval of the door hardware sets must precede fabrication of other work that is critical in Project construction schedule. Include Product Data, Samples, Shop Drawings of other work affected by door hardware, and other information essential to the coordinated review of the door hardware sets.
  - 2. Keying Schedule: Prepared by or under the supervision of Installer's Architectural Hardware Consultant, detailing Owner's final keying instructions for locks. Include schematic keying diagram and index each key set to unique door designations.

#### 1.4 QUALITY ASSURANCE

- A. Installer Qualifications: An employer of workers trained and approved by lock manufacturer.
  - 1. Installer's responsibilities include supplying and installing door hardware and providing a qualified Architectural Hardware Consultant available during the course of the Work to consult with Contractor, Architect, and Owner about door hardware and keying.
  - 2. Installer shall have warehousing facilities in Project's vicinity.
  - 3. Scheduling Responsibility: Preparation of door hardware and keying schedules.
  - 4. Engineering Responsibility: Preparation of data for electrified door hardware, including Shop Drawings, based on testing and engineering analysis of manufacturer's standard units in assemblies similar to those indicated for this Project.

- B. Architectural Hardware Consultant Qualifications: A person who is currently certified by DHI as an Architectural Hardware Consultant and who is experienced in providing consulting services for door hardware installations that are comparable in material, design, and extent to that indicated for this Project.
- C. Source Limitations: Obtain each type and variety of door hardware from a single manufacturer, unless otherwise indicated.
- D. Fire-Rated Door Assemblies: Assemblies complying with NFPA 80, 2007 edition that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire ratings indicated, based on testing according to NFPA 252, 2003 edition.
  - 1. Test Pressure: After 5 minutes into the test, neutral pressure level in furnace shall be established at 40 inches (1016 mm) or less above the sill.
- E. Keying Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination." In addition to Owner, Contractor, and Architect, conference participants shall also include Installer's Architectural Hardware Consultant and Owner's security consultant. Incorporate keying conference decisions into final keying schedule after reviewing door hardware keying system including, but not limited to, the following:
  - 1. Function of building, flow of traffic, purpose of each area, degree of security required, and plans for future expansion.
  - 2. Preliminary key system schematic diagram.
  - 3. Requirements for key control system.
  - 4. Address for delivery of keys.
- F. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination."

#### 1.5 DELIVERY, STORAGE, AND HANDLING

- A. Inventory door hardware on receipt and provide secure lock-up for door hardware delivered to Project site.
- B. Tag each item or package separately with identification related to the final door hardware sets, and include basic installation instructions, templates, and necessary fasteners with each item or package.
- C. Deliver keys to manufacturer of key control system for subsequent delivery to Owner.
- D. Deliver keys and permanent cores to Owner by registered mail or overnight package service.
  - 1. Verify Name and Address of person to receive keys with owner.

#### 1.6 COORDINATION

- A. Templates: Distribute door hardware templates for doors, frames, and other work specified to be factory prepared for installing door hardware. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing door hardware to comply with indicated requirements.

1.7 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of door hardware that fail in materials or workmanship within specified warranty period.
  - 1. Failures include, but are not limited to, the following:
    - a. Structural failures including excessive deflection, cracking, or breakage.
    - b. Faulty operation of operators and door hardware.
    - c. Deterioration of metals, metal finishes, and other materials beyond normal weathering and use.
  - 2. Warranty Period: Three years from date of Substantial Completion, except as follows:
    - a. Exit Devices: Two years from date of Substantial Completion.
    - b. Manual Closers: 10 years from date of Substantial Completion.

1.8 MAINTENANCE SERVICE

- A. Maintenance Tools and Instructions: Furnish a complete set of specialized tools and maintenance instructions as needed for Owner's continued adjustment, maintenance, and removal and replacement of door hardware.
- B. Maintenance Service: Beginning at Substantial Completion, provide six months' full maintenance by skilled employees of door hardware Installer. Include quarterly preventive maintenance, repair or replacement of worn or defective components, lubrication, cleaning, and adjusting as required for proper door hardware operation. Provide parts and supplies same as those used in the manufacture and installation of original products.

PART 2 - PRODUCTS

2.1 SCHEDULED DOOR HARDWARE

- A. General: Provide door hardware for each door to comply with requirements in this Section and door hardware sets indicated in Part 3 "Door Hardware Sets" Article.
  - 1. Door Hardware Sets: Provide quantity, item, size, finish or color indicated, and named manufacturers' products.
- B. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by the manufacturers specified.

2.2 HINGES, GENERAL

- A. Quantity: Provide the following, unless otherwise indicated:
  - 1. Three Hinges: For doors with heights 61 to 90 inches (1549 to 2286 mm).
- B. Template Requirements: Except for hinges and pivots to be installed entirely (both leaves) into wood doors and frames, provide only template-produced units.

- C. Hinge Weight: Unless otherwise indicated, provide the following:
  - 1. Entrance Doors: Heavy-weight hinges.
  - 2. Interior Doors: Standard-weight hinges for openings to 40 inches wide.
  - 3. Interior Doors: Heavy-weight hinges for openings over 40 inches wide.
  
- D. Hinge Base Metal: Unless otherwise indicated, provide the following:
  - 1. Exterior Hinges: Stainless steel, with stainless-steel pin.
  - 2. Interior Hinges: Stainless steel, with stainless-steel pin.
  - 3. Hinges for Fire-Rated Assemblies: Stainless steel, with stainless-steel pin.
  
- E. Hinge Options: Where indicated in door hardware sets or on Drawings:
  - 1. Tips: Flat bottom and matching plug, finished to match leaves.
  - 2. Nonremovable Pins: Provide set screw in hinge barrel that, when tightened into a groove in hinge pin, prevents removal of pin while door is closed.
  
- F. Fasteners: Comply with the following:
  - 1. Screws: Phillips flat-head; machine screws (drilled and tapped holes) for metal doors and wood screws for wood doors and frames. Finish screw heads to match surface of hinges.
    - a. Provide pinned Torx-Plus or pinned Torx drive type fasteners at door hardware for doors and frames located in inmate accessible areas. Administration and visitation areas are the only areas not accessible to inmates.

## 2.3 HINGES

- A. Butts and Hinges: BHMA A156.1.
  
- B. Template Hinge Dimensions: BHMA A156.7.
  
- C. Manufacturers:
  - 1. Baldwin Hardware Corporation (BH).
  - 2. Bommer Industries, Inc. (BI).
  - 3. Cal-Royal Products, Inc. (CRP).
  - 4. Hager Companies (HAG).
  - 5. Lawrence Brothers, Inc. (LB).
  - 6. McKinney Products Company; an ASSA ABLOY Group company (MCK).
  - 7. PBB, Inc. (PBB).
  - 8. Stanley Commercial Hardware; Div. of The Stanley Works (STH).
  
- D. Antifriction-Bearing, Full-Mortise (Butt) Hinges: BHMA A156.1
  - 1. Heavy weight; Grade 1, with 4 ball bearings
  - 2. Standard weight; Grade 2, with 2 ball bearings
  - 3. Hinge Options:
    - a. Tips: Flat bottom and matching plug, finished to match leaves.
    - b. Nonremovable Pins.
  - 4. Base Metal: Stainless steel.

2.4 LOCKS AND LATCHES, GENERAL

- A. Accessibility Requirements: Where indicated to comply with accessibility requirements, comply with the U.S. Architectural & Transportation Barriers Compliance Board's "Americans with Disabilities Act (ADA), Accessibility Guidelines for Buildings and Facilities (ADAAG)."
1. Provide operating devices that do not require tight grasping, pinching, or twisting of the wrist and that operate with a force of not more than 5 lbf (22 N).
- B. Latches and Locks for Means of Egress Doors: Comply with NFPA 101. Latches shall not require more than 15 lbf (67 N) to release the latch. Locks shall not require use of a key, tool, or special knowledge for operation.
- C. Lock Trim:
1. Levers: Forged.
    - a. Schlage, L Series 06 Lever
    - b. ~~Sargent Manufacturing Company, Standard J Lever~~
    - c. ~~Yale Commercial Locks and Hardware, Carmel CRSL Lever~~
  2. Escutcheons (Roses): Forged.
  3. Dummy Trim: Match lever lock trim and escutcheons.
  4. Lockset Designs:
    - a. Schlage; L9000 Series
    - b. ~~Sargent Manufacturing Company; 8200 Lever Lock.~~
    - c. ~~Yale Commercial Locks and Hardware; 8800 Series.~~
  5. Security Lockset Designs:
    - a. Schlage; LV9000 Series
    - b. ~~Sargent Manufacturing Company; 8200 FE Lever Lock with freewheeling trim.~~
    - c. ~~Yale Commercial Locks and Hardware; SL8800 Series.~~
- D. Lock Throw: Comply with testing requirements for length of bolts required for labeled fire doors, and as follows:
1. Mortise Locks: Minimum 3/4-inch (19-mm) latchbolt throw.
  2. Deadbolts: Minimum 1-inch (25-mm) bolt throw.
- E. Backset: 2-3/4 inches (70 mm), unless otherwise indicated.
- F. Rabbeted Meeting Doors: Provide special rabbeted front and strike on locksets for rabbeted meeting stiles.
- G. Strikes: Manufacturer's standard strike with strike box for each latchbolt or lock bolt, with curved lip extended to protect frame, finished to match door hardware set, and as follows:
1. Strikes for Mortise Locks and Latches: BHMA A156.13.
  2. Strikes for Auxiliary Deadlocks: BHMA A156.5.

2.5 MECHANICAL LOCKS AND LATCHES

- A. Lock Functions: Function numbers and descriptions indicated in door hardware sets comply with the following:
1. Mortise Locks: BHMA A156.13.



- B. Mortise Locks: Stamped steel case with steel or brass parts; BHMA A156.13, Grade 1; Series 1000. Security locksets to also meet security grade 1.
  - 1. Manufacturers and respective products:
    - a. Schlage; LV9000 Series.
    - b. ~~SARGENT Manufacturing Company; an ASSA ABLOY Group company (SGT); 8200/8200 FE Series.~~
    - c. ~~Yale Commercial Locks and Hardware; an ASSA ABLOY Group company (YAL); 8800/SL8800 Series.~~

## 2.6 AUXILIARY LOCKS AND LATCHES

- A. Auxiliary Locks: BHMA A156.5, Grade 1.
  - 1. Manufacturers:
    - a. Schlage
    - b. ~~SARGENT Manufacturing Company; an ASSA ABLOY Group company (SGT).~~
    - c. ~~Yale Commercial Locks and Hardware; an ASSA ABLOY Group company (YAL).~~

## 2.7 EXIT DEVICES

- A. Exit Devices: BHMA A156.3, Grade 1.
- B. Accessibility Requirements: Where handles, pulls, latches, locks, and other operating devices are indicated to comply with accessibility requirements, comply with the U.S. Architectural & Transportation Barriers Compliance Board's "Americans with Disabilities Act (ADA), Accessibility Guidelines for Buildings and Facilities (ADAAG)."
  - 1. Provide operating devices that do not require tight grasping, pinching, or twisting of the wrist and that operate with a force of not more than 5 lbf (22 N).
- C. Exit Devices for Means of Egress Doors: Comply with latest edition of NFPA 101. Exit devices shall not require more than 15 lbf (67 N) to release the latch. Locks shall not require use of a key, tool, or special knowledge for operation.
- D. Panic Exit Devices: Listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for panic protection, based on testing according to UL 305.
- E. Fire Exit Devices: Devices complying with latest edition of NFPA Standard 80 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire and panic protection, based on testing according to UL 305 and latest edition of NFPA 252.
- F. Outside Trim: Lever with cylinder; material and finish to match locksets, unless otherwise indicated.
  - 1. Match design for locksets and latchsets, unless otherwise indicated.
- G. Through Bolts: For exit devices and trim on doors.
- H. Manufacturers:
  - 1. Precision Hardware, Inc. (PH).
  - 2. SARGENT Manufacturing Company; an ASSA ABLOY Group company (SGT).

3. Von Duprin; an Ingersoll-Rand Company (VD).
4. Yale Commercial Locks and Hardware; an ASSA ABLOY Group company (YAL).

2.8 Mortise Exit Devices:

- A. Type: BHMA A156.3, Type 3.
- B. Actuating Bar: Push pad.
- C. Material: Brass or Bronze.

2.9 LOCK CYLINDERS

- A. Standard Lock Cylinders: BHMA A156.5, Grade 1.
- B. Cylinders: Manufacturer's standard tumbler type, constructed from brass or bronze, stainless steel, or nickel silver, and complying with the following:
  1. Number of Pins: Seven.
  2. Mortise Type: Threaded cylinders with rings and straight- or clover-type cam.
  3. Rim Type: Cylinders with back plate, flat-type vertical or horizontal tailpiece, and raised trim ring.
- C. Permanent Cores: Manufacturer's standard; finish face to match lockset; complying with the following:
  1. Interchangeable Cores: Core insert, removable by use of a special key; usable with other manufacturers' cylinders.
  2. Stamping: Permanently inscribe each permanent core with a visual key control number and include the following notation:
    - a. Notation: "DO NOT DUPLICATE." These visual key control marks or codes will not include the actual key cuts.
- D. Construction Keying: Comply with the following:
  1. Construction Cores: Provide construction cores that are replaceable by permanent cores. Provide 10 construction master keys.
    - a. Furnish permanent cores to Owner for installation.
- E. Manufacturer: Schlage Removable core high security locksets.

2.10 KEYING

- A. Keying System: Factory registered, complying with guidelines in BHMA A156.28, Appendix A. Incorporate decisions made in keying conference, and as follows:
  1. Great-Grand Master Key System: Cylinders are operated by a change key, a master key, a grand master key, and a great-grand master key.

- B. Keys: Nickel silver.
  - 1. Stamping: Permanently inscribe each key with a visual key control number and include the following notation:
    - a. Notation: "DO NOT DUPLICATE." These visual key control marks or codes will not include the actual key cuts.
  - 2. Quantity: In addition to one extra key blank for each lock, provide the following:
    - a. Cylinder Change Keys: Three.
    - b. Master Keys: Two
    - c. Grand Master Keys: Two
    - d. Great-Grand Master Keys: Two
    - e. Construction Master Keys: Six each

## 2.11 KEY CONTROL SYSTEM

- A. Key Control Cabinet: BHMA A156.5, Grade 1; metal cabinet with baked-enamel finish; containing key-holding hooks, labels, 2 sets of key tags with self-locking key holders, key-gathering envelopes, and temporary and permanent markers; with key capacity of 150 percent of the number of locks.
  - 1. Wall-Mounted Cabinet: Cabinet with hinged-panel door equipped with key-holding panels and pin-tumbler cylinder door lock.
  - 2. Available Manufacturers:
    - a. Key control Systems, Inc.
    - b. Lund Equipment Co., Inc.
    - c. MMF Industries.
    - d. Sunroc Corporation.

## 2.12 CLOSERS, GENERAL

- A. Accessibility Requirements: Where handles, pulls, latches, locks, and other operating devices are indicated to comply with accessibility requirements, comply with the U.S. Architectural & Transportation Barriers Compliance Board's "Americans with Disabilities Act (ADA), Accessibility Guidelines for Buildings and Facilities (ADAAG)."
  - 1. Comply with the following maximum opening-force requirements:
    - a. Interior, Non-Fire-Rated Hinged Doors: 5 lbf (22.2 N) applied perpendicular to door.
    - b. Fire Doors: Minimum opening force allowable by authorities having jurisdiction.
- B. Door Closers for Means of Egress Doors: Comply with NFPA 101. Door closers shall not require more than 30 lbf (133 N) to set door in motion and not more than 15 lbf (67 N) to open door to minimum required width.
- C. Size of Units: Unless otherwise indicated, comply with manufacturer's written recommendations for size of door closers depending on size of door, exposure to weather, and anticipated frequency of use. Provide factory-sized closers, adjustable to meet field conditions and requirements for opening force.
- D. Surface Closers: BHMA A156.4, Grade 1. Provide parallel arm type with brackets as required for closer to be located on non-public side of door, unless otherwise indicated.
  - 1. Manufacturers and respective products:

- a. LCN Closers; an Ingersoll-Rand Company (LCN); 4110 Series.
- b. SARGENT Manufacturing Company; an ASSA ABLOY Group company (SGT);

E. Coordinators: BHMA A156.3.

## 2.13 CLOSERS

- A. Traditional Surface Closers: Rack-and-pinion hydraulic type; with adjustable sweep and latch speeds controlled by key-operated valves; with forged-steel main arm; enclosed in a cast-aluminum alloy shell; complying with the following:
  - 1. Mounting: Opposite hinge side (Push side).
  - 2. Type: Parallel Arm.
    - a. Delayed action closing where indicated.
  - 3. Backcheck: Adjustable, effective between 60 and 85 degrees of door opening.

## 2.14 PROTECTIVE TRIM UNITS, GENERAL

- A. Size: 1-1/2 inches (38 mm) less than door width on push side and 1/2 inch (13 mm) less than door width on pull side, by height specified in door hardware sets.
- B. Fasteners: Manufacturer's standard machine or self-tapping screws.
- C. Metal Protective Trim Units: BHMA A156.6; beveled top and 2 sides; fabricated from the following material:
  - 1. Material: 0.050-inch- (1.3-mm-) thick stainless steel.
  - 2. Manufacturers:
    - a. American Floor Products Co., Inc. (AFP).
    - b. Baldwin Hardware Corporation (BH).
    - c. Hager Companies (HAG).
    - d. Hiawatha, Inc. (HIA).
    - e. IPC Door and Wall Protection Systems, Inc.; Div. of InPro Corporation (IPC).
    - f. IVES Hardware; an Ingersoll-Rand Company (IVS).
    - g. Pawling Corporation (PAW).
    - h. Rockwood Manufacturing Company (RM).
    - i. Trimco (TBM).

## 2.15 PROTECTIVE TRIM UNITS

- A. Kick Plates: 12 inches (305 mm) high by door width, with allowance for frame stops.

## 2.16 STOPS AND HOLDERS

- A. Stops and Bumpers: BHMA A156.16, Grade 1.
  - 1. Provide wall stops for doors unless other type stops are scheduled or indicated. Where floor or wall stops are not appropriate, provide overhead holders.
- B. Combination Overhead Stops and Holders: BHMA A156.8, Grade 1.

- C. Manufacturers:
1. Glynn-Johnson; an Ingersoll-Rand Company (GJ).
  2. Hager Companies (HAG).
  3. Hiawatha, Inc. (HIA).
  4. IVES Hardware; an Ingersoll-Rand Company (IVS).
  5. Rixson Specialty Door Controls; an ASSA ABLOY Group company (RIX).
  6. Rockwood Manufacturing Company (RM).
  7. SARGENT Manufacturing Company; an ASSA ABLOY Group company (SGT).
  8. Stanley Commercial Hardware; Div. of The Stanley Works (STH).
  9. Trimco (TBM).

2.17 STOPS

- A. Wall Bumpers: Polished cast brass or aluminum with rubber bumper; 2-1/2-inch (64-mm) diameter, minimum 3/4-inch (19-mm) projection from wall, with backplate for concealed fastener installation; with convex bumper configuration.

2.18 OVERHEAD STOPS

- A. Overhead Surface-Mounted, Concealed Slide Stops: BHMA A156.8, Type 2; release by push and pull of door unless control is set in inactive position; with stop and shock absorber; adjustable holding pressure; for single-acting doors opening 110 degrees.

2.19 DOOR GASKETING

- A. Standard: BHMA A156.22.
- B. General: Provide continuous weather-strip gasketing on exterior doors and provide smoke, light, or sound gasketing on interior doors where indicated or scheduled. Provide noncorrosive fasteners for exterior applications and elsewhere as indicated.
1. Perimeter Gasketing: Apply to head and jamb, forming seal between door and frame.
- C. Air Leakage: Not to exceed 0.50 cfm per foot (0.000774 cu. m/s per m) of crack length for gasketing other than for smoke control, as tested according to ASTM E 283.
- D. Smoke-Labeled Gasketing: Assemblies complying with NFPA 105 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for smoke-control ratings indicated, based on testing according to UL 1784.
1. Provide smoke-labeled gasketing on 20-minute-rated doors and on smoke-labeled doors.
- E. Fire-Labeled Gasketing: Assemblies complying with NFPA 80 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire ratings indicated, based on testing according to NFPA 252.
1. Test Pressure: After 5 minutes into the test, neutral pressure level in furnace shall be established at 40 inches (1016 mm) or less above the sill.
- F. Gasketing Materials: ASTM D 2000 and AAMA 701/702.

- G. Manufacturers:
  - 1. Hager Companies (HAG).
  - 2. National Guard Products (NGP).
  - 3. Pemko Manufacturing Co. (PEM).
  - 4. Reese Enterprises (RE).
  - 5. Sealeze; a unit of Jason Incorporated (SEL).
  - 6. Zero International (ZRO).

## 2.20 THRESHOLDS

- A. Standard: BHMA A156.21.
- B. Accessibility Requirements: Where thresholds are indicated to comply with accessibility requirements, comply with the U.S. Architectural & Transportation Barriers Compliance Board's "Americans with Disabilities Act (ADA), Accessibility Guidelines for Buildings and Facilities (ADAAG)."
  - 1. Bevel raised thresholds with a slope of not more than 1:2. Provide thresholds not more than 1/2 inch (13 mm) high.
- C. Thresholds for Means of Egress Doors: Comply with NFPA 101. Maximum 1/2 inch (13 mm) high.
- D. Manufacturers:
  - 1. Hager Companies (HAG).
  - 2. National Guard Products (NGP).
  - 3. Pemko Manufacturing Co. (PEM).
  - 4. Reese Enterprises (RE).
  - 5. Sealeze; a unit of Jason Incorporated (SEL).
  - 6. Zero International (ZRO).

## 2.21 FABRICATION

- A. Base Metals: Produce door hardware units of base metal, fabricated by forming method indicated, using manufacturer's standard metal alloy, composition, temper, and hardness. Furnish metals of a quality equal to or greater than that of specified door hardware units and BHMA A156.18. Do not furnish manufacturer's standard materials or forming methods if different from specified standard.
- B. Fasteners: Provide door hardware manufactured to comply with published templates generally prepared for machine, wood, and sheet metal screws. Provide screws according to commercially recognized industry standards for application intended, except aluminum fasteners are not permitted. Provide Phillips flat-head screws with finished heads to match surface of door hardware, unless otherwise indicated.
  - 1. Steel Machine or Wood Screws: For the following fire-rated applications:
    - a. Mortise hinges to doors.
    - b. Strike plates to frames.
    - c. Closers to doors and frames.
  - 2. Steel Through Bolts: For the following fire-rated applications unless door blocking is provided:

- a. Surface hinges to doors.
- b. Closers to doors and frames.
- c. Surface-mounted exit devices.
3. Spacers or Sex Bolts: For through bolting of hollow-metal doors.
4. (ASI-3) Provide pinned Torx-Plus or pinned Torx drive type fasteners at door hardware for doors and frames located in inmate accessible areas. Administration and visitation areas are the only areas not accessible to inmates.

## 2.22 FINISHES

- A. Standard: BHMA A156.18.
  1. Finish and Base Metal Table: (BHMA/US number).

a. Hinges:	630-US32D on stainless steel.
b. Exit Devices:	626-US26D on brass or bronze.
c. Locks:	630-US32D on stainless steel.
d. Pulls and Push Plates/Bars:	630-US32D on stainless steel.
e. Coordinators:	600-USP on steel.
f. Closers:	689-Sprayed AL.
g. Protective Plates:	630-US32D on stainless steel.
h. Overhead Stops:	626-US26D on brass, bronze, or steel.
i. Stops	626-US26D on brass or bronze or.
j. Thresholds:	Mill Aluminum.
k. Weatherstrips and Sweeps:	628-Clear anodized aluminum.
l. Cabinets:	Enamel on steel.
m. Miscellaneous:	626-US26D on brass or bronze, 630-US32D on stainless steel..
- B. Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.
- C. Appearance of Finished Work: Variations in appearance of abutting or adjacent pieces are acceptable if they are within one-half of the range of approved Samples. Noticeable variations in the same piece are not acceptable. Variations in appearance of other components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine doors and frames, with Installer present, for compliance with requirements for installation tolerances, labeled fire door assembly construction, wall and floor construction, and other conditions affecting performance.
- B. Examine roughing-in for electrical power systems to verify actual locations of wiring connections before electrified door hardware installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. Steel Doors and Frames: Comply with DHI A115 Series.
  - 1. Surface-Applied Door Hardware: Drill and tap doors and frames according to ANSI A250.6.
- B. Wood Doors: Comply with DHI A115-W Series.

### 3.3 INSTALLATION

- A. Mounting Heights: Mount door hardware units at heights indicated as follows unless otherwise indicated or required to comply with governing regulations.
  - 1. Standard Steel Doors and Frames: DHI's "Recommended Locations for Architectural Hardware for Standard Steel Doors and Frames."
  - 2. Wood Doors: DHI WDHS.3, "Recommended Locations for Architectural Hardware for Wood Flush Doors."
- B. Install each door hardware item to comply with manufacturer's written instructions. Where cutting and fitting are required to install door hardware onto or into surfaces that are later to be painted or finished in another way, coordinate removal, storage, and reinstallation of surface protective trim units with finishing work specified in Division 09 Sections. Do not install surface-mounted items until finishes have been completed on substrates involved.
  - 1. Set units level, plumb, and true to line and location. Adjust and reinforce attachment substrates as necessary for proper installation and operation.
  - 2. Drill and countersink units that are not factory prepared for anchorage fasteners. Space fasteners and anchors according to industry standards.
- C. Key Control System: Tag keys and place them on markers and hooks in key control system cabinet, as determined by final keying schedule.
- D. Thresholds: Set thresholds for exterior doors in full bed of sealant complying with requirements specified in Division 07 Section "Joint Sealants."
- E. Door Hardware located in inmate accessible areas: Install door hardware with pinned Torx-Plus or pinned Torx drive type fasteners. Administration and Visitation areas are the only areas not accessible to inmates."

### 3.4 ADJUSTING

- A. Initial Adjustment: Adjust and check each operating item of door hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate as intended. Adjust door control devices to compensate for final operation of heating and ventilating equipment and to comply with referenced accessibility requirements.
  - 1. Spring Hinges: Adjust to achieve positive latching when door is allowed to close freely from an open position of 30 degrees.
  - 2. Door Closers: Unless otherwise required by authorities having jurisdiction, adjust sweep period so that, from an open position of 70 degrees, the door will take at least 3 seconds to move to a point 3 inches (75 mm) from the latch, measured to the leading edge of the door.



- B. Occupancy Adjustment: Approximately six months after date of Substantial Completion, Installer's Architectural Hardware Consultant shall examine and readjust, including adjusting operating forces, each item of door hardware as necessary to ensure function of doors, door hardware, and electrified door hardware.

3.5 CLEANING AND PROTECTION

- A. Clean adjacent surfaces soiled by door hardware installation.
- B. Clean operating items as necessary to restore proper function and finish.
- C. Provide final protection and maintain conditions that ensure that door hardware is without damage or deterioration at time of Substantial Completion.

3.6 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain door hardware and door hardware finishes. Refer to Division 01 Section "Demonstration and Training."

3.7 DOOR HARDWARE SCHEDULE

- A. HW-1:
  - Hinges
  - Latchset
  - StopF01 - Passage
- B. HW-2:
  - Hinges
  - Latchset
  - Closer
  - StopF01 - Passage
- C. HW-3:
  - Hinges
  - Lockset
  - Closer
  - StopF05 - Classroom
- D. HW-4:
  - Hinges
  - Lockset
  - Closer
  - StopF05 - Classroom

- E. HW-5:
  - Hinges
  - Lockset
  - Stop
  - Protective PlateF07 - Storeroom
  
- F. HW-6:
  - Hinges
  - Lockset
  - Closer - Delayed Action
  - Stop
  - Protective PlateF07 - Storeroom
  
- G. HW-7:
  - Hinges
  - Lockset
  - StopF19 - Privacy
  
- H. HW-8:
  - Hinges
  - Lockset
  - Closer
  - StopF19 - Privacy
  
- I. HW-9:
  - Hinges
  - Lockset
  - Closer
  - Stop
  - Protective PlateF07 - Storeroom
  
- J. HW-10:
  - Hinges
  - Push Plate
  - Pull
  - Closer
  - Stop
  
- K. HW-11:
  - Hinges
  - Lockset
  - Electric Strike
  - StopF07 - Storeroom  
Operation: Electric strike to be controlled by control station
  
- L. HW12:
  - Hinges
  - Lockset
  - Electric Strike
  - CloserF07 - Storeroom  
Operation: Electric strike to be controlled by control station

Stop

- M. HW-13:  
Hinged  
Panic device                      Lever function  
Closer  
Cylinder  
Stop
- N. HW-20:  
Hinges  
Vandal Resistant Latchset      F01 - Passage  
Closer  
Stop
- O. HW-21:  
Hinges  
Vandal Resistant Lockset      F05 - Classroom  
Closer  
Stop
- P. HW-22:  
Hinges  
Vandal Resistant Lockset      F05 - Classroom  
Closer  
Stop
- Q. HW-23:  
Hinges  
Panic Device  
Vandal Resistant Latchset      F-1 – Passage  
Closer  
Stop
- R. HW-24:  
Hinges  
Panic Device  
Vandal Resistant Lockset      F05 – Classroom  
Closer  
Stop
- S. HW-25:  
Hinges  
Vandal Resistant Lockset      F07 - Storeroom  
Stop

- T. HW-26:
  - Hinges
  - Vandal Resistant Lockset F07 - Storeroom
  - Closer
  - Stop
  - Protective Plate
  
- U. HW-27:
  - Hinges
  - Vandal Resistant Lockset
  - Closer – Delayed Action
  - Stop
  - Protective Plate
  
- V. HW-28: Not Used
  
- W. HW-29:
  - Hinges
  - Vandal Resistant Lockset F01 - Passage
  - Closers – Delayed Action
  - Stops
  - 36 inch (915 mm) high Protective Plates - Each Side
  - Auto Flush Bolts
  - Door Coordinator
  
- X. HW-30: Double Egress Door Assembly with magnetic locks
  - Hinges
  - Vandal Resistant Lockset F01 – Passage
  - Closers – Delayed Action
  - Stops
  - 36 inch (915mm) high Protective Plates – Each Side
  - Door Coordinator
  - Panic Devices
  
- Y. HW-31: Not Used

- Z. HW-32:  
Hinges  
Panic Device                      Lever Function  
Closer – Delayed action  
Cylinder  
Stop  
Protective Plate
- AA. HW-33:  
Hinges  
Panic Device                      Lever Function  
Panic Device                      Exit only  
Closer – delayed action  
Cylinder  
Stops  
Auto Flush Bolts  
Door Coordinator  
36” High Protective Plates – Each Side
- BB. HW-40:  
Cylinder  
Panic Device                      Lever Function  
Closer  
Threshold  
Stop  
Remainder of hardware by door manufacturer  
Exit only under fire alarm
- CC. HW-41:  
Cylinder  
Lockset                              F05 Classroom  
Stop  
Remainder of hardware by door manufacturer
- DD. HW-42:  
Cylinder  
Panic Device                      Lever Function  
Panic Device                      Exit Only Function  
Closers  
Threshold  
Floor Stops  
Remainder of hardware by door manufacturer
- EE. HW-43:  
Push Plate  
Lockset                              Lever Function  
Pull  
Closers

Floor Stop and hold @ doors 111A building 1A & 1B, 113A building 02, 111A building 3  
Magnetic Hold Open @ doors 131A building 1A & 1B, 133A building 02, 119 building 03  
Remainder of hardware by door manufacturer

FF. HW-50:

Hinges  
Vandal Resistant Locket      F05 – Classroom  
Closer  
Weatherstripping  
Threshold  
Stop

GG. HW-51:

Hinges  
Vandal Resistant Lockset      F07 – Storeroom  
Closer  
Weatherstripping  
Threshold  
Stop

HH. HW-52:

Hinges (gate)  
Panic Device      Lever Function – exit only  
Closer – Delayed Action  
Electric Strike

II. HW-53:

Hinges  
Vandal Resistant Lockset      F05 - Classroom  
Closer  
Panic Device  
Stop

- JJ. HW-54:  
Hinges  
Vandal Resistant Lockset F07 – Storeroom  
Closer – Delayed Action  
Weatherstripping  
Threshold  
Stop  
Raincap
- KK. HW-55:  
Hinges  
Door Position Switch  
Closer – Delayed Action  
Weatherstripping  
Threshold  
Stop  
Panic Device Lever Function
- LL. HW-56:  
Hinges  
Vandal Resistant Lockset F07 – Storeroom  
Closers  
Door Coordinator  
Auto Flush Bolts  
Weatherstripping  
Threshold  
Stops  
Rain Cap
- MM. HW-57: Exterior Gate  
Vandal Resistant Lock set F07 – Storeroom  
Panic Device @ non-juvenile side, one way emergency egress only
- NN. HW-58: Not Used
- OO. HW-70:  
Cylinder  
Mortise cylinder for Wire Mesh Partitions  
Mortise type cylinder lock by partition manufacturer  
See Division 10 Section “Wire Mesh Partitions”
- PP. HW-71:  
Cylinder  
Mortise cylinder for Non-Security Access Doors  
Mortise type cylinder lock by access door manufacturer  
See Division 08 Section “ Access Doors and Frames”
- QQ. HW-72:  
Deadbolt  
Mortise Deadbolt for Security Fire Protection Cabinets  
See Division 10 Section “Fire Extinguisher Cabinets”

END OF SECTION 08 7100





## SECTION 087163 – DETENTION DOOR HARDWARE

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and provisions of contract, including General and Supplementary Conditions and Division 1 specification Sections apply to Work in this Section.
- B. Section 013513.16, “Special Project Procedures for Detention Facilities”.

#### 1.2 SUMMARY

- A. This Section includes the following:
  - 1. Electrical and Mechanical Security Hardware for Swinging Doors and Gates.
  - 2. Sliding Devices
  - 3. Miscellaneous Hardware for Security Doors
  - 4. Hardware Schedule for Security Doors.

#### 1.3 SCOPE AND RESPONSIBILITIES

- A. Under the requirements of this specification, the DEC shall be responsible for furnishing and installing all hardware as specified, in all locations.

#### 1.4 SUBMITTALS

- A. General: Submit the following according to Conditions of the Contract and Division 1 Specification Sections. All submittals shall be supplied on USB drive.
- B. Product Data: Manufacturer's printed product data and catalog cuts indicating product characteristics, performance and limiting criteria.
- C. Shop Drawings: For each type of hardware item: Include plans, wiring diagrams, method of construction, installation and attachment details and other information necessary to show compliance with requirements.
- D. It is the DEC's responsibility to coordinate detention/security items in this scope of work, and to answer all manufacturer questions or concerns that are not strictly design related. The DEC shall redline the manufacturers' individual shop drawings and/or schedules, and note corrections prior to submittal for Architectural/Consultant review. When multiple items are submitted by the manufacturer on a single cutsheet, the DEC shall note with an arrow, circle or note cloud, to show which product on the sheet is submitted for this scope of work. DEC submittals not reviewed and redlined prior to submittal to Architect/Consultant for final review, will be returned rejected.

- E. Samples: Provide samples of each item of security hardware item as requested by the Architect-Engineer. Samples shall be shipped as directed, to the location as directed, and shall be shipped within 10 days of receipt of notification of the requirement to provide samples. In addition, if required, provide hardware for all mockups. All mockups shall be fully functional, wired to temporary switches prior to Architect-Consultant's inspection.
- F. Hardware schedule coordinated with doors, frames, and related work to ensure proper size, thickness, hand and function of door hardware.
1. Hardware Schedule Content: Based on hardware indicated, organize schedule into "hardware sets" indicating complete designations of every item required for each door or opening. Include the following information:
    - a. Type, style, exact function, size, and finish of each hardware item.
    - b. Name and manufacturer of each item.
    - c. Fastenings and other pertinent information.
    - d. Location of each hardware set cross-referenced to indications on Drawings both on floor plans and in door and frame schedule.
      - 1) Door numbers and frame types in schedule to match door numbers and frame types shown on Drawings.
      - 2) Hardware sets shall match specified hardware sets found at the end of this specification section. Hardware set extensions (i.e.: "SH1.a") used to signify hardware sets with additional hardware requirements are acceptable.
    - e. Explanation of all abbreviations, symbols, and codes contained in schedule.
    - f. Mounting locations for hardware.
    - g. Door and frame sizes and materials.
  2. Submittal Sequence: Submit schedule at earliest possible date, particularly where acceptance of Hardware Schedule must precede fabrication of other work that is critical in the Project construction schedule. Include with schedule the product data, shop drawings of other work affected by door hardware, and other information essential to the coordinated review of schedule.
  3. Fire Rated Openings: Provide hardware for fire-rated openings in compliance with NFPA Standard 80. This requirement takes precedence over other requirements for such hardware. Provide only hardware which has been tested and listed by UL bears appropriate label or symbol for the types and sizes of doors required and compliance with the requirements of the required label and function of the opening wherever possible.
- G. Keying Schedule: The owner shall provide an approved key schedule to the DEC at the time of detention hardware submittal review.
- H. Submittal of written confirmation from the hardware manufacturer showing individual field technicians as approved installers shall be required.
- I. Operating/Maintenance Manuals: Furnish O&M Manuals, as outlined in Division 1, for all security hardware and all security locking devices. Provide detailed parts lists and cutsheets for all items with mechanical moving parts or electrical components on the approved security hardware schedule. These manuals shall include instructions for the care of the materials, parts list to aid the Owner in ordering replacement parts, as well as instructions for contacting the appropriate personnel not only during the warranty period, but beyond. Manuals shall also include the final approved key schedule and "as built" shop drawings of all components. The Detention Equipment Contractor must have full time employees trained in the maintenance and repair of this equipment.

### 1.5 DELIVERY, STORAGE AND HANDLING

- A. Packing and Marking: Each piece of security hardware furnished under this Section shall be packaged and marked according to the hardware set and door number listed in the approved hardware schedule.
- B. Deliver all components cartoned or crated to provide protection during transit and job storage.
- C. Inspect all components upon delivery for damage. Damages may be repaired, provided the repaired items are equal in all respects to new work and acceptable to the Architect-Engineer; otherwise, remove and replace damaged items as directed.
- D. Store all components in a locked storage area for all components deemed necessary by the Detention Equipment Contractor. Do not store any materials directly on the ground or concrete. Provide adequate ventilation and protection to insure materials are kept dry, clean and secure. Store all materials in the manner and order as prescribed by the Detention Equipment Contractor and/or manufacturer.

### 1.6 COORDINATION

- A. Examine the drawings and specifications of other trades whose work may influence the installation and/or operation of the detention hardware. Prior to the start of work, review the project drawings and specifications and coordinate work with all other trades and Divisions of the Specifications affecting Work of this Section.
  - 1. Responsibilities for electrical and mechanical hardware installation shall include the following:
    - a. Furnish and install door locks, door position switches, limit switches, lock feature switches and push buttons, as required for the system to perform the functions as defined in the "Door Control" section of the Division 28 specifications.
    - b. Coordinate the integration and interfacing of the products and equipment specified in this section with Division 28 (SSI) specified, and in accordance with shop drawings and submittals approved by the Architect / Consultant.
    - c. Review all control submittals submitted by Division 28 (SSI) and confirm that all scheduled controls and monitoring will function in accordance with the specified function. A written confirmation of this review shall be submitted to the Architect / Consultant.
    - d. Coordinate the power requirements with all equipment furnished in this section.

### 1.7 MAINTENANCE

- A. Contractor shall furnish spare parts required in each section, packaged to protect parts from damage and to allow for easy storage.
- B. Supplier of equipment shall stock replacement parts for each system and be able to replace any part of the system within 24 hours.
- C. Provide spare door hardware parts as follows:
  - 1. Hinges: 10 pair
  - 2. Closers: 1 each hand, type and size used

3. Door position switches: 2 % of total doors, or minimum of 10 (whichever is greater)
4. Furnish the following material:
  - a. Two (2) each of all locks specified (less cylinder).
  - b. All parts shall be packaged and labeled to provide for long term storage.

## PART 2 - PRODUCTS

### 2.1 GENERAL

- A. Security design criteria are based upon the requirements and features of the products listed herein. The use of one manufacturer's numeric designation does not imply other manufacturer's products will not be accepted.
- B. Fire Rated Openings: Provide hardware for fire-rated openings in compliance with NFPA Standard 80. This requirement takes precedence over other requirements for such hardware. Provide only hardware which has been tested and listed by UL, bears appropriate label or symbol for the types and sizes of doors required and compliance with the requirements of the required label and function of the opening wherever possible.

### 2.2 MISCELLANEOUS HARDWARE FOR SECURITY DOORS

- A. Acceptable Manufacturers
  1. Except as otherwise specified herein, the equipment and materials of this section shall be products manufactured by one of the listed manufacturers and must be equal to the part specified in the product description.
- B. Products/Manufacturers
  1. Hinges: Southern Folger, Portland, Northwest Specialty Hardware
  2. Pulls: Southern Folger, Portland, Northwest Specialty Hardware
  3. Door Position Switches (DPS): Southern Folger, Sentrol
  4. Door Closers: LCN
  5. Door Stops: Ives
  6. Thresholds: Reese, National Guard and Pemko
  7. Weatherstrip: Reese, National Guard and Pemko
  8. Smoke Seal: Reese, National Guard and Pemko
  9. Silencers: Ives
- C. Product Description
  1. Hinges, SOUTHERN 204FMSS or approved equal:
    - a. Full Mortise Detention Hinges shall be 4-1/2" x 4-1/2" x 0.188" thick investment cast 304 stainless steel with hospital tips and integral studs on both leaves. Pins shall be hardened stainless or alloy steel, concealed and non-removable. Each hinge shall be supplied with eight (8) 1/4-20 flat head machine screws. All hinges and screws shall be US32D finished.
    - b. Furnish three hinges for door through 84-inches in height and one additional hinge for each additional 30-inches of height or fraction thereof. Furnish three hinges for

- doors through 36-inches in width and one additional hinge for each additional 12-inches of width or fraction thereof.
- c. Except where otherwise indicated, hinges shall be mortised, 4-1/2" x 4-1/2", cast steel or stainless steel, ball bearing, with pins made non-removable by a concealed hardened roll pin. All hinges shall be furnished with 1/4-20 TORX FHMS.
  - d. Hinges shall be certified, by an independent testing lab, to meet or exceed the cycle requirements of ASTM 1758, Grade 1A.
  - e. Hinges furnished for use on labeled fire doors shall also comply with the requirements of NFPA 80.
2. Full surface hinges, equal to Southern Folger 203FS/203FP where indicated on architectural details for food pass applications in rated openings.
  3. Strikes: All locks and latches shall be furnished with manufacturer's standard strikes complete with dust boxes to fully conceal the strike pocket. Where monitor strikes are specified, provide strikes as appropriate for the lock specified. All monitor strikes shall be designed to fit within a 2" face frame without protruding beyond the 2" frame depth.
  4. Fasteners:
    - a. Manufacturer hardware to conform to published template, generally prepared for machine screw installation. Do not provide hardware, which has been prepared for self-tapping of sheet metal screws.
    - b. Furnish screws for installation with each hardware item. All exposed screw heads, whether door is open or closed, shall be Torx (with security stud) flat-head or oval head screws except as otherwise indicated. Screws shall be the same material and finished to match the applied hardware item. Other types of security screws are unacceptable unless specifically approved by the Architect-Consultant.
  5. Pull:
    - a. Grip Type Door Pulls shall be cast of brass or bronze with satin finish of approximately US26D unless specified otherwise in hardware schedule. Approximate overall length, 8-11/16"; handhold, 5-1/4"; grip clearance, 1-1/2"; attachment holes, 7-3/4" o.c. Provide two (2) 3/8-16 x 5/8" flat head torx screws of same finish and material as pull.
    - b. Flush Type Door Pulls shall be cast of brass or bronze with satin finish of approximately US26D unless specified otherwise in hardware schedule. Size 4" x 5" x 1/8" x pocket rip 1" deep. Provide four (4) 1/4-20 x 3/8" flat head torx screws of same finish and material as pull.
  6. Door Position Switch, SOUTHERN 200MRS, or as required by hardware schedule:
    - a. Recessed Magnetic Door Position Switch-Triple Biased shall be a five-reed switch magnet mortised type assembly used for remotely monitoring the door status/position. The device shall be triple bias for tamper resistance.
    - b. The device shall be moisture resistant and fit within a 2" hollow metal jamb or head. The device shall be field adjustable on 2 axis and supplied with a 5' vinyl jacketed lead wire and a 3-pin Molex connector. The device shall be all steel construction. The switch and magnet shall be encased in epoxy resin.
    - c. Where this device is used in an exterior location, provide a complete water-tight installation.
  7. High Security Closer (LCN #4210/4510T series) shall be surface mounted with security screws at all exposed locations and shall have fully adjustable spring tension. Closers shall have cast iron cylinders and two separately adjustable non-critical valves for closing speed and latching speed, plus a third valve for adjusting the hydraulic back-check. A smooth molded case cover shall conceal the closer body. Closer to be located on the side of door/frame farthest from inmate contact, unless an exterior door. Mount closer for exterior doors on interior side of the door. Maximum opening clearance shall be 180-

- degrees. Parallel arm shall be used on the 4210 series closer, and the track arm shall be used on the 4510T series closer. Provide finish of standard powder coated aluminum.
8. Wall Mounted Door Stops (Wall mount only) (Ives FS18L) shall be a tamper resistant device that is embedded into the wall with an epoxy resin adhesive. Bumper shall be 2" diameter x 3-1/2" long and made from a non-hazardous silicone elastomer, 80 durometer. The threaded and grooved steel mounting shank shall be 5/8" in diameter and embedded into the bumper at least half the length of the bumper. Mounting shank shall extend 2-1/2" beyond the bumper bottom for embedding into the wall.
    - a. Provide wall-mounted door bumper 8" off of the floor and 8" from edge of door when in the opened position. If the above conditions cannot be achieved, request direction from the Architect.
  9. Thresholds: Provide thresholds as in "Security Hardware Schedule", and where required on security doors per architectural details. All doors into rated stairways shall be provided with Reese S204A thresholds (or approved equal).
  10. Weatherstripping:
    - a. Provide weatherstripping at all exterior doors equal to Reese DB469C door sweep plus 797B weatherstrip, or approved, at all heads and jambs (and astragals if pairs), After installation, razor cut gasketing into pieces not over 12" in length, installed per manufacturer's recommendations. Do not break weatherstrip at head of frame for closer installation. **SILL SWEEP MUST BE FASTENED WITHIN 1/2" MAXIMUM FROM EDGE OF DOOR ON EACH SIDE.**
    - b. Provide rain drips equal to Reese R199A and R201A at frame head and door bottom at all exterior doors installed per manufacturer's recommendations. Apply head drip directly to door frame header 1/4" above door opening.
  11. Smoke/Fire Gasket: Provide head and jamb gasketing equal to Reese 797B weatherstrip and Reese 964C Sill sweep, or approved equal, at all fire and/or smoke rated openings. After installation, razor cut gasketing into pieces not over 12" in length, installed per manufacturer's recommendations. Do not break weatherstrip at head of frame for closer installation. **SILL SWEEP MUST BE FASTENED WITHIN 1/2" MAXIMUM FROM EDGE OF DOOR ON EACH SIDE.**
  12. Door Silencers: (Ives SR64) shall be standard resilient type and removable for replacement.

### 2.3 MECHANICAL LOCKS FOR SECURITY DOORS

- A. Acceptable Manufacturers
  1. Except as otherwise specified herein, the equipment and materials of this section shall be products of the following Manufacturer, no exceptions:
    - a. Southern Folger Detention Equipment Company (SOUTHERN), San Antonio, TX
- B. Mechanical Locks and Accessories for Swinging and sliding Doors
  1. Standard Features
    - a. Lock case to be high tensile strength alloy steel with cold rolled steel cover
    - b. All locks to operate by inserting a key into matching cylinder and rotating key to unlock the lock.
    - c. All lock steel parts shall be zinc plated for corrosion protection and are suitable for both interior and exterior applications.
    - d. Keyed One Side (K1) or Keyed Two Sides (K2).
    - e. At rated locations, provide smoke gasketing, weather strip, sweeps, sill threshold, door skirts, plates, angles and/or additional material as required per the

manufacturer's recommendations to obtain the appropriate label as per the architectural drawings. This requirement takes precedence over other requirements for scheduled hardware. Provide only hardware which has been tested and listed by UL bears the appropriate label or symbol for the types and sizes of doors required and compliance with the requirements of the required label and function of the opening wherever possible.

C. Products

1. Mechanical Deadbolt, SOUTHERN 1010A:
  - a. Lock size to be approximately 4-1/2" x 3" x 1-1/4". Deadbolt to be 3/4" x 1-1/2" hot rolled steel with 5/8" throw. Deadbolt locking and unlocking activated by key only.
  - b. The lock shall be supplied with a six (6) pin paracentric key cylinder.
  - c. Provide extended bolt throw at food pass locations as required by hollow metal fabrication. DEC shall fully coordinate with hardware and hollow metal manufacturers.
2. Mechanical Latch, SOUTHERN 1017A:
  - a. Lock size to be approximately 4" x 2-3/4" x 1-1/4". Beveled latchbolt to be 7/16" x 1" stainless steel with 7/16" throw.
  - b. Beveled latch bolt to be retracted by key operation only. Latchbolt to snap-lock on closing.
  - c. The lock shall be supplied with a six (6) pin paracentric key cylinder.
  - d. Provide extended bolt throw at food pass locations as required by hollow metal fabrication. DEC shall fully coordinate with hardware and hollow metal manufacturers.
3. Mechanical Deadbolt, SOUTHERN 1080A:
  - a. Lock size to be approximately 5-1/2" x 3-3/4" x 1-1/2". Deadbolts to be 3/4" x 2" with 3/4" throw. Deadbolt locking and unlocking activated by key only.
  - b. Deadbolt to be made of cold rolled steel with 1/4" diameter hardened steel inserts (2 each) unless otherwise specified.
  - c. The lock shall be supplied with a six (6)-pin paracentric key cylinder.
  - d. Provide 1-1/2" x 1-1/2" x 1/4" x 10" high custom galvanized angle strike to receive lock bolt where installed in fence system. Weld custom strike to fence frame.
  - e. Provide 3" x 3" gate stop gusset angles where required to stop gate swing. Welded at corners of gate opening.
4. Institutional Mortise Lockset, SOUTHERN 10500 – NO SUBSTITUTION:
  - a. A security mortise lockset for 2" thick individual swing doors that comply with the standard test methods defined in ASTM F1577-05. Locksets shall be supplied with high security rose and functions as specified by the door and/or hardware schedule. Lockset shall be UL listed for use with fire-rated doors where specified.
  - b. Lockset case and cover shall be 12-gauge (minimum) heavy-duty wrought steel, zinc dichromate plated. Latchbolt shall be one-piece stainless steel anti-friction type with 3/4" throw, meeting ANSI A156.13. Deadbolt shall be investment cast stainless steel with hardened steel insert and a 1" throw. Deadlock actuator shall be stainless steel. Strike shall be ANSI standard, universal brass or stainless steel. Faceplate shall be 16 gauge (Minimum) stainless steel, US32D finish.
  - c. Latchset shall be supplied with solid stainless steel (US32D finish) steel lever handles (both sides) unless otherwise specified.
  - d. Lockset shall be supplied with high security ASSA Mogul Key Cylinders unless otherwise specified. All exposed fasteners shall be stainless steel tamper proof.
  - e. Lock functions must match EXACTLY with functions specified herein.

5. Galvanized Material
  - a. All exterior material shall be hot dipped galvanized.

## 2.4 ELECTRO-MECHANICAL LOCKS AND SLIDING DEVICES FOR SECURITY DOORS

- A. Acceptable Manufacturers
  1. Except as otherwise specified herein, the equipment and materials of this article shall be products of the following Manufacturer:
    - a. Southern Folger Detention Equipment Company (SOUTHERN), San Antonio, TX
- B. The lock shall be 24 VDC motor operated security locks for individual swinging doors: Locks shall be frame mounted, complete with integral electronic components. Equal to SOUTHERN 10120AM:
  1. Functions:
    - a. Locks to operate electrically through either 24 VDC constant duty motors. Locks to be remotely unlocked electrically by momentary contact switch, or mechanically operated by key at the lock.
    - b. Refer to the requirements of the Emergency Release function of the door control system specified in Division 28. The electrically controlled locks shall be furnished with the capabilities of a half cycle function when controlled with the Emergency Release control function. The lock shall operate as if it's a full cycle lock with normal door control function.
    - c. Half Cycle Operation
      - 1) When a momentary signal is applied to the unlock input, the latchbolt shall retract. The latchbolt shall remain mechanically retracted. When power is removed, the latchbolt remains retracted.
      - 2) When a momentary signal is applied to the lock input, the latchbolt shall extend, locking the door if closed and allowing the door to be slam-locked if open.
    - d. Manual Operation
      - 1) Each lock shall have local manual key override lock/unlock feature. Keyed one side (K1), Keyed two sides (K2).
      - 2) Rotating the key shall mechanically retract the latchbolt. Removing the key shall extend the bolt, locking the door if closed and allowing the door to be slam-locked if open.
  2. Components
    - a. Mechanical
      - 1) Lock shall operate as a fail-secure slam-lock. Unlocks when energized.
      - 2) Lock body shall be made of steel or stainless steel.
      - 3) Lock shall be supplied with a security key cylinder protection pipe to protect the key cylinder. The protection pipe will be supplied unpainted for installation in the hollow metal frame by the hollow metal manufacturer.
      - 4) Cylinder extensions shall be provided for locks keyed two sides or keyed stop side unless provisions are allowed for recessed pocket in hollow metal.
      - 5) Cylinder shields shall not be required on exterior side of exterior frames in recreation yards.
    - b. Electrical
      - 1) 10120 Motor Operated Lock:
        - a) Lock shall operate when supplied with 24 VDC.
        - b) Single Phase, 3.3 amp max.



- c) Lock shall be provided with a lock status switch to provide interlocking capabilities.
  - d) Switches shall be of the snap acting mechanical type. UL listed and rated at least 5 amps.
  - e) Locks shall be factory wired to a plug disconnect.
  - f) Lock status switch shall be capable of providing the following indications:
    - g) Deadlocked indication
    - h) Unsecure indication
  - c. Features: Where specified by the security hardware/door schedule, the following features shall be provided:
    - 1) Local Electric Keyswitch (LEK): Day key provides local electric operation and may be disabled remotely via central control point. Master key provides both electric and Mechanical operation. Refer to the requirements of the door control system specified in Division 28.
    - 2) Remote Latch Holdback (RLHB): Latchbolt is retracted by the push of a button at the control panel and remains mechanically retracted until button is pushed a second time.
    - 3) Key Operated Mechanical Latch Holdback (KLHB): Latchbolt is retracted locally by key and remains mechanically retracted until relocked by key.
    - 4) Key Switch (KS): Door is electrically unlocked by key operated switch at the lock.
    - 5) Provide ASSA Mogul key Cylinders.
  - d. Weather resistant motor housing shall be constructed of a minimum ¼” (6.4MM) steel plate, framed and stiffened as required.
  - e. Removable front cover panel shall be constructed of 10-gauge galvanized steel.
  - f. The doorjamb and vertical members shall be free of hooks or lugs used for locking or any other purpose.
- C. Electro-Mechanical (Swing) Gate Lock equal to SOUTHERN 1050SD:
- 1. Function:
    - a. Fence post mounted 120VAC, continuous-duty solenoid actuated.
    - b. Deadlocks automatically when gate is closed.
    - c. Bolt is retracted electrically at control panel and remains retracted until gate is opened.
    - d. Bolt is retracted mechanically with key from either side, and remains retracted until relocked by key.
    - e. Internal switches monitor deadlocked condition of the deadbolt.
    - f. Furnish galvanized, including case and cover.
    - g. Provide six-tumbler lock.
    - h. Provide with interlock feature, if required.
    - i. All electrically operated hardware shall be furnished with both male and female Molex connectors
- D. At rated locations, provide smoke gasketing, weather strip, sweeps, sill threshold, door skirts, plates, angles and/or additional material as required per the device manufacturer’s recommendations to obtain the appropriate label. This requirement takes precedence over other requirements for scheduled hardware. Provide only hardware which has been tested and listed by UL bears appropriate label or symbol for the types and sizes of doors required and compliance with the requirements of the required label and function of the opening wherever possible.

## 2.5 KEYING AND KEYS

- A. Keying and Keys
  - 1. The owner shall provide an approved key schedule to the DEC at the time of detention hardware submittal review.
  - 2. Mogul type ASSA Mogul Key Cylinders shall be keyed in sets and master keyed, sub-master keyed etc. to level as directed by the Owner.
    - a. Provide five (5) keys per master code.
    - b. Provide eight (8) keys per change key code.
  - 3. Paracentric prison locks shall be keyed in sets and provided with eight (8) keys for each change key code.
  
- B. Key Control System:
  - 1. Keying: Provide key system as directed by the Owner.
  - 2. The DEC shall be responsible for all keys and in the unlikely event any key is lost, the DEC shall bear all costs incurred in having locks re-keyed. The DEC shall turn all keys over to the Owner as directed by the Owner for inclusion into the key cabinet.
  - 3. Provide key cabinet equal to SOUTHERN 620 series with capacity for all keys required herein, plus 100%.
  - 4. When requested by the Owner, in writing, the DEC shall surrender any or all keys assigned to him.
  - 5. All keys shall be stamped with a maximum of six (6) characters, as directed by Owner. Each key shall be such that meets the 2006 NFPA-101 Life Safety Code (22.7.5) to identify key(s) by touch and sight.
  - 6.

## PART 3 - EXECUTION

### 3.1 GENERAL REQUIREMENTS

- A. Examine and inspect all surfaces, anchors, and grounds that are to receive materials, fixtures, assemblies, and equipment specified herein. Check location, "rough in", and field dimensions prior to beginning work. Report all unsatisfactory conditions in writing to the Architect-Engineer and general contractor.
  - 1. Do not begin installation until all unsatisfactory conditions have been corrected.
  
- B. Verify all dimensions and be responsible for their correctness. No extra compensation will be allowed for differences between actual measurements and the dimensions indicated on the drawings.

### 3.2 INSTALLATION

- A. Install security materials and accessories in accordance with the final shop drawings, manufacturer's data, and as herein specified.
  - 1. Provide manufacturer's supervision of installation, including testing and interfacing of systems.

- B. Install all components and complete system as indicated and in accordance with manufacturer's recommendations and instructions.
- C. Nuts of all bolted work shall be drawn tight and threads battered or welded. Bolting may be used in the installation of detention equipment provided that the nuts are not accessible to inmates or exposed to view. Bolts shall be special oval head or flat head Torx security type. Screws shall be the same material and finished to match the applied hardware item. Other types of security bolts are unacceptable unless specifically approved by the Architect-Engineer. Provide two sets of wrenches for each size bolt used.

### 3.3 ADJUSTING

- A. Final Adjustments: Prior to final inspection check and re-adjust all components to operate within their designed capacity. All components shall be adjusted and tested to verify correct operation prior to final inspection.
- B. All devices shall be tested for specified and manufacturer described operation.
- C. All tests required by local agencies shall be performed.
- D. All tests required by Owner and Owner's representative shall be performed.
- E. Systems not meeting the minimum level of acceptability as defined in the test procedures shall be repaired and retested.
- F. Provide documentation of test procedures and results.
- G. Equipment manufacturer's representative shall certify that the systems are installed and operate as specified.
- H. All costs to test and retest systems shall be the responsibility of the Detention Equipment Contractor.

### 3.4 SECURITY HARDWARE SCHEDULE

- A. GENERAL NOTES:
  - 1. Provide smoke & fire rated materials in accordance with 087163.2.2.C.9, and 11, unless otherwise instructed by the Architect/Consultant.
  - 2. Provide threshold, weatherstrip equal to Reese 797B/DB469C at exterior door openings.
  - 3. Provide appropriate cylinder shield at exterior door openings except in recreation yards.
  - 4. Provide a doorstop equal to Ives FS18L at all door openings in accordance with 087163.2.2.C.8, unless otherwise instructed by the Architect/Consultant.
  - 5. Any door greater than 3'-2" in width and/or 7'-4" in height shall receive four (4) hinges.

SH1

UNIT	PART	CATALOG NO.	FINISH	MANUFACTURER
3EA	HINGE	204FMSS	US32D	SOUTHERN FOLGER
1EA	LOCK	10120AMD-2	US26D	SOUTHERN FOLGER
2EA	CYLINDER	MOGUL	US26D	SOUTHERN FOLGER
1EA	CLOSER	4210/4510T	AL	LCN

COUNTY OF MONTEREY  
NEW JUVENILE HALL

75-14126-00

1EA	DPS	200MRS-TB	US26D	SOUTHERN FOLGER
1EA	RAISED PULL	212C	US26D	SOUTHERN FOLGER
1EA	RECESSED PULL	214S	US26D	SOUTHERN FOLGER
3EA	SILENCERS	SR64	----	IVES

SH2

UNIT	PART	CATALOG NO.	FINISH	MANUFACTURER
3EA	HINGE	204FMSS	US32D	SOUTHERN FOLGER
1EA	LOCK	10120AMD-2	US26D	SOUTHERN FOLGER
2EA	CYLINDER	MOGUL	US26D	SOUTHERN FOLGER
1EA	CLOSER	4210/4510T	AL	LCN
1EA	DPS	200MRS-TB	US26D	SOUTHERN FOLGER
1EA	RAISED PULL	212C	US26D	SOUTHERN FOLGER
1EA	RECESSED PULL	214S	US26D	SOUTHERN FOLGER
1EA	THRESHOLD	S204A	AL	REESE
1EA	WEATHERSTRIP	797B/DB469C	AL	REESE
1EA	RAIN DRIP	R201A/R199A	AL	REESE

SH3

UNIT	PART	CATALOG NO.	FINISH	MANUFACTURER
3EA	HINGE	204FMSS	US32D	SOUTHERN FOLGER
1EA	LOCK	10300	US26D	SOUTHERN FOLGER
1EA	CYLINDER	MOGUL	US26D	SOUTHERN FOLGER
1EA	DPS	200MRS-TB	US26D	SOUTHERN FOLGER
1EA	RAISED PULL	212C	US26D	SOUTHERN FOLGER
1EA	RECESSED PULL	----	----	INTEGRAL BY SHM
3EA	SILENCERS	SR64	----	IVES

SH3A

UNIT	PART	CATALOG NO.	FINISH	MANUFACTURER
3EA	HINGE	204FMSS	US32D	SOUTHERN FOLGER
1EA	LOCK	10300	US26D	SOUTHERN FOLGER
1EA	CYLINDER	MOGUL	US26D	SOUTHERN FOLGER
1EA	FOOD PASS LOCK	1010A	GALV	SOUTHERN FOLGER
2EA	FOOD PASS HINGE	203FP	US26D	SOUTHERN FOLGER
1EA	ESCUTCHEON	218-1	US26D	SOUTHERN FOLGER
1EA	DPS	200MRS-TB	US26D	SOUTHERN FOLGER
1EA	RAISED PULL	212C	US26D	SOUTHERN FOLGER
1EA	RECESSED PULL	----	----	INTEGRAL BY SHM
3EA	SILENCERS	SR64	----	IVES

SH4

UNIT	PART	CATALOG NO.	FINISH	MANUFACTURER
3EA	HINGE	204FMSS	US32D	SOUTHERN FOLGER
1EA	LOCK	10513*Modified	US26D	SOUTHERN FOLGER
1EA	STRIKE	500CL	US26D	SOUTHERN FOLGER
1EA	CYLINDER	MOGUL	US26D	SOUTHERN FOLGER
1EA	CLOSER	4210/4510T	AL	LCN
1EA	DPS	200MRS-TB	US26D	SOUTHERN FOLGER

3EA SILENCERS SR64 ---- IVES

*NOTE: \*MODIFY 10513 LOCK AND REMOVE THUMBTURN.*

SH5 Access Panel

UNIT	PART	CATALOG NO.	FINISH	MANUFACTURER
1EA	LOCK	1010A-1	GALV	SOUTHERN FOLGER
1EA	ESCUTCHEON	218-1	US26D	SOUTHERN FOLGER
1EA	CYLINDER SHIELD	219	US26D	SOUTHERN FOLGER
1EA	WEATHERSTRIP	797B/DB469C	AL	REESE

*NOTE: PROVIDE WEATHERSTRIP AND CYLINDER SHIELD ONLY AT EXTERIOR LOCATIONS.*

SH5A Rated Access Panel

UNIT	PART	CATALOG NO.	FINISH	MANUFACTURER
1EA	LOCK	1017A-1	GALV	SOUTHERN FOLGER
1EA	ESCUTCHEON	218-1	US26D	SOUTHERN FOLGER

*NOTE: PROVIDE WITH AUTOMATIC CLOSING DEVICE BY ACCESS PANEL MANUFACTURER.*

SH6

UNIT	PART	CATALOG NO.	FINISH	MANUFACTURER
1EA	LOCK	1080-2 X FENCE GATE MTG	GALV	SOUTHERN FOLGER
1EA	RAISED PULL – SCREW-ATTACH PULL DIRECTLY TO MTG PLATE.	212C	US26D	SOUTHERN FOLGER
1EA	GATE STRIKE	4C	GALV	SOUTHERN FOLGER

SH7

UNIT	PART	CATALOG NO.	FINISH	MANUFACTURER
1EA	LOCK	1050SD-2	GALV	SOUTHERN FOLGER

END OF SECTION 08 7163



SECTION 08 8000 - GLAZING

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. Types of glazing included:
  1. Primary float glass.
  2. Heat-treated (tempered) float glass.
  3. Insulating glass units

1.3 DEFINITIONS

- A. Manufacturer is used in this Section to refer to a firm that produces primary glass or fabricated glass as defined in the referenced glazing standard.
- B. Deterioration of Insulating Glass: Failure of the hermetic seal under normal use due to causes other than glass breakage and improper practices for maintaining, and cleaning insulating glass. Evidence of failure is the obstruction of vision by dust, moisture, or film on the interior surfaces of glass. Improper practices for maintaining and cleaning glass do not comply with the manufacturer's directions.

1.4 SYSTEM PERFORMANCE REQUIREMENTS

- A. General: Provide glazing systems that are produced, fabricated, and installed to withstand normal thermal movement, wind loading, and impact loading (where applicable), without failure including loss or glass breakage attributable to the following: defective manufacture, fabrication, and installation; failure of sealants or gaskets to remain watertight and airtight; deterioration of glazing materials; and other defects in construction.
- B. Normal thermal movement results from the following maximum change (range) in ambient and surface temperatures acting on glass-framing members and glazing components. Base engineering calculation on materials' actual surface temperatures due to both solar heat gain and nighttime sky heat loss.
  1. Temperature Change (Range): 120 F deg, ambient; 180 F deg, material surfaces.

1.5 SUBMITTALS

- A. Product Data: For each glass product and glazing material indicated.

- B. Samples for verification purposes of 12-inch square samples of each type of glass indicated except for clear monolithic glass products, and 12-inch-long samples of each color required (except black) for each type of sealant or gasket exposed to view. Install sealant or gasket sample between two strips of material representative in color of the adjoining framing system.
- C. Glass fabricator shall submit copy of his glass manufacturer's certification for insulating products.
- D. Product certificates signed by glazing materials manufacturers certifying that their products comply with specified requirements.
- E. Maintenance data for glass and other glazing materials to include in Operating and Maintenance Manual specified in Division 01.

#### 1.6 QUALITY ASSURANCE

- A. Glazing Publications: Comply with published recommendations of glass product manufacturers and organizations below, except where more stringent requirements are indicated. Refer to these publications for glazing terms not otherwise defined in this Section or in referenced standards.
  - 1. GANA Publications: "GANA Glazing Manual."
  - 2. LSGA Publications: "LSGA Design Guide."
  - 3. GANA Laminated Division Publication: "Laminated Glass Design Guide."
  - 4. IGMA Publications: TM-3000 "Vertical Glazing Guidelines" and TB-3001 "Sloped Glazing Guidelines."
- B. Safety Glass: Products complying with ANSI Z97.1 and testing requirements of 16 CFR Part 1201 for Category II materials.
  - 1. Subject to compliance with requirements, provide safety glass permanently marked with certification label of Safety Glazing Certification Council (SGCC) or other certification agency acceptable to authorities having jurisdiction.
- C. Insulating Glass Certification Program: Provide insulating glass units permanently marked either on spacers or at least one component lite of units with appropriate certification label of inspecting and testing agency indicated below:
  - 1. Insulating Glass Certification Council (IGCC).
  - 2. Associated Laboratories, Inc. (ALI).
  - 3. National Certified Testing Laboratories (NCTL).
- D. Glass Fabricator Qualifications: Fabricator of insulating units shall be certified by glass manufacturer.
- E. Glazier Qualifications: Engage an experienced glazier who has completed glazing similar in material, design, and extent to that indicated for Project with a record of successful in-service performance.
- F. Single-Source Responsibility for Glass: Obtain glass from one source for each product indicated below:
  - 1. Primary glass of each (ASTM C 1036) type and class indicated.
  - 2. Heat-treated glass of each (ASTM C 1048) condition indicated.
  - 3. Insulating glass of each construction indicated.



- G. Single-Source Responsibility for Glazing Accessories: Obtain glazing accessories from one source for each product and installation method indicated.
- H. Pre-Installation Conference: Conduct conference at Project site to comply with requirements of Division 01 Section "Project Meetings."

#### 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Protect glazing materials to comply with manufacturer's directions and as needed to prevent damage to glass and glazing materials from condensation, temperature changes, direct exposure to sun, or other causes.
  - 1. Where insulating glass units will be exposed to substantial altitude changes, comply with insulating glass fabricator's recommendations for venting and sealing to avoid hermetic seal ruptures.

#### 1.8 PROJECT CONDITIONS

- A. Environmental Conditions: Do not proceed with glazing when ambient and substrate temperature conditions are outside the limits permitted by glazing materials manufacturer or when glazing channel substrates are wet from rain, frost, condensation, or other causes.
  - 1. Install liquid sealants at ambient and substrate temperatures above 40 deg F.

#### 1.9 WARRANTY

- A. General: Warranties specified in this Article shall not deprive the Owner of other rights the Owner may have under other provisions of the Contract Documents and will be in addition to and run concurrent with other warranties made by the Contractor under requirements of the Contract Documents.
- B. Manufacturer's Warranty on Insulating Glass: Submit written warranty signed by manufacturer of insulating glass agreeing to furnish replacements for insulating glass units that deteriorate as defined in "Definitions" article, f.o.b. point of manufacture, freight allowed Project site, within specified warranty period indicated below. Warranty covers only deterioration due to normal conditions of use and not to handling, installing, protecting, and maintaining practices contrary to glass manufacturer's published instructions.
  - 1. Warranty Period: Manufacturer's standard but not less than 10 years after date of Completion.

### PART 2 - PRODUCTS

#### 2.1 GLASS PRODUCTS, GENERAL

- A. Thickness: Where glass thickness is indicated, it is a minimum. Provide glass lites in thicknesses as needed to comply with requirements indicated.
  - 1. Minimum Glass Thickness for Exterior Lites: Not less than 1/4-inch.
  - 2. Thickness of Tinted Glass: Provide same thickness for each tint color indicated throughout Project.
- B. Strength: Where float glass is indicated, provide annealed float glass, Kind HS heat-treated float glass, or Kind FT heat-treated float glass. Where heat-strengthened glass is indicated,

provide Kind HS heat-treated float glass or Kind FT heat-treated float glass. Where fully tempered glass is indicated, provide Kind FT heat-treated float glass.

- C. Thermal and Optical Performance Properties: Provide glass with performance properties specified, as indicated in manufacturer's published test data, based on procedures indicated below:
1. For monolithic-glass lites, properties are based on units with lites 1/4-inch thick.
  2. For laminated-glass lites, properties are based on products of construction indicated.
  3. For insulating-glass units, properties are based on units of thickness indicated for overall unit and for each lite.
  4. U-Factors: Center-of-glazing values, according to NFRC 100 and based on LBL's WINDOW 5.2 computer program, expressed as Btu/sq. ft. x h x deg F .
  5. Solar Heat-Gain Coefficient and Visible Transmittance: Center-of-glazing values, according to NFRC 200 and based on LBL's WINDOW 5.2 computer program.
  6. Visible Reflectance: Center-of-glazing values, according to NFRC 300.

## 2.2 MANUFACTURERS

- A. Products: Subject to compliance with requirements, provide products of one of the following manufacturers:
1. Manufacturers of Glass:
    - a. Guardian Industries Corp.
    - b. LOF Glass, Inc.
    - c. PPG Industries, Inc.
    - d. AFG Industries, Inc.
  2. Fabricators:
    - a. Oldcastle Glass Group.
    - b. Viracon, Inc.
    - c. Interpane.

## 2.3 FLOAT GLASS PRODUCTS (CG)

- A. Float Glass: ASTM C 1036, Type I (transparent glass, flat), Class as indicated below, and Quality q3 (glazing select).
1. Class 1 (clear) unless otherwise indicated.
- B. Refer to requirements for sealed insulating glass units for performance characteristics of assembled units composed of tinted glass, coated or uncoated, relative to visible light transmittance, U-values, shading coefficient, and visible reflectance.

## 2.4 HEAT-TREATED FLOAT GLASS (CTG)

- A. Fabrication Process: By horizontal (roller-hearth) process.
- B. Uncoated, Clear, Heat-Treated Float Glass: ASTM C 1048, Condition A (uncoated surfaces), Type I (transparent glass, flat), Class 1 (clear), Quality q3 (glazing select), 6 mm thick, kind as indicated below.
1. Kind HS (heat strengthened) where indicated.
  2. Kind FT (fully tempered) where indicated.
- C. Manufacturers: Provide heat-treated glass by manufacturer of clear float glass listed in paragraph 2.1 above.

## 2.5 INSULATING GLASS PRODUCTS (TIG, TTIG)

- A. Sealed Insulating Glass Units: Preassembled units consisting of organically sealed lites of glass separated by dehydrated air spaces complying with ASTM E 774 and with other requirements indicated.
1. For properties of individual glass lites making up units, refer to requirements specified elsewhere in this Section applicable to types, classes, kinds, and conditions of glass products comprising lites of insulating glass units.
  2. Provide float glass or heat-treated float glass of kind indicated or, if not otherwise indicated, Kind HS (heat strengthened) where recommended by manufacturer to comply with system performance requirements specified and Kind FT (fully tempered) where safety glass is designated or required.
  3. Performance characteristics designated for insulating glass are nominal values based on manufacturer's published test data for units with lites 6 mm thick and nominal 1/2-inch dehydrated space between lites, unless otherwise indicated.
  4. U-values are expressed as Btu/hr x sq. ft. x deg F.
- B. Insulating Glass Unit: 1-inch thick PPG "Solarban 60 Gray" Low-E Insulating Glass, with Low-E coating on #3 surface. Manufacturer's standard Low-E units complying with the following requirements:
1. Exterior Pane: Gray tinted float glass, typically (TIG).
    - a. Kind FT (fully tempered) where noted or required by code (TTIG).
  2. Interior Pane: Clear float glass, typically.
    - a. Kind FT (fully tempered) where noted or required by code.
  3. Nominal Performance Characteristics:
    - a. Visible light transmittance: 48%.
    - b. Visible light reflectance: 33%.
    - c. Winter night-time U-Value: 0.29.
    - d. Summer daytime U-Value: 0.27.
    - e. Shading Coefficient: 0.28.
    - f. Solar Heat Gain Coefficient: 0.24.

## 2.6 ELASTOMERIC GLAZING SEALANTS

- A. General: Provide products of type indicated, complying with the following requirements:
1. Compatibility: Select glazing sealants and tapes of proven compatibility with other materials they will contact, including glass products, seals of insulating glass units, and glazing channel substrates, under conditions of installation and service, as demonstrated by testing and field experience.
  2. Suitability: Comply with sealant and glass manufacturer's recommendations for selecting glazing sealants that are suitable for applications indicated and conditions existing at time of installation.
  3. Colors of Exposed Glazing Sealants: Provide selections made by Architect from manufacturer's full range for products of type indicated.
- B. Elastomeric Glazing Sealant Standard: Provide manufacturer's standard chemically curing, elastomeric sealants of base polymer indicated that comply with ASTM C 920 requirements indicated below:
1. Two-Part Polysulfide Glazing Sealant: Type M; Grade NS; Class 25; Uses NT, M, G, A, and, as applicable to uses indicated, O.
  2. One-Part Acid-Curing Silicone Glazing Sealant: Type S; Grade NS; Class 25; Uses NT, G, A, and, as applicable to uses indicated, O.

3. One-Part Non-Acid-Curing Silicone Glazing Sealant: Type S; Grade NS, Class 25; Uses NT, G, A, and, as applicable to uses indicated, O; and complying with the following requirements for modulus and additional joint movement capability.
  - a. Medium Modulus: Tensile strength of not less than 45 nor more than 75 psi at 100 percent elongation when tested per ASTM D 412 after 14 days at 77 deg. F and 50 percent relative humidity.
  - b. Additional capability, when tested per ASTM C 719 for adhesion and cohesion under maximum cyclic movement, to withstand the following percentage increase and decrease of joint width, as measured at time of application, and remain in compliance with other requirements of ASTM C 920: 50 percent.

- C. Glazing Sealant for Fire-Resistive Glazing Products: Identical to product used in test assembly to obtain fire-protection rating.

## 2.7 GLAZING TAPES

- A. Back-Bedding Mastic Glazing Tape: Preformed, butyl-based elastomeric tape with a solids content of 100 percent; nonstaining and nonmigrating in contact with nonporous surfaces; with or without spacer rod as recommended in writing by tape and glass manufacturers for application indicated; packaged on rolls with a release paper backing; and complying with ASTM C 1281 and AAMA 800 for products indicated below:
  1. AAMA 806.3 tape, for glazing applications in which tape is subject to continuous pressure.
  2. AAMA 807.3 tape, for glazing applications in which tape is not subject to continuous pressure.
- B. Expanded Cellular Glazing Tape: Closed-cell, PVC foam tape; factory coated with adhesive on both surfaces; packaged on rolls with release liner protecting adhesive; and complying with AAMA 800 for the following types:
  1. Type 1, for glazing applications in which tape acts as the primary sealant.
  2. Type 2, for glazing applications in which tape is used in combination with a full bead of liquid sealant.

## 2.8 GLAZING GASKETS

- A. Lock-Strip Gaskets: Neoprene extrusions in size and shape indicated, fabricated into frames with molded corner units and zipper lock strips, complying with ASTM C 542, black.
- B. Dense Compression Gaskets: Molded or extruded gaskets of material indicated below, complying with standards referenced with name of elastomer indicated below, and of profile and hardness required to maintain watertight seal:
  1. EPDM, ASTM C 864.
  2. Silicone, ASTM C 1115.
  3. Thermoplastic polyolefin rubber, ASTM C 1115.
  4. Any material indicated above.
- C. Soft Compression Gaskets: Extruded or molded, closed-cell, integral-skinned gaskets of material indicated below; complying with ASTM C 509, Type II, black; and of profile and hardness required to maintain watertight seal:
  1. EPDM.
  2. Silicone.

3. Thermoplastic polyolefin rubber.
4. Any material indicated above.

## 2.9 MISCELLANEOUS GLAZING MATERIALS

- A. General: Provide products of material, size, and shape complying with referenced glazing standard, requirements of manufacturers of glass and other glazing materials for application indicated, and with a proven record of compatibility with surfaces contacted in installation.
- B. Cleaners, Primers, and Sealers: Types recommended by sealant or gasket manufacturer.
- C. Setting Blocks: Elastomeric material with a Shore A durometer hardness of 85, plus or minus 5.
- D. Spacers: Elastomeric blocks or continuous extrusions with a Shore A durometer hardness required by glass manufacturer to maintain glass lites in place for installation indicated.
- E. Edge Blocks: Elastomeric material of hardness needed to limit glass lateral movement (side walking).
- F. Cylindrical Glazing Sealant Backing: ASTM C 1330, Type O (open-cell material), of size and density to control glazing sealant depth and otherwise produce optimum glazing sealant performance.
- G. Perimeter Insulation for Fire-Resistive Glazing: Identical to product used in test assembly to obtain fire-resistance rating.

## 2.10 FABRICATION OF GLASS AND OTHER GLAZING PRODUCTS

- A. Fabricate glass and other glazing products in sizes required to glaze openings indicated for Project, with edge and face clearances, edge and surface conditions, and bite complying with written instructions of product manufacturer and referenced glazing standard, to comply with system performance requirements.
- B. Grind smooth and polish exposed glass edges.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine glass framing, with glazier present, for compliance with the following:
  1. Manufacturing and installation tolerances, including those for size, squareness, offsets at corners.
  2. Presence and functioning of weep system.
  3. Minimum required face or edge clearances.
  4. Effective sealing between joints of glass-framing members.
- B. Do not proceed with glazing until unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Clean glazing channels and other framing members receiving glass immediately before glazing. Remove coatings that are not firmly bonded to substrates.

3.3 GLAZING, GENERAL

- A. Comply with combined recommendations of manufacturers of glass, sealants, gaskets, and other glazing materials, except where more stringent requirements are indicated, including those in referenced glazing publications.
- B. Glazing channel dimensions as indicated on Drawings provide necessary bite on glass, minimum edge and face clearances, and adequate sealant thicknesses, with reasonable tolerances. Adjust as required by Project conditions during installation.
- C. Protect glass from edge damage during handling and installation. Remove damaged glass from Project site and legally dispose of off site. Damaged glass is glass with edge damage or other imperfections that, when installed, weaken glass and impair performance and appearance.
- D. Apply primers to joint surfaces where required for adhesion of sealants, as determined by preconstruction sealant-substrate testing.
- E. Install setting blocks in sill rabbets, sized and located to comply with referenced glazing standard, unless otherwise required by glass manufacturer. Set blocks in thin course of compatible sealant suitable for heel bead.
- F. Do not exceed edge pressures stipulated by glass manufacturers for installing glass lites.
- G. Provide spacers for glass sizes larger than 50 united inches (length plus height) as follows:
  - 1. Locate spacers inside, outside, and directly opposite each other. Install correct size and spacing to preserve required face clearances, except where gaskets and glazing tapes are used that have demonstrated ability to maintain required face clearances and comply with system performance requirements.
  - 2. Provide 3-mm (1/8-inch) minimum bite of spacers on glass and use thickness equal to sealant width. With glazing tape, use thickness slightly less than final compressed thickness of tape.
- H. Provide edge blocking to comply with requirements of referenced glazing publications, unless otherwise required by glass manufacturer.
- I. Set glass lites in each series with uniform pattern, draw, bow, and similar characteristics.
- J. Where wedge-shaped gaskets are driven into one side of channel to pressurize sealant or gasket on opposite side, provide adequate anchorage so gasket cannot walk out when installation is subjected to movement.
- K. Square cut wedge-shaped gaskets at corners and install gaskets in manner recommended by gasket manufacturer to prevent corners from pulling away; seal corner joints and butt joints with sealant recommended by gasket manufacturer.

### 3.4 TAPE GLAZING

- A. Position tapes on fixed stops so that, when compressed by glass, their exposed edges are flush with or protrude slightly above sightline of stops.
- B. Install tapes continuously but not necessarily in one continuous length. Do not stretch tapes to make them fit opening.
- C. Where framing joints are vertical, cover these joints by applying tapes to heads and sills first and then to jambs. Where framing joints are horizontal, cover these joints by applying tapes to jambs and then to heads and sills.
- D. Place joints in tapes at corners of opening with adjoining lengths butted together, not lapped. Seal joints in tapes with compatible sealant approved by tape manufacturer.
- E. Do not remove release paper from tape until just before each lite is installed.
- F. Apply heel bead of elastomeric sealant, if required.
- G. Center glass lites in openings on setting blocks and press firmly against tape by inserting dense compression gaskets formed and installed to lock in place against faces of removable stops. Start gasket applications at corners and work toward centers of openings.
- H. Apply cap bead of elastomeric sealant over exposed edge of tape.

### 3.5 GASKET GLAZING (DRY)

- A. Fabricate compression gaskets in lengths recommended by gasket manufacturer to fit openings exactly, with stretch allowance during installation.
- B. Insert soft compression gasket between glass and frame or fixed stop so it is securely in place with joints miter cut and bonded together at corners.
- C. Center glass lites in openings on setting blocks and press firmly against soft compression gasket by inserting dense compression gaskets formed and installed to lock in place against faces of removable stops. Start gasket applications at corners and work toward centers of openings. Compress gaskets to produce a weathertight seal without developing bending stresses in glass. Seal gasket joints with sealant recommended by gasket manufacturer.
- D. Install gaskets so they protrude past face of glazing stops.

### 3.6 SEALANT GLAZING (WET)

- A. Install continuous spacers, or spacers combined with cylindrical sealant backing, between glass lites and glazing stops to maintain glass face clearances and to prevent sealant from extruding into glass channel weep systems until sealants cure. Secure spacers or spacers and backings in place and in position to control depth of installed sealant relative to edge clearance for optimum sealant performance.
- B. Force sealants into glazing channels to eliminate voids and to ensure complete wetting or bond of sealant to glass and channel surfaces.

- C. Tool exposed surfaces of sealants to provide a substantial wash away from glass.

3.7 LOCK-STRIP GASKET GLAZING

- A. Comply with ASTM C 716 and gasket manufacturer's printed recommendations. Provide supplementary wet seal and weep system, unless otherwise indicated.

3.8 PROTECTION AND CLEANING

- A. Protect exterior glass from damage immediately after installation by attaching crossed streamers to framing held away from glass. Do not apply markers to glass surface. Remove nonpermanent labels, and clean surfaces.
- B. Protect glass from contact with contaminating substances resulting from construction operations including weld splatter. If, despite such protection, contaminating substances do come into contact with glass, remove them immediately as recommended by glass manufacturer.
- C. Examine glass surfaces adjacent to or below exterior concrete and other masonry surfaces at frequent intervals during construction, but not less than once a month, for build-up of dirt, scum, alkali deposits, or stains; remove as recommended by glass manufacturer.
- D. Remove and replace glass that is broken, chipped, cracked, abraded, or damaged in any way, including natural causes, accidents and vandalism, during construction period.
- E. Wash glass on both exposed surfaces in each area of Project not more than 4 days before date scheduled for inspections that establish date of Completion. Wash glass as recommended by glass manufacturer.

END OF SECTION 08 8000



SECTION 08 8700 - GLAZING SURFACE FILM

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Opacifying film; glazing applied.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: For each location.
  - 1. Show size of applied film including location of seams on each panel, if applicable.
- C. Samples for Verification: For each type of film showing all components and with the required finish(es), in size to verify selections made.

1.4 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For Installer and manufacturer.
- B. Sample Warranty: For special warranty.

1.5 QUALITY ASSURANCE

- A. Installer Qualifications: An entity that employs installers and supervisors who are certified by manufacturer.
  - 1. Installer shall have minimum 3 years experience working with similar products.
- B. Single Source Responsibility: All components for applied graphic film shall be as manufactured or recommended by graphic film manufacturer.

1.6 WARRANTY

- A. Special Warranty: Manufacturer agrees to repair or replace applied film that fails in materials within specified warranty period.
  - 1. Failures include, but are not limited to, the following:

- a. Discoloration of film.
- b. Failure of film in material.
2. Warranty Period: Five years from date of Substantial Completion.

B. Installation Warranty: Installer agrees to repair or replace applied graphic film that fails in workmanship within specified warranty period:

1. Failures include:
  - a. Separation or delamination of film from substrate.
2. Warranty Period: Two years from date of Substantial Completion.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

A. Opacifying Film:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Solyx; SXWF-WM or comparable product by one of the following:
  - a. 3M
  - b. Prestige.
2. Film shall have the following performance characteristics:
  - a. Material Thickness: 2 mils.
  - b. Color: White (matte).

B. Accessories:

1. Primer: As required by film manufacturer.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of signage work.
- B. Verify that metal surfaces receiving glazing surface film are free of burrs and deformations that would inhibit adhesion of film to substrate.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. General: Install glazing surface film using methods according to manufacturer's written instructions.
  1. Install film square and true to edge of panel.
  2. Apply film to the #2 surface for non-insulated units and #4 surface for insulated units (interior surface of existing glazing where indicated).

- B. Upon completion of film application, allow 30 days for moisture from film installation to dry thoroughly, and to allow film to dry flat with no moisture dimples when viewed under normal viewing conditions.

### 3.3 PROTECTION

- A. Remove left over material and debris from Work area. Use necessary means to protect film before, during, and after installation.
- B. Touch-up, repair or replace damaged products before Substantial Completion.
- C. After application of film, wash film using common window cleaning solutions, including ammonia solutions, 30 days after application. Do not use abrasive type cleaning agents and bristle brushes to avoid scratching film. Use synthetic sponges or soft cloths.

END OF SECTION

SECTION 088853 - SECURITY GLAZING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.
- B. Section 013513.16, General Detention Work Requirements.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Security glazing.
  - 2. Glazing accessories.
- B. Related Sections: The following Sections contain requirements that relate to this Section.
  - 1. Division 07 Section 079200 "Joint Sealants" for security sealants.
  - 2. Division 08 Section 081113 "Hollow Metal Doors and Frames."
  - 3. Division 08 Section 083463 "Detention Doors & Frames."
  - 4. Division 12 Section 125500 "Detention Furniture" for coordination with speak-port locations.

1.3 SCOPE AND RESPONSIBILITIES

- A. Under the requirements of this specification, the DEC shall be responsible for furnishing and installing all glass and glazing accessories, as specified, in all locations, unless indicated otherwise.
- B. PROVIDE OWNER WITH ATTIC STOCK: Provide 2 (two) spare pieces of security glazing for each size and glass type ordered. Ship attic stock separately. Upon delivery, check crate for broken or damaged glass and re-order as required to complete attic stock requirement. Leave attic stock crated as delivered from the manufacturer. Coordinate storage location with the owner and deliver attic stock crate(s) to the designated storage area prior to final inspection.
- C. Refer to the Modular Metal Detention Wall Panel System section for the related Scope of Work provided in that Section. Fully coordinate this Scope of Work with the Scope of Work shown in the Modular Metal Detention Wall Panel System sections.

1.4 PERFORMANCE REQUIREMENTS

- A. Provide security glazing that complies with the requirements listed below as indicated by the test ratings for specific glazing types.
1. H.P. White Laboratory, Inc.; HPW TP-0500.02.
  2. American Society for Testing and Materials; ASTM F-1915-12.
  3. Underwriter's Laboratories, Inc.; UL 752, UL 972.

1.5 SUBMITTALS

- A. General: Submit the following according to Conditions of Contract and Division 1 Specification Sections.
- B. Product data for each security glazing type, including type of materials, thickness, installation requirements, method of test, and performance. Submit 2 copies of the most recent literature & cleaning instructions and any other documentation deemed necessary to demonstrate compliance to the specification.
- C. Test reports showing compliance with specified requirements.
- D. Certification by manufacturer that products supplied comply with performance requirements specified.
- E. Maintenance data covering cleaning and protection requirements to include in the Operation and Maintenance Manual specified in Division 1.
- F. **Upon request** of the Architect, submit 2 samples, 12" square, of each type of security glazing product.
- G. Submit a composite detail of the glass and frame assembly. This detail shall show and define all products in the assembly including, but not limited to, the following: Frame, glass stop, glass, setting blocks, glazing tape, and sealant. All products used in the glazing composite must be compatible.
- H. It is the DEC's responsibility to coordinate detention/security items in this scope of work, and to answer all manufacturer questions or concerns that are not strictly design related. The DEC shall redline the manufacturers' individual shop drawings and/or schedules, and note corrections prior to submittal for Architectural/Consultant review. When multiple items are submitted by the manufacturer on a single cutsheet, the DEC shall note with an arrow, circle or note cloud, to show which product on the sheet is submitted for this scope of work. DEC submittals not reviewed and redlined prior to submittal to Architect/Consultant for final review, will be returned rejected.

1.6 QUALITY ASSURANCE

- A. Comply with ASTM F-1915-12 containment test for forced entry performance. Round robin testing is not acceptable.

- B. Certified Safety Glazing: Category II products complying with test requirements of 16 CFR 1201 and ANSI Z97.1, certified by Safety Glazing Certification Council, and permanently labeled.
- C. Manufacturer Qualifications: Firm with minimum 5 years experience in manufacturing security glazing products that are similar to those indicated for this Project and that have a record of successful in-service performance.
- D. Installer Qualifications: Engage an experienced Installer who has a minimum of 5 years experience in installing security glazing similar to that required for this Project.

#### 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Protect products according to manufacturer's recommendations. Specifically, avoid damage to glass edges, and prevent damage from temperature changes, sunlight, and moisture.
  - 1. Furnish polycarbonate materials with a strippable water resistant masking paper on exposed surfaces.

#### 1.8 PROJECT CONDITIONS

- A. Environmental Conditions: Do not install glazing when either air or substrate temperature exceeds the range recommended by sealant manufacturer or when substrate is wet, damp, or covered with snow, ice, or frost.
- B. Install bulk sealants only at air and substrate temperatures above 40 deg F (4 deg C).

#### 1.9 WARRANTY – LAMINATED PRODUCTS

- A. Warranty: Submit a written warranty, executed by manufacturer, agreeing to replace laminates that delaminate within 5 years from date of Substantial Completion. If delamination damage occurs and upon inspection is found beyond a reasonable doubt to be caused by security sealant contact with raw glazing edge, the DEC shall be responsible for replacing the glazing at their expense.
- B. Warranty shall not deprive the Owner of other rights the Owner may have under other provisions of the Contract Documents and will be in addition to and run concurrent with other warranties made by the Contractor under requirements of the Contract Documents.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

- A. Acceptable Manufacturers:

1. Global Security Glazing (Polycarbonate, Laminated Polycarbonate, Glass-Clad Polycarbonate & Fire Rated Glass)
2. Sheffield Plastics (Polycarbonate & Laminated Polycarbonate) (Pending Testing)
3. LTI Smart Glass (Glass-Clad Polycarbonate & Fire Rated Glass) (Pending Testing)
4. Dlubak Corporation (Polycarbonate, Laminated Polycarbonate, Glass-Clad Polycarbonate & Fire Rated Glass) (Pending Testing)

B. Acceptable Distributors:

1. Global Security Glazing, Selma, AL (800) 633-2513
2. Allied Protective Glazing LLC., Pittsfield, MA (413) 769-2909 (Pending Testing)
3. Cope Plastics, Hazelwood, MO (877) 528-2594 (Pending Testing)
4. Dlubak Corporation, Blairsville, PA (800) 800-2977 (Pending Testing)

C. Available Products: Unless pre-approved prior to bidding, provide the products specified.

D. The DEC and glazing manufacturer agree to comply with the requirements as defined in section 3.4 and to provide materials and warranty as required by the contract documents using the materials listed in section 2.5.

## 2.2 MATERIALS

A. Float Glass:

1. Clear Heat Strengthened Glass: ASTM C 1048, Condition A (uncoated surfaces), Class 1 (clear), Kind HS (heat strengthened).
2. Tinted Heat-Strengthened Glass: ASTM C 1048, Condition A (uncoated surfaces), Class 2 (tinted, heat-absorbing, and light-reducing), Kind HS (heat strengthened), tint color as specified with security glazing type.
3. Clear Tempered Glass: ASTM C 1048, Condition A (uncoated surfaces), Class 1 (clear), Kind FT (fully tempered). For use on windows on the exterior of the building only.
4. Chemically Tempered Glass: ASTM C 1036, Class 1 (clear) chemically tempered; edges seamed prior to tempering. For use on windows on the exterior of the building only.
5. ASTM C 1048, Condition A (uncoated surfaces), Class 1 (clear), Kind HS (heat strengthened).

B. Polycarbonate Sheet: Rigid, flat polycarbonate sheet; thickness as indicated.

1. Relative Burning Characteristics: Average extent of burning less than 1 inch, when tested per ASTM D 635, using the thickness of material indicated for Project.

## 2.3 GLASS CLAD POLYCARBONATE LAMINATES

A. Type SG1 – Interior

1. 1” clear glass clad polycarbonate laminate, equal to Global Security Glazing Secur-Tem + Poly SP028, or approved equal. H.P. White (TP-0500-03) Level B ballistics, WMFL

Level II – 60 minute physical attack, ASTM 1915-12 Grade 1 - 60 minute containment rated; of the following make up:

- a. 1/8" Clear heat strengthened glass
- b. .050" Urethane
- c. 1/4" Polycarbonate
- d. .025" Urethane
- e. 3/8" Polycarbonate
- f. .050" Urethane
- g. 1/8" Clear heat strengthened glass

B. Type SG1A – Exterior **cells**

1. 1-3/4" (Nominal) gray 1/4" gray Solarban 70XL Low-E HS glass clad polycarbonate laminate air-gap unit, equal to Global Security Glazing Secur-Tem + Poly SP028 with hermetically sealed air-gap insulation, or approved equal. H.P. White (TP-0500-03) Level B Ballistics, ASTM F 1915-12 Grade 1 – 60 minute containment rated; of the following make up:

- a. 1/4" Gray Solarban 70XL Low-E HS glass
- b. 3/8" Airspace
- c. 1/8" Heat Strengthened Glass
- d. .050" Urethane
- e. 1/4" Polycarbonate
- f. .025" Urethane
- g. 3/8" Polycarbonate
- h. .050" Urethane
- i. 1/8" Heat Strengthened Glass

C. Type SG1B – Interior **Control** (rated 20-45 minutes)

1. 1-13/16" UL fire rated for 45 minutes, equal to Global Security Glazing Ultimax 45-SP028G or approved equal. ASTM F1915-12 Grade 1 - 60 minute containment rated, HP White Level IV-TP-0500.03, WMFL level II. Glazing shall be installed with UL classified Rectorseal BlazeSeal

D. Type SG1C – Interior **Visitation/Control** (rated 90 minutes)

1. 1-13/16" UL fire rated for 90 minutes, equal to Global Security Glazing Ultimax 90-SP028G or approved equal. ASTM F1915-12 Grade 1 - 60 minute containment, HP White Level IV-TP-0500.03, WMFL level II. Containment ratings and physical attack ratings will be limited or omitted due to installation in commercial frames. Glazing shall be installed with UL classified Rectorseal BlazeSeal or per commercial frame manufacturer recommendations.

E. Type SG1D – Exterior, **Entry Vestibule** (rated 90 minutes)

1. 3" (Nominal) Gray Solarban 70XL Low-E HS glass clad polycarbonate laminate air-gap unit equal to Ultimax 90-SP019G/SB70XL or approved equal. ASTM F1915-12 Grade 2 - 40 minute containment rated, HP White Level III TP-0500.03, UL 9, UL 10C, WMFL



level III, Ballistics .38 Special- 3 shots, spall no penetration. Glazing shall be installed with UL classified Rectorseal BlazeSeal.

- a. 1/4" Solarban 70XL Low-E HS glass
- b. 1/2" Airspace
- c. 2-5/16" Clear Inferno Lite Ultimax 90-SP019G

F. Type SG2 – Interior

1. 3/4" clear glass clad polycarbonate laminate, equal to Global Security Glazing Secur-Tem + Poly SP019, or approved equal. H.P. White TP-0500.02 Level IV forced entry, WMFL Level III, ASTM F1915-12 Grade 2 – 40 minute containment, ASTM F 1233 9mm ballistic rating.
  - a. 1/8" Clear heat strengthened glass
  - b. .050" Urethane
  - c. 1/4" Polycarbonate
  - d. .025" Urethane
  - e. 1/8" Polycarbonate
  - f. .050" Urethane
  - g. 1/8" Clear heat strengthened glass

G. Type SG3 – Interior

1. 11/16" (Nominal) clear glass clad polycarbonate equal to Global Security Glazing Secur-Tem + Poly 2116 or approved equal. H.P. White TP-0500.02 Level II forced entry, ASTM F1915-12 Grade 3 – 20 minute containment, H.P. White TP-0500.02 Level B ballistic rating (Spall; no penetration); of the following makeup:
  - a. 1/8" Clear heat strengthened glass
  - b. .050" Urethane
  - c. 3/8" Polycarbonate
  - d. .050" Urethane
  - e. 1/8" Clear heat strengthened glass

H. Type SG3A – Exterior

1. 1-5/16" (Nominal) gray 1/4" gray Solarban 70XL Low-E HS glass clad polycarbonate laminate air-gap unit equal to Global Security Glazing Secur-Tem + 2116 or approved equal. H.P. White TP-0500.02 Level II forced entry, ASTM F1915-12 Grade 3 – 20 minute containment, H.P. White TP-0500.02 Level B ballistic rating (Spall; no penetration), ASTM F 1233-08 Class 2.7, ASTM C 1036-01, ASTM C 1048-04, ASTM C 1349-04, CPSC 16 CFR 1201 (Category I and II); of the following makeup:
  - a. 1/4" Gray Solarban 70XL Low-E HS glass
  - b. 3/8" Airspace
  - c. 1/8" Heat strengthened glass
  - d. .050" Urethane
  - e. 3/8" Polycarbonate
  - f. .050" Urethane

g. 1/8" Clear heat strengthened glass

I. Type SG3B – Interior (lite 105A only) Fire rated with one-way film

1. 13/16" (Nominal) UL fire rated glazing for 45 minutes in 1 hour rated masonry and door openings, equal to Global Security Glazing Inferno-Lite FRP -4510 with square pattern wire or approved equal. Glazing shall be installed with UL classified Rectorseal BlazeSeal; **POST APPLY LLUMAR R-20 SR CDF REFLECTIVE FLIM FACING INMATE SIDE**, to the following makeup:

- a. 1/4" Wire glass (Baroque)
- b. .050" Urethane
- c. 1/4" Polycarbonate
- d. .050" Urethane
- e. 1/4" Wire glass (Baroque)

2. Note: Containment ratings and physical attack ratings will be limited or omitted when installed in commercial frames.

J. Type SG4 - For Narrow Vision Lites

1. 1/4" MARGARD® shall be 1-ply, clear, extruded monolithic polycarbonate of 1/4" LEXAN® monolithic sheet with a MARGARD® surface.

K. Type SG5 - For Narrow Vision Lites (rated 20 min – 3 hr)

1. 5/16" (8mm) thick laminated fire-rated and impact safety-rated glazing material. Listed for use in doors, sidelites, transoms and borrowed lites with fire rating requirements ranging from 20 minutes to 3 hours as provided by FireLite Plus®. Install with UL classified Rectorseal Blaze Seal.

## 2.4 FABRICATION

- A. Fabricate glazing with bite and edge clearance dimensions, including tolerances, as recommended by manufacturer and GANA "Glazing Manual." Exception: Where specific bite dimensions are indicated on drawings, as required for proper securement of glazing in frames, comply with those dimensions.
- B. Cut or drill holes in laminated units as required or indicated.
- C. Grind exposed edges smooth, using methods recommended by manufacturer.
- D. Coordinate speak-port locations as indicated on architectural drawings, with glass manufacturer.

## 2.5 GLAZING ACCESSORIES

- A. Installation Materials-General: Select products that have appropriate performance characteristics as recommended by glazing manufacturer and that are compatible with materials they will contact.
  - 1. Provide a letter from the glass manufacturer that states all glazing materials submitted are compatible with the glass submitted.
- B. Glazing Tape:
  - 1. Pre-shimmed, 100 percent solids, polyisobutylene-butyl rubber with internal spacer rod.
  - 2. At fire rated openings, provide Rectorseal Blaze Seal.
- C. Glazing Sealant:
  - 1. **Provide at exterior side of exterior security glazing only:** One part silicone rubber meeting Federal Specification TT-S-00230C, Class A, ASTM C-920 Type S, Grade NS, Class 25; Equal to Dow Corning 795.
- D. Security Sealant:
  - 1. **Provide at all interior security glazing only:** Dynaflex SC. One part non-sag tamper resistant elastomeric STPU meeting Federal Specifications TT-S-00230C, Type II, Class B and ASTM C-920-98, Type S, Grade NS, Class 12.5 as manufactured by Picora. When applying directly to a polycarbonate surface, application area must be primed with Picora P-120 primer prior to use as required per published manufacturer recommendations.
- E. Setting Blocks:
  - 1. TPR (Thermoplastic rubber) with 70-90 shore "A" durometer hardness, chemically compatible with glazing components.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine frames and rabbets in which glazing is to be installed for possible damaging conditions. In particular, check for conditions that would void the manufacturer's warranty.
  - 1. Verify that minimum edge engagement of framing is 1 inch (25 mm).
- B. Submit Installer's report describing unacceptable conditions.
- C. Do not proceed with installation until unsatisfactory conditions have been corrected.

#### 3.2 PREPARATION

- A. Clean surfaces to receive glazing just before installing glazing.

### 3.3 INSTALLATION – GENERAL

- A. Comply with recommendations for installation contained in the GANA "Glazing Manual" and "Sealant Manual" except when specifically not recommended or prohibited by the glazing or glazing accessory manufacturer; comply with manufacturers' recommendations.
- B. Protect glazing from edge and surface damage during handling and installation.
- C. Do not install glazing that has edge or surface damage or defects that reduce glazing strength or diminish appearance.
- D. Permanently adhere setting and edge blocks to frame.
- E. Do not block weep holes.
- F. Applied Stops: Fasten as indicated, after glazing has been set in frame. Do not exert excess force on glazing and glazing spacers.
- G. Remove protective masking paper on polycarbonate materials only as required to set glazing.

### 3.4 TAPE GLAZING

- A. Install tape continuously, placed so that when compressed the exposed face will be 1/8 inch (3 mm nominal) below face of framing.
- B. Do not use joints in tape, except at corners; seal joints with compatible sealant
- C. After installation of stops, install security sealant over exposed tape on **both** sides of all security glass/polycarbonate **provided per this specification section and per 2.5.D.1** above.
  - 1. Security sealant shall be installed as a cap bead only and is never to come in contact with the raw cut edge of the glazing material. Setting blocks shall be installed in a heel bead of glazing sealant equal to Dow Corning 795 per 3.3.D above. If security sealant is found on raw glazing edge during inspection, the DEC shall be responsible for replacing the glass at their expense.
- D. Apply fillet bead of **Dow Corning 795** glazing sealant over exposed tape on exterior side of exterior glazing.

### 3.5 PROTECTION AND CLEANING

- A. Apply warning tape or bands across opening without touching glazing, immediately after installing glazing in frames.
- B. Do not apply tape or labels to glazing; remove temporary labels.
- C. Protect glazing during subsequent construction operations; remove dirt, contaminants, staining agents and other deposits promptly using manufacturer's recommended procedures.

- D. Replace glazing that is damaged.
- E. Provide final protection and maintain conditions in a manner acceptable to manufacturer and Installer that ensures that security glazing is without damage or deterioration at the time of Substantial Completion.
- F. Remove protective masking paper from polycarbonate glazing just prior to cleaning.
- G. Wash both sides of glazing not more than 10 days before inspections for Substantial Completion.

3.6 OWNER PERSONNEL INSTRUCTION

- A. Have manufacturers' maintenance instructions on hand at time of instruction.
- B. Instruct designated Owner personnel on maintaining security glazing.

END OF SECTION

**DIVISION 09 – FINISHES**



SECTION 09 2116.23 - GYPSUM BOARD SHAFT WALL ASSEMBLIES

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes gypsum board shaft-wall assemblies for the following:
  - 1. Chase enclosures at utility level of housing unit dayrooms.
  - 2. Sound wall assembly at dayroom walls.
- B. Related Sections include the following:
  - 1. Division 078446 Section "Fire-Resistive Joint Systems" for head-of-wall assemblies that incorporate gypsum board shaft-wall assemblies.

1.3 SUBMITTALS

- A. Product Data: For each gypsum board shaft-wall assembly indicated.

1.4 QUALITY ASSURANCE

- A. Fire-Resistance Ratings: Provide materials and construction identical to those of assemblies with fire-resistance ratings determined according to ASTM E 119, 2007 edition by a testing and inspecting agency.
- B. STC-Rated Assemblies: Provide materials and construction identical to those of assemblies tested according to ASTM E 90, 2004 edition and classified according to ASTM E 413 by a testing and inspecting agency.
- C. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination." Review methods and procedures for installing gypsum board shaft-wall assemblies including, but not limited to, the following:
  - 1. Fasteners proposed for anchoring nonstructural steel framing to building structure.
  - 2. Wiring devices in shaft-wall assemblies.
  - 3. Doors and other items penetrating shaft-wall assemblies.
  - 4. Mechanical work enclosed within shaft-wall assemblies.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Deliver materials in original packages, containers, and bundles bearing brand name and identification of manufacturer or supplier.



- B. Store materials inside under cover and keep them dry and protected against damage from weather, direct sunlight, surface contamination, corrosion, construction traffic, and other causes.
- C. Stack panels flat on leveled supports off floor or slab to prevent sagging.

#### 1.6 PROJECT CONDITIONS

- A. Environmental Limitations: Comply with ASTM C 840, 2007 edition requirements or with gypsum board manufacturer's written recommendations, whichever are more stringent.
- B. Do not install panels that are wet, moisture damaged, or mold damaged.
  - 1. Indications that panels are wet or moisture damaged include, but are not limited to, discoloration, sagging, and irregular shape.
  - 2. Indications that panels are mold damaged include, but are not limited to, fuzzy or splotchy surface contamination and discoloration.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. American Gypsum Company.
  - 2. BPB America Inc.
  - 3. G-P Gypsum.
  - 4. Lafarge North America Inc.
  - 5. National Gypsum Company.
  - 6. PABCO Gypsum.
  - 7. Temple-Inland Forest Products Corporation.
  - 8. USG Corporation.
  - 9. Corrugated Perforated Metal Panels:
    - a. Alpro Acoustical Systems.
    - b. Noise Control Systems.

#### 2.2 GYPSUM BOARD SHAFT-WALL ASSEMBLIES, GENERAL

- A. Provide materials and components complying with requirements of fire-resistance-rated assemblies indicated.
  - 1. Provide panels in maximum lengths available to eliminate or minimize end-to-end butt joints.
  - 2. Provide auxiliary materials complying with gypsum board shaft-wall assembly manufacturer's written recommendations.

#### 2.3 PANEL PRODUCTS

- A. Gypsum Liner Panels: Comply with ASTM C 442/C 442M.

1. Moisture- and Mold-Resistant Type X: Manufacturer's proprietary liner panels with moisture- and mold-resistant core and surfaces; comply with ASTM D 3273.
  - a. Core: 1 inch (25.4 mm) thick.
  - b. Long Edges: Double bevel.
- B. Corrugated Perforated Metal Panel: Nominal 0.875 inch (22 MM) deep pre-finished corrugated panel with 2.67 inch (68 mm) pitch, perforated with 0.125 inch (3 mm) holes on 0.325 inch (8.3 mm) centers for approximately 13.3% open area.
  1. Material: 0.032 inch (0.8 mm) aluminum or 0.020 inch (0.5 mm) aluminum-zinc coated steel.
  2. Accessories: Manufacturer's standard brake formed "J" trim, "Z" furring, and inside/outside angles as required.
  3. Finish: Manufacturers standard 2-coat fluopolymer coating. (Alpro-Regal White)
    - a. Color: As selected by Architect from manufacturer'

#### 2.4 NON-LOAD-BEARING STEEL FRAMING

- A. Framing Members: Comply with ASTM C 754 for conditions indicated.
- B. Steel Sheet Components: Comply with ASTM C 645 requirements for metal, unless otherwise indicated.
  1. Protective Coating: ASTM A 653/A 653M, G60 (Z180), hot-dip galvanized, unless otherwise indicated.

#### 2.5 AUXILIARY MATERIALS

- A. General: Provide auxiliary materials that comply with referenced product standards and manufacturer's written recommendations.
- B. Trim Accessories: Cornerbead, edge trim, and control joints of material and shapes specified in Division 09 Section "Gypsum Board" that comply with gypsum board shaft-wall assembly manufacturer's written recommendations for application indicated.
- C. Gypsum Board Joint-Treatment Materials: As specified in Division 09 Section "Gypsum Board."
- D. Steel Drill Screws: ASTM C 1002, unless otherwise indicated.
- E. Track Fasteners: Power-driven fasteners of size and material required to withstand loading conditions imposed on shaft-wall assemblies without exceeding allowable design stress of track, fasteners, or structural substrates in which anchors are embedded.
  1. Expansion Anchors: Fabricated from corrosion-resistant materials, with capability to sustain, without failure, a load equal to 5 times design load, as determined by testing per ASTM E 488 conducted by a qualified testing agency.
  2. Power-Actuated Anchors: Fastener system of type suitable for application indicated, fabricated from corrosion-resistant materials, with capability to sustain, without failure, a load equal to 10 times design load, as determined by testing per ASTM E 1190 conducted by a qualified testing agency.

- F. Sound Attenuation Blankets: ASTM C 665, Type I (blankets without membrane facing), produced by combining thermosetting resins with mineral fibers manufactured from glass, slag wool, or rock wool.
  - 1. Color: Provide white color sound attenuation blankets.
- G. Acoustical Sealant: As specified in Division 07 Section "Joint Sealants."

## 2.6 GYPSUM BOARD SHAFT-WALL ASSEMBLIES

- A. Fire or Smoke-Resistance Rating: As indicated.
- B. STC Rating: 51, minimum.
- C. Studs: Manufacturer's standard profile for repetitive members, corner and end members, and fire-resistance-rated assembly indicated.
  - 1. Depth: 4 inches (102 mm).
  - 2. Minimum Base-Metal Thickness: 0.0329 inch (0.84 mm).
- D. Runner Tracks: Manufacturer's standard J-profile track with long-leg length as standard with manufacturer, but at least 2 inches (51 mm) long and in depth matching studs.
  - 1. Minimum Base-Metal Thickness: Matching steel studs.
- E. Firestop Tracks: Top runner manufactured to allow partition heads to expand and contract with movement of structure while maintaining continuity of fire-resistance-rated assembly indicated; in thickness not less than indicated for studs and in width to accommodate depth of studs.
  - 1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Dietrich Metal Framing; The System by Metal-Lite, Inc.
    - b. Fire Trak Corp.; Fire Trak.
- F. Jamb Struts: Manufacturer's standard J-profile strut with long-leg length of 3 inches (76 mm), in depth matching studs, and not less than 0.0329 inch (0.84 mm) thick.
- G. Room-Side Finish: Corrugated Perforated Metal Panel.
- H. Shaft-Side Finish: Taped and sealed to provide smoke rated assembly.
- I. Insulation: Sound attenuation blankets.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates to which gypsum board shaft-wall assemblies attach or abut, with Installer present, including hollow-metal frames, elevator hoistway door frames, cast-in anchors, and structural framing. Examine for compliance with requirements for installation tolerances and other conditions affecting performance.

- B. Examine panels before installation. Reject panels that are wet, moisture damaged, or mold damaged.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. General: Install gypsum board shaft-wall assemblies to comply with requirements of fire-resistance-rated assemblies indicated, manufacturer's written installation instructions, and the following:
  - 1. ASTM C 754 for installing steel framing except comply with framing spacing indicated.
  - 2. Division 09 Section "Gypsum Board" for applying and finishing panels.
- B. Do not bridge architectural or building expansion joints with shaft-wall assemblies; frame both sides of expansion joints with furring and other support.
- C. Install supplementary framing in gypsum board shaft-wall assemblies around openings and as required for blocking, bracing, and support of gravity and pullout loads of fixtures, equipment, services, heavy trim, furnishings, and similar items that cannot be supported directly by shaft-wall assembly framing.
  - 1. For attachment of Corrugated Metal Panels to shaft-wall assemblies, provide galvanized steel reinforcing strip with 0.0312-inch (0.79-mm) minimum thickness of base (uncoated) metal, accurately positioned and secured behind Corrugated Metal Panels. Attach reinforcing strips directly to shaft-wall studs at 16 inches (406 mm) on center vertically.
- D. At penetrations in shaft wall, maintain fire and/or smoke-resistance rating of shaft-wall assembly by installing supplementary steel framing around perimeter of penetration and fire protection behind boxes containing wiring devices, elevator call buttons, elevator floor indicators, and similar items.
- E. Isolate perimeter of gypsum panels from building structure to prevent cracking of panels, while maintaining continuity of fire-rated construction.
- F. Firestop Tracks: Where indicated, install to maintain continuity of fire-resistance-rated assembly indicated.
- G. Control Joints: Install control joints according to ASTM C 840 and in specific locations approved by Architect, while maintaining fire-resistance rating of gypsum board shaft-wall assemblies.
- H. Seal gypsum board shaft walls with acoustical sealant at perimeter of each assembly where it abuts other work and at joints and penetrations within each assembly. Install acoustical sealant to withstand dislocation by air-pressure differential between shaft and external spaces; maintain an airtight and smoke-tight seal; and comply with ASTM C 919 requirements or with manufacturer's written instructions, whichever are more stringent.
- I. Installation Tolerance: Install each framing member so fastening surfaces vary not more than 1/8 inch (3mm) from the plane formed by faces of adjacent framing.

3.3 PROTECTION

- A. Protect installed products from damage from weather, condensation, direct sunlight, construction, and other causes during remainder of the construction period.
- B. Remove and replace panels that are wet, moisture damaged, or mold damaged.
  - 1. Indications that panels are wet or moisture damaged include, but are not limited to, discoloration, sagging, and irregular shape.
  - 2. Indications that panels are mold damaged include, but are not limited to, fuzzy or splotchy surface contamination and discoloration.

END OF SECTION 09 2116.23

SECTION 09 2216 - NON-STRUCTURAL METAL FRAMING

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. Section Includes:
  - 1. Non-load-bearing steel framing systems for interior gypsum board assemblies.
  - 2. Suspension systems for interior gypsum ceilings, soffits, and grid systems.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Fire-Test-Response Characteristics: For fire-resistance-rated assemblies that incorporate non-load-bearing steel framing, provide materials and construction identical to those tested in assembly indicated, according to ASTM E 119, 2007 edition by an independent testing agency.
- B. STC-Rated Assemblies: For STC-rated assemblies, provide materials and construction identical to those tested in assembly indicated, according to ASTM E 90, 2004 edition and classified according to ASTM E 413 by an independent testing agency.

2.2 FRAMING SYSTEMS

- A. Recycled Content of Steel Products: Postconsumer recycled content plus one-half of preconsumer recycled content not less than 25 percent.
- B. Framing Members, General: Comply with ASTM C 754 for conditions indicated.
  - 1. Steel Sheet Components: Comply with ASTM C 645 requirements for metal unless otherwise indicated.
  - 2. Protective Coating: Hot-dip galvanized unless otherwise indicated.
- C. Studs and Runners: ASTM C 645. Use either steel studs and runners or dimpled steel studs and runners.

1. Steel Studs and Runners:
    - a. Minimum Base-Metal Thickness: As indicated on Drawings. If not indicated, use 0.033 inch.
    - b. Depth: As indicated on Drawings. Where not indicated, use 3-5/8 inches.
  2. Dimpled Steel Studs and Runners:
    - a. Minimum Base-Metal Thickness: As indicated on Drawings. If not indicated, use 0.025 inch.
    - b. Depth: As indicated on Drawings. Where not indicated, use 3-5/8 inches.
- D. Slip-Type Head Joints: Where indicated, provide one of the following:
1. Single Long-Leg Runner System: ASTM C 645 top runner with 2-inch-deep flanges in thickness not less than indicated for studs, installed with studs friction fit into top runner and with continuous bridging located within 12 inches of the top of studs to provide lateral bracing.
  2. Double-Runner System: ASTM C 645 top runners, inside runner with 2-inch-deep flanges in thickness not less than indicated for studs and fastened to studs, and outer runner sized to friction fit inside runner.
  3. Deflection Track: Steel sheet top runner manufactured to prevent cracking of finishes applied to interior partition framing resulting from deflection of structure above; in thickness not less than indicated for studs and in width to accommodate depth of studs.
    - a. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
      - 1) Dietrich Metal Framing; SLP-TRK Slotted Deflection Track.
      - 2) MBA Building Supplies; Slotted Deflecto Track.
      - 3) Steel Network Inc. (The); VertiTrack VTD Series.
      - 4) Superior Metal Trim; Superior Flex Track System (SFT).
      - 5) Telling Industries; Vertical Slip Track II.
- E. Firestop Tracks: Top runner manufactured to allow partition heads to expand and contract with movement of the structure while maintaining continuity of fire-resistance-rated assembly indicated; in thickness not less than indicated for studs and in width to accommodate depth of studs.
1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Fire Trak Corp.; Fire Trak System attached to studs with Fire Trak Posi Klip.
    - b. Grace Construction Products; FlameSafe FlowTrak System.
    - c. Metal-Lite, Inc.; The System.
- F. Flat Strap and Backing Plate: Steel sheet for blocking and bracing in length and width indicated.
1. Minimum Base-Metal Thickness: 0.027 inch.
- G. Cold-Rolled Channel Bridging: Steel, 0.053-inch minimum base-metal thickness, with minimum 1/2-inch-wide flanges.
1. Depth: 1-1/2 inches.
  2. Clip Angle: Not less than 1-1/2 by 1-1/2 inches 0.068-inch-thick, galvanized steel.
- H. Hat-Shaped, Rigid Furring Channels: ASTM C 645.

1. Minimum Base-Metal Thickness: 0.033 inch.
  2. Depth: 7/8 inch or as indicated on drawings.
- I. Resilient Furring Channels: 1/2-inch-deep, steel sheet members designed to reduce sound transmission.
1. Configuration: Asymmetrical or hat shaped.
- J. Cold-Rolled Furring Channels: 0.053-inch uncoated-steel thickness, with minimum 1/2-inch-wide flanges.
1. Depth: 3/4 inch or as indicated on drawings..
  2. Furring Brackets: Adjustable, corrugated-edge type of steel sheet with minimum uncoated-steel thickness of 0.033 inch.
  3. Tie Wire: ASTM A 641/A 641M, Class 1 zinc coating, soft temper, 0.062-inch-diameter wire, or double strand of 0.048-inch-diameter wire.
- K. Z-Shaped Furring: With slotted or nonslotted web, face flange of 1-1/4 inches, wall attachment flange of 7/8 inch, minimum uncoated-metal thickness of 0.018 inch, and depth required to fit insulation thickness indicated.

## 2.3 SUSPENSION SYSTEMS

- A. Tie Wire: ASTM A 641/A 641M, Class 1 zinc coating, soft temper, 0.062-inch-diameter wire, or double strand of 0.048-inch-diameter wire.
- B. Hanger Attachments to Concrete:
1. Anchors: Fabricated from corrosion-resistant materials with holes or loops for attaching wire hangers and capable of sustaining, without failure, a load equal to 5 times that imposed by construction as determined by testing according to ASTM E 488 by an independent testing agency.
    - a. Type: As required for the surrounding construction.
  2. Powder-Actuated Fasteners: Suitable for application indicated, fabricated from corrosion-resistant materials with clips or other devices for attaching hangers of type indicated, and capable of sustaining, without failure, a load equal to 10 times that imposed by construction as determined by testing according to ASTM E 1190 by an independent testing agency.
- C. Wire Hangers: ASTM A 641/A 641M, Class 1 zinc coating, soft temper, 0.16 inch in diameter.
- D. Flat Hangers: Steel sheet, 1 by 3/16 inch by length indicated.
- E. Carrying Channels: Cold-rolled, commercial-steel sheet with a base-metal thickness of 0.053 inch and minimum 1/2-inch-wide flanges.
1. Depth: 2-1/2 inches or as indicated on drawings.
- F. Furring Channels (Furring Members):



1. Cold-Rolled Channels: 0.053-inch (1.34-mm) uncoated-steel thickness, with minimum 1/2-inch- (13-mm-) wide flanges, 3/4 inch (19 mm) deep.
  2. Steel Studs and Runners: ASTM C 645.
    - a. Minimum Base-Metal Thickness: 0.033 inch.
    - b. Depth: 2-1/2 inches or as indicated on drawings.
  3. Dimpled Steel Studs and Runners: ASTM C 645.
    - a. Minimum Base-Metal Thickness: 0.025 inch.
    - b. Depth: 2-1/2 inches or as indicated on drawings.
  4. Hat-Shaped, Rigid Furring Channels: ASTM C 645, 7/8 inch deep.
    - a. Minimum Base-Metal Thickness: 0.033 inch.
  5. Resilient Furring Channels: 1/2-inch-deep members designed to reduce sound transmission.
    - a. Configuration: Asymmetrical or hat shaped.
- G. Grid Suspension System for Gypsum Board Ceilings: ASTM C 645, direct-hung system composed of main beams and cross-furring members that interlock.
1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Armstrong World Industries, Inc.; Drywall Grid Systems.
    - b. Chicago Metallic Corporation; Drywall Grid System.
    - c. USG Corporation; Drywall Suspension System.

#### 2.4 AUXILIARY MATERIALS

- A. General: Provide auxiliary materials that comply with referenced installation standards.
1. Fasteners for Metal Framing: Of type, material, size, corrosion resistance, holding power, and other properties required to fasten steel members to substrates.
- B. Isolation Strip at Exterior Walls: Provide the following:
1. Foam Gasket: Adhesive-backed, closed-cell vinyl foam strips that allow fastener penetration without foam displacement, 1/8 inch thick, in width to suit steel stud size.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine areas and substrates, with Installer present, and including welded hollow-metal frames, cast-in anchors, and structural framing, for compliance with requirements and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. Suspended Assemblies: Coordinate installation of suspension systems with installation of overhead structure to ensure that inserts and other provisions for anchorages to building structure have been installed to receive hangers at spacing required to support the Work and that hangers will develop their full strength.
  - 1. Furnish concrete inserts and other devices indicated to other trades for installation in advance of time needed for coordination and construction.
- B. Coordination with Sprayed Fire-Resistive Materials:
  - 1. Before sprayed fire-resistive materials are applied, attach offset anchor plates or ceiling runners (tracks) to surfaces indicated to receive sprayed fire-resistive materials. Where offset anchor plates are required, provide continuous plates fastened to building structure not more than 24 inches o.c.
  - 2. After sprayed fire-resistive materials are applied, remove them only to extent necessary for installation of non-load-bearing steel framing. Do not reduce thickness of fire-resistive materials below that required for fire-resistance ratings indicated. Protect adjacent fire-resistive materials from damage.

### 3.3 INSTALLATION, GENERAL

- A. Installation Standard: ASTM C 754.
  - 1. Gypsum Plaster Assemblies: Also comply with requirements in ASTM C 841 that apply to framing installation.
  - 2. Portland Cement Plaster Assemblies: Also comply with requirements in ASTM C 1063 that apply to framing installation.
  - 3. Gypsum Veneer Plaster Assemblies: Also comply with requirements in ASTM C 844 that apply to framing installation.
  - 4. Gypsum Board Assemblies: Also comply with requirements in ASTM C 840 that apply to framing installation.
- B. Install supplementary framing, and blocking to support fixtures, equipment services, heavy trim, grab bars, toilet accessories, furnishings, or similar construction.
- C. Install bracing at terminations in assemblies.
- D. Do not bridge building control and expansion joints with non-load-bearing steel framing members. Frame both sides of joints independently.

### 3.4 INSTALLING FRAMED ASSEMBLIES

- A. Install framing system components according to spacings indicated, but not greater than spacings required by referenced installation standards for assembly types.
  - 1. Single-Layer Application: 16 inches o.c. unless otherwise indicated.
  - 2. Multilayer Application: 16 inches o.c. unless otherwise indicated.

3. Tile Backing Panels: 16 inches o.c. unless otherwise indicated.
- B. Where studs are installed directly against exterior masonry walls or dissimilar metals at exterior walls, install isolation strip between studs and exterior wall.
- C. Install studs so flanges within framing system point in same direction.
- D. Install tracks (runners) at floors and overhead supports. Extend framing full height to structural supports or substrates above suspended ceilings except where partitions are indicated to terminate at suspended ceilings. Continue framing around ducts penetrating partitions above ceiling.
  1. Slip-Type Head Joints: Where framing extends to overhead structural supports, install to produce joints at tops of framing systems that prevent axial loading of finished assemblies.
  2. Door Openings: Screw vertical studs at jambs to jamb anchor clips on door frames; install runner track section (for cripple studs) at head and secure to jamb studs.
    - a. Install two studs at each jamb unless otherwise indicated.
    - b. Install cripple studs at head adjacent to each jamb stud, with a minimum 1/2-inch clearance from jamb stud to allow for installation of control joint in finished assembly.
    - c. Extend jamb studs through suspended ceilings and attach to underside of overhead structure.
  3. Other Framed Openings: Frame openings other than door openings the same as required for door openings unless otherwise indicated. Install framing below sills of openings to match framing required above door heads.
  4. Fire-Resistance-Rated Partitions: Install framing to comply with fire-resistance-rated assembly indicated and support closures and to make partitions continuous from floor to underside of solid structure.
    - a. Firestop Track: Where indicated, install to maintain continuity of fire-resistance-rated assembly indicated.
  5. Sound-Rated Partitions: Install framing to comply with sound-rated assembly indicated.
  6. Curved Partitions:
    - a. Bend track to uniform curve and locate straight lengths so they are tangent to arcs.
    - b. Begin and end each arc with a stud, and space intermediate studs equally along arcs. On straight lengths of no fewer than two studs at ends of arcs, place studs 6 inches o.c.
- E. Direct Furring:
  1. Screw to wood framing.
  2. Attach to concrete or masonry with stub nails, screws designed for masonry attachment, or powder-driven fasteners spaced 24 inches o.c.
- F. Z-Furring Members:
  1. Erect insulation, specified in Section 07 2100 "Thermal Insulation," vertically and hold in place with Z-furring members spaced 24 inches o.c.
  2. Except at exterior corners, securely attach narrow flanges of furring members to wall with concrete stub nails, screws designed for masonry attachment, or powder-driven fasteners spaced 24 inches o.c.

3. At exterior corners, attach wide flange of furring members to wall with short flange extending beyond corner; on adjacent wall surface, screw-attach short flange of furring channel to web of attached channel. At interior corners, space second member no more than 12 inches from corner and cut insulation to fit.

- G. Installation Tolerance: Install each framing member so fastening surfaces vary not more than 1/8 inch from the plane formed by faces of adjacent framing.

### 3.5 INSTALLING SUSPENSION SYSTEMS

- A. Install suspension system components according to spacings indicated, but not greater than spacings required by referenced installation standards for assembly types.

1. Hangers: 48 inches o.c.
2. Carrying Channels (Main Runners): 48 inches o.c.
3. Furring Channels (Furring Members): 16 inches o.c.

- B. Isolate suspension systems from building structure where they abut or are penetrated by building structure to prevent transfer of loading imposed by structural movement.

- C. Suspend hangers from building structure as follows:

1. Install hangers plumb and free from contact with insulation or other objects within ceiling plenum that are not part of supporting structural or suspension system.
  - a. Splay hangers only where required to miss obstructions and offset resulting horizontal forces by bracing, countersplaying, or other equally effective means.
2. Where width of ducts and other construction within ceiling plenum produces hanger spacings that interfere with locations of hangers required to support standard suspension system members, install supplemental suspension members and hangers in the form of trapezes or equivalent devices.
  - a. Size supplemental suspension members and hangers to support ceiling loads within performance limits established by referenced installation standards.
3. Wire Hangers: Secure by looping and wire tying, either directly to structures or to inserts, eye screws, or other devices and fasteners that are secure and appropriate for substrate, and in a manner that will not cause hangers to deteriorate or otherwise fail.
4. Flat Hangers: Secure to structure, including intermediate framing members, by attaching to inserts, eye screws, or other devices and fasteners that are secure and appropriate for structure and hanger, and in a manner that will not cause hangers to deteriorate or otherwise fail.
5. Do not attach hangers to steel roof deck.
6. Do not attach hangers to permanent metal forms. Furnish cast-in-place hanger inserts that extend through forms.
7. Do not attach hangers to rolled-in hanger tabs of composite steel floor deck.
8. Do not connect or suspend steel framing from ducts, pipes, or conduit.

- D. Fire-Resistance-Rated Assemblies: Wire tie furring channels to supports.

- E. Seismic Bracing: Sway-brace suspension systems with hangers used for support.

- F. Grid Suspension Systems: Attach perimeter wall track or angle where grid suspension systems meet vertical surfaces. Mechanically join main beam and cross-furring members to each other and butt-cut to fit into wall track.
- G. Installation Tolerances: Install suspension systems that are level to within 1/8 inch in 12 feet measured lengthwise on each member that will receive finishes and transversely between parallel members that will receive finishes.

END OF SECTION 09 2216

SECTION 09 2900 - GYPSUM BOARD

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Interior gypsum board.
  - 2. Tile backing panels/cementitious backer units.
  - 3. Gypsum Board Assemblies with Security Barrier Mesh
- B. Related Sections include the following:
  - 1. Division 072100 Section "Thermal Insulation" for insulation and vapor retarders installed in assemblies that incorporate gypsum board.
  - 2. Division 078446 Section "Fire-Resistive Joint Systems" for head-of-wall assemblies that incorporate gypsum board.
  - 3. Division 092216 Section "Non-Structural Metal Framing" for non-structural framing and suspension systems that support gypsum board.
  - 4. Division 092116.23 Section "Gypsum Board Shaft-Wall Assemblies" for metal shaft-wall framing, gypsum shaft liners, and other components of shaft-wall assemblies.
  - 5. Division 09 painting Sections for primers applied to gypsum board surfaces.

1.3 SUBMITTALS

- A. Product Data: For each type of product indicated.

1.4 QUALITY ASSURANCE

- A. Fire-Resistance-Rated Assemblies: For fire-resistance-rated assemblies, provide materials and construction identical to those tested in assembly indicated according to ASTM E 119, 2007 edition by an independent testing agency.
- B. STC-Rated Assemblies: For STC-rated assemblies, provide materials and construction identical to those tested in assembly indicated according to ASTM E 90 and classified according to ASTM E 413 by an independent testing agency.

1.5 STORAGE AND HANDLING

- A. Store materials inside under cover and keep them dry and protected against damage from weather, condensation, direct sunlight, construction traffic, and other causes. Stack panels flat to prevent sagging.

1.6 PROJECT CONDITIONS

- A. Environmental Limitations: Comply with ASTM C 840, 2007 edition requirements or gypsum board manufacturer's written recommendations, whichever are more stringent.
- B. Do not install interior products until installation areas are enclosed and conditioned.
- C. Do not install panels that are wet, those that are moisture damaged, and those that are mold damaged.
  - 1. Indications that panels are wet or moisture damaged include, but are not limited to, discoloration, sagging, or irregular shape.
  - 2. Indications that panels are mold damaged include, but are not limited to, fuzzy or splotchy surface contamination and discoloration.

PART 2 - PRODUCTS

2.1 PANELS, GENERAL

- A. Size: Provide in maximum lengths and widths available that will minimize joints in each area and that correspond with support system indicated.

2.2 INTERIOR GYPSUM BOARD

- A. General: Complying with ASTM C 36/C 36M or ASTM C 1396/C 1396M, 2006 edition as applicable to type of gypsum board indicated and whichever is more stringent.
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. American Gypsum Co.
    - b. BPB America Inc. (Certainteed GlasRoc)
    - c. G-P Gypsum.
    - d. Lafarge North America Inc.
    - e. National Gypsum Company.
    - f. PABCO Gypsum.
    - g. Temple.
    - h. USG Corporation.
- B. Type X:
  - 1. Thickness: 5/8 inch (15.9 mm).

2. Long Edges: Tapered.
- C. Abuse-Resistant Type: Manufactured to produce greater resistance to surface indentation, through-penetration (impact resistance), and abrasion than standard, regular-type and Type X gypsum board.
1. Core: 5/8 inch (15.9 mm), Type X.
  2. Long Edges: Tapered.
- D. Moisture- and Mold-Resistant Type: With moisture- and mold-resistant core and surfaces.
1. Core: 5/8 inch (15.9 mm), Type X.
  2. Long Edges: Tapered.

## 2.3 TILE BACKING PANELS

- A. Cementitious Backer Units: ANSI A118.9.
1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, the following:
  2. Products: Subject to compliance with requirements, provide one of the following:
    - a. Custom Building Products; Wonderboard.
    - b. FinPan, Inc.; Util-A-Crete Concrete Backer Board. (Certaineed Glasroc tile backer)
    - c. USG Corporation; DUROCK Cement Board.
  3. Thickness: 5/8 inch (15.9 mm).

## 2.4 TRIM ACCESSORIES

- A. Interior Trim: ASTM C 1047.
1. Material: Galvanized or aluminum-coated steel sheet or rolled zinc.
  2. Shapes:
    - a. Cornerbead. (Award Metals)
    - b. LC-Bead: J-shaped; exposed long flange receives joint compound.
    - c. Expansion (control) joint.
- B. Exterior Trim: ASTM C 1047.
1. Material: [Hot-dip galvanized steel sheet, plastic, or rolled zinc] <Insert material>.
  2. Shapes:
    - a. Cornerbead.
    - b. LC-Bead: J-shaped; exposed long flange receives joint compound.
    - c. Expansion (Control) Joint: One-piece, rolled zinc with V-shaped slot and removable strip covering slot opening.

## 2.5 JOINT TREATMENT MATERIALS

- A. General: Comply with ASTM C 475, 2005 edition
- B. Joint Tape:
1. Interior Gypsum Wallboard: Paper. (Westpac)
  2. Tile Backing Panels: As recommended by panel manufacturer.



- C. Joint Compound for Interior Gypsum Wallboard: For each coat use formulation that is compatible with other compounds applied on previous or for successive coats.
  - 1. Prefilling: At open joints and damaged surface areas, use setting-type taping compound.
  - 2. Embedding and First Coat: For embedding tape and first coat on joints, fasteners, and trim flanges, use drying-type, all-purpose compound.
    - a. Use setting-type compound for installing paper-faced metal trim accessories.
  - 3. Fill Coat: For second coat, use drying-type, all-purpose compound.
  - 4. Finish Coat: For third coat, use drying-type, all-purpose compound.
  - 5. Skim Coat: For final coat of Level 5 finish, use high-build interior coating product designed for application by airless sprayer and to be used instead of skim coat to produce Level 5 finish.
  
- D. Joint Compound for Tile Backing Panels:
  - 1. Cementitious Backer Units: As recommended by backer unit manufacturer.
  
- E. Security Barrier Mesh: Carbon steel security mesh complying with ASTM A569/569M, ASTM F1267, Type II, Class 1.
  - 1. Basis of Design: Subject to compliance with requirements provide AMICO; ASM .75-13F security mesh.
  - 2. Medium security mesh with maximum 3/4 inch (19mm) holes.
  - 3. Accessories
    - a. Screws: Manufacturer's standard screws for fastening mesh to substrate.
  
- A. b. Clips: Manufacturer's standard security clip for use with screws.

## 2.6 AUXILIARY MATERIALS

- A. General: Provide auxiliary materials that comply with referenced installation standards and manufacturer's written recommendations.
  
- B. Laminating Adhesive: Adhesive or joint compound recommended for directly adhering gypsum panels to continuous substrate.
  
- C. Steel Drill Screws: ASTM C 1002, 2004 edition, unless otherwise indicated.
  - 1. Use screws complying with ASTM C 954 for fastening panels to steel members from 0.033 to 0.112 inch (0.84 to 2.84 mm) thick.
  - 2. For fastening cementitious backer units, use screws of type and size recommended by panel manufacturer.
  
- D. Sound Attenuation Blankets: ASTM C 665, Type I (blankets without membrane facing) produced by combining thermosetting resins with mineral fibers manufactured from glass, slag wool, or rock wool.
  - 1. Fire-Resistance-Rated Assemblies: Comply with mineral-fiber requirements of assembly. (Knauf Ecobatt)
  
- E. Acoustical Sealant: As specified in Division 07 Section "Joint Sealants." (Hilti CF 810)
  
- F. Thermal Insulation: As specified in Division 07 Section "Thermal Insulation."
  
- G. Vapor Retarder: As specified in Division 07 Section "Thermal Insulation."

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas and substrates, with Installer present, and including welded hollow-metal frames and framing, for compliance with requirements and other conditions affecting performance.
- B. Examine panels before installation. Reject panels that are wet, moisture damaged, and mold damaged.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 APPLYING AND FINISHING PANELS, GENERAL

- A. Comply with ASTM C 840, 2007 edition.
- B. Install ceiling panels across framing to minimize the number of abutting end joints and to avoid abutting end joints in central area of each ceiling. Stagger abutting end joints of adjacent panels not less than one framing member.
- C. Install panels with face side out. Butt panels together for a light contact at edges and ends with not more than 1/16 inch (1.5 mm) of open space between panels. Do not force into place.
- D. Locate edge and end joints over supports, except in ceiling applications where intermediate supports or gypsum board back-blocking is provided behind end joints. Do not place tapered edges against cut edges or ends. Stagger vertical joints on opposite sides of partitions. Do not make joints other than control joints at corners of framed openings.
- E. Form control and expansion joints with space between edges of adjoining gypsum panels.
- F. Cover both faces of support framing with gypsum panels in concealed spaces (above ceilings, etc.), except in chases braced internally.
  - 1. Unless concealed application is indicated or required for sound, fire, air, or smoke ratings, coverage may be accomplished with scraps of not less than 8 sq. ft. (0.7 sq. m) in area.
  - 2. Fit gypsum panels around ducts, pipes, and conduits.
  - 3. Where partitions intersect structural members projecting below underside of floor/roof slabs and decks, cut gypsum panels to fit profile formed by structural members; allow 1/4- to 3/8-inch- (6.4- to 9.5-mm-) wide joints to install sealant.
- G. Isolate perimeter of gypsum board applied to non-load-bearing partitions at structural abutments, except floors. Provide 1/4- to 1/2-inch- (6.4- to 12.7-mm-) wide spaces at these locations, and trim edges with edge trim where edges of panels are exposed. Seal joints between edges and abutting structural surfaces with acoustical sealant.
- H. Attachment to Steel Framing: Attach panels so leading edge or end of each panel is attached to open (unsupported) edges of stud flanges first.

- I. STC-Rated Assemblies: Seal construction at perimeters, behind control joints, and at openings and penetrations with a continuous bead of acoustical sealant. Install acoustical sealant at both faces of partitions at perimeters and through penetrations. Comply with ASTM C 919 and with manufacturer's written recommendations for locating edge trim and closing off sound-flanking paths around or through assemblies, including sealing partitions above acoustical ceilings.

### 3.3 APPLYING INTERIOR GYPSUM BOARD

- A. Install interior gypsum board in the following locations:
  1. Type X: Vertical and ceiling surfaces, unless otherwise indicated.
  2. Abuse-Resistant/Impact-Penetration Resistant Type: At all inmate accessible spaces.
  3. Moisture- and Mold-Resistant Type: At moist environment rooms, including but not limited to toilet rooms, shower rooms, janitor closets, mechanical rooms and utility rooms.
- B. Single-Layer Application:
  1. On ceilings, apply gypsum panels before wall/partition board application to greatest extent possible and at right angles to framing, unless otherwise indicated.
  2. On partitions/walls, apply gypsum panels vertically (parallel to framing), unless otherwise indicated or required by fire-resistance-rated assembly, and minimize end joints.
    - a. Stagger abutting end joints not less than one framing member in alternate courses of panels.
    - b. At high walls, install panels horizontally, unless otherwise indicated or required by fire-resistance-rated assembly.
  3. On Z-furring members, apply gypsum panels vertically (parallel to framing) with no end joints. Locate edge joints over furring members.
  4. Fastening Methods: Apply gypsum panels to supports with steel drill screws.
- C. Multilayer Application:
  1. On partitions/walls, apply gypsum board indicated for base layers and face layers vertically (parallel to framing) with joints of base layers located over stud or furring member and face-layer joints offset at least one stud or furring member with base-layer joints, unless otherwise indicated or required by fire-resistance-rated assembly. Stagger joints on opposite sides of partitions.
  2. Fastening Methods: Fasten base layers and face layers separately to supports with screws.
- D. Laminating to Substrate: Where gypsum panels are indicated as directly adhered to a substrate (other than studs, joists, furring members, or base layer of gypsum board), comply with gypsum board manufacturer's written recommendations and temporarily brace or fasten gypsum panels until fastening adhesive has set.

### 3.4 APPLYING TILE BACKING PANELS

- A. Cementitious Backer Units: ANSI A108.11, at locations indicated on drawings.

- B. Where tile backing panels abut other types of panels in same plane, shim surfaces to produce a uniform plane across panel surfaces.

### 3.5 INSTALLING TRIM ACCESSORIES

- A. General: For trim with back flanges intended for fasteners, attach to framing with same fasteners used for panels. Otherwise, attach trim according to manufacturer's written instructions.
- B. Control Joints: Install control joints according to ASTM C 840, 2007 edition and at locations indicated on drawings.
- C. Interior Trim: Install in the following locations:
  - 1. Cornerbead: Use at outside corners.
  - 2. LC-Bead: Use at exposed panel edges.

### 3.6 Installing Security Barrier Mesh

- A. Where indicated install security barrier mesh under gypsum wall board per manufacturer's recommendations.
- B. But adjoining panels vertically on studs and attaché with screws and clips.
- C. Lap adjoining panels horizontally per manufacturer's recommendations.
- D. When installed in ceilings install similar to vertical stud requirements.

### 3.7 FINISHING GYPSUM BOARD

- A. General: Treat gypsum board joints, interior angles, edge trim, control joints, penetrations, fastener heads, surface defects, and elsewhere as required to prepare gypsum board surfaces for decoration. Promptly remove residual joint compound from adjacent surfaces.
- B. Prefill open joints and damaged surface areas.
- C. Apply joint tape over gypsum board joints, except those with trim having flanges not intended for tape.
- D. Gypsum Board Finish Levels: Finish panels to levels indicated below and according to ASTM C 840, 2007 edition:
  - 1. Level 1: Ceiling plenum areas, concealed areas, and where indicated.
  - 2. Level 4: At panel surfaces that will be exposed to view, unless otherwise indicated.
    - a. Primer and its application to surfaces are specified in other Division 09 painting Sections.
- E. Cementitious Backer Units: Finish according to manufacturer's written instructions.

3.8 PROTECTION

- A. Protect installed products from damage from weather, condensation, direct sunlight, construction, and other causes during remainder of the construction period.
- B. Remove and replace panels that are wet, moisture damaged, and mold damaged.
  - 1. Indications that panels are wet or moisture damaged include, but are not limited to, discoloration, sagging, or irregular shape.
  - 2. Indications that panels are mold damaged include, but are not limited to, fuzzy or splotchy surface contamination and discoloration.

END OF SECTION 09 2900

SECTION 09 5113 - ACOUSTICAL PANEL CEILINGS

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes acoustical panels and exposed suspension systems for ceilings.
- B. Products furnished, but not installed under this Section, include anchors, clips, and other ceiling attachment devices to be cast in concrete at ceilings.

1.3 DEFINITIONS

- A. AC: Articulation Class.
- B. CAC: Ceiling Attenuation Class.
- C. LR: Light Reflectance coefficient.
- D. NRC: Noise Reduction Coefficient.

1.4 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Coordination Drawings: Reflected ceiling plans, drawn to scale, on which the following items are shown and coordinated with each other, based on input from installers of the items involved:
  - 1. Ceiling suspension system members.
  - 2. Method of attaching hangers to building structure.
    - a. Furnish layouts for cast-in-place anchors, clips, and other ceiling attachment devices whose installation is specified in other Sections.
  - 3. Ceiling-mounted items including lighting fixtures, diffusers, grilles, speakers, sprinklers, access panels, and special moldings.
  - 4. Minimum Drawing Scale: 1/8 inch = 1 foot (1:96).
- C. Samples for Verification: For each component indicated and for each exposed finish required, prepared on Samples of size indicated below.
  - 1. Acoustical Panel: Set of 6-inch- (150-mm-) square Samples of each type, color, pattern, and texture.
  - 2. Exposed Suspension System Members, Moldings, and Trim: Set of 12-inch- (300-mm-) long Samples of each type, finish, and color.

- D. Qualification Data: For testing agency.
- E. Field quality-control test reports.
- F. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency, for each acoustical panel ceiling.
- G. Maintenance Data: For finishes to include in maintenance manuals.

#### 1.5 QUALITY ASSURANCE

- A. Source Limitations: Obtain each type of acoustical ceiling panel and supporting suspension system through one source from a single manufacturer.
- B. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination."

#### 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Deliver acoustical panels, suspension system components, and accessories to Project site in original, unopened packages and store them in a fully enclosed, conditioned space where they will be protected against damage from moisture, humidity, temperature extremes, direct sunlight, surface contamination, and other causes.
- B. Before installing acoustical panels, permit them to reach room temperature and a stabilized moisture content.
- C. Handle acoustical panels carefully to avoid chipping edges or damaging units in any way.

#### 1.7 PROJECT CONDITIONS

- A. Environmental Limitations: Do not install acoustical panel ceilings until spaces are enclosed and weatherproof, wet work in spaces is complete and dry, work above ceilings is complete, and ambient temperature and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.

#### 1.8 COORDINATION

- A. Coordinate layout and installation of acoustical panels and suspension system with other construction that penetrates ceilings or is supported by them, including light fixtures, HVAC equipment, fire-suppression system, and partition assemblies.

#### 1.9 EXTRA MATERIALS

- A. Furnish extra materials described below that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Acoustical Ceiling Panels: Full-size panels equal to 2.0 percent of quantity installed.

2. Suspension System Components: Quantity of each exposed component equal to 2.0 percent of quantity installed.
3. Hold-Down Clips: Equal to 2.0 percent of quantity installed.

## PART 2 - PRODUCTS

### 2.1 ACOUSTICAL PANELS, GENERAL

- A. Acoustical Panel Standard: Provide manufacturer's standard panels of configuration indicated that comply with ASTM E 1264 classifications as designated by types, patterns, acoustical ratings, and light reflectances, unless otherwise indicated.
  1. Mounting Method for Measuring NRC: Type E-400; plenum mounting in which face of test specimen is 15-3/4 inches (400 mm) away from test surface per ASTM E 795.
- B. Acoustical Panel Colors and Patterns: Match appearance characteristics indicated for each product type.

### 2.2 ACOUSTICAL PANELS FOR ACOUSTICAL PANEL CEILING

- A. Products: Subject to compliance with requirements, provide one of the following:
  1. Armstrong World Industries, Inc.; Cortega 769. (Certainteed HHF 197 Ceiling tile)
  2. Chicago Metallic Corporation; Artic (Recycled Content)
  3. USG Interiors, Inc.; Radar Panels (SQ).
- B. Classification: Provide panels complying with ASTM E 1264 for type, form, and pattern as follows:
  1. Type and Form: Type III, mineral base with painted finish; Form 2, water felted.
  2. Pattern: CD (perforated, small holes and fissured).
- C. Color:
  1. APC-1: White (All locations)
  2. APC-2: Black (Control Room)
- D. LR:
  1. APC-1 (White) Not less than 0.80.
  2. APC-2 (Black) Not less than 0.10.
- E. NRC: Not less than 0.55.
- F. CAC: Not less than 35.
- G. Edge/Joint Detail: Square.
- H. Thickness: 5/8 inch (15 mm).
- I. Modular Size: 24 by 48 inches (610 by 1220 mm).



## 2.3 METAL SUSPENSION SYSTEMS, GENERAL

- A. Metal Suspension System Standard: Provide manufacturer's standard direct-hung metal suspension systems of types, structural classifications, and finishes indicated that comply with applicable requirements in ASTM C 635.
- B. Finishes and Colors, General: Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes. Provide manufacturer's standard factory-applied finish for type of system indicated.
- C. Attachment Devices: Size for five times the design load indicated in ASTM C 635, Table 1, "Direct Hung," unless otherwise indicated. Comply with seismic design requirements.
  - 1. Anchors in Concrete: Anchors of type and material indicated below, with holes or loops for attaching hangers of type indicated and with capability to sustain, without failure, a load equal to five times that imposed by ceiling construction, as determined by testing per ASTM E 488 or ASTM E 1512 as applicable, conducted by a qualified testing and inspecting agency.
    - a. Type: Postinstalled expansion or Postinstalled bonded anchors.
    - b. Corrosion Protection: Carbon-steel components zinc plated to comply with ASTM B 633, Class Fe/Zn 5 (0.005 mm) for Class SC 1 service condition.
  - 2. Power-Actuated Fasteners in Concrete: Fastener system of type suitable for application indicated, fabricated from corrosion-resistant materials, with clips or other accessory devices for attaching hangers of type indicated, and with capability to sustain, without failure, a load equal to 10 times that imposed by ceiling construction, as determined by testing per ASTM E 1190, conducted by a qualified testing and inspecting agency.
- D. Wire Hangers, Braces, and Ties: Provide wires complying with the following requirements:
  - 1. Zinc-Coated, Carbon-Steel Wire: ASTM A 641/A 641M, Class 1 zinc coating, soft temper.
  - 2. Size: Select wire diameter so its stress at 3 times hanger design load (ASTM C 635, Table 1, "Direct Hung") will be less than yield stress of wire, but provide not less than 0.106-inch- (2.69-mm-) diameter wire.
- E. Hold-Down Clips: Where indicated, provide manufacturer's standard hold-down clips spaced 24 inches o.c. on all cross tees.

## 2.4 METAL SUSPENSION SYSTEM FOR ACOUSTICAL PANEL CEILING

- A. Products: Subject to compliance with requirements, provide one of the following:
  - 1. Armstrong World Industries, Inc.; Prelude 15/16" Exposed Tee System.
  - 2. Chicago Metallic Corporation; Seismic 1200.
  - 3. USG Interiors, Inc.; DONN Brand DX/DXL.

- B. Wide-Face, Capped, Double-Web, Steel Suspension System: Main and cross runners roll formed from cold-rolled steel sheet, prepainted, electrolytically zinc coated, or hot-dip galvanized according to ASTM A 653/A 653M, not less than G30 (Z90) coating designation, with prefinished 15/16-inch-wide metal caps on flanges.
1. Structural Classification: Intermediate-duty system.
  2. End Condition of Cross Runners: Override (stepped) or butt-edge type.
  3. Face Design: Flat, flush.
  4. Cap Material: Steel cold-rolled sheet.
  5. Cap Finish:
    - a. APC-1: Painted white.
    - b. APC-2: Painted Black to match color of acoustical panels.

## 2.5 METAL EDGE MOLDINGS AND TRIM

- A. Products: Subject to compliance with requirements, provide one of the following:
1. Armstrong World Industries, Inc.; Prelude 15/16" Exposed Tee System.
  2. BPB USA; 15/16" (24mm) Classic Stab System.
  3. Chicago Metallic Corporation; Seismic 1200.
  4. USG Interiors, Inc.; DONN Brand DX/DXL.
- B. Roll-Formed, Sheet-Metal Edge Moldings and Trim: Type and profile indicated or, if not indicated, manufacturer's standard moldings for edges and penetrations that comply with seismic design requirements; formed from sheet metal of same material, finish, and color as that used for exposed flanges of suspension system runners.
1. Provide manufacturer's standard edge moldings that fit acoustical panel edge details and suspension systems indicated and that match width and configuration of exposed runners, unless otherwise indicated.
  2. For circular penetrations of ceiling, provide edge moldings fabricated to diameter required to fit penetration exactly.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, including structural framing to which acoustical panel ceilings attach or abut, with Installer present, for compliance with requirements specified in this and other Sections that affect ceiling installation and anchorage and with requirements for installation tolerances and other conditions affecting performance of acoustical panel ceilings.
1. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. Measure each ceiling area and establish layout of acoustical panels to balance border widths at opposite edges of each ceiling. Avoid using less-than-half-width panels at borders, and comply with layout shown on reflected ceiling plans.

### 3.3 INSTALLATION

- A. General: Install acoustical panel ceilings to comply with ASTM C 636 and seismic design requirements indicated, per manufacturer's written instructions and CISCA's "Ceiling Systems Handbook."
- B. Suspend ceiling hangers from building's structural members and as follows:
  - 1. Install hangers plumb and free from contact with insulation or other objects within ceiling plenum that are not part of supporting structure or of ceiling suspension system.
  - 2. Splay hangers only where required to miss obstructions; offset resulting horizontal forces by bracing, countersplaying, or other equally effective means.
  - 3. Where width of ducts and other construction within ceiling plenum produces hanger spacings that interfere with location of hangers at spacings required to support standard suspension system members, install supplemental suspension members and hangers in form of trapezes or equivalent devices.
  - 4. Secure wire hangers to ceiling suspension members and to supports above with a minimum of three tight turns. Connect hangers directly either to structures or to inserts, eye screws, or other devices that are secure and appropriate for substrate and that will not deteriorate or otherwise fail due to age, corrosion, or elevated temperatures.
  - 5. Do not support ceilings directly from permanent metal forms or floor deck. Fasten hangers to cast-in-place hanger inserts, postinstalled mechanical or adhesive anchors, or power-actuated fasteners that extend through forms into concrete.
  - 6. When steel framing does not permit installation of hanger wires at spacing required, install carrying channels or other supplemental support for attachment of hanger wires.
  - 7. Do not attach hangers to steel roof deck. Attach hangers to structural members.
  - 8. Space hangers not more than 48 inches (1200 mm) o.c. along each member supported directly from hangers, unless otherwise indicated; provide hangers not more than 8 inches (200 mm) from ends of each member.
  - 9. Size supplemental suspension members and hangers to support ceiling loads within performance limits established by referenced standards and publications.
- C. Install edge moldings and trim of type indicated at perimeter of acoustical ceiling area and where necessary to conceal edges of acoustical panels.
  - 1. Screw attach moldings to substrate at intervals not more than 16 inches (400 mm) o.c. and not more than 3 inches (75 mm) from ends, leveling with ceiling suspension system to a tolerance of 1/8 inch in 12 feet (3.2 mm in 3.6 m). Miter corners accurately and connect securely.
  - 2. Do not use exposed fasteners, including pop rivets, on moldings and trim.
- D. Install suspension system runners so they are square and securely interlocked with one another. Remove and replace dented, bent, or kinked members.
- E. Install acoustical panels with undamaged edges and fit accurately into suspension system runners and edge moldings. Scribe and cut panels at borders and penetrations to provide a neat, precise fit.
  - 1. For square-edged panels, install panels with edges fully hidden from view by flanges of suspension system runners and moldings.
  - 2. Install hold-down clips in areas indicated, in areas required by authorities having jurisdiction, and for fire-resistance ratings; space as recommended by panel manufacturer's written instructions, unless otherwise indicated.

3.4 CLEANING

- A. Clean exposed surfaces of acoustical panel ceilings, including trim, edge moldings, and suspension system members. Comply with manufacturer's written instructions for cleaning and touchup of minor finish damage. Remove and replace ceiling components that cannot be successfully cleaned and repaired to permanently eliminate evidence of damage.

END OF SECTION 09 5113



SECTION 09 6513 - RESILIENT BASE AND ACCESSORIES

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section contains Specifications for the following:
  - 1. Rubber wall base (Type TS - Rubber, Vulcanized, Thermoset).
  - 2. Molding accessories.

1.3 SUBMITTALS

- A. Product Data: For each type of product specified.
- B. Samples: For verification purposes in manufacturer's standard sample sets, but not less than 12 inches long, of each resilient product color, texture and pattern required.

1.4 QUALITY ASSURANCE

- A. Single-Source Responsibility for Products: Obtain each type and color of product specified from a single source with resources to provide products of consistent quality in appearance and physical properties without delaying progress of the Work.
- B. Fire Performance Characteristics: Provide products with the following fire performance characteristics as determined by testing products per ASTM test method indicated below by UL or another testing and inspecting agency acceptable to authorities having jurisdiction.
  - 1. Critical Radiant Flux: 0.45 watts per sq. cm or more per ASTM E 648.
  - 2. Smoke Density: Less than 450 per ASTM E 662.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Deliver products to Project site in original manufacturer's unopened cartons and containers, each bearing names of product and manufacturer, Project identification, and shipping and handling instructions.
- B. Store products in dry spaces protected from the weather with ambient temperatures maintained between 50 deg F and 90 deg F.
- C. Move products into spaces where they will be installed at least 48 hours in advance of installation.

1.6 PROJECT CONDITIONS

- A. Maintain a minimum temperature of 70 deg F in spaces to receive products specified in this Section for at least 48 hours prior to installation, during installation, and for not less than 48 hours after installation. After this period, maintain a temperature of not less than 55 deg F.
- B. Do not install products until they are at the same temperature as that of the space where they are to be installed.
- C. Close spaces to traffic during installation of products specified in this Section.

1.7 SEQUENCING AND SCHEDULING

- A. Sequence installing products specified in this Section with other construction to minimize possibility of damage and soiling during remainder of construction period.

1.8 EXTRA MATERIALS

- A. Deliver extra materials to Owner. Furnish extra materials matching products installed as described below, packaged with protective covering for storage, and identified with labels clearly describing contents.
  - 1. Furnish not less than 10 linear feet for each 500 linear feet or fraction thereof, of each type, color, pattern and size of resilient product installed.
  - 2. Deliver extra materials to Owner.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Products: Subject to compliance with requirements, provide one of the products specified in each Product Data Sheet at end of this Section.

2.2 RESILIENT WALL BASE

- A. Rubber Wall Base: Products complying with ASTM F 1861, Type TS, Group I, and requirements specified in the Rubber Wall Base Product Data Sheet at end of this Section.
  - 1. Roll base only – sticks not acceptable.
  - 2. Preformed inside and outside corners to be used throughout.

2.3 INSTALLATION ACCESSORIES

- A. Trowelable Leveling and Patching Compounds: Latex-modified, portland-cement-based or blended hydraulic cement-based formulation provided or approved by resilient product manufacturers for applications indicated.
- B. Adhesives: Water-resistant type recommended by manufacturer to suit resilient base product and substrate conditions indicated.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas where installation of products specified in this Section will occur, with Installer present, to verify that substrates and conditions are satisfactory for installation and comply with manufacturer's requirements and those specified in this Section.

3.2 PREPARATION

- A. General: Comply with manufacturer's installation specifications for preparing substrates indicated to receive products indicated.
- B. Use trowelable leveling and patching compounds per manufacturer's directions to fill cracks, holes, and depressions in substrates.
- C. Broom or vacuum clean substrates to be covered immediately before installing products specified in this Section. Following cleaning, examine substrates for moisture, alkaline salts, carbonation, or dust.

3.3 RESILIENT WALL BASE INSTALLATION

- A. General: Install products specified in this Section using methods indicated according to manufacturer's installation directions.
- B. Apply resilient wall base to walls, columns, pilasters, casework, and other permanent fixtures in rooms and areas where base is required. Install wall base in lengths as long as practicable. Tightly adhere wall base to substrate throughout length of each piece, with base in continuous contact with horizontal and vertical substrates.
  - 1. On masonry surfaces or other similar irregular substrates, fill voids along top edge of resilient wall base with manufacturer's recommended adhesive filler material.
  - 2. Install inside and exterior corners before installing straight pieces.
- C. Place resilient accessories so they are butted to adjacent materials of type indicated and bond to substrates with adhesive. Install reducer strips at edges of flooring that otherwise would be exposed.

3.4 RESILIENT ACCESSORY INSTALLATION

3.5 CLEANING AND PROTECTION

- A. Perform the following operations immediately after completing installation:
  - 1. Remove adhesive and other blemishes from exposed surfaces.
  - 2. Sweep and vacuum surfaces thoroughly.
- B. Clean products specified in this Section not more than 4 days prior to dates scheduled for inspections intended to establish date of Completion in each area of Project. Clean products using method recommended by manufacturer.



3.6 RUBBER WALL BASE SCHEDULE

A. Designation: RB

1. Style: Cove with top-set toe (ASTM F 1861, Style B).
2. Height: 4".
3. Nominal Thickness: 1/8 inch.
4. Lengths: Coils in lengths standard with manufacturer but not less than 100 feet.
5. Exterior Corners: Pre-molded.
6. Interior Corners: Mitered.
7. Color: 624 Chameleon, Roppe basis of design
8. Acceptable Products:
  - a. Roppe Corporation.
  - b. Marley Flexco.
  - c. Burke Mercer.
  - d. Johnsonite.

END OF SECTION 09 6513

SECTION 09 6723 - RESINOUS FLOORING

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes resinous flooring systems with epoxy body coat(s).
  - 1. Application Method: Trowel-applied slurry with broadcast aggregates.
- B. Related Sections include the following:
  - 1. Division 079200 Section "Joint Sealants" for sealants installed at joints in resinous flooring systems.

1.3 SUBMITTALS

- A. Product Data: For each type of product indicated. Include manufacturer's technical data, application instructions, and recommendations for each resinous flooring component required.
- B. Samples for Initial Selection.
- C. Installer Certificates: Signed by manufacturer certifying that installers comply with specified requirements.
- D. Material Test Reports: For each resinous flooring component.
- E. Maintenance Data: For resinous flooring to include in maintenance manuals.

1.4 QUALITY ASSURANCE

- A. Installer Qualifications: Engage an experienced installer (applicator) who is experienced in applying resinous flooring systems similar in material, design, and extent to those indicated for this Project, whose work has resulted in applications with a record of successful in-service performance, and who is acceptable to resinous flooring manufacturer.
  - 1. Engage an installer who employs only persons trained and approved by resinous flooring manufacturer for applying resinous flooring systems indicated.
- B. Source Limitations: Obtain primary resinous flooring materials, including primers, resins, hardening agents, grouting coats, and aggregate, through one source from a single manufacturer. Provide secondary materials, including patching and fill material, joint sealant, and repair materials, of type and from source recommended by manufacturer of primary materials.

- C. Federal Agency Approvals: Where indicated, provide resinous flooring systems approved by the USDA for use indicated.

#### 1.5 DELIVERY, STORAGE, AND HANDLING

- A. Deliver materials in original packages and containers, with seals unbroken, bearing manufacturer's labels indicating brand name and directions for storage and mixing with other components.
- B. Store materials to prevent deterioration from moisture, heat, cold, direct sunlight, or other detrimental effects.

#### 1.6 PROJECT CONDITIONS

- A. Environmental Limitations: Comply with resinous flooring manufacturer's written instructions for substrate temperature, ambient temperature, moisture, ventilation, and other conditions affecting resinous flooring application.
- B. Close spaces to traffic during resinous flooring application and for not less than 24 hours after application, unless manufacturer recommends a longer period.

### PART 2 - PRODUCTS

#### 2.1 RESINOUS FLOORING (RF)

- A. Basis of Design Product: Subject to compliance with requirements provide Dur-A-Flex, Inc. Polycrete MDB or a comparable product by one of the following:
  - 1. Crossfield Products Corp., Dex-O-Tex.
  - 2. Stonhard Stonclad UT
  - 3. General Polymers (Sherwin Williams)
  - 4. Sika.
  - 5. Prime Coat Corporation
- B. System Characteristics:
  - 1. Color and Pattern: Match Prime Coat Granite 321-23
  - 2. Wearing Surface: Textured for slip resistance.
  - 3. Integral Cove Base: 4 inches high.
  - 4. Overall System Thickness: 3/16 inch minimum.
  - 5. Federal Agency Approvals: USDA approved for food-processing environments.
- C. System Components: Manufacturer's standard components that are compatible with each other and as follows:
  - 1. Base Coat:
    - a. Urethane Mortar.
    - b. Application Method: Trowel-applied with broadcast aggregates.
    - c. Aggregates: Colored quartz.
  - 2. Primer: Type recommended by manufacturer for substrate as required.

3. Sealcoat: UV-resistant sealing coat.
  - a. Resin: EURETHANE
  - b. Type: Pigmented.
  - c. Finish: Gloss.
  - d. Number of Coats: One.
  
- D. System Physical Properties: Provide resinous flooring system with the following minimum physical property requirements when tested according to test methods indicated:
  1. Compressive Strength: 7,700 PSI per ASTM C 579.
  2. Tensile Strength: 1,000 PSI per ASTM C 307.
  3. Flexural Modulus of Elasticity:  $2.6 \times 10^6$  PSI per ASTM C 580.
  4. Water Absorption: <1% per ASTM C 413.
  5. Coefficient of Thermal Expansion:  $1.1 \times 10^{-5}$  mm/mm degrees C per ASTM C 531.
  6. Impact Resistance: >160 in/lbs per ASTM D-2794.
  7. Abrasion Resistance: 0.05 gm maximum weight loss per ASTM D 4060.
  8. Heat Resistance Limitation: 200 degrees F (93 degrees C) continuous, 250 degrees F (121 degrees C) intermittent.
  9. Hardness: 80 to 84, Shore D per ASTM D 2240.
  10. Bond Strength: >400 PSI, 100 percent concrete failure per ASTM D-7234.
  11. Service Temperature: -100 degrees F to 220 degrees F
  12. All products must be 100% solids with zero VOC's

## 2.2 ACCESSORY MATERIALS

- A. Patching and Fill Material: Resinous product of or approved by resinous flooring manufacturer and recommended by manufacturer for application indicated.

## PART 3 - EXECUTION

### 3.1 PREPARATION

- A. General: Prepare and clean substrates according to resinous flooring manufacturer's written instructions for substrate indicated. Provide clean, dry, and neutral Ph substrate for resinous flooring application.
  
- B. Concrete Substrates: Provide sound concrete surfaces free of laitance, glaze, efflorescence, curing compounds, form-release agents, dust, dirt, grease, oil, and other contaminants incompatible with resinous flooring.
  1. If substrate is unacceptable, roughen concrete as follows:
    - a. Shot-blast surfaces with an apparatus that abrades the concrete surface, contains the dispensed shot within the apparatus, and recirculates the shot by vacuum pickup.
  2. Repair damaged and deteriorated concrete according to resinous flooring manufacturer's written recommendations.
  3. Verify that concrete substrates are dry.
  
- C. Resinous Materials: Mix components and prepare materials according to resinous flooring manufacturer's written instructions.

- D. Use patching and fill material to fill holes and depressions in substrates according to manufacturer's written instructions.
- E. Treat control joints and other nonmoving substrate cracks to prevent cracks from reflecting through resinous flooring according to manufacturer's written recommendations.

### 3.2 APPLICATION

- A. General: Apply components of resinous flooring system according to manufacturer's written instructions to produce a uniform, monolithic wearing surface of thickness indicated.
  - 1. Coordinate application of components to provide optimum adhesion of resinous flooring system to substrate, and optimum intercoat adhesion.
  - 2. Cure resinous flooring components according to manufacturer's written instructions. Prevent contamination during application and curing processes.
  - 3. At substrate expansion and isolation joints, provide joint in resinous flooring to comply with resinous flooring manufacturer's written recommendations.
- B. Integral Cove Base: Apply cove base mix to wall surfaces before applying flooring. Apply according to manufacturer's written instructions and details including those for taping, mixing, priming, troweling, sanding, and topcoating of cove base. Round internal and external corners.
- C. Apply screeded base coat in thickness indicated for flooring system. Using hand trowels and spiked rollers, smooth surface to required thickness.
  - 1. Broadcast aggregates and, after resin is cured, remove excess aggregates to provide surface texture indicated.
    - a. Provide medium texture finish.
- D. Apply seal coat for flooring system at spreading rates recommended in writing by manufacturer.

### 3.3 CLEANING AND PROTECTING

- A. Protect resinous flooring from damage and wear during the remainder of construction period. Use protective methods and materials, including temporary covering, recommended in writing by resinous flooring manufacturer.

END OF SECTION 09 6723

SECTION 09 6813 - TILE CARPETING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes modular, looped, bonded carpet tile.
- B. Related Requirements:
  - 1. Division 09 Section "Resilient Base and Accessories" for resilient wall base and accessories installed with carpet tile.

1.3 PREINSTALLATION MEETINGS

- A. Preinstallation Conference: Conduct conference at Project site.
  - 1. Review methods and procedures related to carpet tile installation including, but not limited to, the following:
    - a. Review delivery, storage, and handling procedures.
    - b. Review ambient conditions and ventilation procedures.
    - c. Review subfloor preparation procedures.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. Include manufacturer's written data on physical characteristics, durability, and fade resistance.
  - 2. Include installation recommendations for each type of substrate.
- B. Shop Drawings: Show the following:
  - 1. Columns, doorways, enclosing walls or partitions, built-in cabinets, and locations where cutouts are required in carpet tiles.
  - 2. Carpet tile type, color, and dye lot.
  - 3. Type of subfloor.
  - 4. Type of installation.
  - 5. Pattern type, location, and direction.
  - 6. Pile direction.

7. Type, color, and location of edge, transition, and other accessory strips.
8. Transition details to other flooring materials.

C. Samples: For each of the following products and for each color and texture required. Label each Sample with manufacturer's name, material description, color, pattern, and designation indicated on Drawings and in schedules.

1. Carpet Tile: Full-size Sample.
2. Exposed Edge, Transition, and Other Accessory Stripping: 12-inch- (300-mm-) long Samples.

D. Product Schedule: For carpet tile. Use same designations indicated on Drawings. Coordinate.

#### 1.5 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For Installer.
- B. Product Test Reports: For carpet tile, for tests performed by a qualified testing agency.
- C. Sample Warranty: For special warranty.

#### 1.6 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For carpet tiles to include in maintenance manuals. Include the following:
  1. Methods for maintaining carpet tile, including cleaning and stain-removal products and procedures and manufacturer's recommended maintenance schedule.
  2. Precautions for cleaning materials and methods that could be detrimental to carpet tile.

#### 1.7 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials, from the same product run, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  1. Carpet Tile: Full-size units equal to 5 percent of amount installed for each type indicated, but not less than 10 sq. yd. (8.3 sq. m).

#### 1.8 QUALITY ASSURANCE

- A. Installer Qualifications: An experienced installer who is certified by the International Certified Floorcovering Installers Association at the Commercial II certification level.
- B. Fire-Test-Response Ratings: Where indicated, provide carpet tile identical to those of assemblies tested for fire response according to NFPA 253 by a qualified testing agency.
- C. Mockups: Build mockups to verify selections made under Sample submittals and to demonstrate aesthetic effects and set quality standards for fabrication and installation.

1. Build mockups at locations and in sizes shown on Drawings.
2. Subject to compliance with requirements, approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.

1.9 DELIVERY, STORAGE, AND HANDLING

- A. Comply with CRI 104.

1.10 FIELD CONDITIONS

- A. Comply with CRI 104 for temperature, humidity, and ventilation limitations.
- B. Environmental Limitations: Do not deliver or install carpet tiles until spaces are enclosed and weathertight, wet work in spaces is complete and dry, and ambient temperature and humidity conditions are maintained at occupancy levels during the remainder of the construction period.
- C. Do not install carpet tiles over concrete slabs until slabs have cured and are sufficiently dry to bond with adhesive and concrete slabs have pH range recommended by carpet tile manufacturer.
- D. Where demountable partitions or other items are indicated for installation on top of carpet tiles, install carpet tiles before installing these items.

1.11 WARRANTY

- A. Special Warranty for Carpet Tiles: Manufacturer agrees to repair or replace components of carpet tile installation that fail in materials or workmanship within specified warranty period.
  1. Warranty does not include deterioration or failure of carpet tile due to unusual traffic, failure of substrate, vandalism, or abuse.
  2. Failures include, but are not limited to, more than 10 percent edge raveling, snags, runs, dimensional stability, excess static discharge, loss of tuft bind strength, loss of face fiber, and delamination.
  3. Warranty Period: 10 years from date of Completion.

PART 2 - PRODUCTS

2.1 CARPET TILE – Refer to drawing A12.0 for locations.

- A. Basis-of-Design Product: Subject to compliance with requirements, provide Interface carpet tile:
  1. CPT-1: Patraft I0349-Flutter 00725 Bamboo Page
- B. Subject to compliance with requirements, provide Patcraft, or approved equal by one of the following:
  1. Shaw.



2. Tandus C & A.
  3. Masland Modular.
  4. Chaw Malang EW24.
  5. Interface
- C. Pattern: Match Architect's samples.
- D. Fiber Content: 100 percent nylon 6,6.
- E. Fiber Type: Premium
- F. Pile Characteristic: Tufted textured loop.
- G. Pile Density: 5.231 oz/ sq. yard.
- H. Pile Thickness: 0.117 inches for finished carpet tile.
- I. Stitches: 8.7 stitches per inch.
- J. Gage: 1/12 inch
- K. Primary Backing/Backcoating: Manufacturer's standard composite materials.
- L. Secondary Backing: Manufacturer's standard material.
- M. Size: 50cm x 50cm
- N. Applied Soil-Resistance Treatment: Manufacturer's standard material.
- O. Antimicrobial Treatment: Manufacturer's standard material
- P. Performance Characteristics: As follows:
1. Appearance Retention Rating: Heavy traffic, 3.0 minimum according to ASTM D 7330.
  2. Critical Radiant Flux Classification: Not less than 0.45 W/sq. cm.
  3. Dry Breaking Strength: Not less than 100 lbf (445 N) according to ASTM D 2646.
  4. Tuft Bind: 8 lbf (36 N) according to ASTM D 1335.
  5. Delamination: Not less than 4 lbf/in. (18 N/mm) according to ASTM D 3936.
  6. Dimensional Tolerance: Within 1/32 inch (0.8 mm) of specified size dimensions, as determined by physical measurement.
  7. Dimensional Stability: 0.2 percent or less according to ISO 2551 (Aachen Test).
  8. Resistance to Insects: Comply with AATCC 24.
  9. Noise Reduction Coefficient (NRC): .50 NRC according to ASTM C 423.
  10. Colorfastness to Crocking: Not less than 4, wet and dry, according to AATCC 165.
  11. Colorfastness to Light: Not less than 4 after 40 AFU (AATCC fading units) according to AATCC 16, Option E.
  12. Antimicrobial Activity: Not less than 2-mm halo of inhibition for gram-positive bacteria, not less than 1-mm halo of inhibition for gram-negative bacteria, and no fungal growth, according to AATCC 174.
  13. Electrostatic Propensity: Less than 3.5 kV according to AATCC 134.

14. Emissions: Provide carpet tile that complies with testing and product requirements of CRI's "Green Label Plus" program.

## 2.2 INSTALLATION ACCESSORIES

- A. Trowelable Leveling and Patching Compounds: Latex-modified, hydraulic-cement-based formulation provided or recommended by carpet tile manufacturer.
- B. Adhesives: Water-resistant, mildew-resistant, nonstaining, pressure-sensitive type to suit products and subfloor conditions indicated, that complies with flammability requirements for installed carpet tile and is recommended by carpet tile manufacturer for releasable installation.
  1. Adhesives shall have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  2. Adhesives shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- C. Metal Edge/Transition Strips: Extruded aluminum with mill finish of profile and width shown, of height required to protect exposed edge of carpet, and of maximum lengths to minimize running joints.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for maximum moisture content, alkalinity range, installation tolerances, and other conditions affecting carpet tile performance. Examine carpet tile for type, color, pattern, and potential defects.
- B. Concrete Subfloors: Verify that concrete slabs comply with ASTM F 710 and the following:
  1. Slab substrates are dry and free of curing compounds, sealers, hardeners, and other materials that may interfere with adhesive bond. Determine adhesion and dryness characteristics by performing bond and moisture tests recommended by carpet tile manufacturer.
  2. Subfloor finishes comply with requirements specified in Division 03 Section "Cast-in-Place Concrete" for slabs receiving carpet tile.
  3. Subfloors are free of cracks, ridges, depressions, scale, and foreign deposits.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. General: Comply with CRI 104, Section 6.2, "Site Conditions; Floor Preparation," and with carpet tile manufacturer's written installation instructions for preparing substrates indicated to receive carpet tile installation.
- B. Use trowelable leveling and patching compounds, according to manufacturer's written instructions, to fill cracks, holes, depressions, and protrusions in substrates. Fill or level cracks, holes and depressions 1/8 inch (3 mm) wide or wider and protrusions more than 1/32 inch (0.8 mm) unless more stringent requirements are required by manufacturer's written instructions.
- C. Remove coatings, including curing compounds, and other substances that are incompatible with adhesives and that contain soap, wax, oil, or silicone, without using solvents. Use mechanical methods recommended in writing by carpet tile manufacturer.
- D. Clean metal substrates of grease, oil, soil and rust, and prime if directed by adhesive manufacturer. Rough sand painted metal surfaces and remove loose paint. Sand aluminum surfaces, to remove metal oxides, immediately before applying adhesive.
- E. Broom and vacuum clean substrates to be covered immediately before installing carpet tile.

### 3.3 INSTALLATION

- A. General: Comply with CRI 104, Section 14, "Carpet Modules," and with carpet tile manufacturer's written installation instructions.
- B. Installation Method: Glue down; install every tile with full-spread, releasable, pressure-sensitive adhesive.
- C. Maintain dye lot integrity. Do not mix dye lots in same area.
- D. Cut and fit carpet tile to butt tightly to vertical surfaces, permanent fixtures, and built-in furniture including cabinets, pipes, outlets, edgings, and threshold. Bind or seal cut edges as recommended by carpet tile manufacturer.
- E. Extend carpet tile into toe spaces, door reveals, closets, open-bottomed obstructions, removable flanges, alcoves, and similar openings.
- F. Maintain reference markers, holes, and openings that are in place or marked for future cutting by repeating on finish flooring as marked on subfloor. Use nonpermanent, nonstaining marking device.
- G. Install pattern parallel to walls and borders.

### 3.4 CLEANING AND PROTECTION

- A. Perform the following operations immediately after installing carpet tile:

1. Remove excess adhesive, seam sealer, and other surface blemishes using cleaner recommended by carpet tile manufacturer.
  2. Remove yarns that protrude from carpet tile surface.
  3. Vacuum carpet tile using commercial machine with face-beater element.
- B. Protect installed carpet tile to comply with CRI 104, Section 16, "Protecting Indoor Installations."
- C. Protect carpet tile against damage from construction operations and placement of equipment and fixtures during the remainder of construction period. Use protection methods indicated or recommended in writing by carpet tile manufacturer.

END OF SECTION 09 6813

SECTION 09 9113 - EXTERIOR PAINTING

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes surface preparation and the application of paint systems on the following exterior substrates:

- 1. Concrete
- 2. Concrete masonry units (CMU).
- 3. Steel.
- 4. Galvanized metal.
- 5. Wood

- B. Related Sections include the following:

- 1. Division 05 Sections for shop priming of metal substrates with primers specified in this Section.
- 2. Division 08 Sections for factory priming windows and doors with primers specified in this Section.
- 3. Division 09 9601 painting Sections for special-use and high-performance coatings.
- 4. Division 09 9123 Section "Interior Painting" for surface preparation and the application of paint systems on interior substrates.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated. Include listing of VOC content and chemical components.
- B. Samples for Initial Selection: For each type of topcoat product indicated.
- C. Product List: For each product indicated, include the following:
  - 1. Cross-reference to paint system and locations of application areas. Use same designations indicated on Drawings and in schedules.
  - 2. Printout of current "MPI Evaluation of Exterior Systems" for each product category specified in Part 2.

1.4 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials, from the same product run, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Paint: 5 percent, but not less than 1 gal. (3.8 L) of each material and color applied.

1.5 QUALITY ASSURANCE

- A. MPI Standards:
  - 1. Preparation and Workmanship: Comply with requirements in "MPI Architectural Painting Specification Manual" for products and paint systems indicated.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Store materials not in use in tightly covered containers in well-ventilated areas with ambient temperatures continuously maintained at not less than 45 deg F (7 deg C).
  - 1. Maintain containers in clean condition, free of foreign materials and residue.
  - 2. Remove rags and waste from storage areas daily.

1.7 PROJECT CONDITIONS

- A. Apply paints only when temperature of surfaces to be painted and ambient air temperatures are between 50 and 95 deg F (10 and 35 deg C).
- B. Do not apply paints in snow, rain, fog, or mist; when relative humidity exceeds 85 percent; at temperatures less than 5 deg F (3 deg C) above the dew point; or to damp or wet surfaces.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Benjamin Moore & Co.
  - 2. ICI Paints.
  - 3. PPG Architectural Finishes, Inc.
  - 4. Pratt & Lambert Paints.
  - 5. Sherwin-Williams Company (The). (Basis of Design)
  - 6. Dunn Edwards (Basis of Colors)

2.2 PAINT, GENERAL

A. Material Compatibility:

1. Provide materials for use within each paint system that are compatible with one another and substrates indicated, under conditions of service and application as demonstrated by manufacturer, based on testing and field experience.
2. For each coat in a paint system, provide products recommended in writing by manufacturers of topcoat for use in paint system and on substrate indicated.

B. VOC Content: Provide materials that comply with VOC limits of authorities having jurisdiction.

C. Colors: As selected by Architect from manufacturer's full range

2.3 BLOCK FILLERS

A. Interior/Exterior Latex Block Filler:

1. Basis of Design: Sherwin Williams; Heavy Duty Block Filler, B42W46
2. VOC Content (maximum): 100 g/L.

2.4 PRIMERS/SEALERS

A. Alkali-Resistant Primer:

1. Basis of Design: Sherwin-Williams; Loxon, Acrylic Primer A24W300.
2. VOC Content: E Range of E3.

B. Exterior Wood Primer:

1. Basis of Design: Sherwin-Williams; Exterior Latex Wood Primer, B42W8041.
2. VOC Content (maximum): 100 g/L.

2.5 METAL PRIMERS

A. Rust-Inhibitive Metal Primer:

1. Basis of Design: Sherwin Williams Pro Industrial Pro-Cryl Universal Primer, B66-310 Series.
2. VOC Content (maximum): 100 g/L.

2.6 EXTERIOR LATEX PAINTS

A. Exterior Latex (Flat):

1. Basis of Design: Sherwin Williams; A0199 Exterior Latex Flat A6-100 Series.
2. VOC Content (maximum): 50 g/L.



B. Exterior Latex (Semigloss):

1. Basis of Design: Sherwin Williams; Pro Industrial 0 VOC Acrylic B66-650 Series.
2. VOC Content (maximum): 50 g/L.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates and conditions, with Applicator present, for compliance with requirements for maximum moisture content and other conditions affecting performance of work.
- B. Maximum Moisture Content of Substrates: When measured with an electronic moisture meter as follows:
  1. Masonry (Clay and CMU): 12 percent.
- C. Verify suitability of substrates, including surface conditions and compatibility with existing finishes and primers.
  1. Verify PH of concrete surfaces.
- D. Proceed with coating application only after unsatisfactory conditions have been corrected.
  1. Application of coating indicates acceptance of surfaces and conditions.

3.2 PREPARATION

- A. Comply with manufacturer's written instructions and recommendations in "MPI Architectural Painting Specification Manual" applicable to substrates and paint systems indicated.
- B. Remove plates, machined surfaces, and similar items already in place that are not to be painted. If removal is impractical or impossible because of size or weight of item, provide surface-applied protection before surface preparation and painting.
  1. After completing painting operations, use workers skilled in the trades involved to reinstall items that were removed. Remove surface-applied protection if any.
- C. Clean substrates of substances that could impair bond of paints, including dirt, oil, grease, and incompatible paints and encapsulants.
  1. Remove incompatible primers and reprime substrate with compatible primers as required to produce paint systems indicated.
- D. Concrete Substrates: Remove release agents, curing compounds, efflorescence, and chalk. Do not paint surfaces if moisture content or alkalinity of surfaces to be painted exceeds that permitted in manufacturer's written instructions.

1. Verify with Contractor that surface meets requirements for surfaces receiving a painted finish as defined in Division 3 Sections for concrete finishes.
- E. Masonry Substrates: Remove efflorescence and chalk. Do not paint surfaces if moisture content of surfaces or alkalinity of mortar joints to be painted exceed that permitted in manufacturer's written instructions.
- F. Steel Substrates: Remove rust, loose mill scale, and shop primer if any. Clean using methods recommended in writing by paint manufacturer. but not less than the following:
  1. SSPC-SP 2, "Hand Tool Cleaning."
  2. SSPC-SP 3, "Power Tool Cleaning."
  3. SSPC-SP 7/NACE No. 4, "Brush-off Blast Cleaning."
  4. SSPC-SP 11, "Power Tool Cleaning to Bare Metal."
- G. Shop-Primed Steel Substrates: Clean field welds, bolted connections, and abraded areas of shop paint, and paint exposed areas with the same material as used for shop priming to comply with SSPC-PA 1 for touching up shop-primed surfaces.
- H. Galvanized-Metal Substrates: Remove grease and oil residue from galvanized sheet metal fabricated from coil stock by mechanical methods to produce clean, lightly etched surfaces that promote adhesion of subsequently applied paints.

### 3.3 APPLICATION

- A. Apply paints according to manufacturer's written instructions.
  1. Use applicators and techniques suited for paint and substrate indicated.
  2. Paint surfaces behind movable items same as similar exposed surfaces. Before final installation, paint surfaces behind permanently fixed items with prime coat only.
  3. Paint both sides and edges of exterior doors and entire exposed surface of exterior door frames.
  4. Paint entire exposed surface of window frames and sashes.
  5. Do not paint over labels of independent testing agencies or equipment name, identification, performance rating, or nomenclature plates.
  6. Primers specified in painting schedules may be omitted on items that are factory primed or factory finished if acceptable to topcoat manufacturers.
- B. Tint each undercoat a lighter shade to facilitate identification of each coat if multiple coats of same material are to be applied. Tint undercoats to match color of topcoat, but provide sufficient difference in shade of undercoats to distinguish each separate coat.
- C. If undercoats or other conditions show through topcoat, apply additional coats until cured film has a uniform paint finish, color, and appearance.
- D. Apply paints to produce surface films without cloudiness, spotting, holidays, laps, brush marks, roller tracking, runs, sags, ropiness, or other surface imperfections. Cut in sharp lines and color breaks.

### 3.4 FIELD QUALITY CONTROL

- A. Dry Film Thickness Testing: Owner may engage the services of a qualified testing and inspecting agency to inspect and test paint for dry film thickness.
  - 1. Contractor shall touch up and restore painted surfaces damaged by testing.
  - 2. If test results show that dry film thickness of applied paint does not comply with paint manufacturer's written recommendations, Contractor shall pay for testing and apply additional coats as needed to provide dry film thickness that complies with paint manufacturer's written recommendations.

### 3.5 CLEANING AND PROTECTION

- A. At end of each workday, remove rubbish, empty cans, rags, and other discarded materials from Project site.
- B. After completing paint application, clean spattered surfaces. Remove spattered paints by washing, scraping, or other methods. Do not scratch or damage adjacent finished surfaces.
- C. Protect work of other trades against damage from paint application. Correct damage to work of other trades by cleaning, repairing, replacing, and refinishing, as approved by Architect, and leave in an undamaged condition.
- D. At completion of construction activities of other trades, touch up and restore damaged or defaced painted surfaces.

### 3.6 EXTERIOR PAINTING SCHEDULE

- A. Concrete Substrates, Nontraffic Surfaces:
  - 1. Latex Over Alkali-Resistant Primer System: MPI EXT 3.1K.
    - a. Prime Coat: Alkali-resistant primer.
    - b. Intermediate Coat: Exterior latex matching topcoat.
    - c. Topcoat: Exterior latex (flat).
- B. CMU Substrates:
  - 1. Latex Over Alkali-Resistant Primer System: MPI EXT 4.2L.
    - a. Prime Coat: Alkali-resistant primer.
    - b. Intermediate Coat: Exterior latex matching topcoat.
    - c. Topcoat: Exterior latex flat.
- C. Steel Substrates:
  - 1. Acrylic System: Similar to MPI EXT 5.1M.
    - a. Prime Coat: Rust-Inhibitive acrylic.
    - b. Intermediate Coat: Exterior latex matching topcoat.

- c. Topcoat: Exterior latex enamel (semigloss).
- D. Galvanized-Metal Substrates:
- 1. Latex System: MPI EXT 5.3H.
    - a. Prime Coat: Rust-Inhibitive acrylic primer.
    - b. Intermediate Coat: Exterior latex matching topcoat.
    - c. Topcoat: Exterior latex (semigloss).
- E. Wood Substrates:
- 1. Latex System: MPI EXT 6.4K.
    - a. Prime / Sealer Coat: Exterior wood primer.
    - b. Intermediate Coat: Exterior latex matching topcoat.
    - c. Topcoat: Exterior latex (semigloss).

### 3.7 EXTERIOR PAINTING COLOR SCHEDULE

- A. EP-1: Exterior Wall Paint Base Color:
  - 1. DE5360 Wheat Bread LRV 49– Dunn Edwards
- B. EP-2: 1 Exterior Accent Paint at frames, metal fabrications, steel structure, etc.
  - 1. DE5456 Sandy Shore LRV 74 – Dunn Edwards
- C. EP-3: Exterior Accent Paint at door frames.
  - 1. DEA162 Log Cabin LRV 11 – Dunn Edwards
- D. EP-4: Bollards and Gas Piping.
  - 1. SW6911, Confident yellow. – Sherwin Williams
- E. EP-5: Exposed Fire Suppression System Piping.
  - 1. SW6867, Fireworks. – Sherwin Williams

END OF SECTION 09 9113

SECTION 09 9123 - INTERIOR PAINTING

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes surface preparation and the application of paint systems on the following interior substrates:

1. Concrete.
2. Concrete masonry units (CMU).
3. Steel.
4. Galvanized metal.
5. Aluminum (not anodized or otherwise coated).
6. Wood.
7. Gypsum board.

- B. Related Sections include the following:

1. Division 05 Sections for shop priming of metal substrates with primers specified in this Section.
2. Division 08 Sections for factory priming windows and doors with primers specified in this Section.
3. Division 09 9113 Section "Exterior Painting" for surface preparation and the application of paint systems on exterior substrates.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Samples for Initial Selection: For each type of topcoat product indicated.
- C. Samples for Verification: For each type of paint system and in each color and gloss of topcoat indicated.
  1. Submit Samples on rigid backing, 8 inches (200 mm) square.
  2. Step coats on Samples to show each coat required for system.
  3. Label each coat of each Sample.
  4. Label each Sample for location and application area.
- D. Product List: For each product indicated, include the following:

1. Cross-reference to paint system and locations of application areas. Use same designations indicated on Drawings and in schedules.
2. Printout of current "MPI Interior systems" for each product category specified in Part 2, with the proposed product highlighted.

#### 1.4 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials, from the same product run, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  1. Paint: 5 percent, but not less than 1 gal. (3.8 L) of each material and color applied.

#### 1.5 QUALITY ASSURANCE

- A. MPI Standards:
  1. Preparation and Workmanship: Comply with requirements in "MPI Architectural Painting Specification Manual" for paint systems indicated.

#### 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Store materials not in use in tightly covered containers in well-ventilated areas with ambient temperatures continuously maintained at not less than 45 deg F (7 deg C).
  1. Maintain containers in clean condition, free of foreign materials and residue.
  2. Remove rags and waste from storage areas daily.

#### 1.7 FIELD CONDITIONS

- A. Apply paints only when temperature of surfaces to be painted and ambient air temperatures are between 50 and 95 deg F (10 and 35 deg C).
- B. Do not apply paints when relative humidity exceeds 85 percent; at temperatures less than 5 deg F (3 deg C) above the dew point; or to damp or wet surfaces.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  1. Benjamin Moore & Co.
  2. ICI Paints.
  3. PPG Architectural Finishes, Inc.
  4. Pratt & Lambert Paints.

5. Sherwin-Williams Company (The). (Basis of Design)
6. Dunn Edwards (Basis of Colors)

## 2.2 PAINT, GENERAL

### A. Material Compatibility:

1. Provide materials for use within each paint system that are compatible with one another and substrates indicated, under conditions of service and application as demonstrated by manufacturer, based on testing and field experience.
2. For each coat in a paint system, provide products recommended in writing by manufacturers of topcoat for use in paint system and on substrate indicated.

### A. VOC Content: Products shall comply with VOC limits of authorities having jurisdiction.

1. Flat Paints and Coatings: 50 g/L.
2. Nonflat Paints and Coatings: 150 g/L.
3. Dry-Fog Coatings: 400 g/L.
4. Primers, Sealers, and Undercoaters: 200 g/L.
5. Anticorrosive and Antirust Paints Applied to Ferrous Metals: 250 g/L.
6. Zinc-Rich Industrial Maintenance Primers: 340 g/L.
7. Pretreatment Wash Primers: 420 g/L.
8. Floor Coatings: 100 g/L.
9. Shellacs, Clear: 730 g/L.
10. Shellacs, Pigmented: 550 g/L.

### B. Colors: As selected by Architect from manufacturer's full range and As indicated in a color schedule. Colors will be selected to match existing construction.

## 2.3 BLOCK FILLERS

### A. Interior/Exterior Latex Block Filler:

1. Basis of Design: Sherwin Williams; Heavy Duty Block Filler B42W46.

## 2.4 PRIMERS/SEALERS

### A. Interior Latex Primer/Sealer:

1. Basis of Design: Sherwin Williams; ProGreen 200 Interior Latex Primer B28W600.

### B. Interior Acrylic Primer/Sealer:

1. Basis of Design: Sherwin Williams; Loxon Block Surfacer A42W200.

## 2.5 METAL PRIMERS

### A. Rust-Inhibitive Acrylic Primer:



1. Basis of Design: Sherwin Williams; Pro Industrial Pro-Cryl Universal Primer B66-310 Series.

## 2.6 LATEX PAINTS

- A. High Performance Architectural Interior Latex (Semigloss):

1. Basis of Design: Sherwin Williams; Pro Industrial 0 Voc Acrylic, B66-650 Series.

## 2.7 FLOOR COATINGS

- A. Exterior/Interior Acrylic Floor Enamel (Gloss):

1. Basis of Design: Sherwin Williams; Porch & Floor Enamel A32-100 Series.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates and conditions, with Applicator present, for compliance with requirements for maximum moisture content and other conditions affecting performance of work.
- B. Maximum Moisture Content of Substrates: When measured with an electronic moisture meter as follows:
  1. Concrete: 12 percent.
  2. Masonry (Clay and CMU): 12 percent.
  3. Wood: 15 percent.
  4. Gypsum Board: 12 percent.
- C. Verify suitability of substrates, including surface conditions and compatibility with existing finishes and primers.
  1. Verify ph range of concrete surfaces.
- D. Gypsum Board Substrates: Verify that finishing compound is sanded smooth.
- E. Verify suitability of substrates, including surface conditions and compatibility with existing finishes and primers.
- F. Proceed with coating application only after unsatisfactory conditions have been corrected.
  1. Application of coating indicates acceptance of surfaces and conditions.

3.2 PREPARATION

- A. Comply with manufacturer's written instructions and recommendations in "MPI Architectural Painting Specification Manual" applicable to substrates indicated.
- B. Remove hardware, covers, plates, and similar items already in place that are removable and are not to be painted. If removal is impractical or impossible because of size or weight of item, provide surface-applied protection before surface preparation and painting.
  - 1. After completing painting operations, use workers skilled in the trades involved to reinstall items that were removed. Remove surface-applied protection if any.
- C. Clean substrates of substances that could impair bond of paints, including dirt, oil, grease, and incompatible paints and encapsulants.
  - 1. Remove incompatible primers and reprime substrate with compatible primers as required to produce paint systems indicated.
- D. Concrete Substrates: Remove release agents, curing compounds, efflorescence, and chalk. Do not paint surfaces if moisture content or alkalinity of surfaces to be painted exceeds that permitted in manufacturer's written instructions.
  - 1. Verify with Contractor that surface meets requirements for surfaces receiving a painted finish as defined in Division 3 Sections for concrete finishes.
- E. Masonry Substrates: Remove efflorescence and chalk. Do not paint surfaces if moisture content of surfaces or alkalinity of mortar joints to be painted exceed that permitted in manufacturer's written instructions.
- F. Steel Substrates: Remove rust, loose mill scale, and shop primer, if any. Clean using methods recommended in writing by paint manufacturer but not less than the following:
  - 1. SSPC-SP 2, "Hand Tool Cleaning."
  - 2. SSPC-SP 3, "Power Tool Cleaning."
  - 3. SSPC-SP 7/NACE No. 4, "Brush-off Blast Cleaning."
  - 4. SSPC-SP 11, "Power Tool Cleaning to Bare Metal."
- G. Shop-Primed Steel Substrates: Clean field welds, bolted connections, and abraded areas of shop paint, and paint exposed areas with the same material as used for shop priming to comply with SSPC-PA 1 for touching up shop-primed surfaces.
- H. Galvanized-Metal Substrates: Remove grease and oil residue from galvanized sheet metal fabricated from coil stock by mechanical methods to produce clean, lightly etched surfaces that promote adhesion of subsequently applied paints.
- I. Aluminum Substrates: Remove surface oxidation.
- J. Wood Substrates:
  - 1. Scrape and clean knots, and apply coat of knot sealer before applying primer.
  - 2. Sand surfaces that will be exposed to view, and dust off.

3. Prime edges, ends, faces, undersides, and backsides of wood.
  4. After priming, fill holes and imperfections in the finish surfaces with putty or plastic wood filler. Sand smooth when dried.
- K. Gypsum Board Substrates: Do not begin paint application until finishing compound is dry and sanded smooth.

### 3.3 APPLICATION

- A. Apply paints according to manufacturer's written instructions.
1. Use applicators and techniques suited for paint and substrate indicated.
  2. Paint surfaces behind movable equipment and furniture same as similar exposed surfaces. Before final installation, paint surfaces behind permanently fixed equipment or furniture with prime coat only.
  3. Paint front and backsides of access panels and doors, removable or hinged covers, and similar hinged items to match exposed surfaces.
  4. Do not paint over labels of independent testing agencies or equipment name, identification, performance rating, or nomenclature plates.
  5. Primers specified in painting schedules may be omitted on items that are factory primed or factory finished if acceptable to topcoat manufacturers.
- B. Tint each undercoat a lighter shade to facilitate identification of each coat if multiple coats of same material are to be applied. Tint undercoats to match color of topcoat, but provide sufficient difference in shade of undercoats to distinguish each separate coat.
- C. If undercoats or other conditions show through topcoat, apply additional coats until cured film has a uniform paint finish, color, and appearance.
- D. Apply paints to produce surface films without cloudiness, spotting, holidays, laps, brush marks, roller tracking, runs, sags, ropiness, or other surface imperfections. Cut in sharp lines and color breaks.
- E. Painting Fire Suppression, Plumbing, HVAC, Electrical, Communication, and Electronic Safety and Security Work:
1. Paint the following work where exposed in equipment rooms:
    - a. Uninsulated metal piping.
    - b. Tanks that do not have factory-applied final finishes.
    - c. Duct, equipment, and pipe insulation having cotton or canvas insulation covering or other paintable jacket material.
  2. Paint the following work where exposed in occupied spaces:
    - a. Equipment, including panelboards.
    - b. Uninsulated metal piping.
    - c. Uninsulated plastic piping.
    - d. Pipe hangers and supports.
    - e. Metal conduit.

- f. Plastic conduit.
  - g. Equipment, and pipe insulation having cotton or canvas insulation covering or other paintable jacket material.
  - h. Exception: Do not paint exposed main ducts and their fasteners. Verify locations with Architect.
  - i. Other items as directed by Architect.
3. Paint portions of internal surfaces of metal ducts, without liner, behind air inlets and outlets that are visible from occupied spaces.

### 3.4 FIELD QUALITY CONTROL

- A. Dry Film Thickness Testing: Owner may engage the services of a qualified testing and inspecting agency to inspect and test paint for dry film thickness.
1. Contractor shall touch up and restore painted surfaces damaged by testing.
  2. If test results show that dry film thickness of applied paint does not comply with paint manufacturer's written recommendations, Contractor shall pay for testing and apply additional coats as needed to provide dry film thickness that complies with paint manufacturer's written recommendations.

### 3.5 CLEANING AND PROTECTION

- A. At end of each workday, remove rubbish, empty cans, rags, and other discarded materials from Project site.
- B. After completing paint application, clean spattered surfaces. Remove spattered paints by washing, scraping, or other methods. Do not scratch or damage adjacent finished surfaces.
- C. Protect work of other trades against damage from paint application. Correct damage to work of other trades by cleaning, repairing, replacing, and refinishing, as approved by Architect, and leave in an undamaged condition.
- D. At completion of construction activities of other trades, touch up and restore damaged or defaced painted surfaces.

### 3.6 INTERIOR PAINTING SCHEDULE

- A. Concrete Substrates, Walls and Ceilings:
1. High-Performance Architectural Latex System: MPI INT 3.1C.
    - a. Prime Coat: Interior acrylic primer/sealer.
    - b. Intermediate Coat: High-performance architectural latex matching topcoat.
    - c. Topcoat: High-performance architectural latex (semigloss).
- B. Concrete Substrates, Traffic Surfaces:

1. Floor Enamel System: MPI INT 3.2A.
  - a. Prime Coat: Exterior/interior floor enamel (gloss).
  - b. Topcoat: Exterior/interior floor enamel (gloss).
  
- C. CMU Substrates:
  1. High-Performance Architectural Latex System: MPI INT 4.2D.
    - a. Prime Coat: Interior/exterior latex block filler.
    - b. Intermediate Coat: High-performance architectural latex matching topcoat.
    - c. Topcoat: High-performance architectural latex (semigloss).
  
- D. Steel Substrates:
  1. High-Performance Architectural Latex System: MPI INT 5.1R.
    - a. Prime Coat: Rust inhibitive Acrylic metal primer.
    - b. Intermediate Coat: High-performance architectural latex matching topcoat.
    - c. Topcoat: High-performance architectural latex (semigloss).
  
- E. Galvanized-Metal Substrates:
  1. High-Performance Architectural Latex System: MPI INT 5.3M.
    - a. Prime Coat: Rust inhibitive Acrylic metal primer.
    - b. Intermediate Coat: High-performance architectural latex matching topcoat.
    - c. Topcoat: High-performance architectural latex (semigloss).
  
- F. Aluminum (Not Anodized or Otherwise Coated) Substrates:
  1. High-Performance Architectural Latex System: MPI INT 5.4F.
    - a. Prime Coat: High-performance architectural latex matching topcoat.
    - b. Topcoat: High-performance architectural latex (semigloss).
  
- G. Dressed Lumber Substrates: Including architectural woodwork
  1. High-Performance Architectural Latex System: MPI INT 6.3A.
    - a. Prime Coat: Wood-Knot Sealer.
    - b. Intermediate Coat: High-performance architectural latex matching topcoat.
    - c. Topcoat: High-performance architectural latex (semigloss).
  
- H. Wood Panel Substrates: Including painted plywood, medium-density fiberboard, hardboard.
  1. High-Performance Architectural Latex System: MPI INT 6.4S.
    - a. Prime Coat: Wood Knot Sealer.
    - b. Intermediate Coat: High-performance architectural latex matching topcoat.
    - c. Topcoat: High-performance architectural latex (semigloss).

I. Gypsum Board Substrates:

1. High-Performance Architectural Latex System: MPI INT 9.2B.
  - a. Prime Coat: [Interior latex primer/sealer][Vinyl Acrylic Latex coating for Level 5 finish].
  - b. Intermediate Coat: High-performance architectural latex matching topcoat.
  - c. Topcoat: High-performance architectural latex (semigloss).

3.7 INTERIOR PAINTING COLOR SCHEDULE

A. P-1: Exterior Wall Paint Base Color:

1. DEW340 Whisper – Dunn Edwards

B. P-2: 1 Exterior Accent Paint at walls.

1. DE5529 Stuffed Olive LRV 37 – Dunn Edwards

C. P-3: Exterior Accent Paint at door and window frames and metal fabrications.

1. DE6144 Graham Cracker – Dunn Edwards

D. P-4: Bollards and Gas Piping.

1. SW6911, Confident yellow. – Sherwin Williams

E. P-5: Exposed Fire Suppression System Piping.

1. SW6867, Fireworks. – Sherwin Williams

END OF SECTION 09 9123



SECTION 09 9601 - HIGH-PERFORMANCE COATINGS FOR INTERIORS

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes surface preparation and application of high-performance epoxy coating systems on the following substrates:

- 1. Interior Substrates:

- a. Concrete masonry units (CMU).
    - b. Concrete, vertical and horizontal surfaces
    - c. Steel.
    - d. Galvanized metal.
    - e. Aluminum (not anodized or otherwise coated).
    - f. Gypsum board.

- B. Related Sections include the following:

- 1. Division 05 Sections for shop priming of metal substrates with primers specified in this Section.
  - 2. Division 09 painting Sections for special-use coatings and general exterior and interior painting.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Samples for Initial Selection: For each type of finish-coat product indicated.
- C. Product List: For each product indicated. Cross-reference products to coating system and locations of application areas. Use same designations indicated on Drawings and in schedules.

1.4 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials, from the same product run, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Coatings: 5 percent, but not less than 1 gal. (3.8 L) of each material and color applied.



1.5 QUALITY ASSURANCE

A. Master Painters Institute (MPI) Standards:

1. Preparation and Workmanship: Comply with requirements in "MPI Architectural Painting Specification Manual" for coating systems indicated.

1.6 DELIVERY, STORAGE, AND HANDLING

A. Store materials not in use in tightly covered containers in well-ventilated areas with ambient temperatures continuously maintained at not less than 45 deg F (7 deg C).

1. Maintain containers in clean condition, free of foreign materials and residue.
2. Remove rags and waste from storage areas daily.

1.7 FIELD CONDITIONS

A. Apply coatings only when temperature of surfaces to be coated and surrounding air temperatures are between 50 and 95 deg F (10 and 35 deg C).

B. Do not apply coatings in snow, rain, fog, or mist; when relative humidity exceeds 85 percent; at temperatures less than 5 deg F (3 deg C) above the dew point; or to damp or wet surfaces.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:

1. ICI Paints.
2. PPG Architectural Finishes, Inc.
3. Sherwin-Williams Company (The).
4. Tnemec.

2.2 HIGH-PERFORMANCE COATINGS, GENERAL

A. Material Compatibility:

1. Provide materials for use within each coating system that are compatible with one another and substrates indicated, under conditions of service and application as demonstrated by manufacturer, based on testing and field experience.
2. For each coat in a coating system, provide products recommended in writing by manufacturers of topcoat for use in coating system and on substrate indicated.
3. Provide products of same manufacturer for each coat in a coating system.

- B. VOC Content: Products shall comply with VOC limits of authorities having jurisdiction[ and, for interior coatings applied at project site, the following VOC limits, exclusive of colorants added to a tint base, when calculated according to 40 CFR 59, Subpart D (EPA Method 24)].
  - 1. Flat Paints and Coatings: 50 g/L.
  - 2. Nonflat Paints and Coatings: 150 g/L.
  - 3. Primers, Sealers, and Undercoaters: 200 g/L.
  - 4. Anti-Corrosive and Anti-Rust Paints Applied to Ferrous Metals: 250 g/L.
  - 5. Zinc-Rich Industrial Maintenance Primers: 340 g/L.
  - 6. Pre-Treatment Wash Primers: 420 g/L.
- C. Colors: As selected by Architect from manufacturer's full range and indicated in color schedule.

### 2.3 BLOCK FILLERS

- A. Interior/Exterior Acrylic Block Filler:
  - 1. Basis of Design: Sherwin Williams; Heavy Duty Block Filler B42W46.

### 2.4 PRIMERS/SEALERS

- A. Acrylic Primer/Sealer:
  - 1. Basis of Design: Sherwin Williams, Loxon Block Surfacer A42W200.
- B. Gypsum Wall Board Primer:
  - 1. Basis of Design: Sherwin Williams; Prep Rite 200 Interior Latex Primer B28W200.

### 2.5 METAL PRIMERS

- A. Rust-Inhibitive Acrylic Primer:
  - 1. Basis of Design: Sherwin-Williams; Pro Industrial Pro-Cyrl Universal Primer, B66-310 Series.

### 2.6 EPOXY COATINGS

- A. Water-Based Epoxy:
  - 1. Basis of Design: Sherwin Williams, Waterbased Catalyzed Epoxy B70W211/B60V25.

### 2.7 SOURCE QUALITY CONTROL

- A. Testing of Coating Materials: Owner reserves the right to invoke the following procedure:

1. Owner will engage the services of a qualified testing agency to sample coating materials. Contractor will be notified in advance and may be present when samples are taken. If coating materials have already been delivered to Project site, samples may be taken at Project site. Samples will be identified, sealed, and certified by testing agency.
2. Testing agency will perform tests for compliance with product requirements.
3. Owner may direct Contractor to stop applying paints if test results show materials being used do not comply with product requirements. Contractor shall remove noncomplying coating materials from Project site, pay for testing, and recoat surfaces coated with rejected materials. Contractor will be required to remove rejected materials from previously coated surfaces if, on recoating with complying materials, the two coatings are incompatible.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine substrates and conditions, with Applicator present, for compliance with requirements for maximum moisture content and other conditions affecting performance of work.
  1. Maximum Moisture Content of Substrates: When measured with an electronic moisture meter as follows:
    - a. Concrete: 12 percent.
    - b. Masonry (Clay and CMU): 12 percent.
    - c. Wood: 15 percent.
    - d. Gypsum Board: 12 percent.
- B. Gypsum Board Substrates: Verify that finishing compound is sanded smooth.
- C. Verify compatibility with and suitability of substrates, including compatibility with existing finishes or primers.
- D. Proceed with coating application only after unsatisfactory conditions have been corrected.
  1. Beginning coating application constitutes Contractor's acceptance of substrates and conditions.

#### 3.2 PREPARATION

- A. Comply with manufacturer's written instructions and recommendations in "MPI Architectural Painting Specification Manual" applicable to substrates indicated.
- B. Remove hardware, covers, plates, and similar items already in place that are removable and are not to be painted. If removal is impractical or impossible because of size or weight of item, provide surface-applied protection before surface preparation and painting.
  1. After completing painting operations, use workers skilled in the trades involved to reinstall items that were removed. Remove surface-applied protection.

- C. Clean substrates of substances that could impair bond of coatings, including dirt, oil, grease, and incompatible paints and encapsulants.
  - 1. Remove incompatible primers and reprime substrate with compatible primers as required to produce coating systems indicated.
- D. Concrete Substrates: Remove release agents, curing compounds, efflorescence, and chalk. Do not coat surfaces if moisture content or alkalinity of surfaces to be coated exceeds that permitted in manufacturer's written instructions.
  - 1. If required by manufacturer, use one of the following methods for cleaning.
    - a. Clean surfaces with pressurized water. Use pressure range of 1500 to 4000 psi (10 350 to 27 580 kPa) at 6 to 12 inches (150 to 300 mm).
    - b. Abrasive blast clean surfaces to comply with SSPC-SP 7/NACE No. 4, "Brush-Off Blast Cleaning."
- E. Masonry Substrates: Remove efflorescence and chalk. Do not coat surfaces if moisture content or alkalinity of surfaces to be coated exceeds that permitted in manufacturer's written instructions.
  - 1. If required by manufacturer, clean surfaces with pressurized water. Use pressure range of 100 to 600 psi (690 to 4140 kPa) at 6 to 12 inches (150 to 300 mm).
- F. Steel Substrates: Remove rust, loose mill scale, and shop primer if any. Clean using methods recommended in writing by paint manufacturer but not less than the following:
  - 1. SSPC-SP 7/NACE No. 4, "Brush-Off Blast Cleaning."
  - 2. SSPC-SP 11, "Power Tool Cleaning to Bare Metal."
  - 3. SSPC-SP 6/NACE No. 3, "Commercial Blast Cleaning."
  - 4. SSPC-SP 10/NACE No. 2, "Near-White Blast Cleaning."
  - 5. SSPC-SP 5/NACE No. 1, "White Metal Blast Cleaning."
- G. Shop-Primed Steel Substrates: Clean field welds, bolted connections, and abraded areas of shop paint, and paint exposed areas with the same material as used for shop priming to comply with SSPC-PA 1 for touching up shop-primed surfaces.
- H. Galvanized-Metal Substrates: Remove grease and oil residue from galvanized sheet metal fabricated from coil stock by mechanical methods to produce clean, lightly etched surfaces that promote adhesion of subsequently applied coatings.
- I. Aluminum Substrates: Remove surface oxidation.

### 3.3 APPLICATION

- A. Apply high-performance coatings according to manufacturer's written instructions.
  - 1. Use applicators and techniques suited for coating and substrate indicated.
  - 2. Coat surfaces behind movable equipment and furniture same as similar exposed surfaces. Before final installation, coat surfaces behind permanently fixed equipment or furniture with prime coat only.

3. Coat back sides of access panels, removable or hinged covers, and similar hinged items to match exposed surfaces.
  4. Do not apply coatings over labels of independent testing agencies or equipment name, identification, performance rating, or nomenclature plates.
- B. Tint each undercoat a lighter shade to facilitate identification of each coat if multiple coats of the same material are to be applied. Tint undercoats to match color of finish coat, but provide sufficient difference in shade of undercoats to distinguish each separate coat.
- C. If undercoats or other conditions show through final coat, apply additional coats until cured film has a uniform coating finish, color, and appearance.
- D. Apply coatings to produce surface films without cloudiness, spotting, holidays, laps, brush marks, runs, sags, ropiness, or other surface imperfections. Produce sharp glass lines and color breaks.

### 3.4 FIELD QUALITY CONTROL

- A. Owner reserves the right to invoke the following procedure at any time and as often as Owner deems necessary during the period when coatings are being applied:
1. Dry Film Thickness Testing: Owner will engage the services of a qualified testing and inspecting agency to inspect and test coatings for dry film thickness.
    - a. Contractor shall touch up and restore coated surfaces damaged by testing.
    - b. If test results show that dry film thickness of applied coating does not comply with coating manufacturer's written recommendations, Contractor shall pay for testing and apply additional coats as needed to provide dry film thickness that complies with coating manufacturer's written recommendations.

### 3.5 CLEANING AND PROTECTION

- A. At end of each workday, remove rubbish, empty cans, rags, and other discarded materials from Project site.
- B. After completing coating application, clean spattered surfaces. Remove spattered coatings by washing, scraping, or other methods. Do not scratch or damage adjacent finished surfaces.
- C. Protect work of other trades against damage from coating operation. Correct damage by cleaning, repairing, replacing, and recoating, as approved by Architect, and leave in an undamaged condition.
- D. At completion of construction activities of other trades, touch up and restore damaged or defaced coated surfaces.

### 3.6 INTERIOR HIGH-PERFORMANCE COATING SCHEDULE

- A. Concrete Substrates, Vertical Surfaces:

1. Water-Based Epoxy Coating System:
  - a. Prime Coat: Water-based epoxy.
    - 1) Where required due to high alkalinity, apply coat of Acrylic Primer sealer to surface.
  - b. Intermediate Coat: Water-based epoxy (interior and exterior).
  - c. Topcoat: Water-based epoxy (interior and exterior).

B. CMU Substrates:

1. Water-Based Epoxy Coating System:
  - a. Prime Coat: Interior/exterior acrylic block filler.
  - b. Intermediate Coat: Water-based epoxy (interior and exterior).
  - c. Topcoat: Water-based epoxy (interior and exterior).

C. Steel Substrates:

1. Water-Based Epoxy Coating System:
  - a. Prime Coat: Rust-inhibitive acrylic primer.
  - b. Intermediate Coat: Water-based epoxy (interior and exterior).
  - c. Topcoat: Water-based epoxy (interior and exterior).

D. Galvanized-Metal Substrates:

1. Water-Based Epoxy Coating System:
  - a. Prime Coat: Rust-inhibitive acrylic primer.
  - b. Intermediate Coat: Water-based epoxy (interior and exterior).
  - c. Topcoat: Water-based epoxy (interior and exterior).

E. Gypsum Board Substrates:

1. Water-Based Epoxy Coating System:
  - a. Prime Coat: Gypsum Wall Board Primer.
  - b. Intermediate Coat: Water-based epoxy.
  - c. Topcoat: Water-based epoxy.

3.7 INTERIOR HIGH PERFORMANCE COATINGS COLOR SCHEDULE

A. Water-Based Epoxy Coating System.

B. HPC-1: Interior Wall Paint Base Color:

1. Match Interior Paint Color P-1: DEW340 Whisper – Dunn Edwards

C. HPC-2: Interior Wall Paint Base Color:

1. Match Interior Paint Color P-2: DE5529 Stuffed Olive LRV 37 – Dunn Edwards

D. HPC-3: Interior Wall Paint Base Color:

1. Match Interior Paint Color P-3: DE6144 Graham Cracker – Dunn Edwards

END OF SECTION 09 9601

SECTION 09 9603 – SPECIAL COATINGS

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes surface preparation and application of special coating systems for showers on the following substrates:
  - 1. Interior Substrates:
    - a. Concrete, vertical and horizontal surfaces.
    - b. Concrete masonry units (CMU).
    - c. Steel.
    - d. Galvanized metal.
    - e. Cement backer units.
- B. Related Sections include the following:
  - 1. Division 033000 Section “Cast-in-Place Concrete” for concrete finishes for floor slabs.
  - 2. Division 034100 Section “Precast Structural Concrete” for concrete finishes on precast concrete wall and floor units.
  - 3. Division 042200 Section “Unit Masonry” for requirements for concrete masonry work.
  - 4. Division 135000 Section “Modular Metal Detention Wall Panel System” for metal requirements for wall and ceiling panels.

1.3 SUBMITTALS

- A. Product Data: For each type of product indicated including generic description, technical data, surface preparation, and application instructions.
- B. Color Samples: Full range of manufacturer’s standard colors.
- C. Samples for Verification: For each type of coating system and in each color and gloss of finish coat indicated.
  - 1. Submit Samples on rigid backing, 8 inches (200 mm) square.
  - 2. Step coats on Samples to show each coat required for system.
  - 3. Label each coat of each Sample.
  - 4. Label each Sample for location and application area.
- D. Qualification Data: For Installer and Manufacturer.



1.4 QUALITY ASSURANCE

- A. Single-source Responsibility: Coatings and coating application accessories to be products of a single manufacturer.
- B. Installer's Qualification: Furnish list of projects using materials specified for this project that applicator has furnished during the past five years. Include the following:
1. Letter of training certification from the manufacturer/distributor stating that contractor is an approved installer of the products specified in this Section.
  2. Submit written description of the contractors' experience with the specified material over the last five (5) years. Include job size (in square feet) and complexity of projects. List a minimum of five (5) projects with different Owners giving contact names and phone numbers.
  3. Submit resume of the key person(s) who will be performing the actual work and list a minimum of five (5) projects with different Owners giving contact names and phone numbers that this key person has performed work for.
  4. References: Installer shall submit a list of 10 projects of similar size and complexity as this project with experience in spray applied fiberglass reinforced epoxy shower systems, including Owner's names and contact phone numbers. Project list shall be submitted with contractor's bid proposal. Failure to include project list with names and references in bid proposal shall disqualify bid.
- C. Manufacturer's Qualifications: Specializing in manufacture of coatings with minimum of ten years successful in-service performance including the following.
1. Manufacturer must supply written warranty that covers liability for failures due to product performance or installation error.
  2. Manufacturer must supply a manufacturer's representative to be present and on site throughout all phases of the project. This includes being present for all work related to the installation of specified system(s).
  3. Manufacturer must supply written letter agreeing to perform the following services:
    - a. Material Manufacturer shall be responsible for the review of the project conditions that may impact product performance before product installation, including but not limited to project climate, acceptable temperature of substrate and air, acceptable humidity levels of air, acceptable moisture content of substrates to be coated, surface preparation, and all other conditions that are necessary for optimum product performance. The manufacturer's field engineer shall document and verify that all conditions are acceptable prior to commencement of work.
    - b. The manufacturer's field representative shall submit through the Contractor written approvals of the proposed coating system including manufacturer's recommended applicator, manufacturer's recommended application procedures, and manufacturer's recommended surface preparation.
    - c. The manufacturer is solely liable for any warranty claims resulting from product failure, whether caused by defective product or improper installation for a period of 5 years. See warranty section: 1.7 for clarification.

- d. The manufacturer shall observe, measure and document that installer has applied all specified products over properly prepared substrates. Documentation shall include the measuring of film thickness of both flooring and wall finishes. All documentation shall become part of the warranty documents to verify products were installed in accordance with manufacturer's published installation instructions and at the specified thickness herein.

#### 1.5 DELIVERY, STORAGE, AND HANDLING

- A. Store materials not in use in tightly covered containers in well-ventilated areas with ambient temperatures continuously maintained between 65 deg F and 90 deg F or as recommended by product manufacturer.
  1. Maintain containers in clean condition, free of foreign materials and residue.
  2. Remove rags and waste from storage areas daily.

#### 1.6 PROJECT CONDITIONS

- A. Apply coatings only when temperature of surfaces to be coated and surrounding air temperatures are between 65 and 90 deg F and surface temperature is a minimum of 5 deg F (3 deg C) above dew point.
- B. Do not apply coatings in areas where dust is being generated, to damp or wet surfaces, or where relative humidity is outside range per manufacturer's instructions.
- C. Provide ventilation during coating evaporation stage in confined or enclosed areas in accordance with manufacturer's instructions.
- D. Cover or otherwise protect finish work of other trades and surfaces not to be coated concurrently or not to be coated.

#### 1.7 WARRANTY

- A. Manufacturer alone shall furnish a single, written warranty covering 100% of the material and labor costs protecting the Owner from delamination and product failure caused by defective product or defective installation for a period of 5 years from date of installation. Joint warranties between manufacturer and installer not accepted.
  1. Issuance of warranty shall be a condition contingent on the receipt of final payment to the Installer.
  2. Extent of warranty shall be limited to the repair or replacement of defective surfaces at no cost to the Owner including both material and installation costs associated with any repairs or replacement of defective product or defective installation. The warranty shall not include any remedy for defects caused by abuse, improper maintenance, change of use or operation, moisture migration from the back side of coating system, substrate deterioration, substrate movement or by normal wear, tear and usage of the building structure.

PART 2 - PRODUCTS

2.1 SPECIAL COATINGS, GENERAL

A. Material Compatibility:

1. Provide materials for use within each coating system that are compatible with one another and substrates indicated, under conditions of service and application as demonstrated by manufacturer, based on testing and field experience.

2.2 MANUFACTURERS

A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the work include, but are not limited to, the following:

1. Prime Coat Coating Systems, Waukegan, IL Contact: 847-362-5111 or Kurt Schilling at 217-971-3746.
2. Alternate companies to the basis of design must be preapproved 21 days prior to bid date. Only companies willing to meet performance requirements, installation requirements, product composition and thickness requirements, and manufacturer's responsibilities and warranties as specified shall be approved.

2.3 MATERIALS

A. Wall and Ceilings Coating: Spray applied fiber-reinforced, 100% solids, accelerated aliphatic amine cured epoxy system.

B. Floor Coating: High performance 100% solids floor coating system of aggregate-filled polyamine epoxy.

C. Product Characteristics and Composition:

1. Epoxy Wall and Ceiling System SC-1.
  - a. Compressive Strength: 11,700 psi (ASTM D-695-77).
  - b. Tensile Strength: 3,900 psi (ASTM D638-77a).
  - c. Tensile Elongation: 2% (ASTM D638-77a).
  - d. Flexural Modulus: 1.8 x 10<sup>6</sup> psi (ASTM D 790-71).
  - e. Flexural Strength: 10,400 psi (ASTM D 790-71).
  - f. Water Absorption: 0.1% (ASTM C413).
  - g. Heat Resistance Limitation: Continuous exposure: 140 F; Intermittent spills 200 F.
  - h. Abrasion Resistance: 0.03 gm. Maximum weight loss (ASTM D 4060, Taber Abrader CS-17 wheel, 1,000 gm load, 1,000 revolutions).
  - i. Flammability: Self-extinguishing (ASTM D 635).
  - j. Hardness: 88 Shore D (ASTM D 2240) minimum.
  - k. Bond Strength: >400 psi or substrate failure (ASTM D4542).
  - l. Chopped fiberglass strands, premixed into the material.
  - m. Form a horizontal matrix within the finished coating.
  - n. 100% solids products.
  - o. Color continuous throughout the entire system.

2. Aggregate Filled Epoxy Floor Coating (SC-2).
  - a. Integral Cove Base: Cant or radius 4 inches high.
  - b. Compressive Strength: 12,400 psi after 7 days (ASTM C-579).
  - c. Tensile Strength: 2,200 psi (ASTM C-307).
  - d. Flexural Strength: 4,800 psi (ASTM C-307).
  - e. Bond Strength: >400 psi or substrate failure (ASTM D-4541).
  - f. Indentation: No indentation (MIL-D-3134F).
  - g. Abrasion Resistance: 0.04 gm max. loss (ASTM D-4060, Taber Abrader).
  - h. Hardness: 85-90 Shore D (ASTM D2240).
  - i. Flammability: Self-extinguishing. Burning 0.25 inches max. (ASTM D-635).
  - j. Thermal Coefficient of Linear Expansion:  $3.5 \times 10^{-5}$  C (ASTM E-831).
  - k. Water Absorption: 0.1% (ASTM C-413).
  - l. All 100% solids material.
  - m. Color throughout the entire floor system.
  - n. Capable of achieving a chemical bond with wall system.
  - o. Finish coat to be manufacturer's clear finish coat material.

## 2.4 MIXES

### A. Walls and Ceilings (SC-1).

1. Mix components in containers furnished by the manufacturer.
2. Proportioning of two-part and three-part coatings shall be done in accordance with manufacturer's recommended procedures.
3. Mix prime coat using a variable speed drill. Parts A and B shall be pre-mixed and then combined and mixed together a minimum of two minutes. Ensure full blending of both parts with all material measured into the mixing container. Apply the mixed material within the pot life and temperatures recommended by the manufacturer.
4. Intermediate fiber reinforced coats shall be mixed similar to that method employed for the prime coat.
5. Glaze coat, consisting of Parts A and B, shall be mixed similar to that method employed for the prime coat.
6. For all mixing operations, the system components shall be considered as hazardous materials. Read and observe container label warnings and Material Safety Data Sheets for health and safety information prior to starting mixing operations.
7. Do not reseal mixed material. Permit final chemical set to occur in the container and when set has been achieved, dispose of hardened material by legal means.
8. Do not apply any material that has exceeded shelf and pot life as determined by manufacturer.

### B. Floors (SC-2):

1. Mix components only in containers furnished by the manufacturer.
2. Proportioning of two-part and three-part coatings shall be done in strict accordance with manufacturer's recommended procedures.
3. Mix prime coat using a variable speed drill. Parts A and B shall be mixed with a variable speed drill for a minimum of two minutes. Ensure full blending of both parts with all material measured into the mixing container. Apply the mixed material within the pot life and temperature recommended by the manufacturer.
4. Intermediate coats shall be mixed similar to that method employed for the prime coat.
5. Glaze coat, consisting of Parts A and B, shall be mixed for a minimum of two minutes using a variable speed drill.

6. For all mixing operations, the system components shall be considered as hazardous materials. Read and observe container label warnings and Material Safety Data Sheets for health and safety information prior to starting mixing operations.
7. Do not reseal mixed material. Permit final chemical set to occur in the container and when set has been achieved, dispose of hardened material by legal means.
8. Do not apply any material that has exceeded shelf and pot life as determined by manufacturer.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine substrates and conditions, with Applicator present, for compliance with requirements for maximum moisture content and other conditions affecting performance of work.
  1. Maximum Moisture Content of Substrates: When measured with an electronic moisture meter as follows:
    - a. Concrete: 12 percent.
    - b. Masonry: 12 percent.
  2. Verify compatibility with and suitability of substrates, including compatibility with existing finishes or primers.
  3. Begin coating application only after unsatisfactory conditions have been corrected and surfaces are dry.
  4. Coating application indicates acceptance of surfaces and conditions.

#### 3.2 PREPARATION

- A. Comply with manufacturer's written instructions and recommendations applicable to substrates indicated.
- B. Remove plates, machined surfaces, and similar items already in place that are not to be coated. If removal is impractical or impossible because of size or weight of item, provide surface-applied protection before surface preparation and coating.
  1. After completing coating operations, reinstall items that were removed; use workers skilled in the trades involved.
- C. Clean substrates of substances that could impair bond of coatings, including dirt, oil, grease, and incompatible paints and encapsulants.
- D. Concrete Wall and Ceiling Substrates: Remove release agents, curing compounds, efflorescence, and chalk. Do not coat surfaces if moisture content or alkalinity of surfaces to be coated exceeds that permitted in manufacturer's written instructions.
  1. Prepare surfaces in accordance with manufacturer's instructions, SSPC-SP13/NACE 6 and ICRI 03732.
  2. Surface to be clean, dry and free of contaminants prior to installing coating system.
- E. Concrete Floor Slabs-on-Grade Substrates:
  1. Smooth troweled dense finish concrete that shall have been properly cured not less than twenty-eight (28) days after placement.

2. Employ a radio frequency moisture meter to determine that residual uncombined moisture content of concrete slab is less than five (5) percent by weight. Conduct ASTM F1869 to further record the Moisture Vapor Emission Rate. Do not apply high performance floor coatings to floor slabs that exceed 5 percent moisture content or 3 pounds per 1,000 square feet per 24 hours unless approved by the material manufacturer.
  3. Prepare all concrete floor surfaces per SSPC-SP13/NACE 6.
  4. Remove and legally dispose of all debris and contaminants produced by the surface preparation process.
- F. CMU Substrates: Remove efflorescence and chalk. Do not coat surfaces if moisture content or alkalinity of surfaces to be coated exceeds that permitted in manufacturer's written instructions.
1. Verify mortar joints are struck clean and filled tightly to avoid gaps or holes and provide a uniform appearance.
  2. Remove mortar spatter, protruding mortar edges and other excessive mortar.
  3. Grind rough edges smooth.
  4. Clean CMU as specified.
  5. Verify all surfaces are clean, dry and free of contaminants prior to installing coating system.
- G. Steel Substrates: Remove rust and loose mill scale.
1. Clean using methods recommended by coating manufacturer and in accordance with SSPC guidelines.
- H. Galvanized-Metal Substrates: Remove grease and oil residue from galvanized sheet metal fabricated from coil stock by mechanical methods to produce clean, lightly etched surfaces that promote adhesion of subsequently applied coatings, in accordance with SSPC guidelines.

### 3.3 APPLICATION

- A. Apply special coatings according to manufacturer's written instructions and approved shop drawings.
1. Use applicators and techniques suited for coating and substrate indicated.
- B. Walls and Ceilings:
1. Do not apply initial coating until moisture content of surface is within limitations recommended by coating manufacturer.
  2. Apply 100% solids plural component thixotropic epoxy primer at coverage rates recommended by manufacturer but at a rate that will produce a dry film thickness not less than 8 mils on concrete surfaces or at a spreading rate of 12-16 mils on porous surfaces such as CMU. Airless spray, brush or rollers may be used to apply the primer.
  3. After primer has become tacky, apply the fiber glass stranded reinforced epoxy system using an air powered airless spray rig with a gravity fed hopper attachment. While applying the fiberglass reinforced product verify product thickness and reapply in multiple coats until specified mil thickness is achieved. Specified mil thickness for fiberglass epoxy layer is 45 mils WFT. Note: Product must be checked for proper mil thickness on all wall surfaces while wet and documented as part of warranty.
  4. When the fiber reinforced epoxy system has cured, abrade the substrates to remove exposed fiberglass and other surface imperfections. Apply 100% solids final with integrated anti-microbial glazing coat with a brush, roller or airless sprayer at 8-10 mils

WFT. A total DFT of the complete system shall be a minimum 60 mils thick including primers, body coat(s) and final finish coat.

5. Keep all application equipment free from contaminates and suitable for the finish required.
6. Comply with recommendation of product manufacturer for cure times and re-coat windows. Unless specifically allowed by the manufacturer, re-coat windows will not be violated.
7. Finish coats shall be smooth to the touch and free of skipped or missed areas. An orange peel texture with occasional fiberglass lumps is normal and acceptable.
8. Make edges where adjoining other materials or colors, clean and sharp with no overlapping.
9. Change colors at points designated by Owner's agent and/or on color schedule where colors differ between adjoining spaces or rooms and where door frames match wall colors.

C. Floors:

1. Do not apply initial coating until moisture content of surface is within limitations recommended by coating manufacturer.
2. Apply primer at coverage rates as recommended by manufacturer. Airless spray, brushes, rollers or squeegee may be used in coating application.
3. Apply two intermediate coats of clear, mixed liquids at a rate to achieve approximately 20 mils wet film thickness. After each intermediate coat, broadcast onto the liquid surface colored quartz aggregate passing 40 to 60 mesh screen to rejection. Remove excess aggregate after film is dried by broom sweeping or industrial grade vacuum. A total dry film thickness of the intermediate coat shall be not less than 40 mils including encapsulated aggregate.
4. When the intermediate coats have cured and excess aggregate thoroughly removed, apply the final clear glazing coat to a minimum dry film thickness of 10 mils. Apply glazing coat with a brush, roller or airless sprayer. The finished floor to meet ADA specifications for this project. Use a Sullmair FSC 2000-1346 floor tester to validate ADA requirements.
  - a. Please note to achieve the required ADA coefficient of friction, additional topcoat material or anti-slip additives may be necessary.
5. A total DFT of the broadcast system shall be a minimum 250 mils thick.
6. Comply with recommendations of manufacturer of high performance floor system for drying time between prime and succeeding coats.
7. Finished product shall be uniform in color and texture and free of skipped or missed areas.
8. Where walls and floors abut insure a seamless installation.

D. Finished Work Requirements:

1. Curtaining on face not permitted.
2. Damage to finished surfaces caused by other than coating contractor shall be repaired to acceptable condition by coating contractor under cost reimbursement by Contractor.

3.4 CLEANING AND PROTECTION

- A. At end of each workday, remove rubbish, empty cans, rags, and other discarded materials from Project site.

- B. After completing coating application, clean spattered surfaces. Remove spattered coatings by washing, scraping, or other methods. Do not scratch or damage adjacent finished surfaces.
- C. Protect work of other trades against damage from coating operation. Correct damage by cleaning, repairing, replacing, and recoating, as approved by Architect, and leave in an undamaged condition.
- D. At completion of construction activities of other trades, touch up and restore damaged or defaced coated surfaces.

3.5 Color Schedule

- A. SC-1: Match Primecoat C18 White
- B. SC-2: Match Primecoat C13 FAWN BEIGE

END OF SECTION 09 9603





SECTION 099646 - INTUMESCENT PAINTING

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. Section includes surface preparation and application of fire-retardant intumescent paint to interior items and surfaces.
- B. Related Sections:
  - 1. Section 051200 "Structural Steel Framing."
  - 2. Section 078100 "Applied Fireproofing" for fire-resistance-rated intumescent mastic materials.
  - 3. Section 099113 "Exterior Painting" for primers, finish coats, and wood stains that may be used with intumescent paint finishes.
  - 4. Section 099123 "Interior Painting" for primers, finish coats, and wood stains that may be used with intumescent paint finishes.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.
  - 1. Product List: Cross-reference to coating system and locations of application areas. Use same designations indicated on Drawings and in schedules. Include manufacturer's recommended spreading rate for each separate coat for each type of substrate indicated.
  - 2. Printout of current "MPI Approved Products List" for each product category specified in Part 2 that specifies coatings approved by MPI, with the proposed product highlighted.
- B. Samples for Initial Selection: For each intumescent paint finish indicated.
- C. Samples for Verification: For each type of coating system and each color and gloss of intumescent paint finish indicated.
  - 1. Submit Samples on rigid backing not less than 8 inches (200 mm) square.
  - 2. Step coats on Samples to show each coat required for system.
  - 3. Label each coat of each Sample.
  - 4. Label each Sample for location and application area.

1.4 INFORMATIONAL SUBMITTALS

- A. Material Test Reports: For each intumescent paint.

1.5 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that are from same production run (batch mix) as materials applied and that are packaged with protective covering for storage and identified with labels describing contents.
1. Quantity: Furnish an additional 5 percent of each color applied, but not less than 1 gal. (3.8 L) of each material and color applied.

1.6 QUALITY ASSURANCE

- A. Source Limitations: Obtain each paint system from single source from single manufacturer or provide a system approved in writing by intumescent paint manufacturer.
- B. Surface-Burning Characteristics: As determined by testing identical products according to ASTM E 84 by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
1. Flame-Spread Index: 26 to 75.
  2. Smoke-Developed Index: 450 or less.
- C. Mockups: Apply benchmark Samples of paint system indicated and of each color and finish selected to verify preliminary selections made under Sample submittals and to demonstrate aesthetic effects and set quality standards for materials and execution.
- D. Preinstallation Conference: Conduct conference at Project site.

1.7 REFERENCES

- A. ANSI A2.1 - Standard Test Method for Fire Tests of Building Construction and Materials.
- B. ASTM International:
1. ASTM D 1475 - Standard Test Method For Density of Paint, Varnish, Lacquer, and Related Products.
  2. ASTM D 2369 - Standard Test Method For Volatile Content of Coatings.
  3. ASTM D 3359 - Standard Methods for Measuring Adhesion by Tape Test (Methods A and B)
  4. ASTM D 3960 - Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings.
  5. ASTM D 4017 - "Standard Test Method for Water in Paints and Paint Materials by Karl Fischer Method.
  6. ASTM E 84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
  7. ASTM E 119 - Standard Test Methods for Fire Tests of Building Construction and Materials.
  8. ASTM E 662 - Standard Guide for Measurement of Gases Present or Generated During Fires.

- C. BSS 476 - Standard Test Method for Fire Tests of Building Construction and Materials.
- D. BSS 7239 - Test Method for Toxic Gas Generation by Materials on Combustion.
- E. UBC 8.1 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- F. DIN 4102, Part 8 - Standard Test Method for Fire Tests of Building Construction and Materials.
- G. National Fire Protection Association (NFPA) Latest Editions of the following:
  - 1. NFPA 251 - Standard Test Method for Fire Tests of Building Construction and Materials.
  - 2. NFPA 255 - Standard Test Method for Surface Burning Characteristics of Building Materials.
  - 3. NFPA 286 – Standard Methods of Fire Tests for Evaluating contribution of Wall and Ceiling Interior Finish to Room
- H. UL 263 - Fire Tests of Building Construction and Materials.
- I. UL 723 - Test for Surface Burning Characteristics of Building Materials.
- J. UL-C-S101 - Standard Test Method for Fire Tests of Building Construction and Materials.
- K. 2010 California Building Code.

#### 1.8 DELIVERY, STORAGE, AND HANDLING

- A. Store materials not in use in tightly covered containers in well-ventilated areas with ambient temperatures continuously maintained at not less than 45 deg F (7 deg C).
  - 1. Maintain containers in clean condition, free of foreign materials and residue.
  - 2. Remove rags and waste from storage areas daily.

#### 1.9 PROJECT CONDITIONS

- A. Apply waterborne intumescent paints only when temperatures of surfaces to be painted and ambient air temperatures are between 50 and 90 deg F (10 and 32 deg C).
- B. Apply solvent-thinned intumescent paints only when temperatures of surfaces to be painted and ambient air temperatures are between 45 and 95 deg F (7 and 35 deg C).
- C. Do not apply intumescent paints in snow, rain, fog, or mist; when relative humidity exceeds 85 percent; at temperatures less than 5 deg F (3 deg C) above the dew point; or to damp or wet surfaces.
- D. Allow wet surfaces to dry thoroughly and to attain temperature and conditions specified before starting or continuing coating operation.

PART 2 - PRODUCTS

2.1 Products: Subject to compliance with requirements, Provide Contego Passive Fire Barrier Intumescent Latex Paint as Manufactured by Contego International, approved comparable product or comparable product by one of the following:

- A. Flame Control Coatings, LLC.
- B. Magna Coatings Technology, Inc.
- C. Albi Manufacturing, a division of StanChem, Inc.
- D. Fire Research Laboratories / Ocean Fire Retardants, Inc.
- E. NoFire Technologies, Inc.

2.2 INTUMESCENT PAINT MATERIALS, GENERAL

A. Materials

- 1. Basis of Design: Contego Passive Fire Barrier Intumescent Latex Paint as manufactured by Contego International:
  - a. Color: Gray
  - b. VOC (Less Water): 0 Grams/Liter
  - c. Weight/US Gallon: 10.8 lbs. (11.2 for HS Version)
  - d. Hazardous Ingredient: N/A.
  - e. WHMIS Class: Not Controlled.
  - f. Flammability: Not Flammable.
  - g. Weight Solids: 52.93 percent. (62.45 for HS Version)
  - h. Volume Solids: 43.7 percent. (68.3% for HS Version)
  - i. Specific Gravity: 1.29. (1.67 for HS Version)
  - j. pH Range: 8.0-8.5.
- 2. Testing Compliance:
  - a. ANSI/UL723 Class A Doug Fir. (a=10 minutes, b=Extended to 30 minutes)
    - 1) Results: Average Flame spread Index 0; Smoke Index 0, Class A.
    - 2) Results: Average Flame spread Index 0; Smoke Index 5, Class A.
  - b. ASTM E 119/UL-263/UBC 7.1, ANSI A2.1/ULC-S01/NFPA 251:
    - 1) Results: Ranged from 103 to 121 minutes. STEEL "I" Beams Unrestrained.
    - 2) Steel Plate: ASTM 119 UL-263 ON .250 Plate 73 mil coating of Contego achieved 126 minutes (1000 degrees F, 538 degrees C unexposed surface) Unrestrained.
    - 3) Steel Beams and Decking With 4 Inches Concrete: ASTM 119 UL-263 with 58 mil coating of Contego achieved 87 minutes (1100 degrees F, 593 degrees C unexposed surface) Unrestrained, 174 minutes Restrained.
    - 4) 0.500 Steel Plate: ASTM E 119/UL-263/UBC 7.1, ANSI A2.1/ULC-S01/NFPA 251 Top Coated with 60 mils and Acrylic Enamel. The thermocouples exceeded an average of 1,200 degrees F (649 degrees C) at 2:21.50 proving that top coating adds 25% to 32% to the total fire resistance.
  - c. NFPA 286, Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room. Met all criteria.

B. Material Compatibility:

1. Provide materials for use within each paint system that are compatible with one another and substrates indicated, under conditions of service and application as demonstrated by manufacturer, based on testing and field experience.
2. For each material or coat, provide products and spreading rates recommended in writing by intumescent paint manufacturer for use on substrate indicated. Comply with requirements for fire-retardant coating classification and surface-burning characteristics indicated.

C. Colors and Gloss: As selected by Architect from manufacturer's full range.

2.3 EXTERIOR, PIGMENTED, INTUMESCENT PAINT SYSTEM

- A. Primer: Intumescent paint manufacturer's recommended primer, if required, compatible with substrate and other materials indicated.
1. VOC Content: 0 Grams / Litre.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates and conditions, with Applicator present, for compliance with manufacturer's requirements for surface treatments, shop-primed surfaces, maximum moisture content, and other conditions affecting performance of the Work.
- B. Verify suitability of substrates, including surface conditions, and compatibility with existing finishes and primers.
- C. Begin coating application only after unsatisfactory conditions have been corrected and surfaces are dry.

3.2 PREPARATION

- A. Comply with manufacturer's written instructions applicable to substrates and coating systems indicated.
- B. Remove hardware and hardware accessories, plates, machined surfaces, light fixtures, and similar items already installed that are not to be coated. If removal is impractical or impossible because of size or weight of item, provide surface-applied protection before surface preparation and coating.
1. After completing coating operations, use workers skilled in the trades involved to reinstall items that were removed. Remove surface-applied protection if any.

- C. Clean substrates of substances, including dirt, oil, grease, and incompatible paints and encapsulants, that could impair bond of coatings. Do not coat surfaces if surface moisture content or alkalinity exceeds that permitted in manufacturer's written instructions.
  - 1. Remove incompatible primers, and reprime substrate with compatible primers as required to produce coating systems indicated.
  - 2. Perform cleaning and coating application so dust and other contaminants from cleaning process will not fall on wet, newly coated surfaces.

### 3.3 APPLICATION

- A. General: Apply intumescent paints according to manufacturer's written instructions and to comply with requirements for fire-retardant coating classification.
  - 1. Use equipment and techniques best suited for substrate and type of material being applied.
  - 2. Coat surfaces behind movable items the same as similar exposed surfaces.
  - 3. Apply each coat separately according to manufacturer's written instructions.
- B. Apply coatings to prepared surfaces as soon as practical after preparation and before subsequent surface soiling or deterioration.
- C. Apply coatings to produce surface films without cloudiness, spotting, holidays, laps, brush marks, roller tracking, runs, sags, ropiness, or other surface imperfections. Cut in sharp lines and color breaks.
  - 1. Pigmented Finishes: If undercoats or other conditions show through pigmented topcoat/overcoat, apply additional coats until cured film has a uniform paint finish, color, and appearance.
  - 2. Clear Finishes: Produce a smooth surface film of even sheen using multiple coats.

### 3.4 CLEANING AND PROTECTION

- A. At end of each workday, remove rubbish, empty cans, rags, and other discarded materials from Project site.
- B. After completing coating application, clean spattered surfaces. Remove spattered coatings by washing, scraping, or other methods. Do not scratch or damage adjacent finished surfaces.
- C. Protect work of other trades against damage from coating application. Correct damage to work of other trades by cleaning, repairing, replacing, and refinishing, as approved by Architect, and leave in an undamaged condition.
- D. At completion of construction activities, touch up and restore damaged or defaced coated surfaces.

3.5 PAINT SYSTEM SCHEDULE

- A. Prime Coat: If required and approved by intumescent paint manufacturer.
- B. Fire-Retardant Intumescent Coating: Minimum coats to comply with requirements for fire-retardant coating classification and surface-burning characteristics indicated.
- C. Topcoat/Overcoat: Apply if required or recommended and approved by intumescent paint manufacturer.



END OF SECTION 099646

SECTION 09 8433 - SOUND-ABSORBING WALL UNITS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes shop-fabricated, acoustical panel units tested for acoustical performance, including the following:
  - 1. Sound-absorbing wall panels.

1.3 DEFINITIONS

- A. NRC: Noise Reduction Coefficient.
- B. SAA: Sound Absorption Average.

1.4 PREINSTALLATION MEETINGS

- A. Preinstallation Conference: Conduct conference at Project site.

1.5 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. Include panel edge, core material, and mounting indicated.
- B. Shop Drawings: For unit assembly and installation.
  - 1. Include plans, elevations, sections, and mounting devices and details.
  - 2. Include details at panel head, base, joints, and corners; and details at ceiling, floor base, and wall intersections. Indicate panel edge profile and core materials.
  - 3. Include details at cutouts and penetrations for other work.
- C. Samples for Verification: For the following products:
  - 1. Assembled Panels: Approximately 12 by 12 inches (305 by 305 mm), including joints mounting methods, and panel corner.

#### 1.6 INFORMATIONAL SUBMITTALS

- A. Coordination Drawings: Elevations and other details, drawn to scale, on which the following items are shown and coordinated with each other, using input from installers of the items involved:
  - 1. Electrical outlets, switches, and thermostats.
  - 2. Items penetrating or covered by units including the following:
    - a. Lighting fixtures.
    - b. Air outlets and inlets.
    - c. Speakers.
    - d. Alarms.
    - e. Sprinklers.
    - f. Access panels.
- B. Product Certificates: For each type of unit.

#### 1.7 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For each type of unit to include in maintenance manuals.

#### 1.8 DELIVERY, STORAGE, AND HANDLING

- A. Comply with unit manufacturers' written instructions for minimum and maximum temperature and humidity requirements for shipment, storage, and handling.
- B. Deliver materials and units in unopened bundles and store in a temperature-controlled dry place with adequate air circulation.

#### 1.9 FIELD CONDITIONS

- A. Environmental Limitations: Do not install units until spaces are enclosed and weathertight, wet-work in spaces is complete and dry, work at and above ceilings is complete, and ambient temperature and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.
- B. Air-Quality Limitations: Protect units from exposure to airborne odors, such as tobacco smoke, and install units under conditions free from odor contamination of ambient air.
- C. Field Measurements: Verify unit locations and actual dimensions of openings and penetrations by field measurements before fabrication, and indicate them on Shop Drawings.

#### 1.10 WARRANTY

- A. Special Warranty: Manufacturer agrees to repair or replace units and components that fail in materials or workmanship within specified warranty period.

1. Failures include, but are not limited to the following:
  - a. Acoustical performance.
  - b. Failure of panel finish.
2. Warranty Period: Two years from date of Substantial Completion.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. Source Limitations: Obtain wall units specified in this Section from single source from single manufacturer.

### 2.2 PERFORMANCE REQUIREMENTS

- A. Fire-Test-Response Characteristics: Units shall comply with "Surface-Burning Characteristics" or "Fire Growth Contribution" Subparagraph below, or both, as determined by testing identical products by UL or another testing and inspecting agency acceptable to authorities having jurisdiction:
  1. Surface-Burning Characteristics: Comply with ASTM E 84 or UL 723; testing by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
    - a. Flame-Spread Index: 25 or less.
    - b. Smoke-Developed Index: 450 or less.

### 2.3 SOUND-ABSORBING WALL UNITS

- A. Sound-Absorbing Wall Panel <Insert drawing designation>: Manufacturer's standard panel construction consisting of facing material [laminated to front face, edges, and back edge border of core] [stretched over front face of edge-framed core and bonded or attached to edges and back of frame] <Insert description>.
- B. <Double click here to find, evaluate, and insert list of manufacturers and products.>
  1. Panel Shape: [Flat] [As indicated on Drawings] <Insert shape>.
  2. Mounting: Edge mounted with splines secured to substrate.
    - a. Finish Color at Exposed Edges: [White] [Black] [Match color of facing material] [Match Architect's sample] [As selected by Architect from manufacturer's full range] <Insert requirement>.
  3. Mounting: Back mounted with manufacturer's standard [adhesive] [adhesive tape strips] [hook-and-loop strips] [impaling clips] [magnetic devices] [metal clips or bar hangers], secured to substrate.

4. Core: [Manufacturer's standard] [Glass-fiber board] [Mineral-fiber board] [Cementitious-fiber board] <Insert requirement>.[ Provide wood or plywood nailing strips in core where indicated.]
  - a. Core-Face Layer: Manufacturer's standard [tackable, impact-resistant, high-density board] [impact-resistant, acoustically transparent, copolymer sheet] <Insert requirement>.
5. Edge Construction: Manufacturer's standard [chemically hardened core with no frame] [extruded-aluminum or zinc-coated, rolled-steel frame] [extruded PVC frame] [wood frame, rabbeted, and splined with glued joints and machined corners] <Insert requirement>.
6. Edge Profile: [Long edges kerfed and rabbeted to receive splines] [Chamfered (beveled)] [Eased (small radius)] [Mitered (beveled to a point)] [Radiused (bullnosed)] [Square] [Custom profile as indicated on Drawings] <Insert profile>.
7. Corner Detail in Elevation: [Square] [Round, radius as indicated on Drawings] [Custom as indicated on Drawings] <Insert description> with continuous edge profile indicated.
8. Reveals between Panels: [Recessed] [Flush] [Projecting] reveals [as selected by Architect from manufacturer's full range] [as indicated on Drawings] <Insert requirement>.
9. Facing Material: [Owner-furnished material] [As indicated on Drawings] <Insert drawing designation>.
10. Acoustical Performance: Sound absorption [NRC] [or] [SAA] of [0.50 to 0.90] [0.60 to 0.70] [0.65 to 0.75] [not less than 0.65] <Insert range or single value> according to ASTM C 423 for [Type A] <Insert type> mounting according to ASTM E 795.
11. Nominal [Core] [Overall Panel] Thickness: [3/4 inch (19 mm)] [1 inch (25 mm)] [1-1/2 inches (38 mm)] [2 inches (51 mm)] [As indicated on Drawings] <Insert dimension>.
12. Panel Width: [24 inches (610 mm)] [30 inches (762 mm)] [48 inches (1220 mm)] [As indicated on Drawings] <Insert dimension>.
13. Panel Height: [72 inches (1829 mm)] [96 inches (2438 mm)] [108 inches (2743 mm)] [120 inches (3048 mm)] [As indicated on Drawings] <Insert dimension>.

#### 2.4 SOUND-DIFFUSING AND -REFLECTING WALL UNITS

- A. Sound-[Diffusing] [Reflecting] Wall Panel <Insert drawing designation>: Manufacturer's standard panel construction[ consisting of facing material laminated to front face, edges, and back edge border of core] <Insert description>.
- B. <Double click here to find, evaluate, and insert list of manufacturers and products.>
  1. Panel Shape: [Barrel] [Pyramidal] [Flat] [Radially curved flat panel] [As indicated on Drawings] <Insert shape>.
  2. Mounting: Back mounted with manufacturer's standard [adhesive] [adhesive tape strips] [hook-and-loop strips] [impaling clips] [magnetic devices] [metal clips or bar hangers], secured to substrate.
  3. Core: [Manufacturer's standard] [Glass-fiber board with a reflective component] [Mineral-fiber board with a reflective component] [Cementitious-fiber board with a reflective component] [Fire-retardant formed plastic] [Medium-density fiberboard] [Particleboard] <Insert requirement>, prepared for required acoustical performance.

4. Edge Construction: [Manufacturer's standard] [Chemically hardened core with no frame] [Extruded-aluminum or zinc-coated, rolled-steel frame] [Extruded PVC frame] [Wood frame, rabbeted, and splined with glued joints and machined corners] <Insert requirement>.
5. Reveals between Panels: [Recessed] [Flush] [Projecting] reveals [as selected by Architect from manufacturer's full range] [as indicated on Drawings] <Insert requirement>.
6. Facing Material: [Owner-furnished material] [As indicated on Drawings] <Insert drawing designation>.
7. Acoustical Performance: Sound absorption [NRC] [or] [SAA] of [0.05 to 0.10] [0.15 to 0.25] [0.30 to 0.40] [not more than 0.35] <Insert range or single value> according to ASTM C 423 for [Type A] <Insert type> mounting according to ASTM E 795.
8. Panel Width: [24 inches (610 mm)] [30 inches (762 mm)] [48 inches (1220 mm)] [As indicated on Drawings] <Insert dimension>.
9. Panel Height: [72 inches (1829 mm)] [96 inches (2438 mm)] [108 inches (2743 mm)] [120 inches (3048 mm)] [As indicated on Drawings] <Insert dimension>.

## 2.5 MATERIALS

- A. <Double click to insert sustainable design text for composite wood products.>
- B. <Double click to insert sustainable design text for recycled content.>
- C. <Double click to insert sustainable design text for regional materials.>
- D. <Double click to insert sustainable design text for certified wood.>
- E. Core Materials:[ Manufacturer's standard.]
  1. Glass-Fiber Board: ASTM C 612; of type standard with manufacturer; nominal density of [6 to 7 lb/cu. ft. (96 to 112 kg/cu. m)] <Insert value>, unfaced, and dimensionally stable, molded rigid board; and with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively.
  2. Mineral-Fiber Board: Maximum flame-spread and smoke-developed indexes of 25 and 10, respectively; minimum density of [13 lb/cu. ft. (208 kg/cu. m)] [20 lb/cu. ft. (320 kg/cu. m)], and with perforated surface.
  3. Cementitious-Fiber Board: Density of not less than [20 lb/cu. ft. (320 kg/cu. m)] <Insert value>.
  4. Fire-Retardant Formed Plastic: Manufacturer's standard formed plastic with flame-spread index of 25 or less and smoke-developed index of 25 or less according to ASTM E 84 or UL 723.
  5. Medium-Density Fiberboard: Panels complying with ANSI A208.2, [grade to suit performance requirements] [Grade 130] <Insert grade>.
    - a. Fire-retardant panels made from softwood fibers, synthetic resins, and fire-retardant chemicals mixed together at time of panel manufacture to achieve flame-spread index of 25 or less and smoke-developed index of 200 or less per ASTM E 84 or UL 723.

6. Particleboard: Panels complying with ANSI A208.1, [grade to suit performance requirements] [Grade M-2] <Insert grade>.
    - a. Fire-retardant panels made from softwood particles and fire-retardant chemicals mixed together at time of panel manufacture to achieve flame-spread index of 25 or less and smoke-developed index of 25 or less per ASTM E 84 or UL 723.
  7. Tackable, Impact-Resistant, High-Density Board for Face Layer: 1/8-inch- (3.2-mm-) thick layer of compressed molded glass-fiber board with a nominal density of 16 to 18 lb/cu. ft. (256 to 288 kg/cu. m) laminated to face of core.
  8. Impact-Resistant, Acoustically Transparent, Copolymer Sheet for Face Layer: 1/16- to 1/8-inch- (1.6- to 3.2-mm-) thick layer of perforated, noncombustible, copolymer sheet laminated to face of core.
  9. Wood and Plywood: Manufacturer's standard plywood or clear, vertical grain, straight, kiln-dried hardwood.
    - a. Fire-retardant treated by pressure process with a flame-spread index of 25 or less when tested according to ASTM E 84 or UL 723, and with no evidence of significant progressive combustion when the test is extended an additional 20 minutes, and with the flame front not extending more than 10.5 feet (3.2 m) beyond the centerline of the burners at any time during the test.
      - 1) Treated material shall have a moisture content of 28 percent or less when tested according to ASTM D 3201/D 3201M at 92 percent relative humidity.
      - 2) Kiln-dry material after treatment to 19 percent or less for lumber and 15 percent or less for plywood.
- F. Facing Material <Insert drawing designation>: Fabric from same dye lot; color and pattern [as indicated by manufacturer's designations] [matching Architect's samples] [as selected by Architect from manufacturer's full range] [as indicated on Drawings] <Insert requirement>.
1. Manufacturer: <Insert manufacturer's name>.
  2. Product Line/Pattern: <Insert product name or designation>.
  3. Pattern Repeat: <Insert requirement>.
  4. Style Number: <Insert number>.
  5. Color: <Insert name or number, or both>.
  6. Fiber Content: [100] <Insert number> percent [woven polyester] [nonwoven polyester] [polyolefin] [acoustically transparent vinyl] <Insert fiber requirement>.
  7. Width: [54 inches (1371 mm)] [66 inches (1676 mm)] <Insert dimension>.
  8. Source: <Insert fabric-vendor's name>.
  9. Applied Treatments: [Stain resistance] [and] [flame retardant] <Insert treatment>.
- G. Mounting Devices: Concealed on back of unit, recommended by manufacturer to support weight of unit, and as follows:
1. Splines: Manufacturer's standard concealed metal or plastic splines that engage the kerfed edges of the unit, with other moldings and trim for interior corners, exterior corners, and exposed edges, with factory-applied finish on exposed items.
  2. <Double click to insert sustainable design text for VOC content of adhesive.>
  3. <Double click to insert sustainable design text for adhesives.>

4. Adhesive Tape Strips: [Manufacturer's standard 1/16-inch- (1.6-mm-) thick, double-sided foam tape] <Insert requirement>.
5. Hook-and-Loop Strips: [Manufacturer's standard] <Insert requirement>.
6. Impaling Clips: [Manufacturer's standard] <Insert requirement>.
7. Magnetic Strip or Devices: [Manufacturer's standard] <Insert requirement>.
8. Metal Clips or Bar Hangers: Manufacturer's standard two-part metal "Z" clips, with one part of each clip mechanically attached to back of unit and the other part to substrate, designed to permit unit removal.

## 2.6 FABRICATION

- A. Standard Construction: Use manufacturer's standard construction unless otherwise indicated; with facing material applied to face, edges, and back border of dimensionally stable core; and with rigid edges to reinforce panel perimeter against warpage and damage.
- B. Edge Hardening: For [glass-fiber board] [and] [mineral-fiber board] cores, chemically harden core edges and areas of core where mounting devices are attached.
- C. Core-Face Layer: Evenly stretched over core face and edges and securely attached to core; free from puckers, ripples, wrinkles, or sags.
- D. Facing Material: Apply fabric facing fully covering visible surfaces of unit; with material stretched straight, on the grain, tight, square, and free from puckers, ripples, wrinkles, sags, blisters, seams, adhesive, or other visible distortions or foreign matter.
  1. Square Corners: Tailor corners.[ Heat-seal vinyl fabric seams at corners.]
  2. Radius and Other Nonsquare Corners: Attach facing material so there are no seams or gathering of material.
  3. Fabrics with Directional or Repeating Patterns or Directional Weave: Mark fabric top and attach fabric in same direction so pattern or weave matches in adjacent units.
- E. Dimensional Tolerances of Finished Units: Plus or minus 1/16 inch (1.6 mm) for the following:
  1. Thickness.
  2. Edge straightness.
  3. Overall length and width.
  4. Squareness from corner to corner.
  5. Chords, radii, and diameters.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine fabric, fabricated units, substrates, areas, and conditions for compliance with requirements, installation tolerances, and other conditions affecting unit performance.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.



3.2 INSTALLATION

- A. Install units in locations indicated. Unless otherwise indicated, install units with vertical surfaces and edges plumb, top edges level and in alignment with other units, faces flush, and scribed to fit adjoining work accurately at borders and at penetrations.
- B. Comply with manufacturer's written instructions for installation of units using type of mounting devices indicated. Mount units securely to supporting substrate.
- C. Align fabric pattern and grain [with adjacent units] [as indicated on Drawings].

3.3 INSTALLATION TOLERANCES

- A. Variation from Plumb and Level: Plus or minus [1/16 inch (1.6 mm)] <Insert dimension> in 48 inches (1200 mm), noncumulative.
- B. Variation of Joint Width: Not more than [1/16-inch (1.6-mm)] [1/32-inch (0.79-mm)] <Insert dimension> variation from [hairline] [reveal line] in 48 inches (1200 mm), noncumulative.

3.4 CLEANING

- A. Clip loose threads; remove pills and extraneous materials.
- B. Clean panels on completion of installation to remove dust and other foreign materials according to manufacturer's written instructions.

END OF SECTION 098433

**DIVISION 10 – SPECIALTIES**

## SECTION 10 1100 - VISUAL DISPLAY SURFACES

### PART 1 - GENERAL

#### 1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

#### 1.2 SUMMARY

- A. This Section includes markerboards.

#### 1.3 SUBMITTALS

- A. Shop Drawings: Provide for each type of markerboard required. Include sections of typical trim members and dimensioned elevations. Show anchors, grounds, reinforcement, accessories, layout, and installation details.
- B. Product Data: Submit for all products in this Section.

#### 1.4 QUALITY ASSURANCE

- A. Design Criteria: The drawings indicate size, profiles, and dimensional requirements of visual display boards and are based on the specific type and model indicated. Other visual display boards having equal performance characteristics by other manufacturers may be considered provided that deviations in dimensions and profiles are minor and do not change the design concept or intended performance as judged by the Architect. The burden of proof of equality is on the proposer.

#### 1.5 WARRANTY

- A. Porcelain Enamel Markerboard Warranty: Furnish the manufacturer's written warranty, agreeing to replace porcelain enamel markerboards that do not retain their original writing and erasing qualities, become slick and shiny, or exhibit crazing, cracking, or flaking, provided the manufacturer's instructions with regard to handling, installation, protection, and maintenance have been followed.
  - 1. Warranty Period: Life of the building.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

- A. Manufacturer: Subject to compliance with requirements, provide products of one of the following:
  - 1. Porcelain Enamel Marker Boards and Tackboards:
    - a. Claridge Products and Equipment, Inc.
    - b. Allied Visual Display Boards.

- c. Lemco.
- d. NACO/GSI (Polyvision).
- e. Venus Manufacturing Co.

## 2.2 MATERIALS

- A. Porcelain Enamel Markerboard: Provide balanced, high-pressure-laminated porcelain enamel markerboards of 3-ply construction consisting of face sheet, core material, and backing.
  - 1. Face Sheet: 0.024-inch enameling grade steel especially processed for temperatures used in coating porcelain on steel. Coat exposed face and edges with a 3-coat process consisting of primer, ground coat, and color cover coat. Coat concealed face with a 2-coat process consisting of primer and ground coat. Fuse cover and ground coats to steel at manufacturer's standard firing temperatures, but not less than 1200 deg F.
    - a. Cover Coat (Markerboards): Provide the manufacturer's standard light-colored special writing surface with gloss finish intended for use with liquid felt-tipped markers.
    - b. Color: Similar to Claridge No. 32 LCS White.
  - 2. Core: 3/8-inch-thick particleboard core material complying with the requirements of ANSI A208.1, Grade 1-M-1.
  - 3. Backing Sheet: Provide the manufacturer's standard .002 aluminum foil sheet backing.
  - 4. Laminating Adhesive: Manufacturer's standard moisture-resistant thermoplastic-type adhesive.
  - 5. Markings: Provide permanently affixed music staff markings at boards in Music Rooms.

## 2.3 ACCESSORIES

- A. Metal Trim and Accessories: Claridge trim and accessory numbers are specified to establish the standard required by other listed manufacturers. Fabricate frames and trim of not less than 0.062-inch-thick aluminum alloy, size and shape as indicated, to suit type of installation. Provide straight, single-length units wherever possible; keep joints to a minimum. Miter corners to a neat, hairline closure. Aluminum finish: Satin anodized.
  - 1. Chalktray: Claridge No. 263 for each board (full length of board).
  - 2. Map Rail: Claridge No. 275; furnish map rail at the top of each unit, complete with the following accessories:
    - a. Display Rail: Provide continuous cork display rail approximately 1 or 2 inches wide, as indicated, integral with the map rail.
    - b. End Stops: Provide one end stop at each end of the map rail.
    - c. Map Hooks: Provide 4 map hooks with flexible metal clips for each 4 feet by 8 feet board.
    - d. Flagholder: Provide one flagholder for each room.
  - 3. Trim: Claridge No. 272 and No. 273.
  - 4. Mullion: Claridge No. 186A.

## 2.4 FABRICATION

- A. Porcelain Enamel Markerboards: Laminate facing sheet and backing sheet to core material under pressure with manufacturer's recommended flexible, waterproof adhesive.

- B. Assembly: Provide factory-assembled markerboard and tackboard units, except where field-assembled units are required.
  - 1. Make joints only where total length exceeds maximum manufactured length. Fabricate with the minimum number of joints, balanced around the center of the board, as acceptable to the Architect.
  - 2. Provide the manufacturer's standard vertical joint system between abutting sections of markerboard.
  - 3. Provide manufacturer's standard mullion trim at joints between markerboard and tackboard.

## 2.5 FINISHES

- A. General: Comply with NAAMM "Metal Finishes Manual" for recommendations relative to application and designations of finishes.
- B. Finish designations prefixed by "AA" conform to the system established by the Aluminum Association for designating aluminum finishes.
- C. Class II Clear Anodized Finish: AA-M12C22A31 (Mechanical Finish: as fabricated, nonspecular; Chemical Finish: etched, medium matte, Anodic Coating: Class II Architectural, clear film thicker than 0.4 mil).

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- A. Deliver factory-built visual display board units completely assembled in one piece without joints, wherever possible. Where dimensions exceed panel size, provide 2 or more pieces of equal length as acceptable to the Architect. When overall dimensions require delivery in separate units, prefit components at the factory, disassemble for delivery, and make final joints at the site. Use splines at joints to maintain surface alignment.
- B. Install units and accessories in locations and at mounting heights indicated and in accordance with the manufacturer's instructions. Keep perimeter lines straight, plumb, and level. Provide grounds, clips, backing materials, adhesives, brackets, anchors, trim, and accessories necessary for a complete installation.

### 3.2 ADJUST AND CLEAN

- A. Verify that accessories required for each unit have been properly installed and that operating units function properly.
- B. Clean units in accordance with the manufacturer's instructions.

END OF SECTION 10 1100

SECTION 10 1400 - SIGNAGE

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following types of signs:
  - 1. Interior panel signs (ADA compliant).
  - 2. Signage for Fire compliance.
  - 3. Toilet room signage (ADA compliant).
  - 4. Entry decals.
  - 5. Exit door signage.

1.3 SUBMITTALS

- A. Product Data: For each type of sign specified, including details of construction relative to materials, dimensions of individual components, profiles, and finishes.
- B. Shop Drawings: Show fabrication and erection of signs. Include plans, elevations, and large-scale sections of typical members and other components. Show anchors, grounds, layout, reinforcement, accessories, and installation details.
  - 1. Provide message list for each sign required, including large-scale details of wording and lettering layout.
  - 2. For signs supported by or anchored to permanent construction, provide setting drawings, templates, and directions for installation of anchor bolts and other anchors to be installed as a unit of Work in other Sections.
  - 3. Templates: Furnish full-size spacing templates for individually mounted dimensional letters and numbers.
  - 4. Furnish full-size rubbings for metal plaques.
- C. Samples: Provide the following samples of each sign component for initial selection of color, pattern and surface texture as required and for verification of compliance with requirements indicated.
  - 1. Samples for verification of color, pattern, and texture:
    - a. Etched Zinc: Manufacturer's color samples consisting of actual sections of material including the specified background colors selected for panel signs.
    - b. Bronze Casting: Manufacturer's samples consisting of actual sections of material, minimum 6" x 6". Submit samples showing specified borders, background and letter style.

#### 1.4 QUALITY ASSURANCE

- A. Sign Fabricator Qualifications: Firm experienced in producing signs similar to those indicated for this Project, with a record of successful in-service performance, and sufficient production capacity to produce sign units required without causing delay in the Work.
  - 1. Signage shall be ADA compliant. California Grade 2 Braille is to be used at all signs requiring the use of Braille.
  - 2. Signage shall be compliant with 2010 CBC.
- B. Single-Source Responsibility: For each separate sign type required, obtain signs from one source of a single manufacturer.
- C. Design Concept: The Drawings indicate sizes, profiles, and dimensional requirements of signs and are based on the specific types and models indicated. Sign units by other manufacturers may be considered provided deviations in dimensions and profiles do not change the design concept as judged by the Architect. The burden of proof of equality is on the proposer.

#### 1.5 PROJECT CONDITIONS

- A. Field Measurements: Take field measurements prior to preparation of shop drawings and fabrication to ensure proper fitting. Show recorded measurements on final shop drawings. Coordinate fabrication schedule with construction progress to avoid delay.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

- A. Manufacturers of Panel Signs: Products specified herein in Paragraph 2.4.A. are manufactured by VisionMark, Inc. and establish the appearance and quality desired by the Owner for this project. Subject to compliance with requirements, products of the following manufacturers are also acceptable:
  - 1. ASI Modulex, Inc.
  - 2. Best Sign Systems, Inc.
  - 3. Mohawk Sign Systems.
  - 4. Sign Source (cast aluminum signage with smooth background and custom border/logo).
  - 5. Vomar.

#### 2.2 MATERIALS

- A. Zinc: Provide sign material of 99 percent zinc alloy, 0.125 inch thick. Material shall be as recommended by the sign manufacturer for the chemical etching process used and for the use and finish indicated.
- B. Plastic Laminate: Provide high-pressure plastic laminate engraving stock with face and core plies in contrasting colors, in finishes and color combinations indicated or, if not indicated, as selected from the manufacturer's standards.
- C. Aluminum Castings: Provide aluminum castings of alloy and temper recommended by the sign manufacturer for the casting process used and for the use and finish indicated.



- D. Fasteners: Use concealed fasteners fabricated from metals that are not corrosive to the sign material and mounting surface.
- E. Anchors and Inserts: Use nonferrous metal or hot-dipped galvanized anchors and inserts for exterior installations and elsewhere as required for corrosion resistance. Use toothed steel or lead expansion bolt devices for drilled-in-place anchors. Furnish inserts, as required, to be set into concrete or masonry work.

### 2.3 PANEL SIGNS

- A. Typical interior signs shall be 0.125 square corner, solid photo-etched zinc. Signage shall have background color, with natural stain zinc highlights. Cast sign shall meet all the requirements of ADA 101-336, Public Law of 1990, sections 4.30 through 4.30-5. Etched zinc signs shall incorporate raised graphics, symbols, and Braille. Sign panel background color shall be custom color to meet the 70 percent contrast with a non-glare finish requirement of ADA 101-336, Section 4.30-5. All restrooms identified as accessible shall be provided with correct gender sign, one each per type of restroom. Manufacturer shall submit detail drawings for approval showing layout of signs, mounting method, graphic applications and letter style.
  - 1. Nominal etching depth: 0.032 inch.
  - 2. Fasteners shall be copper studs flash-welded to back of plate for blind stud mounting.
  - 3. Panel sign characters and Braille shall comply with ADAAG and CBC Chapter 11.
    - a. Characters on signs shall be raised 1/32-inch minimum and shall be sans serif uppercase characters accompanied by California Grade 2 Braille.
    - b. Raised characters shall be a minimum of 5/8-inch and a max. of 2-inches high.
    - c. Characters on signs shall have a width-to-height ratio of between 1:5 and 1:10 per CBC Sect. 1117B.5.3.
    - d. California Grade 2 Braille shall be used wherever Braille is required in other portions of these standards. Dots shall be 1/10-inch on center in each cell with 2/10-inch space between cells, measured from the last column of dots in the first cell to the first column of dots in the second cell. Dots shall be raised a minimum of 1/40-inch above the background, and domed or rounded. Reference CBC Sect. 1117B.5.6.
- B. Signage for Fire compliance: Signs shall be plastic laminate with engraved copy. Refer to Detail. Machine-engrave letters, numbers, symbols, and other graphic devices into sign panel on the face indicated to produce precisely formed copy, incised to uniform depth. Use high-speed cutters mechanically linked to master templates in a pantographic system or equivalent process capable of producing characters of the style indicated with sharply formed edges. Size: 6" x 12".
  - 1. Engraved Plastic Laminate: Engrave through the exposed face ply of the plastic laminate sheet to expose the contrasting core ply.
- C. Toilet Room Signage: Signs shall be plastic laminate conforming to California Title 24 regulations for signs for toilet rooms. Provide with inset symbols and raised Braille characters. Minimum total thickness of .25-inch, adhesive type as recommended by sign manufacturer for type of substrate to which sign will be applied.
  - 1. Men's Room: 12-inch equilateral triangle, vertex pointing up.
  - 2. Ladies' Room: 12-inch diameter circle.
  - 3. Unisex Toilet: 12-inch diameter circle with equilateral triangle, vertex pointing up inscribed in circle. Circle and triangle each .25-inch thick.
  - 4. Colors: As selected by Architect. Colors shall contrast with background color.

- D. ADAAG Toilet Room Signs: Signs shall be plastic laminate conforming to ADAAG requirements for signs for permanent rooms. Comply with ADAAG requirements for raised and Braille characters, pictorial symbols, finish and contrast requirements. Colors as selected by Architect from manufacturer's standards.
- E. Entry Decals: Provide min. 6-inch square decals with international symbol of accessibility, white on blue background with white border, applied to glass at accessible entry doors.
- F. Braille Exit Door Signs: Signs shall be plastic laminate conforming to ADAAG requirements for signs for permanent rooms. Comply with ADAAG requirements for raised and Braille characters, finish and contrast requirements. Colors as selected by Architect from manufacturer's standards.

## 2.4 FINISHES

- A. Colors and Surface Textures: For exposed sign material that requires selection of materials with integral or applied colors, surface textures or other characteristics related to appearance, provide color matches indicated, or if not indicated, as selected by the Architect from the manufacturer's standards.
- B. Metal Finishes: Comply with NAAMM "Metal Finishes Manual" for finish designations and applications recommendations.
- C. Aluminum Finishes: Finish designations prefixed by "AA" conform to the system established by the Aluminum Association for designating aluminum finishes.
  - 1. Class II Clear Anodized Medium Satin Finish: AA-M31C22A31 (Mechanical Finish: Fine satin directional textured; Chemical Finish: Medium matte etched finish; Anodic Coating: Class II Architectural, clear film thicker than 0.4 mil).

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- A. General: Locate sign units and accessories where indicated, using mounting methods of the type described and in compliance with the manufacturer's recommendations and instructions.
  - 1. Install signs level, plumb, and at the height indicated, with sign surfaces free from distortion or other defects in appearance.
  - 2. Provide continuous clear silicone bead at perimeter of sign in all exterior signage locations.
- B. Wall-Mounted Panel Signs: Attach panel signs to wall surfaces using the methods indicated below:
  - 1. Mount signs 60" above floor to center and 8" from strike side of door frame. Attach signs as shown with mechanical fasteners.
- C. Toilet Room Signage: Install signs on doors after doors are painted and finished.
  - 1. Mount signs 60" above finished floor to center. Install centered on door width and in-line with adjacent door-mounted signs.
  - 2. Install in accordance with manufacturer's recommendations for substrate involved.

- D. ADAAG Toilet Room Signs: Install signs on walls after surfaces to which they are to be mounted are painted and finished.
  - 1. Mount signs 60" above finished floor to center on strike side of door.
  - 2. Install level and in-line with adjacent toilet room signage.
  - 3. Install in accordance with ADAAG requirements to allow a person to approach within 3-inches of signs without being within a door swing.
- E. Entry Decals: Install in locations as approved by the Architect.
- F. Braille Exit Door Signs: Install at doors with lighted "Exit" signs. Apply only after walls to which signs are to be mounted are painted and finished.
  - 1. Mount signs 60" above finished floor to center on strike side of door.
  - 2. Install level and in-line with adjacent signage.
  - 3. Install in accordance with ADAAG requirements to allow a person to approach within 3-inches of signs without being within a door swing.

### 3.2 CLEANING AND PROTECTION

- A. After installation, clean soiled sign surfaces according to the manufacturer's instructions. Protect units from damage until acceptance by the Owner.

### 3.3 SIGNAGE SCHEDULE

- A. Interior Panel Signs: Follow Room Finish Schedule; verify locations with Owner.
  - 1. 6" x 9" accessible restroom signs.
  - 2. 6" x 6" door labels with room name.
  - 3. 2" x 6" door number signs.
  - 4. 6" x 12" Maximum Occupancy signs.

END OF SECTION 10 1400

SECTION 101419 - DIMENSIONAL LETTER SIGNAGE

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Cast dimensional characters.

1.3 DEFINITIONS

- A. Illuminated: Illuminated by lighting source integrally constructed as part of the sign unit.

1.4 COORDINATION

- A. Furnish templates for placement of electrical service embedded in permanent construction by other installers.

1.5 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: For dimensional letter signs.
  - 1. Include fabrication and installation details and attachments to other work.
  - 2. Show sign mounting heights, locations of supplementary supports to be provided by others, and accessories.
  - 3. Show message list, typestyles, graphic elements, and layout for each sign at least half size.
- C. Samples for Verification: For each type of sign assembly showing all components and with the required finish(es), in manufacturer's standard size unless otherwise indicated and as follows:
  - 1. Dimensional Characters: Full-size Sample of each type of dimensional character.
- D. Sign Schedule: Use same designations specified or indicated on Drawings.

1.6 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For Installer and manufacturer.
- B. Sample Warranty: For special warranty.

1.7 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For signs to include in maintenance manuals.

1.8 QUALITY ASSURANCE

- A. Installer Qualifications: An entity that employs installers and supervisors who are trained and approved by manufacturer.

1.9 FIELD CONDITIONS

- A. Field Measurements: Verify locations of electrical service embedded in permanent construction by other installers by field measurements before fabrication, and indicate measurements on Shop Drawings.

1.10 WARRANTY

- A. Special Warranty: Manufacturer agrees to repair or replace components of signs that fail in materials or workmanship within specified warranty period.
  - 1. Failures include, but are not limited to, the following:
    - a. Deterioration of finishes beyond normal weathering.
    - b. Separation or delamination of sheet materials and components.
  - 2. Warranty Period: Five years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 DIMENSIONAL LETTER SIGNS, GENERAL

2.2 DIMENSIONAL CHARACTERS

- A. Cast Characters: Characters with uniform faces, sharp corners, and precisely formed lines and profiles, and as follows:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:

- a. A.R.K. Ramos.
- b. ASI Sign Systems, Inc.
- c. Cosco.
- d. Gemini Incorporated.
- e. Matthews International Corporation; Bronze Division.
- f. Metal Arts.
- g. Metallic Arts.
2. Character Material: Cast aluminum.
3. Character Height: As indicated.
4. Thickness: Manufacturer's standard for size of character
5. Finishes:
  - a. Integral Aluminum Finish: Clear anodized.
6. Mounting: Concealed studs.
7. Typeface: Arial.
8. On County Seal applied to site signage (monument sign), fabricate seal as follows:
  - a. Cast seal face with minimum 1/2 inch thickness at thinnest point in size as indicated on Drawings and with font and graphics as provided by Architect.
  - b. Factory weld 1/2-inch-thick x 2 inches deep aluminum shroud to seal face around entire perimeter. Set aluminum shroud proud of recessed portions of seal face so that front of shroud is in same plain as characters standing proud on seal. All welds shall be either performed on concealed side of element or ground smooth to match adjacent finish.
  - c. Provide anchor point on aluminum shroud for threaded concealed studs as required for mounting element to masonry wall.
  - d. Prior to application of anodic finish, mechanically finish county seal as follows:
    - 1) Front of Shroud and Characters: No. 8 (polished) finish.
    - 2) Recessed Elements: Mill finish.
    - 3) Sides of Shroud: Mill finish.
  - e. Final Finish: Clear anodized.

### 2.3 DIMENSIONAL CHARACTER MATERIALS

- A. Aluminum Castings: ASTM B 26/B 26M, alloy and temper recommended by sign manufacturer for casting process used and for type of use and finish indicated.
- B. Aluminum Sheet and Plate: ASTM B 209 (ASTM B 209M), alloy and temper recommended by aluminum producer and finisher for type of use and finish indicated.
- C. Aluminum Extrusions: ASTM B 221 (ASTM B 221M), alloy and temper recommended by aluminum producer and finisher for type of use and finish indicated.

### 2.4 ACCESSORIES

- A. Fasteners and Anchors: Manufacturer's standard as required for secure anchorage of signage, noncorrosive and compatible with each material joined, and complying with the following:
  1. Use concealed fasteners and anchors unless indicated to be exposed.
  2. For exterior exposure, furnish stainless-steel devices unless otherwise indicated.

3. Sign Mounting Fasteners:

- a. Concealed Studs: Concealed (blind), threaded studs welded or brazed to back of sign material, screwed into back of sign assembly, or screwed into tapped lugs cast integrally into back of cast sign material, unless otherwise indicated.

2.5 FABRICATION

A. General: Provide manufacturer's standard sign assemblies according to requirements indicated.

1. Preassemble signs and assemblies in the shop to greatest extent possible. Disassemble signs and assemblies only as necessary for shipping and handling limitations. Clearly mark units for reassembly and installation; apply markings in locations concealed from view after final assembly.
2. Mill joints to a tight, hairline fit. Form assemblies and joints exposed to weather to resist water penetration and retention.
3. Comply with AWS for recommended practices in welding and brazing. Provide welds and brazes behind finished surfaces without distorting or discoloring exposed side. Clean exposed welded and brazed connections of flux, and dress exposed and contact surfaces.
4. Conceal connections if possible; otherwise, locate connections where they are inconspicuous.
5. Internally brace signs for stability and for securing fasteners.
6. Provide rebates, lugs, and brackets necessary to assemble components and to attach to existing work. Drill and tap for required fasteners. Use concealed fasteners where possible; use exposed fasteners that match sign finish.
7. Castings: Fabricate castings free of warp, cracks, blowholes, pits, scale, sand holes, and other defects that impair appearance or strength. Grind, wire brush, sandblast, and buff castings to remove seams, gate marks, casting flash, and other casting marks before finishing.

2.6 GENERAL FINISH REQUIREMENTS

- A. Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.
- B. Appearance of Finished Work: Noticeable variations in same piece are not acceptable. Variations in appearance of adjoining components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.
- C. Directional Finishes: Run grain with long dimension of each piece and perpendicular to long dimension of finished trim or border surface unless otherwise indicated.
- D. Organic, Anodic, and Chemically Produced Finishes: Apply to formed metal after fabrication but before applying contrasting polished finishes on raised features unless otherwise indicated.

2.7 ALUMINUM FINISHES

- A. Clear Anodic Finish: AAMA 611, Class II, 0.010 mm or thicker.



### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of signage work.
- B. Verify that sign-support surfaces are within tolerances to accommodate signs without gaps or irregularities between backs of signs and support surfaces unless otherwise indicated.
- C. Verify that electrical service is correctly sized and located to accommodate signs.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 INSTALLATION

- A. General: Install signs using mounting methods indicated and according to manufacturer's written instructions.
  - 1. Install signs level, plumb, true to line, and at locations and heights indicated, with sign surfaces free of distortion and other defects in appearance.
  - 2. Before installation, verify that sign surfaces are clean and free of materials or debris that would impair installation.
  - 3. Corrosion Protection: Coat concealed surfaces of exterior aluminum in contact with grout, concrete, masonry, wood, or dissimilar metals, with a heavy coat of bituminous paint.
- B. Mounting Methods:
  - 1. Concealed Studs: Using a template, drill holes in substrate aligning with studs on back of sign. Remove loose debris from hole and substrate surface.
    - a. Masonry Substrates: Fill holes with adhesive. Leave recess space in hole for displaced adhesive. Place sign in position and push until flush to surface, embedding studs in holes. Temporarily support sign in position until adhesive fully sets.
    - b. Thin or Hollow Surfaces: Place sign in position and flush to surface, install washers and nuts on studs projecting through opposite side of surface, and tighten.

#### 3.3 ADJUSTING AND CLEANING

- A. Remove and replace damaged or deformed characters and signs that do not comply with specified requirements. Replace characters with damaged or deteriorated finishes or components that cannot be successfully repaired by finish touchup or similar minor repair procedures.
- B. Remove temporary protective coverings and strippable films as signs are installed.

- C. On completion of installation, clean exposed surfaces of signs according to manufacturer's written instructions, and touch up minor nicks and abrasions in finish. Maintain signs in a clean condition during construction and protect from damage until acceptance by Owner.

END OF SECTION 101419



## SECTION 10 2113 - TOILET COMPARTMENTS

### PART 1 - GENERAL

#### 1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

#### 1.2 SUMMARY

- A. This Section includes solid-polymer units as follows:
  - 1. Stainless steel toilet compartment partitions, floor and ceiling anchored for following applications:
    - a. Toilet enclosures.
    - b. Privacy screens.
    - c. Urinal screens.
- B. Related Sections include the following:
  - 1. Division 055000 Section "Metal Fabrications" for supports that attach floor- anchored units.
  - 2. Division 061000 Section "Rough Carpentry" for blocking of floor-and-anchored units.
  - 3. Division 102800 "Toilet, Bath, and Laundry Accessories".

#### 1.3 SUBMITTALS

- A. Product Data: For each type of product indicated. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes.
- B. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
- C. Samples for Initial Selection: For each type of unit indicated.

#### 1.4 QUALITY ASSURANCE

- A. Comply with requirements in CID-A-A-60003, "Partitions, Toilets, Complete."

#### 1.5 REFERENCES

- A. ASTM International (ASTM):
  - 1. ASTM A 240 - Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications.
  - 2. ASTM A 666 - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar.

3. ASTM A 743/A 743M - Standard Specification for Castings, Iron-Chromium, Iron-Chromium-Nickel, Corrosion Resistant, for General Application.
4. ASTM B 86 - Standard Specification for Zinc and Zinc-Aluminum (ZA) Alloy Foundry and Die Castings.
5. ASTM E 84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
6. ASTM B 221/B 221M - Standard Specification for Zinc and Zinc-Aluminum (ZA) Alloy Foundry and Die Castings.

#### 1.6 PROJECT CONDITIONS

- A. Field Measurements: Verify actual locations of walls, columns, ceilings, and other construction contiguous with toilet compartments by field measurements before fabrication and indicate measurements on Shop Drawings.
  1. Established Dimensions: Where field measurements cannot be made without delaying the Work, establish dimensions and proceed with fabricating toilet compartments without field measurements. Coordinate wall, floor, ceilings, and other contiguous construction to ensure that actual dimensions correspond to established dimensions.

#### 1.7 WARRANTY

- A. Special Manufacturer's Warranty: Provide manufacturer's standard form in which manufacturer agrees to repair or replace products that fail in materials or workmanship during the following period after substantial completion:
  1. Stainless Toilet Partitions: Against rust-out: 15 years. Chrome Hardware: 5 years.
  2. Stainless Steel Hardware: Lifetime.

### PART 2 - PRODUCTS

#### 2.1 PERFORMANCE REQUIREMENTS

- A. Surface-Burning Characteristics: Comply with ASTM E 84; testing by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
  1. Flame-Spread Index: 25 or less.
  2. Smoke-Developed Index: 450 or less.
- B. Recycled Content of Solid-Plastic Components: Postconsumer recycled content plus one-half of preconsumer recycled content not less than 25 percent.
- C. Regulatory Requirements: Comply with applicable provisions in the U.S. Architectural & Transportation Barriers Compliance Board's ADA-ABA Accessibility Guidelines for Buildings and Facilities and the California Building Code for toilet compartments designated as accessible.

## 2.2 SOLID-PLASTIC TOILET COMPARTMENTS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
1. Accurate Partitions Corporation.
  2. Ampco, Inc.
  3. Bradley Corporation; Mills Partitions.
  4. Capitol Partitions, Inc.
  5. Comtec Industries.
  6. General Partitions Mfg. Corp.
  7. Global Steel Products Corp.
  8. Hadrian Manufacturing Inc.
  9. Knickerbocker Partition Corporation.
  10. Marlite.
  11. Metpar Corp.
  12. Partition Systems Incorporated of South Carolina; Columbia Partitions.
- B. Toilet and shower-Enclosure Style: Floor and ceiling anchored.
- C. Urinal-Screen Style: Wall hung
- D. Door, Panel, and Pilaster Construction: Solid, high-density polyethylene (HDPE) panel material, not less than 1 inch (25 mm) thick, seamless, with eased edges, and with homogenous color and pattern throughout thickness of material.
1. Integral Hinges: Configure doors and pilasters to receive integral hinges.
  2. Heat-Sink Strip: Manufacturer's standard continuous, extruded-aluminum strip fastened to exposed bottom edges of solid-plastic components to hinder malicious combustion.
  3. Color and Pattern: One color and pattern in each room as selected by Architect from manufacturer's full range.
- E. Pilaster Shoes and Sleeves (Caps): Manufacturer's standard design; stainless steel.
- F. Brackets (Fittings):
1. Full-Height (Continuous) Type: Manufacturer's standard design; polymer.
    - a. Polymer Color and Pattern: Matching panel.
- G. Overhead Cross Bracing for Ceiling-Hung Units: As recommended by manufacturer and fabricated from solid polymer.

## 2.3 HARDWARE AND ACCESSORIES

- A. Hardware and Accessories: Manufacturer's heavy-duty operating hardware and accessories.
1. Hinges: Manufacturer's minimum 0.062-inch-thick stainless-steel continuous, cam type that swings to a closed or partially open position allowing emergency access by lifting door. Mount with through-bolts.

2. Latch and Keeper: Manufacturer's heavy-duty surface-mounted cast-stainless-steel latch unit designed to resist damage due to slamming, with combination rubber-faced door strike and keeper, and with provision for emergency access. Provide units that comply with regulatory requirements for accessibility at compartments designated as accessible. Mount with through-bolts.
3. Coat Hook: Manufacturer's heavy-duty combination cast-stainless-steel hook and rubber-tipped bumper, sized to prevent in-swinging door from hitting compartment-mounted accessories. Mount with through-bolts on each door.
4. Door Bumper: Manufacturer's heavy-duty rubber-tipped cast-stainless-steel bumper at out-swinging doors. Mount with through-bolts.
5. Door Pull: Manufacturer's heavy-duty cast-stainless-steel pull at out-swinging doors that complies with regulatory requirements for accessibility. Provide units on both sides of doors at compartments designated as accessible. Mount with through-bolts.

- B. Anchorages and Fasteners: Manufacturer's standard exposed fasteners of stainless steel, finished to match the items they are securing, with theft-resistant-type heads. Provide sex-type bolts for through-bolt applications. For concealed anchors, use stainless-steel, hot-dip galvanized-steel, or other rust-resistant, protective-coated steel compatible with related materials.

#### 2.4 MATERIALS

- A. Aluminum Castings: ASTM B 26.
- B. Aluminum Extrusions: ASTM B 221.
- C. Brass Castings: ASTM B 584.
- D. Brass Extrusions: ASTM B 455.
- E. Stainless-Steel Sheet: ASTM A 666, Type 304, stretcher-leveled standard of flatness.
- F. Stainless-Steel Castings: ASTM A 743.
- G. Zamac: ASTM B 86, commercial zinc-alloy die castings.

#### 2.5 FABRICATION

- A. Fabrication, General: Fabricate toilet compartment components to sizes indicated. Coordinate requirements and provide cutouts for through-partition toilet accessories where required for attachment of toilet accessories.
- B. Floor-and-Ceiling-Anchored Units: Provide manufacturer's standard corrosion-resistant anchoring assemblies with leveling adjustment nuts at tops and bottoms of pilasters. Provide shoes and sleeves (caps) at pilasters to conceal anchorage.
- C. Door Size and Swings: Unless otherwise indicated, provide 24-inch- (610-mm-) wide, in-swinging doors for standard toilet compartments and 36-inch- (914-mm-) wide, out-swinging doors with a minimum 32-inch- (813-mm-) wide, clear opening for compartments designated as accessible.



PART 3 - EXECUTION

3.1 INSTALLATION

- A. General: Comply with manufacturer's written installation instructions. Install units rigid, straight, level, and plumb. Secure units in position with manufacturer's recommended anchoring devices.
  - 1. Maximum Clearances:
    - a. Pilasters and Panels: 1/2 inch (13 mm).
    - b. Panels and Walls: 1 inch (25 mm).
  - 2. Full-Height (Continuous) Brackets: Secure panels to walls and to pilasters with full-height brackets.
    - a. Locate bracket fasteners so holes for wall anchors occur in masonry or tile joints.
    - b. Align brackets at pilasters with brackets at walls.
- B. Floor-and-Ceiling-Anchored Units: Secure pilasters to supporting construction and level, plumb, and tighten. Hang doors and adjust so doors are level and aligned with panels when doors are in closed position.
- C. Urinal Screens: Attach with anchoring devices to suit supporting structure. Set units level and plumb, rigid, and secured to resist lateral impact.

3.2 ADJUSTING

- A. Hardware Adjustment: Adjust and lubricate hardware according to manufacturer's written instructions for proper operation. Set hinges on in-swinging doors to hold doors open approximately 30 degrees from closed position when unlatched. Set hinges on out-swinging doors to return doors to fully closed position.

END OF SECTION 10 2113



SECTION 10 2123 - CUBICLES

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Curtain tracks and curtain carriers.
  - 2. Cubicle and shower curtains.
- B. Related Sections include the following:
  - 1. Division 061000 Section "Rough Carpentry" for wood blocking for mounting items requiring anchorage.
  - 2. Division 095113 Section "Acoustical Panel Ceilings" for metal framing and furring for mounting items requiring anchorage.

1.3 PERFORMANCE REQUIREMENTS

- A. Curtains: Provide curtain fabrics with the following characteristics:
  - 1. Fabrics are launderable to a temperature of not less than 160 deg F (71 deg C).
  - 2. Fabrics are flame resistant and are identical to those that have passed NFPA 701, 2004 edition when tested by a testing and inspecting agency acceptable to authorities having jurisdiction.
    - a. Identify fabrics with appropriate markings of applicable testing and inspecting agency.

1.4 SUBMITTALS

- A. Product Data: Include durability, laundry temperature limits, fade resistance, and fire-test-response characteristics for each type of curtain fabric indicated.
  - 1. Include data on each type of applied curtain treatment.
- B. Shop Drawings: Show layout and types of cubicles, sizes of curtains, number of carriers, anchorage details, and conditions requiring accessories. Indicate dimensions taken from field measurements.
  - 1. Include details on blocking above ceiling.
- C. Coordination Drawings: Reflected ceiling plans, drawn to scale, on which the following items are shown and coordinated with each other, based on input from installers of the items involved:
  - 1. Suspended ceiling components.
  - 2. Structural members to which suspension systems will be attached.

3. Items penetrating finished ceiling, including the following:
  - a. Lighting fixtures.
  - b. Air outlets and inlets.
  - c. Speakers.
  - d. Sprinklers.
  - e. Access panels.

D. Samples for Initial Selection: For each type of curtain material indicated.

E. Curtain and Track Schedule: Use same designations indicated on Drawings.

F. Manufacturer Certificates: Signed by manufacturers certifying that products comply with requirements.

G. Operation and Maintenance Data: For curtains, track, and hardware to include in operation and maintenance manuals.

#### 1.5 PROJECT CONDITIONS

A. Environmental Limitations: Do not install cubicles until spaces are enclosed and weatherproof, wet work in spaces is complete and dry, work above ceilings is complete, and ambient temperature and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.

#### 1.6 EXTRA MATERIALS

- A. Furnish extra materials described below, before installation begins, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
1. Curtain Carriers and Track End Caps: Full-size units equal to 3 percent of amount installed for each size indicated, but no fewer than 10 units.
  2. Curtains: Full-size units equal to 10 percent of amount installed for each size indicated, but no fewer than 2 units.

### PART 2 - PRODUCTS

#### 2.1 CURTAIN TRACKS

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
1. Coldraco, Inc.
  2. Cubicle Curtain Factory, Inc.
  3. General Cubicle Company, Inc.
  4. Imperial Fastener Company, Inc.
  5. InPro Corporation.

- B. Extruded-Aluminum Track: Not less than 1-1/4 inches wide by 3/4 inch high (32 mm wide by 19 mm high); with minimum wall thickness of 0.050 inch (1.27 mm).
  - 1. Curved Track: Factory-fabricated, 12-inch- (305-mm-) radius bends.
  - 2. Finish: Clear anodized.
- C. Track Accessories: Fabricate splices, end caps, connectors, end stops, coupling and joining sleeves, wall flanges, brackets, ceiling clips, and other accessories from same material and with same finish as track.
  - 1. End Stop: Nonremovable.
- D. Breakaway Curtain Carriers: One-piece nylon or Velcro breakaway curtain carriers designed to allow curtains to detach from tracks with a pulling force of no more the 5 lbf (22.2 N).
- E. Exposed Fasteners: Stainless steel.
- F. Concealed Fasteners: Hot-dip galvanized or Stainless steel.

## 2.2 CURTAINS

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Coldraco, Inc.
  - 2. Cubicle Curtain Factory, Inc.
  - 3. General Cubicle Company, Inc.
  - 4. Imperial Fastener Company, Inc.
  - 5. InPro Corporation.
- B. Cubicle Curtain Fabric: Curtain manufacturer's standard, 100 percent polyester, inherently and permanently flame resistant, stain resistant, and antimicrobial.
  - 1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Color and Pattern: As selected by Architect from manufacturer's full range.
- C. Shower Curtain Fabric: Curtain manufacturer's standard. Polyester-reinforced vinyl fabric; flame resistant, stain resistant, and antimicrobial.
  - 1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Color and Pattern: Translucent vinyl fabric as selected by Architect from manufacturer's full range.
- D. Curtain Grommets: Two-piece, rolled-edge, rustproof, nickel-plated brass; spaced not more than 6 inches o.c.; machined into top hem.
- E. Mesh Top: No. 50 nylon mesh.
  - 1. Color and Pattern: As selected by Architect from manufacturer's full range.

### 2.3 CURTAIN FABRICATION

- A. Fabricate curtains to comply with the following requirements:
  - 1. Width: Equal to track length from which curtain is hung plus 10 percent added fullness, but not less than 12 inches added fullness.
  - 2. Length: Equal to floor-to-ceiling height minus depth of track and carrier at top and distance above finished floor at bottom of 12 inches.
    - a. Mesh Top:
      - 1) Height: Provide height of mesh fabric at top of curtain as required to provide from track and carrier to start of curtain fabric at 5'-0" above floor.
    - b. Curtain Fabric:
      - 1) Height: 48 inches.
      - 2) Distance above finished floor at bottom: 12 inches.
  - 3. Top Hem: Not less than 1 inch and not more than 1-1/2 inches wide, triple thickness, reinforced with integral web, and double lock stitched.
  - 4. Mesh Top: Top hem not less than 1 inch and not more than 1-1/2 inches wide, triple thickness, reinforced with integral web, and double lock stitched. Double lock stitch bottom of mesh directly to 1/2-inch triple thickness, top hem of curtain fabric.
  - 5. Bottom Hem: Not less than 1 inch and not more than 1-1/2 inches wide, triple thickness, reinforced, and double lock stitched.
  - 6. Side Hems: Not less than 1/2 inch and not more than 1-1/4 inches wide, with double turned edges, and single lock stitched.
- B. Vertical Seams: Not less than 1/2 inch wide, double turned and double stitched.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine substrates and conditions, with Installer present, for compliance with requirements for installation tolerances, and other conditions affecting performance of work.
  - 1. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 INSTALLATION

- A. General: Install tracks level and plumb, according to manufacturer's written instructions.
- B. Up to 16 feet in length, provide track fabricated from 1 continuous length.
  - 1. Curtain Track Mounting: Surface.
- C. Surface Track Mounting: Fasten surface-mounted tracks at intervals of not less than 24 inches. Fasten support at each splice and tangent point of each corner. Center fasteners in track to ensure unencumbered carrier operation. Attach track to ceiling as follows:
  - 1. Mechanically fasten directly to bottom of concrete deck with post-installed anchors.
  - 2. Mechanically fasten to suspended ceiling grid with screws.
- D. Track Accessories: Install splices, end caps, connectors, end stops, coupling and joining sleeves, and other accessories as required for a secure and operational installation.

- E. Curtain Carriers: Provide curtain carriers adequate for 6-inch spacing along full length of curtain plus an additional carrier.
- F. Curtains: Hang curtains on each curtain track.
- G. Curtains are not to obstruct automatic fire sprinkler heads.

END OF SECTION 10 2123



## SECTION 10 2213 - WIRE MESH PARTITIONS

### PART 1 - GENERAL

#### 1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Heavy-duty wire mesh partitions (WMP).
- B. Related Sections:
  - 1. Division 033000 Section "Cast-in-Place Concrete" for building anchors into concrete construction for wire mesh partitions.
  - 2. Division 042200 Section "Unit Masonry" for building anchors into masonry construction for wire mesh partitions.
  - 3. Division 087100 Section "Door Hardware" for cylinder for door hardware in wire mesh partitions.
  - 4. Division 323113.53 Section "High-Security Chain Link Fences and Gates" for chain-link fencing.

#### 1.3 DEFINITIONS

- A. As defined in ASTM E 2016:
  - 1. Intermediate Crimp: Wires pass over one and under the next adjacent wire in both directions, with wires crimped before weaving and with extra crimps between the intersections.
  - 2. Lock Crimp: Deep crimps at points of the intersection that lock wires securely in place.

#### 1.4 SUBMITTALS

- A. Product Data: For each type of product indicated. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for wire mesh items.
- B. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
  - 1. Include clearances required for operation of doors.
- C. Setting Drawings: For anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors, that are to be embedded in concrete or masonry.
- D. Samples for Initial Selection: For units with factory-applied color finishes.

- E. Welding certificates.
- F. Maintenance Data: For wire mesh unit hardware to include in maintenance manuals.

### 1.5 QUALITY ASSURANCE

- A. Installer Qualifications: An employer of workers trained and approved by manufacturer.
  - 1. Installer's responsibilities include fabricating and installing wire mesh items and providing professional engineering services needed to assume engineering responsibility.
  - 2. Engineering Responsibility: Preparation of data for wire mesh items, including Shop Drawings, based on testing and engineering analysis of manufacturer's standard units in assemblies similar to those indicated for this Project.
- B. Source Limitations: Obtain wire mesh items from single source from single manufacturer.
- C. Welding Qualifications: Qualify procedures and personnel according to the following:
  - 1. AWS D1.1/D1.1M, "Structural Welding Code - Steel."
- D. Preinstallation Conference: Conduct conference at Project site.

### 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Deliver wire mesh items with cardboard protectors on perimeters of panels and doors and with posts wrapped to provide protection during transit and Project-site storage. Use vented plastic.
- B. Inventory wire mesh partition door hardware on receipt and provide secure lockup for wire mesh partition door hardware delivered to Project site.
  - 1. Tag each item or package separately with identification and include basic installation instructions with each item or package.

### 1.7 PROJECT CONDITIONS

- A. Field Measurements: Verify actual dimensions of construction contiguous with wire mesh units by field measurements before fabrication.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Acorn Wire & Iron Works, Inc.
  - 2. American Woven Wire Corporation.
  - 3. California Wire Products Corporation.
  - 4. Central Wire and Iron.
  - 5. Donaldson, R. J., Inc.

6. Folding Guard Corporation.
7. G-S Company (The).
8. Indiana Wire Products, Inc.
9. Jesco Industries, Inc.
10. Kenco Wire and Iron Products Inc.
11. Kentucky Metal Products Co.
12. King Wire Partitions, Inc.
13. Lakeside Wire and Iron Company.
14. Miller Wire Works, Inc.
15. Newark Wire Works Inc.
16. Standard Wire & Steel Works.
17. Wire Crafters, LLC.

## 2.2 MATERIALS

- A. Steel Wire: ASTM A 510 (ASTM A 510M).
- B. Steel Plates, Channels, Angles, and Bars: ASTM A 36/A 36M.
- C. Cold-Rolled Steel Sheet: ASTM A 1008/A 1008M, Commercial Steel (CS), Type B.
- D. Steel Pipe: ASTM A 53/A 53M, Schedule 40 unless another weight is indicated or required by structural loads.
- E. Square Steel Tubing: ASTM A 500, cold-formed structural-steel tubing.
- F. Metallic-Coated Steel Sheet: ASTM A 653/A 653M, Commercial Steel (CS), Type B; with G60 (Z180) zinc (galvanized) or A60 (ZF180) zinc-iron-alloy (galvannealed) coating designation.
- G. Panel-to-Panel Fasteners: Manufacturer's standard steel bolts, nuts, and washers.
- H. Postinstalled Expansion Anchors: With capability to sustain, without failure, load imposed within factors of safety indicated, as determined by testing per ASTM E 488, conducted by a qualified independent testing agency.
  1. Carbon Steel: Zinc plated to comply with ASTM B 633, Class Fe/Zn 5 (0.005 mm) for Class SC 1 service condition (mild).
  2. For Postinstalled Anchors in Concrete: Capability to sustain, without failure, a load equal to four times the loads imposed.
  3. For Postinstalled Anchors in Grouted Masonry Units: Capability to sustain, without failure, a load equal to six times the loads imposed.
- I. Universal Shop Primer: Fast-curing, lead- and chromate-free, universal modified-alkyd primer, complying with MPI#79.
- J. Galvanizing Repair Paint: High-zinc-dust-content paint for regalvanizing welds in steel, complying with SSPC-Paint 20.

### 2.3 HEAVY-DUTY WIRE MESH PARTITIONS (WMP)

- A. Mesh: 0.135-inch- (3.5-mm-) diameter, intermediate-crimp steel wire woven into 1 1/8-inch (28.5-mm) c/c diamond mesh.
- B. Vertical and Horizontal Panel Framing: 1-1/2-by-3/4-by-1/4-inch (38-by-19-by-6-mm) cold-rolled steel channels; with 3/8-inch- (9.5-mm-) diameter bolt holes spaced not more than 18 inches (450 mm) o.c. along center of framing. Provide vertical panel stiffeners in shapes and sizes as recommended by manufacturers.
- C. Horizontal Panel Stiffeners: 2 cold-rolled steel channels, not less than 1 by 1/2 by 1/8 inch (25 by 13 by 3 mm), bolted or riveted toe to toe through mesh or 1-1/2-by-3/4-by-1/8-inch (38-by-19-by-3-mm) cold-rolled steel channels with wire woven through.
- D. Top Capping Bars: 3-inch-by-4.1-lb (76-mm-by-1.9-kg) hot-rolled steel channels.
- E. Posts for 90-Degree Corners: 2-by-2-by-1/8-inch (50-by-50-by-3-mm) steel angles with 3/8-inch- (9.5-mm-) diameter bolt holes aligning with bolt holes in vertical framing; with floor anchor clips.
- F. Line Posts: Minimum 2-inch (50mm) square x 0.067 inch (1.3mm) steel tube with 2 x 7 x 1/4 inch (50 x 178 x 6mm) welded on base plate with factory drilled holes for anchoring.
- G. Floor Shoes: Not used.
- H. Swinging Doors: Fabricated from same mesh as partitions, with framing fabricated from 1-1/2-by-3/4-by-1/8-inch (38-by-19-by-3-mm) steel channels or C-channels, banded with 1-1/2-by-1/8-inch (38-by-3-mm) flat steel bar cover plates on 4 sides, and with 1/8-inch- (3-mm-) thick angle strike bar and cover on strike jamb.
  - 1. Hinges: Full-surface type, 3-1/2-by-3-1/2-inch (89-by-89-mm) steel, 1-1/2 pairs per door; bolted, riveted, or welded to door and jamb framing.
  - 2. Cylinder Lock: Mortise type with cylinder specified in Division 08 Section "Door Hardware "; operated by key outside and recessed turn knob inside.
- I. Accessories:
  - 1. Adjustable Filler Panels: Not less than 0.0598-inch- (1.5-mm-) thick, cold-rolled steel sheet; capable of filling openings from 2 to 12 inches (50 to 300 mm).
  - 2. Wall Clips: Manufacturer's standard, cold-rolled steel sheet; allowing up to 1 inch (25 mm) of adjustment.
- J. Finish for Uncoated Ferrous Steel: Baked-enamel finish or Powder-coated finish unless otherwise indicated.
  - 1. Color: As selected by Architect from manufacturer's full range.

### 2.4 FABRICATION

- A. General: Fabricate wire mesh items from components of sizes not less than those indicated. Use larger-sized components as recommended by wire mesh item manufacturer. As required

for complete installation, provide bolts, hardware, and accessories with manufacturer's standard finishes.

1. Fabricate wire mesh items to be readily disassembled.
  2. Welding: Weld corner joints of framing and remove spatter.
- B. Heavy-Duty Wire Mesh Partitions: Fabricate wire mesh partitions with cutouts for pipes, ducts, beams, and other items indicated. Finish edges of cutouts to provide a neat, protective edge.
1. Mesh: Securely clinch mesh to framing.
  2. Framing: Fabricate framing with mortise and tenon corner construction.
    - a. Provide horizontal stiffeners as indicated or, if not indicated, as required by panel height and as recommended by wire mesh partition manufacturer. Weld horizontal stiffeners to vertical framing.
    - b. Fabricate partition and door framing with slotted holes for connecting adjacent panels.
  3. Fabricate wire mesh partitions with 1 inches (25 mm) of clear space between finished floor and bottom horizontal framing.
  4. Doors: Align bottom of door with bottom of adjacent panels.
    - a. For doors that do not extend full height of partition, provide transom over door, fabricated from same mesh and framing as partition panels.
  5. Hardware Preparation: Mortise, reinforce, drill, and tap doors and framing as required to install hardware.

## 2.5 GENERAL FINISH REQUIREMENTS

- A. Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.

## 2.6 STEEL AND IRON FINISHES

- A. Preparation for Shop Priming: Prepare uncoated ferrous-metal surfaces to comply with minimum requirements indicated below for SSPC surface-preparation specifications and environmental exposure conditions of installed metal fabrications:
  1. Interiors (SSPC Zone 1A): SSPC-SP 3, "Power Tool Cleaning."
- B. Shop Priming: Apply shop primer to uncoated surfaces of metal fabrications, except those with galvanized finishes and those to be embedded in concrete or masonry, unless otherwise indicated. Comply with SSPC-PA 1, "Paint Application Specification No. 1: Shop, Field, and Maintenance Painting of Steel," for shop painting.
- C. Baked-Enamel or Powder-Coat Finish: Immediately after cleaning and pretreating, apply manufacturer's standard 2-coat, baked-on finish, suitable for use indicated, consisting of prime coat and thermosetting topcoat, with a minimum dry film thickness of 1 mil (0.025 mm) for topcoat.
  1. Color and Gloss: As selected by Architect from manufacturer's full range.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Examine floors for suitable conditions where wire mesh items will be installed.
- C. Examine walls to which wire mesh items will be attached for properly located blocking, grounds, and other solid backing for attachment of support fasteners.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 WIRE MESH PARTITIONS ERECTION

- A. Anchor wire mesh partition posts to floor with 3/8-inch- (9.5-mm-) diameter, postinstalled expansion anchors at 12 inches (305 mm) o.c. through base plate located at each post and corner. Adjust wire mesh partition posts to achieve level and plumb installation.
  - 1. Anchors may be set with power-actuated fasteners instead of postinstalled expansion anchors if indicated on Shop Drawings.
- B. Anchor wire mesh partitions to walls at 12 inches (305 mm) o.c. through back corner panel framing and as follows:
  - 1. For concrete and solid masonry anchorage, use drilled-in expansion shields and hanger or lag bolts.
  - 2. For hollow masonry anchorage, use toggle bolts.
  - 3. Install so that gap between wall and mesh does not exceed 1-inch (25mm) maximum.
- C. Secure top capping bars to top framing channels with 1/4-inch- (6-mm-) diameter "U" bolts spaced not more than 28 inches (700 mm) o.c.
- D. Provide line posts at locations indicated or, if not indicated, as follows:
  - 1. For partitions that are 7 to 9 feet high, spaced at 15 to 20 feet o.c.
  - 2. For partitions that are 10 to 12 feet high, located between every other panel.
  - 3. For partitions that are more than 12 feet high, located between each panel.
- E. Provide seismic supports and bracing as indicated or, if not indicated, as recommended by manufacturer and as required for stability, extending and fastening members to supporting structure.
- F. Where standard-width wire mesh partition panels do not fill entire length of run, provide adjustable filler panels to fill openings.
- G. Install doors complete with door hardware.
- H. Bolt accessories to wire mesh partition framing.

3.3 ADJUSTING AND CLEANING

- A. Adjust doors to operate smoothly and easily, without binding or warping. Adjust hardware to function smoothly. Confirm that latches and locks engage accurately and securely without forcing or binding.
- B. Remove and replace defective work including doors and framing that are warped, bowed, or otherwise unacceptable.
- C. Touchup Painting: Immediately after erection, clean field welds, bolted connections, and abraded areas. Paint uncoated and abraded areas with the same material as used for shop painting to comply with SSPC-PA 1 for touching up shop-painted surfaces.
- D. Touchup Painting: Cleaning and touchup painting of field welds, bolted connections, and abraded areas of shop paint are specified in Division 09 painting Sections.

END OF SECTION 10 2213





SECTION 10 2600 - WALL PROTECTION

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Corner guards.

1.3 SUBMITTALS

- A. Product Data: Include construction details, material descriptions, impact strength, dimensions of individual components and profiles, and finishes for each impact-resistant wall-protection unit.
- B. Shop Drawings: For each impact-resistant wall-protection unit showing locations and extent. Include sections, details, and attachments to other work.
- C. Samples for Initial Selection: For each type of impact-resistant wall-protection unit indicated.
  - 1. Include similar Samples of accent strips and accessories involving color selection.
- D. Qualification Data: For Installer.
- E. Material Test Reports: For each impact-resistant plastic material.
- F. Material Certificates: For each impact-resistant plastic material, signed by manufacturer.
- G. Maintenance Data: For each impact-resistant wall-protection unit to include in maintenance manuals.
  - 1. Include recommended methods and frequency of maintenance for maintaining optimum condition of plastic covers under anticipated traffic and use conditions. Include precautions against using cleaning materials and methods that may be detrimental to plastic finishes and performance.
- H. Warranty: Special warranty specified in this Section.

1.4 QUALITY ASSURANCE

- A. Installer Qualifications: An employer of workers trained and approved by manufacturer.
- B. Testing Agency Qualifications: An independent agency qualified according to ASTM E 329 for testing indicated, as documented according to ASTM E 548.

- C. Source Limitations: Obtain impact-resistant wall-protection units through one source from a single manufacturer.
- D. Product Options: Drawings indicate size, profiles, and dimensional requirements of impact-resistant wall-protection units and are based on the specific system indicated. Refer to Division 01 Section "Product Requirements."
  - 1. Do not modify intended aesthetic effects, as judged solely by Architect, except with Architect's approval. If modifications are proposed, submit comprehensive explanatory data to Architect for review.
- E. Fire-Test-Response Characteristics: Provide impact-resistant, plastic wall-protection units with surface-burning characteristics as determined by testing identical products per ASTM E 84, 2007 edition, NFPA 255, or UL 723 by UL or another testing and inspecting agency acceptable to authorities having jurisdiction.
- F. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination."

#### 1.5 DELIVERY, STORAGE, AND HANDLING

- A. Store impact-resistant wall-protection units in original undamaged packages and containers inside well-ventilated area protected from weather, moisture, soiling, extreme temperatures, and humidity.
  - 1. Maintain room temperature within storage area at not less than 70 deg F during the period plastic materials are stored.
  - 2. Keep plastic sheet material out of direct sunlight.
  - 3. Store plastic wall-protection components for a minimum of 72 hours, or until plastic material attains a minimum room temperature of 70 deg F.
    - a. Store corner-guard covers in a vertical position.

#### 1.6 PROJECT CONDITIONS

- A. Environmental Limitations: Do not deliver or install impact-resistant wall-protection units until building is enclosed and weatherproof, wet work is complete and dry, and HVAC system is operating and maintaining temperature at 70 deg F for not less than 72 hours before beginning installation and for the remainder of the construction period.
- B. Field Measurements: Verify actual locations of walls, columns, and other construction contiguous with impact-resistant wall-protection units by field measurements before fabrication and indicate measurements on Shop Drawings.

#### 1.7 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of impact-resistant wall-protection units that fail in materials or workmanship within specified warranty period.
  - 1. Failures include, but are not limited to, the following:
    - a. Structural failures.

- b. Deterioration of plastic and other materials beyond normal use.
- 2. Warranty Period: Five years from date of Substantial Completion.

## 1.8 EXTRA MATERIALS

- A. Furnish extra materials described below that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Corner-Guard and Crash Rail Covers: Full-size plastic covers of maximum length equal to 2 percent of each type, color, and texture of units installed, but no fewer than two full-size units.
- B. Include mounting and accessory components. Replacement materials shall be from same production run as installed units.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the manufacturers specified.

### 2.2 MATERIALS

- A. Extruded Rigid Plastic: ASTM D 1784, Class 1, textured, chemical- and stain-resistant, high-impact-resistant PVC or acrylic-modified vinyl plastic with integral color throughout; thickness as indicated.
  - 1. Impact Resistance: Minimum 25.4 ft-lbf/in. (1356 J/m) of notch when tested according to ASTM D 256, Test Method A.
  - 2. Chemical and Stain Resistance: Tested according to ASTM D 543.
  - 3. Self-extinguishing when tested according to ASTM D 635.
  - 4. Flame-Spread Index: 25 or less.
  - 5. Smoke-Developed Index: 450 or less.
- B. Aluminum Extrusions: Alloy and temper recommended by manufacturer for type of use and finish indicated but with not less than strength and durability properties specified in ASTM B 221 (ASTM B 221M) for Alloy 6063-T5.
- C. Fasteners: Aluminum, nonmagnetic stainless-steel, or other noncorrosive metal screws, bolts, and other fasteners compatible with items being fastened. Use security-type fasteners in inmate areas.

## 2.3 CORNER GUARDS

- A. Surface-Mounted, Resilient, Plastic Corner Guards (CG): Assembly consisting of snap-on plastic cover installed over continuous retainer; including mounting hardware; fabricated with 90- or 135-degree turn to match wall condition.
1. Available Manufacturers:
  2. American Floor Products Co., Inc.
  3. Arden Architectural Specialties, Inc.
  4. Balco, Inc.
  5. Boston Retail Products.
  6. Construction Specialties, Inc.
  7. IPC Door and Wall Protection Systems, Inc.
  8. Koroseal Wall Protection Systems, Inc.
  9. K. J. Miller Corp.
  10. Pawling Corporation.
  11. Tepromark International, Inc.
  12. Tri-Guards, Inc.
  13. Wilkinson Company, Inc.
  14. Cover: Extruded rigid plastic, minimum 0.100-inch (2.5-mm) wall thickness; as follows:
    - a. Profile: Nominal 3-inch- (75-mm-) long leg and 1-1/4-inch (32-mm) corner radius.
    - b. Height: 4 feet (1.2 m).
    - c. Color and Texture: As selected by Architect from manufacturer's full range.
  15. Retainer: Minimum 0.060-inch- (1.5-mm-) thick, 1-piece, extruded aluminum.
  16. Top and Bottom Caps: Prefabricated, injection-molded plastic; color matching cover; field adjustable for close alignment with snap-on cover.

## 2.4 FABRICATION

- A. Fabricate impact-resistant wall-protection units to comply with requirements indicated for design, dimensions, and member sizes, including thicknesses of components.
- B. Assemble components in factory to greatest extent possible to minimize field assembly. Disassemble only as necessary for shipping and handling.
- C. Fabricate components with tight seams and joints with exposed edges rolled. Provide surfaces free of wrinkles, chips, dents, uneven coloration, and other imperfections. Fabricate members and fittings to produce flush, smooth, and rigid hairline joints.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates and wall areas, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of work.
1. Examine walls to which impact-resistant wall protection will be attached for blocking, grounds, and other solid backing that have been installed in the locations required for secure attachment of support fasteners.

2. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. Complete finishing operations, including painting, before installing impact-resistant wall-protection system components.
- B. Before installation, clean substrate to remove dust, debris, and loose particles.

### 3.3 INSTALLATION

- A. General: Install impact-resistant wall-protection units level, plumb, and true to line without distortions. Do not use materials with chips, cracks, voids, stains, or other defects that might be visible in the finished Work.
  1. Install impact-resistant wall-protection units in locations and at mounting heights indicated on Drawings or, if not indicated, at heights indicated below:
    - a. Corner Guards: 4" above finish floor.
    - b. Abar FRP.
  2. Provide splices, mounting hardware, anchors, and other accessories required for a complete installation.
    - a. Provide anchoring devices to withstand imposed loads.
    - b. Adjust top and bottom caps as required to ensure tight seams.

### 3.4 CLEANING

- A. Immediately after completion of installation, clean plastic covers and accessories using a standard, ammonia-based, household cleaning agent.
- B. Remove excess adhesive using methods and materials recommended in writing by manufacturer.

END OF SECTION 10 2600



SECTION 10 2800 - TOILET, BATH, AND LAUNDRY ACCESSORIES

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Public-use washroom accessories.
  - 2. Private-use bathroom accessories.
  - 3. Healthcare accessories.
  - 4. Custodial accessories.
- B. Related Sections include the following:
  - 1. Division 102813.63 Section "Detention Toilet Accessories" for accessories designed for installation in detention facilities.

1.3 SUBMITTALS

- A. Product Data: For each type of product indicated. Include the following:
  - 1. Construction details and dimensions.
  - 2. Anchoring and mounting requirements, including requirements for cutouts in other work and substrate preparation.
  - 3. Material and finish descriptions.
  - 4. Features that will be included for Project.
  - 5. Manufacturer's warranty.
- B. Product Schedule: Indicating types, quantities, sizes, and installation locations by room of each accessory required.
  - 1. Identify locations using room designations indicated on Drawings.
  - 2. Identify products using designations indicated on Drawings.
- C. Maintenance Data: For toilet and bath accessories to include in maintenance manuals.

1.4 QUALITY ASSURANCE

- A. Source Limitations: For products listed together in the same articles in Part 2, provide products of same manufacturer unless otherwise approved by Architect.

1.5 COORDINATION

- A. Coordinate accessory locations with other work to prevent interference with clearances required for access by people with disabilities, and for proper installation, adjustment, operation, cleaning, and servicing of accessories.
- B. Deliver inserts and anchoring devices set into concrete or masonry as required to prevent delaying the Work.

1.6 WARRANTY

- A. Special Mirror Warranty: Manufacturer's standard form in which manufacturer agrees to replace mirrors that develop visible silver spoilage defects and that fail in materials or workmanship within specified warranty period.
  - 1. Warranty Period: 15 years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Stainless Steel: ASTM A 666, Type 304, 0.0312-inch (0.8-mm) minimum nominal thickness, unless otherwise indicated.
- B. Brass: ASTM B 19 flat products; ASTM B 16 (ASTM B 16M), rods, shapes, forgings, and flat products with finished edges; or ASTM B 30, castings.
- C. Steel Sheet: ASTM A 1008/A 1008M, Designation CS (cold rolled, commercial steel), 0.0359-inch (0.9-mm) minimum nominal thickness.
- D. Galvanized Steel Sheet: ASTM A 653/A 653M, with G60 (Z180) hot-dip zinc coating.
- E. Galvanized Steel Mounting Devices: ASTM A 153/A 153M, hot-dip galvanized after fabrication.
- F. Fasteners: Screws, bolts, and other devices of same material as accessory unit and tamper-and-theft resistant where exposed, and of galvanized steel where concealed.
- G. Chrome Plating: ASTM B 456, Service Condition Number SC 2 (moderate service).
- H. Mirrors: ASTM C 1503, Mirror Glazing Quality, clear-glass mirrors, nominal 6.0 mm thick.



2.2 WASHROOM ACCESSORIES

- A. Basis-of-Design Product: The design for accessories is based on products indicated in the Toilet Accessory Schedule. Subject to compliance with requirements, provide the named product or a comparable product by one of the following:
1. A & J Washroom Accessories, Inc.
  2. American Specialties, Inc.
  3. Bobrick Washroom Equipment, Inc.
  4. General Accessory Manufacturing Co. (GAMCO).
- B. Toilet Tissue (Roll) Dispenser:
1. Description: Double-roll dispenser.
  2. Mounting: Surface mounted.
  3. Operation: Noncontrol delivery with standard spindle.
  4. Capacity: Designed for 4-1/2- or 5-inch- (114- or 127-mm-) diameter tissue rolls.
  5. Material and Finish: Satin-finish aluminum bracket with plastic spindle.
- C. Paper Towel (Folded) Dispenser:
1. Mounting: Surface mounted.
  2. Minimum Capacity: 200 C-fold or 275 multifold towels.
  3. Material and Finish: Stainless steel, No. 4 finish (satin)
  4. Lockset: Tumbler type.
  5. Refill Indicators: Pierced slots at sides or front.
- D. Combination Towel (Folded) Dispenser/Waste Receptacle:
1. Description: Combination unit for dispensing C-fold or multifold towels, with removable waste receptacle.
  2. Mounting: Semirecessed.
    - a. Designed for nominal 4-inch (100-mm) wall depth.
  3. Minimum Towel-Dispenser Capacity: 600 C-fold or 800 multifold paper towels.
  4. Minimum Waste-Receptacle Capacity: 4 gal. (15 L).
  5. Material and Finish: Stainless steel, No. 4 finish (satin).
  6. Liner: Reusable, vinyl waste-receptacle liner.
  7. Lockset: Tumbler type for towel-dispenser compartment and waste receptacle.
- E. Grab Bar:
1. Mounting: Flanges with exposed fasteners.
  2. Material: Stainless steel, 0.05 inch (1.3 mm) thick.
    - a. Finish: Smooth, No. 4, satin finish on ends and slip-resistant texture in grip area.
  3. Outside Diameter: 1-1/2 inches (38 mm).
  4. Configuration and Length: As indicated in schedule at end of section.
- F. Sanitary-Napkin Disposal Unit:
1. Mounting: Partition mounted and dual access Surface mounted.
  2. Door or Cover: Self-closing disposal-opening cover.
  3. Material and Finish: Stainless steel, No. 4 finish (satin).

- G. Mirror Unit:
  - 1. Frame: Stainless-steel channel.
    - a. Corners: Manufacturer's standard.
  - 2. Hangers: Produce rigid, tamper- and theft-resistant installation, using method indicated below.
    - a. One-piece, galvanized steel, wall-hanger device with spring-action locking mechanism to hold mirror unit in position with no exposed screws or bolts.
    - b. Wall bracket of galvanized steel, equipped with concealed locking devices requiring a special tool to remove.
  - 3. Size: As indicated.
- H. Robe/Towel Hook:
  - 1. Description: Double-prong unit.
  - 2. Material and Finish: Stainless steel, No. 4 finish (satin).

### 2.3 SHOWER ROOM ACCESSORIES

- A. Basis-of-Design Product: The design for accessories is based on products indicated in the Toilet Accessory Schedule. Subject to compliance with requirements, provide the named product or a comparable product by one of the following:
  - 1. A & J Washroom Accessories, Inc.
  - 2. American Specialties, Inc.
  - 3. Bobrick Washroom Equipment, Inc.
  - 4. General Accessory Manufacturing Co. (GAMCO).
- B. Shower Curtain Rod:
  - 1. Description: 1-inch (25.4-mm) OD; fabricated from nominal 0.0375-inch- (0.95-mm-) thick stainless steel.
  - 2. Mounting Flanges: Stainless-steel flanges designed for exposed fasteners.
  - 3. Finish: No. 4 (satin).
- C. Shower Curtain:
  - 1. Size: Minimum 6 inches (152 mm) wider than opening by 72 inches (1828 mm) high.
  - 2. Material: Nylon-reinforced vinyl, minimum 10-oz. (284-g) or 0.008-inch- (0.2-mm-) thick vinyl, with integral antibacterial agent.
  - 3. Color: White.
  - 4. Grommets: Corrosion resistant at minimum 6 inches (152 mm) o.c. through top hem.
  - 5. Shower Curtain Hooks: Chrome-plated or stainless-steel, spring wire curtain hooks with snap fasteners, sized to accommodate specified curtain rod. Provide one hook per curtain grommet.

### 2.4 HEALTHCARE ACCESSORIES

- A. Basis-of-Design Product: The design for accessories is based on products indicated in the Toilet Accessory Schedule. Subject to compliance with requirements, provide the named product or a comparable product by one of the following:
  - 1. A & J Washroom Accessories, Inc.
  - 2. American Specialties, Inc.
  - 3. Bobrick Washroom Equipment, Inc.

4. General Accessory Manufacturing Co. (GAMCO).

B. Specimen Pass-Through Cabinet:

1. Description: With self-closing doors on both sides, lock that prevents doors from both being opened at the same time, and removable stainless-steel tray.
2. Nominal Wall Opening: 12 by 11-1/4 inches (305 by 285 mm), width times height.
3. Material and Finish: Stainless steel, No. 4 finish (satin).

2.5 CUSTODIAL ACCESSORIES

A. Basis-of-Design Product: The design for accessories is based on products indicated in the Toilet Accessory Schedule. Subject to compliance with requirements, provide the named product or a comparable product by one of the following:

1. Maintex
2. A & J Washroom Accessories, Inc.
3. American Specialties, Inc.
4. Bobrick Washroom Equipment, Inc.
5. General Accessory Manufacturing Co. (GAMCO).

B. Mop and Broom Holder:

1. Description: Unit with shelf and holders.
2. Length: 36 inches (914 mm).
3. Mop/Broom Holders: Four, spring-loaded, rubber hat, cam type.
4. Material and Finish: Stainless steel, No. 4 finish (satin).
  - a. Shelf: Not less than nominal 0.05-inch- (1.3-mm-) thick stainless steel.

2.6 FABRICATION

A. General: Fabricate units with tight seams and joints, and exposed edges rolled. Hang doors and access panels with full-length, continuous hinges. Equip units for concealed anchorage and with corrosion-resistant backing plates.

B. Keys: Provide universal keys for internal access to accessories for servicing and resupplying. Provide minimum of six keys to Owner's representative.

PART 3 - EXECUTION

3.1 INSTALLATION

A. Install accessories according to manufacturers' written instructions, using fasteners appropriate to substrate indicated and recommended by unit manufacturer. Install units level, plumb, and firmly anchored in locations and at heights indicated.

B. Grab Bars: Install to withstand a downward load of at least 250 lbf (1112 N), when tested according to method in ASTM F 446.

3.2 ADJUSTING AND CLEANING

- A. Adjust accessories for unencumbered, smooth operation. Replace damaged or defective items.
- B. Remove temporary labels and protective coatings.
- C. Clean and polish exposed surfaces according to manufacturer's written recommendations.

3.3 TOILET ACCESSORY SCHEDULE

PLAN SYMBOL	DESCRIPTION	MANUFACTURE BOBRICK	MOUNTING HEIGHT
CU-1	Combination Unit (recessed)	B-3944	40 inches to towels
CU-2	Combination Unit (surface)	B-3949	40 inches to towels
FSS	Folding Shower Seat	B-5181	17 inches to top
GB	Grab Bar (Toilet Side)	B-6806 Series x 42"	33 inches to centerline
GB-1	Grab Bar (Toilet Back)	B-6806 Series x 36"	33 inches to centerline
GB-2	Grab Bar (2 Side Shower)	B-6816 Series 24" x 30"	33 inches to centerline
MR	Mirror	B-290- 24 x 36	40 inches to bottom
MBH	Mop and Broom Holder	B-223 x 36	60 inches to shelf
PTD	Paper Towel Dispenser	B-2621	40 inches to bottom
SCR	Shower Curtain and Rod	B-6047	78 inches
SND	Sanitary Napkin Disposal	B-270	24 inches to top
TH	Towel Hook	B-672	54 inches to centerline 40 inches at H.C.
TTD	Toilet Tissue Dispenser	B-2740	24 inches to centerline
SP	Specimen Pass	B-505	See detail
SD	Soap Dispenser	B-818615	40 inches to bottom
SCD-1	Seat Cover Dispenser (resd)	B-301	40 inches to bottom
SCD-2	Seat Cover Dispenser (srfc)	B-3013	40 inches to bottom
SNV	Sanitary Napkin Vendor	B-2706 25	40 inches to bottom

END OF SECTION 10 2800



SECTION 10 2813.63 - DETENTION TOILET ACCESSORIES

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

A. Section Includes:

1. Safety hooks.
2. Miscellaneous toilet accessories.
3. Stainless-steel mirrors.
4. Grab bars.
5. Shower seats.
6. Shelves.

B. Related Sections:

1. Division 03 300 Section "Cast-in-Place Concrete" for embedding anchors into cast-in-place construction.
2. Division 042200 Section "Unit Masonry" for inserting anchors into masonry construction and proprietary built-in masonry anchors.
3. Division 055000 Section "Metal Fabrications" for security fasteners.
4. Division 079200 Section "Joint Sealants" for security sealant requirements.
5. Division 099123 Section "Interior painting" Sections for field painting detention toilet accessories.
6. Division 102800 Section "Toilet, Bath, and Laundry Accessories" for nondetention toilet accessories.

1.3 COORDINATION

- A. Coordinate installation of anchorages for detention toilet accessories. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors, that are to be embedded in adjoining construction. Deliver such items to Project site in time for installation.
- B. Coordinate size and location of recesses in wall construction to receive recessed detention toilet accessories.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes.
- B. Samples for Verification: For each type of detention toilet accessory indicated.
  - 1. Approved full-size Samples will be returned and may be used in the Work.
- C. Product Schedule: For detention toilet accessories. Indicate types, quantities, sizes, and installation locations by room of each accessory required. Use same designations indicated on Drawings and in Detention Toilet Accessory Schedule.

1.5 INFORMATIONAL SUBMITTALS

- A. Coordination Drawings: Drawings showing location of each built-in anchor supporting detention toilet accessories, including anchors to be installed as work of other Sections, drawn to scale and coordinating anchorage with detention toilet accessories. Show the following:
  - 1. Locations, dimensions, and profiles of wall and floor reinforcements.
  - 2. Locations and installation details of built-in anchors.
  - 3. Elevations of each detention toilet accessory showing dimensions of accessory, preparations for receiving anchors, and locations of anchorage.
  - 4. Details of attachment of each detention toilet accessory to built-in anchors.
- B. Examination reports documenting inspection of substrates, areas, and conditions.
- C. Anchor inspection reports documenting inspections of built-in and cast-in anchors.
- D. Field quality-control certification signed by Contractor and Detention Specialist.
- E. Welding certificates.
- F. Warranties: Sample of special warranties.

1.6 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For detention toilet accessories to include in maintenance manuals.

1.7 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Security Fasteners: Furnish not less than 20 of each type and size of security fastener installed.
  - 2. Tools: Provide two sets of tools for installing and removing security fasteners.



1.8 QUALITY ASSURANCE

- A. Source Limitations: Obtain each type of detention toilet accessory from single source from single manufacturer.
- B. Welding Qualifications: Qualify procedures and personnel according to the following:
  - 1. AWS D1.1/D1.1M, "Structural Welding Code - Steel."
  - 2. AWS D1.3, "Structural Welding Code - Sheet Steel."
  - 3. AWS D1.6, "Structural Welding Code - Stainless Steel."
- C. Preinstallation Conference: Conduct conference at Project site.
- D. Coordination Meetings: Conduct coordination meetings at Project site to comply with requirements in Division 01 Section "Special Project Procedures for Detention Facilities."

1.9 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace detention toilet accessories that fail in materials or workmanship within specified warranty period.
  - 1. Failures include, but are not limited to, the following:
    - a. Structural failures including deflection exceeding 1/4 inch (6.3 mm).
    - b. Faulty operation of hardware.
    - c. Deterioration of metals, metal finishes, and other materials.
  - 2. Warranty Period: Two years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Cold-Rolled Steel Sheet: ASTM A 1008/A 1008M, CS (Commercial Steel), Type B.
- B. Metallic-Coated Steel Sheet: ASTM A 653/A 653M, CS (Commercial Steel), Type B; with G60 (Z180) zinc (galvanized) coating designation.
- C. Stainless-Steel Sheet: ASTM A 666 or ASTM A 240/A 240M, austenitic stainless steel, Type 304; Type 430 for mirrors.
- D. Steel Plates, Shapes, and Bars: ASTM A 36/A 36M.
- E. Concealed Bolts: ASTM A 307, Grade A unless otherwise indicated.

- F. Cast-in-Place Anchors in Concrete: Anchors of type indicated below, fabricated from corrosion-resistant materials capable of sustaining, without failure, a load equal to 4 times the load imposed, as determined by testing per ASTM E 488, conducted by a qualified independent testing agency.
  - 1. Threaded or wedge type; galvanized ferrous castings, either ASTM A 47/A 47M malleable iron or ASTM A 27/A 27M cast steel. Provide bolts, washers, and shims as needed, hot-dip galvanized per ASTM A 153/A 153M.
- G. Embedded Plate Anchors: Fabricated from steel shapes and plates, minimum 3/16 inch (4.8 mm) thick; with minimum 1/2-inch- (12.7-mm-) diameter headed studs welded to back of plate.
- H. Welding Rods and Bare Electrodes: Select according to AWS specifications.

## 2.2 SECURITY FASTENERS

- A. Fasteners that are operable only by tools produced by fastener manufacturer or other licensed fabricator for use on specific type of fastener.
  - 1. See Division 05 Section "Metal Fabrications."

## 2.3 DETENTION SAFETY HOOKS

- A. Individual, Curved, Detention Safety Hook (DCH): 0.188-inch (4.77-mm) nominal-thickness, stainless-steel curved hook held by minimum 0.109-inch- (2.77-mm-) thick, stainless-steel bracket punched with not less than 2 holes for fastening with security fastener. Provide friction washer assembly, adjustable with a nonremovable security screw that maintains pressure on hook and allows hook to pivot when load exceeds preset limit. Provide No. 4 finish.
  - 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. A & J Washroom Accessories Inc.; Security Hook, US17.
    - b. American Specialties, Inc.; Surface Mounted Clothes Hook, Model No. 120.
    - c. KLN Steel Products Company; Safety Hook, Model 9217.
    - d. Portland Hardware Company Inc.; Clothes Hook, Model PH765.
    - e. Peterson Detention, Inc.; Safety Clothes Hook Bolt-On.
    - f. PSI LLC.; Single Collapsible Safety Hook, Model RS-515.
  - 2. Mounting: Front mounting with security fasteners.

## 2.4 MISCELLANEOUS DETENTION TOILET ACCESSORIES

- A. Recessed, Detention Toilet Tissue Dispenser (DTTD): Minimum 5-inch diameter by 4-1/2 inches (127-mm diameter by 114 mm) deep; formed from minimum 0.062-inch- (1.57-mm-) thick, stainless-steel sheet. Secure to wall with rear-mounting steel strap and adjustment bolts. Provide No. 4 finish.
  - 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:

- a. A & J Washroom Accessories Inc.; Security Toilet Paper Holder, US74.
  - b. American Specialties, Inc.; Security Recessed Toilet Paper Holder, Model No. 110.
  - c. GAMCO; Toilet Tissue Dispenser, MSA-1.
  - d. Maximum Security Products Corp.; Model TP 970.
  - e. Norix, ITP-100.
  - f. PSILLC; Recessed Toilet Paper Holder, Model TPH-600.
  - g. Willoughby Industries, Inc.; Rear Mounted Tissue Holder, Model No. RTH-1.
2. Face: 1-inch (25.4-mm) lip around entire face.
- B. Recessed, Detention Soap Dish (DSD): Minimum inside dimensions of 5-3/4 inches wide by 4-1/2 inches high by 2-1/2 inches (146 mm wide by 114 mm high by 64 mm) deep with 3/4-inch (19-mm) lip around entire face; formed from 0.062-inch- (1.57-mm-) thick, stainless-steel sheet. Secure to wall with rear-mounting steel strap and adjustment bolts. Provide No. 4 finish.
1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. A & J Washroom Accessories Inc.; Security Soap Dish, US80.
    - b. American Specialties, Inc.; Security Recessed Soap Dish, Model No. 140.
    - c. Willoughby Industries, Inc.; Recessed Soap Dish Rear Mounted, Model No. RSD-

## 2.5 DETENTION MIRRORS

- A. Large, Framed Detention Mirror with Square Corners (DMR-1): Minimum 18 inches wide by 36 inches (457 mm wide by 915 mm) high; formed from 0.038-inch- (0.95-mm-) thick, stainless-steel sheet with fiberboard backing and No. 8 finish; enclosed in a No. 4 finish metal frame.
1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. A & J Washroom Accessories, Inc.; US 7011 modified.
    - b. American Specialties, Inc.; Security Framed Mirror, Model No. 105 modified.
    - c. GAMCO; Framed Mirror, MSA-11 modified.
  2. Frame: Formed from minimum 0.062-inch- (1.57-mm-) thick, stainless-steel sheet. Fabricate frame with welded and ground corners or from one piece of metal.
  3. Mounting: Front mounting with security fasteners.
- B. Integrally Framed Detention Mirror with Round Corners (DMR): Minimum 11 inches wide by 16 inches (279 mm wide by 406 mm) high; with mirror and integral frame formed from minimum 0.062-inch- (1.57-mm-) thick, stainless-steel sheet; with round corners. Provide No. 8 finish for mirror, chrome plating for frame.
1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. A & J Washroom Accessories Inc.; Security Mirror, US7408B.
    - b. American Specialties, Inc.; Security Framed Mirror, Model No. 107.
    - c. Norix Group, Inc.; Ironman Cell Mirror, Model No. R565-411.
    - d. Portland Hardware Company Inc.; Large One-Piece Security Mirror, Model PH721.
    - e. Willoughby Industries, Inc.; Front Access Security Mirror, Model No. MR2.

- f. Peterson Detention, Inc.; Stainless Steel Mirror (one piece)
2. Mounting: Front mounting with security fasteners.

## 2.6 DETENTION GRAB BARS

- A. Grab Bars (DSGB): 1-1/2 inches (38.1 mm) in diameter; formed from 0.042-inch- (1.2-mm-) thick, stainless-steel tubing, with 3-inch- (76.2-mm-) diameter flanges formed from 0.125-inch- (3.18-mm-) thick, stainless steel. Closure plates for suicide prevention formed from 0.125-inch- (3.18-mm-) thick, stainless steel. All-welded construction. Provide No. 4 finish.
1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Security Grab Bars with closure plate (DSGB)
      - 1) A & J Washroom Accessories Inc.; US130 Series.
      - 2) American Specialties, Inc.; 160 Series.
      - 3) GAMCO; MSA-14.
      - 4) Norix; IGS series.
      - 5) Peterson Detention, Inc.; Grab Bar with Closure plate.
  2. Length: As indicated in schedule.
  3. Mounting: Front mounting with security fasteners.

## 2.7 DETENTION SHOWER SEATS

- A. Shower Seats (DSS): Stainless steel recess-mounted shower seat, formed from minimum 16 gauge stainless-steel sheet. Minimum 500 lb. (227 kg) loading capacity. Provide No. 4 finish.
1. Products: Limited to sole product allowed by BSCC:
    - a. Bradley Stainless Steel Corner Shower Seat, Model 9541 – Fixed Corner Shower Seat.

## 2.8 DETENTION CLOTHES HOOKS

- A. Individual, Curved, Detention Safety Hook (DCH): 0.188-inch (4.77-mm) nominal-thickness, stainless-steel curved hook held by minimum 0.109-inch- (2.77-mm-) thick, stainless-steel bracket punched with not less than 2 holes for fastening with security fastener. Provide friction washer assembly, adjustable with a nonremovable security screw that maintains pressure on hook and allows hook to pivot when load exceeds preset limit. Provide No. 4 finish.
1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. A & J Washroom Accessories Inc.; Security Hook, US17.
    - b. American Specialties, Inc.; Surface Mounted Clothes Hook, Model No. 120.
    - c. KLN Steel Products Company; Safety Hook, Model 9217.
    - d. Portland Hardware Company Inc.; Clothes Hook, Model PH765.
    - e. Peterson Detention, Inc.; Safety Clothes Hook Bolt-On.
    - f. PSI LLC.; Single Collapsible Safety Hook, Model RS-515.
  2. Mounting: Front mounting with security fasteners.

2.9 SHELVES

- A. Detention Toilet Tissue Shelf (DTTS): Minimum 6 inches (203 mm) deep by length indicated, formed from 0.0478-inch(1.21-mm) nominal-thickness, Type 304 stainless steel sheet, with integral welded side gussets and curved and hemmed front edge.
  - 1. Basis-of-Design Product: Subject to compliance with requirements, provide American Specialties, Inc; Roval Surface-Mounted Shelf or a comparable product by one of the following:
    - a. AJW Architectural Products.
    - b. Bradley Corporation.
  - 2. Mounting: Front mounting with security fasteners.
- B. Materials:
  - 1. Stainless-Steel Sheet, Strip, Plate, and Flat Bars: ASTM A 666 or ASTM A 240/A 240M, austenitic stainless steel, Type 304.
- C. Finishes:
  - 1. Stainless-Steel Finish:
    - a. Surface Preparation: Remove tool and die marks and stretch lines, or blend into finish.
    - b. Polished Finish: Grind and polish surfaces to produce uniform finish, free of cross scratches.
      - 1) Run grain of directional finishes with long dimension of each piece.
      - 2) When polishing is completed, passivate and rinse surfaces. Remove embedded foreign matter and leave surfaces chemically clean.
      - 3) Directional Satin Finish: No. 4.

2.10 FABRICATION

- A. Coordinate dimensions and attachment methods of detention toilet accessories with those of adjoining construction to produce integrated assemblies with closely fitting joints and with edges and surfaces aligned unless otherwise indicated.
- B. Shear and punch metals cleanly and accurately. Remove burrs.
- C. Form edges and corners to be free of sharp edges and rough areas. Fold back exposed edges of unsupported sheet metal to form a 1/2-inch- (12.7-mm-) wide hem on the concealed side, or ease edges to a radius of approximately 1/32 inch (0.8 mm) and support with concealed stiffeners.
- D. Form metal in maximum lengths to minimize joints. Form bent-metal corners to smallest radius possible without causing grain separation or otherwise impairing work.

- E. Weld corners and seams continuously to comply with referenced AWS standard and the following:
  - 1. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
  - 2. Obtain fusion without undercut or overlap.
  - 3. Remove welding flux immediately.
  - 4. At exposed connections, finish exposed welds and surfaces smooth and blended so no roughness shows after finishing and contour of welded surface matches that of adjacent surface.
  - 5. Provide smoothly finished eased edges of 1/32" minimum at outside corners.
  - 6. Weld before finishing components to greatest extent possible. Remove weld spatter and welding oxides from exposed surfaces by descaling or grinding.
- F. Provide for anchorage of type indicated; coordinate with supporting structure. Fabricate and space anchoring devices to secure detention toilet accessories rigidly in place and to support expected loads. Build in straps, plates, and brackets as needed to support and anchor fabricated items to adjoining construction. Reinforce formed-metal units as needed to attach and support other construction.
- G. Cut, reinforce, drill, and tap detention toilet accessories to receive hardware, security fasteners, and similar items.
- H. Form exposed work true to line and level with accurate angles and surfaces. Grind off and ease edges unless otherwise indicated.
- I. Form exposed connections with hairline joints, flush and smooth, using concealed fasteners where possible. Use exposed security fasteners of type indicated or, if not indicated, flat-head (countersunk) security fasteners. Locate joints where least conspicuous.

## 2.11 FINISHES

- A. Finish detention toilet accessories after assembly.
- B. Stainless-Steel Finishes:
  - 1. Surface Preparation: Remove tool and die marks and stretch lines, or blend into finish.
  - 2. Polished Finish: Grind and polish surfaces to produce uniform finish, free of cross scratches.
    - a. Run grain of directional finishes with long dimension of each piece.
    - b. When polishing is completed, passivate and rinse surfaces. Remove embedded foreign matter and leave surfaces chemically clean.
    - c. Directional Satin Finish: No. 4.
    - d. For mirror surfaces provide #8 non directional polished surface.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of detention toilet accessories.
  - 1. Examine roughing-in for embedded and built-in anchors to verify actual locations of detention toilet accessory connections before detention toilet accessory installation.
  - 2. For the record, prepare written report, endorsed by Installer, listing conditions detrimental to performance of detention toilet accessories.
- B. Inspect built-in and cast-in anchor installations before installing detention toilet accessories to verify that anchor installations comply with requirements. Prepare inspection reports.
  - 1. Remove and replace anchors where inspections indicate that they do not comply with specified requirements. Reinspect after repairs or replacements are made.
  - 2. Perform additional inspections to determine compliance of replaced or additional work. Prepare inspection reports.
- C. Verify locations of detention toilet accessories.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. Fastening to In-Place Construction: Provide anchorage devices and fasteners where necessary for securing detention toilet accessories to in-place construction. Include threaded fasteners for concrete and masonry inserts, security fasteners, and other connectors.
- B. Provide temporary bracing or anchors in formwork for items that are to be built into concrete or masonry or similar construction.
- C. Apply security sealant around perimeter in a continuous ribbon on back of detention toilet accessories before installation.
- D. Security Fasteners: Install detention toilet accessories using security fasteners with head style appropriate for installation requirements, strength, and finish of adjacent materials. Provide stainless-steel security fasteners in stainless-steel materials.

### 3.3 FIELD QUALITY CONTROL

- A. Inspect installed products to verify compliance with requirements. Prepare inspection reports and indicate compliance with and deviations from the Contract Documents.
- B. Remove and replace detention work where inspections indicate that work does not comply with specified requirements.
- C. Perform additional inspections to determine compliance of replaced or additional work. Prepare inspection reports.

- D. Prepare field quality-control certification endorsed by Detention Specialist that states installed products and their installation comply with requirements in the Contract Documents.

3.4 ADJUSTING AND CLEANING

- A. Remove temporary labels and protective coatings.
- B. Adjust safety hooks to release with application of 8-lbf (35.6-N) load.
- C. Touchup Painting: Immediately after erection, clean bolted connections and abraded areas of shop paint, and paint exposed areas with same material as used for shop painting to comply with SSPC-PA 1 for touching up shop-painted surfaces.
- D. Touchup Painting: Cleaning and touchup painting of bolted connections and abraded areas of shop paint are specified in Division 09 painting Sections.

3.5 DETENTION TOILET ACCESSORY SCHEDULE

PLAN SYMBOL	DESCRIPTION	(American Specialties Inc.) MODEL #	MOUNTING HEIGHT
DCH	Detention Clothes Hook	120	60 inches to centerline typical 40 inches to centerline at H.C. locations
DTTD	Detention Toilet Tissue Dispenser	110 or 110-1	24 inches to centerline typical (or as indicated on drawings)
DSD	Recessed Detention Soap Dish	140	40 inches to centerline typical (or as indicated on drawings)
DMR	Integral Framed Mirror	107	74 inches to top of mirror
DMR-1	Framed Detention Mirror	107 Modified	40 inches to reflective Surface 18" x 36" (Handicap Locations)
DSGB-1	Security Grab Bar 42 inches long (Toilet Side)	160 Series	33 inches to centerline
DSGB-2	Security Grab Bar 36 inches long (Toilet Back)	160 Series	33 inches to centerline
DSGB-3	Security Grab Bar	160 Series	33 inches to centerline L shape 24 inches by 36 inches Long (H.C. Roll-in Shower Back Wall)
DST	Shower Seat	Bradley 9541	18 inches (483 mm) to seat
DTTS	Detention Toilet Tissue Shelf	ASI 20692	24 inches to top of shelf



COUNTY OF MONTEREY  
NEW JUVENILE HALL

75-14126-00

END OF SECTION 10 2813.63

DETENTION TOILET ACCESSORIES

10 28 13.63 - 11  
09/01/2015

## SECTION 10 4413 - FIRE EXTINGUISHER CABINETS

### PART 1 - GENERAL

#### 1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Fire protection cabinets for the following:
    - a. Portable fire extinguishers.
- B. Related Sections:
  - 1. Division 104416 Section "Fire Extinguishers."

#### 1.3 SUBMITTALS

- A. Product Data: For each type of product indicated. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for fire protection cabinets.
  - 1. Fire Protection Cabinets: Include roughing-in dimensions, details showing mounting methods, relationships of box and trim to surrounding construction, door hardware, cabinet type, trim style, and panel style.
- B. Product Schedule: For fire protection cabinets. Coordinate final fire protection cabinet schedule with fire extinguisher schedule to ensure proper fit and function. Use same designations indicated on Drawings.
- C. Maintenance Data: For fire protection cabinets to include in maintenance manuals.

#### 1.4 QUALITY ASSURANCE

- A. Fire-Rated, Fire Protection Cabinets: Listed and labeled to comply with requirements in ASTM E 814, 2006 edition for fire-resistance rating of walls where they are installed.

#### 1.5 COORDINATION

- A. Coordinate size of fire protection cabinets to ensure that type and capacity of fire extinguishers indicated are accommodated.
- B. Coordinate sizes and locations of fire protection cabinets with wall depths.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Cold-Rolled Steel Sheet: ASTM A 1008/A 1008M, Commercial Steel (CS), Type B.
- B. Tempered Float Glass: ASTM C 1048, Kind FT, Condition A, Type I, Quality q3, 3 mm thick, Class 1 (clear).

2.2 FIRE PROTECTION CABINET

- A. Cabinet Type: Suitable for fire extinguisher.
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Fire End & Croker Corporation.
    - b. J. L. Industries, Inc., a division of Activar Construction Products Group.
    - c. Kidde Residential and Commercial Division, Subsidiary of Kidde plc.
    - d. Larsen's Manufacturing Company.
    - e. Modern Metal Products, Division of Technico Inc..
    - f. Moon-American.
    - g. Potter Roemer LLC.
    - h. Watrous Division, American Specialties, Inc.
- B. Cabinet Construction: Nonrated.
- C. Cabinet Material: Steel sheet.
  - 1. Shelf: Same metal and finish as cabinet.
- D. Semirecessed Cabinet (FEC): Cabinet box partially recessed in walls of sufficient depth to suit style of trim indicated; with one-piece combination trim and perimeter door frame overlapping surrounding wall surface with exposed trim face and wall return at outer edge (backbend). Provide where walls are of insufficient depth for recessed cabinets but are of sufficient depth to accommodate semirecessed cabinet installation.
  - 1. Rolled-Edge Trim: 2-1/2-inch (64-mm) backbend depth.
- E. Cabinet Trim Material: Steel sheet.
- F. Door Material: Steel sheet.
- G. Door Style: Fully glazed panel with frame.
- H. Door Glazing: Tempered float glass (clear).
- I. Door Hardware: Manufacturer's standard door-operating hardware of proper type for cabinet type, trim style, and door material and style indicated.
  - 1. Provide projecting door pull and friction latch.
  - 2. Provide manufacturer's standard hinge permitting door to open 180 degrees.

- J. Accessories:
1. Mounting Bracket: Manufacturer's standard steel, designed to secure fire extinguisher to fire protection cabinet, of sizes required for types and capacities of fire extinguishers indicated, with plated or baked-enamel finish.
  2. Identification: Lettering complying with authorities having jurisdiction for letter style, size, spacing, and location. Locate as indicated.
    - a. Identify fire extinguisher in fire protection cabinet with the words "FIRE EXTINGUISHER."
      - 1) Location: Applied to cabinet glazing.
      - 2) Application Process: Decals.
      - 3) Lettering Color: Red.
      - 4) Orientation: Vertical.
- K. Finishes:
1. Manufacturer's standard baked-enamel paint for the following:
    - a. Exterior of cabinet door, and trim except for those surfaces indicated to receive another finish.
    - b. Interior of cabinet and door.
  2. Steel: Baked enamel or powder coat.

### 2.3 SECURITY FIRE PROTECTION CABINET

- A. Cabinet Type: Suitable for fire extinguisher.
1. Products: Subject to compliance with requirements, provide one of the following:
    - a. J. L. Industries, Inc., a division of Activar Construction Products Group.
    - b. Larsen's Manufacturing Company.
    - c. Potter Roemer LLC.
- B. Cabinet Construction: Nonrated.
- C. Cabinet Material: 0.0966-inch- (2.5-mm-) thick steel sheet.
- D. Surface-Mounted Cabinet (**DFEC**): Cabinet box fully exposed and mounted directly on wall; with no trim.
- E. Cabinet Trim Material: Steel sheet.
- F. Door Material: 0.0966-inch- (2.5-mm-) thick steel.
- G. Door Style: Solid opaque panel with frame.
- H. Door Hardware: Manufacturer's standard door-operating hardware of proper type for cabinet type, trim style, and door material and style indicated, and as follows:
1. Recessed door pull.
  2. Continuous Hinge: Same material and finish as trim, permitting door to open 180 degrees.
  3. Mechanical Deadlock: Lockbolt retracted and extended by five-tumbler mogul cylinder; keyed one side.
    - a. Lockbolt: 1-1/2 inches high by 3/4 inch (38 mm high by 19 mm) thick; 5/8-inch (16-mm) throw.

- I. Accessories:
  - 1. Mounting Bracket: Manufacturer's standard steel, designed to secure fire extinguisher to security fire protection cabinet, of sizes required for types and capacities of fire extinguishers indicated, with plated or baked-enamel finish.
  - 2. Keys to Door Locks: Five total, key all locks the same.
- J. Finishes:
  - 1. Manufacturer's standard baked-enamel paint for the following:
    - a. Exterior of cabinet door, and trim except for those surfaces indicated to receive another finish.
    - b. Interior of cabinet and door.
  - 2. Steel: Baked enamel or powder coat.

## 2.4 FABRICATION

- A. Fire Protection Cabinets: Provide manufacturer's standard box (tub) with trim, frame, door, and hardware to suit cabinet type, trim style, and door style indicated.
  - 1. Weld joints and grind smooth.
  - 2. Provide factory-drilled mounting holes.
  - 3. Prepare doors and frames to receive locks.
  - 4. Install door locks at factory.
- B. Cabinet Doors: Fabricate doors according to manufacturer's standards, from materials indicated and coordinated with cabinet types and trim styles selected.
  - 1. Fabricate door frames with tubular stiles and rails and hollow-metal design, minimum 1/2 inch (13 mm) thick.
  - 2. Fabricate door frames of one-piece construction with edges flanged.
  - 3. Miter and weld perimeter door frames.
- C. Cabinet Trim: Fabricate cabinet trim in one piece with corners mitered, welded, and ground smooth.

## 2.5 GENERAL FINISH REQUIREMENTS

- A. Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Protect mechanical finishes on exposed surfaces of fire protection cabinets from damage by applying a strippable, temporary protective covering before shipping.
- C. Finish fire protection cabinets after assembly.
- D. Appearance of Finished Work: Noticeable variations in same piece are not acceptable. Variations in appearance of adjoining components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.

2.6 STEEL FINISHES

- A. Surface Preparation: Remove mill scale and rust, if present, from uncoated steel, complying with SSPC-SP 5/NACE No. 1, "White Metal Blast Cleaning" or SSPC-SP 8, "Pickling". After cleaning, apply a conversion coating suited to the organic coating to be applied over it.]
- B. Factory Prime Finish: Apply manufacturer's standard, fast-curing, lead- and chromate-free, universal primer immediately after surface preparation and pretreatment.
- C. Baked-Enamel or Powder-Coat Finish: Immediately after cleaning and pretreating, apply manufacturer's standard two-coat, baked-on finish consisting of prime coat and thermosetting topcoat. Comply with coating manufacturer's written instructions for applying and baking to achieve a minimum dry film thickness of 2 mils (0.05 mm).
  - 1. Color and Gloss: White, semi-gloss.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine roughing-in for cabinets to verify actual locations of piping connections before cabinet installation.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. General: Install fire protection cabinets in locations and at mounting heights indicated.
  - 1. Fire Protection Cabinets: 60 inches (1525 mm) above finished floor to top of cabinet.
- B. Fire Protection Cabinets: Fasten cabinets to structure, square and plumb.
  - 1. Fasten mounting brackets to inside surface of fire protection cabinets, square and plumb.
- C. Identification: Apply decals at locations indicated.

3.3 ADJUSTING AND CLEANING

- A. Remove temporary protective coverings and strippable films, if any, as fire protection cabinets are installed unless otherwise indicated in manufacturer's written installation instructions.
- B. Adjust fire protection cabinet doors to operate easily without binding. Verify that integral locking devices operate properly.
- C. On completion of fire protection cabinet installation, clean interior and exterior surfaces as recommended by manufacturer.
- D. Touch up marred finishes, or replace fire protection cabinets that cannot be restored to factory-finished appearance. Use only materials and procedures recommended or furnished by fire protection cabinet and mounting bracket manufacturers.

- E. Replace fire protection cabinets that have been damaged or have deteriorated beyond successful repair by finish touchup or similar minor repair procedures.

3.4 FIRE CABINET SCHEDULE:

- A. Non Security Cabinets:
  - 1. Semi-Recess Mounted - **FEC**.
- B. Security Cabinets:
  - 1. Surface Mounted - **DFEC**.

END OF SECTION 10 4413

## SECTION 10 4416 - FIRE EXTINGUISHERS

### PART 1 - GENERAL

#### 1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

#### 1.2 SUMMARY

- A. Section includes portable, hand-carried fire extinguishers and mounting brackets for fire extinguishers.
- B. Related Sections:
  - 1. Division 104413 Section "Fire Extinguisher Cabinets."

#### 1.3 SUBMITTALS

- A. Product Data: For each type of product indicated. Include rating and classification, material descriptions, dimensions of individual components and profiles, and finishes for fire extinguisher and mounting brackets.
- B. Product Schedule: For fire extinguishers. Coordinate final fire extinguisher schedule with fire protection cabinet schedule to ensure proper fit and function. Use same designations indicated on Drawings.
- C. Operation and Maintenance Data: For fire extinguishers to include in maintenance manuals.

#### 1.4 QUALITY ASSURANCE

- A. Title 19 Compliance: Fabricate and label fire extinguishers to comply with CCR, Title 19, Division 1, Chapter 3, "Portable Fire Extinguishers."
- B. Fire Extinguishers: Listed and labeled for type, rating, and classification by an independent testing agency acceptable to authorities having jurisdiction.
  - 1. Provide fire extinguishers approved, listed, and labeled by FMG.

#### 1.5 COORDINATION

- A. Coordinate type and capacity of fire extinguishers with fire protection cabinets to ensure fit and function.



## PART 2 - PRODUCTS

### 2.1 PORTABLE, HAND-CARRIED FIRE EXTINGUISHERS

- A. Fire Extinguishers: Type, size, and capacity for each fire protection cabinet and mounting bracket indicated.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Amerex Corporation.
    - b. Ansul Incorporated; Tyco International Ltd.
    - c. Badger Fire Protection; a Kidde company.
    - d. Buckeye Fire Equipment Company.
    - e. Fire End & Croker Corporation.
    - f. J. L. Industries, Inc.; a division of Activar Construction Products Group.
    - g. Kidde Residential and Commercial Division; Subsidiary of Kidde plc.
    - h. Larsen's Manufacturing Company.
    - i. Moon-American.
    - j. Pem All Fire Extinguisher Corp.; a division of PEM Systems, Inc.
    - k. Potter Roemer LLC.
    - l. Pyro-Chem; Tyco Safety Products.
- B. Multipurpose Dry-Chemical Type (FE): UL-rated 4-A;60-B:C nominal capacity, with monoammonium phosphate-based dry chemical in manufacturer's standard enameled container.
- C. Wet-Chemical Type (FE-K): UL-rated 2-A:1-B:C:K, 2.5-gal. (9.5-L) nominal capacity, with potassium carbonate-based chemical in stainless-steel container; with pressure-indicating gage.

### 2.2 MOUNTING BRACKETS

- A. Mounting Brackets: Manufacturer's standard steel, designed to secure fire extinguisher to wall or structure, of sizes required for types and capacities of fire extinguishers indicated, with plated or red baked-enamel finish.
- B. Identification: Lettering complying with authorities having jurisdiction for letter style, size, spacing, and location. Locate as indicated by Architect.
  - 1. Identify bracket-mounted fire extinguishers with the words "FIRE EXTINGUISHER" in red letter decals applied to mounting surface.
    - a. Orientation: Vertical.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine fire extinguishers for proper charging and tagging.
  - 1. Remove and replace damaged, defective, or undercharged fire extinguishers.

- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. General: Install fire extinguishers in fire extinguisher cabinets and with mounting brackets in locations indicated and in compliance with requirements of authorities having jurisdiction.
  - 1. Mounting Brackets: 54 inches above finished floor to top of fire extinguisher.
- B. Mounting Brackets: Fasten mounting brackets to surfaces, square and plumb, at locations indicated.

END OF SECTION 10 4416

SECTION 10 5113 - METAL LOCKERS

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Knocked-down, quiet metal lockers.
- B. Related Sections include the following:
  - 1. Division 061000 Section "Rough Carpentry" for furring, blocking, and shims required for installing metal lockers and concealed within other construction before metal locker installation.

1.3 DEFINITIONS

- A. Uncoated Steel Sheet Thicknesses: Indicated as the minimum thicknesses.

1.4 SUBMITTALS

- A. Product Data: Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for each type of metal locker and bench.
- B. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
  - 1. Show base, sloping tops, filler panels and other accessories.
  - 2. Include locker identification system.
- C. Samples for Initial Selection: For units with factory-applied color finishes.
- D. Qualification Data: For Installer.
- E. Maintenance Data: For adjusting, repairing, and replacing locker doors and latching mechanisms to include in maintenance manuals.
- F. Warranty: Special warranty specified in this Section.

### 1.5 QUALITY ASSURANCE

- A. **Installer Qualifications:** An authorized representative of metal locker manufacturer for installation and maintenance of units required for this Project.
- B. **Source Limitations:** Obtain metal lockers and accessories through one source from a single manufacturer.
- C. **Regulatory Requirements:** Where metal lockers are indicated to comply with accessibility requirements, comply with the California Building Code, the U.S. Architectural & Transportation Barriers Compliance Board's "Americans with Disabilities Act (ADA), Accessibility Guidelines for Buildings and Facilities (ADAAG)."
  - 1. Provide not less than 1 shelf located no higher than 54 inches (1372 mm) above the floor for side reach.
  - 2. Provide 1 shelf located at bottom of locker no lower than 9 inches (230 mm) above the floor for side reach.
  - 3. Provide hardware that does not require tight grasping, pinching, or twisting of the wrist, and that operates with a force of not more than 5 lbf (22.2 N).
  - 4. Provide decal indicating accessibility.

### 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Do not deliver metal lockers until spaces to receive them are clean, dry, and ready for metal locker installation.

### 1.7 PROJECT CONDITIONS

- A. **Field Measurements:** Verify the following by field measurements before fabrication and indicate measurements on Shop Drawings:
  - 1. Concealed framing, blocking, and reinforcements that support metal lockers before they are enclosed.
  - 2. **Established Dimensions:** Where field measurements cannot be made without delaying the Work, establish recessed opening dimensions and proceed with fabricating metal lockers without field measurements. Coordinate wall and floor construction to ensure that actual recessed opening dimensions correspond to established dimensions.

### 1.8 COORDINATION

- A. Coordinate size and location of concrete bases for metal lockers.
- B. Coordinate sizes and locations of framing, blocking, furring, reinforcements, and other related units of Work specified in other Sections to ensure that metal lockers can be supported and installed as indicated.

1.9 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of metal lockers that fail in materials or workmanship, excluding finish, within specified warranty period.
1. Failures include, but are not limited to, the following:
    - a. Structural failures.
    - b. Faulty operation of latches and other door hardware.
  2. Damage from deliberate destruction and vandalism is excluded.
  3. Warranty Period for Knocked-Down Metal Lockers: Two years from date of Substantial Completion.

1.10 EXTRA MATERIALS

- A. Furnish extra materials described below, before construction begins, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
1. Full-size units of the following metal locker hardware items equal to 10 percent of amount installed for each type and finish installed, but no fewer than 5 units:
    - a. Locks.
    - b. Identification plates.
    - c. Hooks.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
1. Products: Subject to compliance with requirements, provide products by one of the specified manufacturers.

2.2 MATERIALS

- A. Cold-Rolled Steel Sheet: ASTM A 1008, Commercial Steel (CS) Type B, suitable for exposed applications.
- B. Expanded Metal: ASTM F 1267, Type II (flattened), Class I, 3/4-inch (19-mm) steel mesh, with at least 70 percent open area.
- C. Stainless-Steel Sheet: ASTM A 666, Type 304.
- D. Extruded Aluminum: ASTM B 221 (ASTM B 221M), alloy and temper recommended by aluminum producer and manufacturer for type of use and finish indicated.

- E. Fasteners: Zinc- or nickel-plated steel, slotless-type exposed bolt heads, and self-locking nuts or lock washers for nuts on moving parts.
- F. Anchors: Select material, type, size, and finish required for secure anchorage to each substrate.
  - 1. Provide nonferrous-metal or hot-dip galvanized anchors and inserts on inside face of exterior walls and elsewhere as required for corrosion resistance.
  - 2. Provide toothed-steel or lead expansion sleeves for drilled-in-place anchors.

2.3 KNOCKED-DOWN, QUIET METAL LOCKERS (MWL-1, MWL-2, MWL-3)

- A. Products:
  - 1. Spacesaver Corp (Basis of Design)
  - 2. Art Metal Products, Div. of Fort Knox Storage Co.
  - 3. DeBourgh Mfg. Co.
  - 4. General Storage Systems, Div. of North American Steel.
  - 5. Hadrian Inc.
  - 6. List Industries Inc.
  - 7. Lyon Workspace Products.
  - 8. Penco Products, Inc., Subsidiary of Vesper Corporation.
  - 9. Republic Storage Systems Company.
  - 10. Shanahan's Ltd.
  - 11. Tensco Corp.
- B. Locker Arrangement: As indicated in Metal Locker Schedule located at the end of Part 3.
- C. Body: Assembled by riveting or bolting body components together. Fabricate from unperforated, cold-rolled steel sheet with thicknesses as follows:
  - 1. Tops, Bottoms, and Intermediate Dividers: 0.0209 inch, with single bend at sides.
  - 2. Backs and Sides: 0.0209 inch thick, with full-height, double-flanged connections.
  - 3. Shelves: 0.0209 inch thick, with double bend at front and single bend at sides and back.
- D. Frames: Channel formed; fabricated from 0.0528-inch- (1.35-mm-) thick, cold-rolled steel sheet; lapped and factory welded at corners; with top and bottom main frames factory welded into vertical main frames. Form continuous, integral door strike full height on vertical main frames. Retain subparagraph below if needed; cross frames between tiers are not offered by all manufacturers.
  - 1. Cross Frames between Tiers: Channel formed and fabricated from same material as main frames; welded to vertical frame members.
  - 2. Frame Vents: Fabricate horizontal face frames with vents.
- E. Doors: One-piece; fabricated from 0.0528-inch- (1.35-mm-) thick, cold-rolled steel sheet; formed into channel shape with double bend at vertical edges, and with right-angle single bend at horizontal edges.
  - 1. Doors less than 12 inches (305 mm) wide may be fabricated from 0.0428-inch- (1.1-mm) thick, cold-rolled steel sheet.
  - 2. Reinforcement: Manufacturer's standard reinforcing angles, channels, or stiffeners for doors more than 15 inches (381 mm) wide; welded to inner face of doors.

3. Stiffeners: Manufacturer's standard full-height stiffener fabricated from 0.0428-inch- (1.1-mm-) thick, cold-rolled steel sheet; welded to inner face of doors.
  4. Sound-Dampening Panels: Manufacturer's standard, designed to stiffen doors and reduce sound levels when doors are closed, of die-formed metal with full perimeter flange and sound-dampening material; welded to inner face of doors.
  5. Door Style: Vented panel as follows:
    - a. Louvered Vents: Not less than:
      - 1) Six louver openings at top and bottom for single-tier.
      - 2) Three louver openings at top and bottom for double-tier.
      - 3) Two louver openings at top and bottom for multiple-tier lockers.
- F. Hinges: Self-closing; welded to door and attached to door frame with not less than 2 factory-installed rivets per hinge that are completely concealed and tamper resistant when door is closed; fabricated to swing 180 degrees.
1. Hinges: Manufacturer's standard, steel continuous or knuckle type.
    - a. Knuckle Hinges: Steel, full loop, 5 or 7 knuckles, tight pin; minimum 2 inches (51 mm) high. Provide not less than 3 hinges for each door more than 42 inches (1067 mm) high.
- G. Recessed Door Handle and Latch: Stainless-steel cup with integral door pull, recessed so locking device does not protrude beyond face of door; pry resistant.
1. Multipoint Latching: Finger-lift latch control designed for use with built-in combination locks, built-in key locks, or padlocks; positive automatic and prelocking.
    - a. Latch Hooks: Equip doors 48 inches (1219 mm) and higher with 3 latch hooks and doors less than 48 inches (1219 mm) high with 2 latch hooks; fabricated from minimum 0.0966-inch- (2.5-mm-) thick steel; welded or riveted to full-height door strikes; with resilient silencer on each latch hook.
    - b. Latching Mechanism: Manufacturer's standard rattle-free latching mechanism and moving components isolated with vinyl or nylon to prevent metal-to-metal contact, and incorporating a prelocking device that allows locker door to be locked while door is open and then closed without unlocking or damaging lock or latching mechanism.
- H. Combination Padlocks: Key-controlled, three-number dialing combination locks; capable of five combination changes.
- I. Equipment: Equip each metal locker with identification plate and the following, unless otherwise indicated:
1. Single-Tier Units: Shelf, one double-prong ceiling hook, and two single-prong wall hooks.
  2. Double-Tier Units: One double-prong ceiling hook and two single-prong wall hooks.
  3. Multiple-Tier Units: Two single-prong wall hooks.
  4. Coat Rods: In lieu of ceiling hook for metal lockers 18 inches (457 mm) deep or greater.
- J. Accessories:
1. Continuous Sloping Tops: Fabricated from cold-rolled steel sheet, manufacturer's standard thickness, but not less than 0.0329 inch (0.85 mm) thick.



- a. Closures: Vertical-end type.
- b. Sloped top corner fillers, mitered.
2. Recess Trim: Fabricated from 0.0428-inch- (1.1-mm-) thick, cold-rolled steel sheet.
3. Filler Panels: Fabricated from cold-rolled steel sheet, manufacturer's standard thickness, but not less than 0.0329 inch (0.85 mm) thick.
4. Finished End Panels: Fabricated from 0.0209-inch- (0.55-mm-) thick, cold-rolled steel sheet.

K. Finish: Baked enamel or powder coat.

1. Color: As selected by Architect from manufacturer's full range.

## 2.4 FABRICATION

- A. General: Fabricate metal lockers square, rigid, and without warp; with metal faces flat and free of dents or distortion. Make exposed metal edges free of sharp edges and burrs, and safe to touch.
1. Form body panels, doors, shelves, and accessories from one-piece steel sheet, unless otherwise indicated.
  2. Provide fasteners, filler plates, supports, clips, and closures as required for a complete installation.
- B. Unit Principle: Fabricate each metal locker with an individual door and frame; individual top, bottom, and back; and common intermediate uprights separating compartments.
- C. Knocked-Down Construction: Fabricate metal lockers for nominal assembly at Project site using nuts, bolts, screws, or rivets. Factory weld frame members together to form a rigid, one-piece assembly.
- D. Hooks: Manufacturer's standard ball-pointed type, aluminum or steel; zinc plated.
- E. Coat Rods: Fabricated from 3/4-inch- (19-mm-) diameter steel; chrome finished.
- F. Identification Plates: Manufacturer's standard etched, embossed, or stamped aluminum plates; with numbers and letters at least 3/8 inch (9 mm) high.
- G. Continuous Sloping Tops: Fabricated in lengths as long as practicable, without visible fasteners at splice locations; finished to match lockers.
1. Sloped top corner fillers, mitered.
- H. Filler Panels: Fabricated in an unequal leg angle shape; finished to match lockers. Provide slip joint filler angle formed to receive filler panel.
- I. Finished End Panels: Designed for concealing unused penetrations and fasteners, except for perimeter fasteners, at exposed ends of nonrecessed metal lockers; finished to match lockers.
1. Provide one-piece panels for double-row (back-to-back) locker ends.

2.5 STEEL SHEET FINISHES

- A. General: Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Factory finish steel surfaces and accessories except stainless-steel and chrome-plated surfaces.
- C. Surface Preparation: Clean surfaces of dirt, oil, grease, mill scale, rust, and other contaminants that could impair paint bond. Use manufacturer's standard methods.
- D. Baked-Enamel Finish: Immediately after cleaning, pretreating, and phosphatizing, apply manufacturer's standard thermosetting baked-enamel finish. Comply with paint manufacturer's written instructions for application, baking, and minimum dry film thickness.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine walls, floors, and support bases, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of work.
  - 1. For the record, prepare written report, endorsed by Installer, listing conditions detrimental to performance of work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. General: Install level, plumb, and true; shim as required, using concealed shims.
  - 1. Anchor locker runs at ends and at intervals recommended by manufacturer, but not more than 36 inches (910 mm) o.c. Install anchors through backup reinforcing plates, channels, or blocking as required to prevent metal distortion, using concealed fasteners.
  - 2. Anchor single rows of metal lockers to walls near top and bottom of lockers.
  - 3. Anchor back-to-back metal lockers to floor.
- B. Knocked-Down Metal Lockers: Assemble knocked-down metal lockers with standard fasteners, with no exposed fasteners on door faces or face frames.
- C. Equipment and Accessories: Fit exposed connections of trim, fillers, and closures accurately together to form tight, hairline joints, with concealed fasteners and splice plates.
  - 1. Attach hooks with at least two fasteners.
  - 2. Attach door locks on doors using security-type fasteners.
  - 3. Identification Plates:
    - a. Identify metal lockers with identification noted on shop drawing submittal.
    - b. Attach plates to each locker door, near top, centered, with at least two aluminum rivets.

4. Attach filler panels with concealed fasteners. Locate fillers panels where indicated on Drawings.
5. Attach sloping top units to metal lockers, with closures at exposed ends.
6. Attach finished end panels with fasteners only at perimeter to conceal exposed ends of nonrecessed metal lockers.

- D. Fixed Locker Benches: Provide not less than 2 pedestals for each bench, uniformly spaced not more than 60 inches (1830 mm) apart. Securely fasten tops of pedestals to undersides of bench tops, and anchor bases to floor.

### 3.3 ADJUSTING, CLEANING, AND PROTECTION

- A. Clean, lubricate, and adjust hardware. Adjust doors and latches to operate easily without binding. Verify that integral locking devices operate properly.
- B. Protect metal lockers from damage, abuse, dust, dirt, stain, or paint. Do not permit metal locker use during construction.
- C. Touch up marred finishes, or replace metal lockers that cannot be restored to factory-finished appearance. Use only materials and procedures recommended or furnished by metal locker manufacturer.

### 3.4 METAL LOCKER SCHEDULE

- A. Metal Wardrobe Locker **MWL-1**:
  1. Locker Classification: Single Tier.
  2. Locker Size: 12-inches wide x 18-inches deep x 72-inches high.
    - a. 1 tier for a total of 72-inches high.
  3. Color: As selected by Architect from manufacturer's full range.
- B. Metal Wardrobe Locker **MWL-2**:
  1. Locker Classification: Multiple Tier.
  2. Locker Size: 12-inches wide x 18-inches deep x 36-inches high.
    - a. 2 tiers for a total of 72-inches high.
  3. Color: As selected by Architect from manufacturer's full range.
- C. Metal Wardrobe Locker **MWL-3**:
  1. Locker Classification: Single Tier, ACCESSIBLE.
  2. Locker Size: 18-inches wide x 24-inches deep x 36-inches high.
    - a. 2 tier for a total of 72-inches high.
  3. Color: As selected by Architect from manufacturer's full range.
- D. Metal Wardrobe Locker **MWL-4**:
  1. Locker Classification: Multiple Tier, ACCESSIBLE.
  2. Locker Size: 12-inches wide x 12-inches deep x 12-inches high.
    - a. 6 tiers for a total of 72-inches high.
  3. Color: As selected by Architect from manufacturer's full range.



END OF SECTION 10 5113

SECTION 10 5613 - METAL STORAGE SHELVING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- 1. Section Includes: Post-and-beam metal storage shelving.

B. Related Sections:

- 1. Section 11 4000 "Foodservice Equipment" for metal shelving in kitchen, pantry, and refrigerated spaces.

1.3 PERFORMANCE REQUIREMENTS

- A. Delegated Design: Design metal storage shelving, including comprehensive engineering analysis by a qualified professional engineer, using performance requirements and design criteria indicated.
- B. Structural Performance for Four-Post Metal Storage Shelving: Capable of withstanding the loads indicated according to MH 28.1.
- C. Structural Performance for Post-and-Beam Metal Storage Shelving: Capable of withstanding the loads indicated according to MH 28.2.
- D. Seismic Performance: Metal storage shelving shall withstand the effects of earthquake motions determined according to ASCE/SEI 7.
  - 1. Seismic Component Importance Factor: 1.0.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated. Include rated capacities, construction details, material descriptions, dimensions of individual components and profiles, and finishes for metal storage shelving.
- B. Shop Drawings: For customized metal storage shelving. Include plans, elevations, sections, details, and attachments to other work. Include installation details of connectors, lateral bracing, and special bracing.
- C. Samples for Initial Selection: For units with factory-applied color finishes. Include similar Samples of accessories involving color selection.

- D. Samples for Verification: For the following components, of size indicated below:
  - 1. Vertical Posts: 12 inches (305 mm) tall.
  - 2. Shelves: Full size, but not more than 24 inches wide by 18 to 24 inches deep.
  - 3. Connectors for Beam to Post: Full size.
  - 4. Shelf-Label Holders: Full size.
- E. Product Schedule: For metal storage shelving. Refer to floor plan(s) for layout and shelving depth.
- F. Delegated-Design Submittal: For metal storage shelving indicated to comply with performance requirements, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation.
  - 1. Design Calculations: Calculate requirements for seismic restraints.

#### 1.5 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For qualified Installer.
- B. Seismic Qualification Certificates: For metal storage shelving, accessories, and components, from manufacturer.
- C. Product Certificates: For each type of metal storage shelving from manufacturer.

#### 1.6 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For metal storage shelving to include in maintenance manuals.

#### 1.7 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials from same production run that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Shelves: Full-size units equal to 5 percent of amount installed for each type indicated, but no fewer than five shelves.
  - 2. Shelf-to-Post Connectors: Full-size units equal to 5 percent of amount installed for each type indicated, but no fewer than 10 connectors.
  - 3. Shelf-Label Holders: Full-size units equal to 5 percent of amount installed for each type indicated, but no fewer than 10 holders.

#### 1.8 QUALITY ASSURANCE

- A. Installer Qualifications: Manufacturer's authorized representative who is trained and approved for installation of units required for this Project.
- B. Source Limitations: Obtain metal storage shelving from single source from single manufacturer.

- C. Preinstallation Conference: Conduct conference at Project site.

## 1.9 PROJECT CONDITIONS

- A. Environmental Limitations: Do not deliver or install metal storage shelving until spaces are enclosed and weathertight, wet work in spaces is complete and dry, and temporary HVAC system is operating and maintaining ambient temperature and humidity conditions at occupancy levels during the remainder of the construction period.

## 1.10 COORDINATION

- A. Coordinate sizes and locations of blocking and backing required for installation of metal storage shelving attached to wall and ceiling assemblies.
- B. Coordinate locations and installation of metal storage shelving that may interfere with ceiling systems including lighting, HVAC, speakers, sprinklers, access panels, electrical switches or outlets, and floor drains.

## PART 2 - PRODUCTS

### 2.1 MATERIALS

- A. Hot-Rolled Steel Sheet: ASTM A 1011/A 1011M, Commercial Steel (CS), Type B; free of scale, pitting, or surface defects; pickled and oiled.
- B. Cold-Rolled Steel Sheet: ASTM A 1008/A 1008M, Commercial Steel (CS), Type B.
- C. Metallic-Coated Steel Sheet: ASTM A 653/A 653M, Commercial Steel (CS), Type B; with G60 (Z180) zinc (galvanized) or A60 (ZF180) zinc-iron-alloy (galvannealed) coating.
- D. Steel Tubing: ASTM A 513, Type 2.
- E. Stainless-Steel Tubing: ASTM A 554, Grade MT-304.
- F. Steel Wire: ASTM A 899.
- G. Stainless-Steel Wire: ASTM A 580/A 580M, Type 304.
- H. Particleboard: ANSI A208.1, made with binder containing no urea formaldehyde.
- I. Hardboard: ANSI A135.4.
- J. Composite Wood Products: Products shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- K. Floor Anchors: Galvanized-steel, post-installed expansion anchors. Provide number per unit recommended by manufacturer unless additional anchors are indicated in calculations.



- L. Wall Anchors: Manufacturer's standard, galvanized-steel anchors designed to secure metal storage shelving to adjacent wall. Provide two per shelving unit for each shelving unit adjacent to a wall unless additional anchors are indicated in calculations.

## 2.2 POST-AND-BEAM METAL STORAGE SHELVING

- A. General: Factory-formed, field-assembled, freestanding, post-and-beam metal storage shelving system, designed for shelves to be supported by beams that span between and are supported by corner posts, with beams adjustable over the entire height of shelving unit. Fabricate initial shelving unit with a post at each corner. Fabricate additional shelving units similarly, so each unit is independent. Provide fixed top and bottom beams, adjustable intermediate beams, and accessories indicated.
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
    - a. Borroughs Corporation.
    - b. Durham Manufacturing Company (The).
    - c. Edsal.
    - d. Equipto.
    - e. Hallowell; Division of List Industries, Inc.
    - f. Lyon Workspace Products, LLC.
    - g. Mecalux.
    - h. Penco Products, Inc.
    - i. Rousseau Metal Inc.
    - j. Safco Products; a division of LDI.
    - k. Schaefer Systems International, Inc.
    - l. Tennsco.
    - m. Unicor; Federal Prison Industries, Inc.
    - n. Western Pacific Storage Systems.
- B. Load-Carrying Capacity per Shelf: 400 lb (181 kg).
- C. Posts: Fabricated from cold-rolled steel; in shape; with perforations at 1-1/2 inches (38 mm) o.c. to receive beam-to-post connectors.
  - 1. Steel Thickness, Nominal: As required for load-carrying capacity per shelf and number of shelves.
  - 2. Add-On Shelf Posts: Fabricated from hot-rolled steel, T-shape; perforated to match main posts and of same thickness.
  - 3. Post Base: Cold-rolled steel floor plate, drilled for floor anchors.
- D. Beams: Fabricated from cold-rolled steel; in manufacturer's standard shape; with projecting manufacturer's standard beam-to-post connectors at each end designed to engage posts. Provide beam at each side of each shelf, with center supports as required for load-carrying capacity of shelf.

1. Steel Thickness, Nominal: As required for load-carrying capacity per shelf.
2. Provide top, bottom, and intermediate shelf beams with double beam-to-post connectors.
3. Provide top and bottom shelf beams with double beam-to-post connectors and intermediate shelf beams with single beam-to-post connectors.
4. Provide beams for the number of shelves required.
5. Provide beams for one intermediate shelf per shelving unit in addition to top and bottom shelf beams.

E. Flat Metal Shelves: Fabricated from steel sheet as follows:

1. Steel-Sheet Thickness, Nominal: As required for load-carrying capacity per shelf.
2. Metallic-Coated Steel-Sheet Thickness, Nominal: As required for load-carrying capacity per shelf.
3. Fabricate fronts, backs, and sides of shelves with box-formed edges, with corners lapped and welded.

F. Shelf Quantity: Five shelves per shelving unit in addition to top and bottom shelf.

G. Overall Unit Width: 36 inches (914 mm).

H. Overall Unit Depth: 18 inches (457 mm) or 24 inches (610 mm). Refer to Floor Plans.

I. Overall Unit Height: 72 inches (1829 mm).

J. Accessories:

1. Tie Plates: Cold-rolled steel, finished to match posts; designed for joining posts of adjacent shelving units.
2. Supports: Back-to-wall type that bolt to posts; as required for shelving unit stability.

K. Finish: Baked Enamel.

1. Color and Gloss: As selected by Architect from manufacturer's full range.

## 2.3 FABRICATION

A. Shop Fabrication: Prefabricate shelving components in shop to greatest extent possible to minimize field fabrication; temporarily preassemble shelving components where necessary to ensure that field-assembled components fit together properly. Use connections that maintain structural value of joined pieces. Clearly mark units for reassembly and coordinated installation.

B. Fabricate metal storage shelving square and rigid, with posts plumb and true and shelves flat and free of dents or distortion. Fabricate connections to form a rigid structure, free of buckling and warping.

1. Form exposed work true to line and level with accurate angles and surfaces and straight sharp edges.
2. Form exposed connections with hairline joints, flush and smooth, using concealed fasteners where possible. Locate joints where least conspicuous.

3. Build in straps, plates, brackets, and other reinforcements as needed to support shelf loading.
  4. Cut, reinforce, drill, and tap metal fabrications to receive hardware, fasteners, and similar items.
- C. Form metal in maximum lengths to minimize joints. Form bent-metal corners to smallest radius possible without causing grain separation or otherwise impairing the Work. Form backs of shelving units up to 48 inches (1219 mm) wide from one piece.
- D. Form edges and corners free of sharp edges or rough areas. Fold back and crimp exposed edges of unsupported sheet metal to form a 1/2-inch- (13-mm-) wide hem on the concealed side; ease edges of metal plate to radius of approximately 1/32 inch (0.8 mm). Shear and punch metals cleanly and accurately. Remove burrs.
- E. Weld corners and seams continuously to develop strength, minimize distortion, and maintain the corrosion resistance of base metals. At exposed locations, finish welds and surfaces smooth and blended so no roughness shows after finishing and contour of welded surface matches that of adjacent surface. Weld before finishing components to greatest extent possible. Remove weld spatter and welding oxides from exposed surfaces before finishing.

#### 2.4 GENERAL FINISH REQUIREMENTS

- A. Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Appearance of Finished Work: Noticeable variations in same piece are not acceptable. Variations in appearance of adjoining components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.

#### 2.5 METALLIC-COATED STEEL-SHEET FINISHES

- A. Surface Preparation: Clean surfaces with nonpetroleum solvent so surfaces are free of oil and other contaminants. After cleaning, apply a conversion coating suited to the organic coating to be applied over it. Clean welds, mechanical connections, and abraded areas, and apply galvanizing repair paint, complying with SSPC-Paint 20, to comply with ASTM A 780.
- B. Baked-Enamel or Powder-Coat Finish: Manufacturer's standard baked-on finish consisting of prime coat and thermosetting topcoat. Comply with coating manufacturer's written instructions for cleaning, pretreatment, application, and minimum dry thickness.

#### 2.6 STEEL FINISHES

- A. Surface Preparation: Remove mill scale and rust, if present, from uncoated steel, complying with SSPC-SP 5/NACE No. 1, "White Metal Blast Cleaning" or SSPC-SP 8, "Pickling."
- B. Baked-Enamel or Powder-Coat Finish: Manufacturer's standard baked-on finish consisting of prime coat and thermosetting topcoat. Comply with coating manufacturer's written instructions for cleaning, pretreatment, application, and minimum dry thickness.

2.7 STAINLESS-STEEL FINISHES

- A. Surface Preparation: Remove tool and die marks and stretch lines, or blend into finish.
- B. Polished Finishes: Grind and polish surfaces to produce uniform finish, free of cross scratches.
  - 1. Run grain of directional finishes with long dimension of each piece.
  - 2. When polishing is completed, passivate and rinse surfaces. Remove embedded foreign matter and leave surfaces chemically clean.
  - 3. Directional Satin Finish: No. 4.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Examine floors for suitable conditions where metal storage shelving will be installed.
- C. Examine ceilings to which metal storage shelving will be attached for properly located blocking, grounds, or other solid backing for attachment of support fasteners.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Vacuum finished floor and wet mop resilient flooring over which metal storage shelving is to be installed.

3.3 INSTALLATION

- A. Install metal storage shelving level, plumb, square, rigid, true, and with shelves flat and free of dents or distortion. Make connections to form a rigid structure, free of buckling and warping.
  - 1. Install exposed connections with hairline joints, flush and smooth, using concealed fasteners where possible.
  - 2. Install braces, straps, plates, brackets, and other reinforcements as needed to support shelf loading and as required for stability.
  - 3. Adjust post-base bolt leveler to achieve level and plumb installation.
  - 4. Anchor shelving units to floor with floor anchors through floor plate. Shim floor plate to achieve level and plumb installation.
  - 5. Install seismic restraints.
  - 6. Connect side-to-side shelving units together.
  - 7. Install shelves in each shelving unit at spacing indicated on Drawings or, if not indicated, at equal spacing.

- a. Case-Type Metal Storage Shelving: Install adjustable shelf clips at front and back of each shelf.
- b. Four-Post Metal Storage Shelving: Install four clips, one at each post, for support of each shelf; with clips fully engaged in post perforations.
- c. Post-and-Beam Metal Storage Shelving: Install beams with beam-to-post connectors fully engaged in post perforations.

B. Accessories:

1. Install finished end panels and trim at exposed ends of shelving units.

3.4 ERECTION TOLERANCES

- A. Erect four-post metal storage shelving to a maximum tolerance from vertical of 1/2 inch (13 mm) in up to 10 feet (3 m) of height, not exceeding 1 inch (25 mm) for heights taller than 10 feet (3 m).
- B. Erect post-and-beam metal storage shelving to a maximum tolerance from vertical of 1/4 inch (6 mm) in 84 inches (2134 mm) of height.

3.5 ADJUSTING

- A. Adjust metal storage shelving so that connectors and other components engage accurately and securely.
- B. Adjust and lubricate operable components to operate smoothly and easily, without binding or warping. Check and readjust operating hardware.
- C. Touch up marred finishes or replace metal storage shelving that cannot be restored to factory-finished appearance. Use only materials and procedures recommended or furnished by metal storage shelving manufacturer.
- D. Replace metal storage shelving that has been damaged or has deteriorated beyond successful repair by finish touchup or similar minor repair procedures.

END OF SECTION 10 5613

SECTION 10 5620 – MOBILE STORAGE SHELVING UNITS (MECHANICAL ASSIST  
OPERATION)

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Mechanically assisted, carriage mounted high density mobile storage units, support rails, fabrication, and installation including leveling of support rails.
  - 2. 4-Post type shelving for use with high density mobile storage units.
- B. Related Work, Not Furnished:
  - 1. Structural floor system capable of supporting live and dead loads required by prevailing building codes, including rolling loads of storage units to be installed.
  - 2. Finish floor covering materials and installation.
- C. Related Sections:
  - 1. Section 033000 – Cast In Place Concrete

1.3 SYSTEM DESCRIPTION

- A. General: The system consists of storage units mounted on manufacturer's track-guided carriages to form a compact storage system. System design permits access to any single aisle by manually moving units until the desired aisle is opened. The carriage/rail system provides uniform carriage movement along the total length of travel, even with unbalanced loads.
- B. Carriage System Design and Features: The carriage system consists of a formed structural steel frame with hardened steel wheel riding on steel rails mounted to the floor. Rails and guidance shall ensure smooth operation and self-centering of mobile storage units during travel without end play or binding. All bearings used in the drive mechanism shall be permanently shielded and lubricated.
- C. Movement Controls: Triple arm operating wheels with rotating hand knobs shall be provided on the accessible (drive) ends of shelf units, centered on the end panel, located 39" from the base of each unit to permit units to be moved to create a single aisle opening. Turning the handle transmits power through a chain drive to drive wheels on each carriage.
- D. Drive System: The system shall be designed with a positive type mechanically-assisted drive which minimizes end play, ensures there is no play in the drive handle, and that carriages will stop without drifting.
  - 1. System shall include a chain sprocket drive system for each movable carriage to ensure that carriages move uniformly along the total length of travel, even with unbalanced

loads. All system components shall be selected to ensure a smooth, even movement along the entire carriage length.

2. Drive system gearing shall be designed to permit 1 lb. of force applied to the drive handle to move a minimum of 4,000 lbs. of load. Optional gear ratio to be provided which offer 1:6,000, 1:8,000 or 1:10,000.
3. A tensioning device shall be provided on each chain drive with provision for adjusting tension without removing end panels. Adjustments that require removal of end panels are not acceptable.
4. All bearings used in the drive mechanism shall be permanently shielded and lubricated.

E. Safety Features:

1. Color-coded visual indicators shall provide verification that carriages are in a locked or unlocked mode.
2. A single safety lock button, mounted on each operating wheel hub, will permit moving a carriage in either direction to create a new access aisle when pulled out (unlocked), or locking the carriage when pushed in.

F. Finishes:

1. Fabricated Metal Components And Assemblies: Manufacturer's standard powder coat paint finish.
2. End Panels, Accessible Ends: Plastic laminate, manufacturer's standard textures and patterns.

#### 1.4 PERFORMANCE REQUIREMENTS

- A. Ease of Movement: Provide mechanically assisted units capable of being moved by exerting a maximum horizontal force of 5 lbs. on the operating wheel.
- B. Seismic Performance: Provide mobile storage units capable of withstanding the effects of earthquake movement as required by applicable building codes.
- C. Seismic calculations prepared by a California certified structural engineer may be required to verify compliance.

#### 1.5 SUBMITTALS

- A. Product Data: Submit manufacturer's product literature and installation instructions for each type of shelving, track and installation accessory required. Include data substantiating that products to be furnished comply with requirements of the contract documents.
- B. Shop Drawings: Show fabrication, assembly, and installation details. Show complete extent of installation layout including clearances, spacing, and relation to adjacent construction in plan, elevation, and sections. Indicate clear exit and access aisle widths; access to concealed components; assemblies, connections, attachments, reinforcement, and anchorage; and deck details, edge conditions, and extent of finish flooring within area where units are to be installed.
  1. Show installation details at non-standard conditions. Furnish floor layouts, technical and installation manuals for every unit shipment with necessary dimensions for rail layout and system configuration at the project site. Include installed weight, load criteria, furnished specialties, and accessories.

2. Provide layout, dimensions, and identification of each unit corresponding to sequence of installation and erection procedures. Specifically include the following:
    - a. Location, position and configuration of tracks on all floors.
    - b. Plan layouts of positions of carriages, including all required clearances.
    - c. Details of shelving, indicating method and configuration of installation in carriages.
  3. Provide location and details of anchorage devices to be embedded in or fastened to other construction.
- C. Installer Certificates: Furnish signed certification by manufacturer attesting that installers comply with specified requirements. Submit manufacturer's certification that products comply with requirements of the contract documents.
- D. Maintenance Data: Provide in form suitable for inclusion in maintenance manuals for mobile storage units. Data shall include operating and maintenance instructions, purchase source listing, emergency instructions, and related information.
1. Submit manufacturer's instructions for proper maintenance and procedures.
  2. Submit manufacturer's printed instructions for maintenance of installed work, including methods and frequency recommended for maintaining optimum condition under anticipated use conditions. Include precautions against using materials and methods which may be detrimental to finishes and performance.

#### 1.6 QUALITY ASSURANCE

- A. All products, including rails, carriages, stationary platforms, operating controls and shelving to be fabricated by one manufacturer. Color selections for carriages, shelving and other components to be made from the same standard color selector of a single manufacturer. Mobile components and shelving components fabricated by different manufacturers will be disqualified. Warranty for all products to be from the same manufacturer.
- B. Installer Qualifications: Engage an experienced installer who is a manufacturer's authorized representative for the specified products for installing carriages and anchoring shelving units to carriages.
1. Minimum Qualifications: 3 years experience installing systems of comparable size and complexity to specified project requirements.
  2. Installers to be Factory Certified, employees of contractor. Installation by non-employees or other subcontractors are not permitted.

#### 1.7 DELIVERY, STORAGE AND HANDLING

- A. Follow manufacturer's instructions and recommendations for delivery, storage and handling requirements.

#### 1.8 PROJECT CONDITIONS

- A. Field Measurements: Verify dimensions before fabrication. Indicate verified measurements on Shop Drawings. Coordinate fabrication and delivery to ensure no delay in progress of the Work.



- B. Established Dimensions: Where field measurements cannot be made without delaying the Work, establish dimensions and proceed with fabricating mobile storage units. Coordinate construction to ensure actual dimensions correspond to established dimensions.

#### 1.9 SEQUENCING AND SCHEDULING

- A. Sequencing: Coordinate storage shelving system installation with other work to minimize possibility of damage and soiling during remainder of construction period.
- B. Scheduling: Plan installation to commence after finishing operations, including painting, have been completed.
- C. Pre-installation Conference: Schedule and conduct conference on project site to review methods and procedures for installing mobile storage units including, but not limited to, the following:
  1. Review project conditions and levelness of flooring and other preparatory work performed under other contracts.
  2. Review and verify structural loading limitations.
  3. Recommended attendees include:
    - a. Owner's Representative.
    - b. Prime Contractor or representative.
    - c. The Architect.
    - d. Subcontractors or installers whose work may affect, or be affected by, the work of this section.

#### 1.10 WARRANTY

- A. Provide a written warranty, executed by Contractor, Installer, and Manufacturer, agreeing to repair or replace units which fail in materials or workmanship within the established warranty period. This warranty shall be in addition to, and not a limitation of, other rights the Owner may have under General Conditions provisions of the Contract Documents.
- B. Warrant the entire movable compact shelving installation against defects in materials and workmanship for a period of five (5) years from date of acceptance by the Owner.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

- A. Products are based upon mobile shelving system products manufactured by Spacesaver Corporation, Fort Atkinson, WI. Other pre-approved manufacturers may be included.
- B. Local contact: Systems & Space, Inc., 500 Boulder Ct., Suite B, Pleasanton, CA 94566.  
Telephone: 925 621 3655, Fax: 925 426 0882, Email: etaylor@systemsnspace.com

2.2 BASIC MATERIALS

- A. General: Provide materials and quality of workmanship which meet or exceed established industry standards for products specified. Material thickness/gauges are manufacturer's option unless indicated otherwise.
- B. Plastic Laminates: NEMA LD-3, GP-28, Vertical Grade.

2.3 GROUT

- A. General: Provide non-shrink, non-staining hydraulic cement compound conforming to the following requirements, based on the performance of the test specimens at room temperature and in laboratory air.
  - 1. Linear Movement: No shrinkage while setting; maximum expansion limited to .002 inches per linear inch.
  - 2. Compressive Strength: Based on two inch cubes made following ASTM standards, tested on a Balding-Southward machine of 60,000 lbs. capacity, meet or exceed the following:
    - a. Age: 1 hour ---- 4,500 p.s.i.
    - 7 days ---- 8,000 p.s.i.

2.4 COMPONENTS

- A. Rails:
  - 1. Material: ASTM/AISI Type 1035 or 1045 steel, manufacturer's selection.
  - 2. Capacity: 1,000 pounds per lineal foot of carriage.
  - 3. Minimum Contact Surface: 5/8 inch wide.
  - 4. Rail configuration shall permit attachment to top of structural floor system with provision for leveling rails to compensate for variations in floor surface level.
  - 5. Provide rail connections designed to provide horizontal and vertical continuity between rail sections, to gradually transfer the concentrated wheel point load to and from adjoining rail sections. Butt joints are not permitted.
  - 6. Rails to be recessed in concrete
- B. Carriages:
  - 1. Carriage to be capable of supporting 1,000 lbs. minimum per carriage foot length. Carriages rated at 750 lbs. per carriage foot length are not acceptable.
  - 2. Provide manufacturer's design movable carriages fabricated of welded or bolted steel construction. Galvanized structural components and/or riveted carriages are unacceptable.
  - 3. Design carriages to allow the shelving uprights to recess and interlock into the carriages a minimum of 3/4 inch. Top mount carriages are unacceptable.
  - 4. Provide each carriage with two wheels per rail.
- C. Drive / Guide System:
  - 1. Design: Provide drive system which prevents carriage whipping, binding and excessive wheel/rail wear under normal operation.
    - a. If line shafts are used, all wheels on one side of carriage shall drive.
    - b. If synchronized drives are used, a minimum of one wheel assembly driving both sides of carriage at center location required. Drive shaft shall exhibit no play or

- looseness over the entire length of that assembly.
2. Shafts: Solid steel rod or tube.
  3. Shaft Connections: Secured couplings.
  4. Bearing Surfaces: Provide rotating load bearing members with ball or roller bearings. Provide shafts with pillow block or flanged self-aligning type bearings.
- D. Wheels:
1. Materials: Type 1045 solid steel. Minimum load capacity per wheel: 3200 lbs.
  2. Size: Minimum 5 inches, outside diameter drive wheels.
  3. Guides: Determined by manufacturer; minimum 2 locations.
- E. Face Panels:
1. Materials: Plastic laminate clad particle board with plastic edging on vertical edges.
  2. Finishes: Selected from manufacturer's standard available colors and patterns.
- F. 4-Post shelving:
1. Finishes: Selected from manufacturer's standard available colors and patterns.
  2. Design: Wedge-lock type consisting of uprights, shelves, and shelf supports, designed to be assembled without fasteners or clips. Shelves shall not have any holes on exposed surfaces. Front and back flanges shall be flush with outside faces of posts. Design shall permit individual shelf adjustment and/or removal anywhere along the entire height of uprights.
  3. Materials and Workmanship: Fabricate units from Class 1, cold-rolled steel sheet with all bends sharp and true and no exposed "knife" edges.
  4. All units shall be free of burrs, sharp edges and projecting hardware with smooth, non-abrasive surfaces and edges.
  5. After fabrication, shelving shall exhibit no dents, "oil canning", buckling or other surface irregularities.
  6. Uprights: Formed from steel sheet to a "tee" shape for intermediate supports and formed angles for end supports. Uprights shall have keyhole slots on inner wall only. Provide with closed sheet steel panels full height and depth for all uprights. Open uprights are not acceptable.
  7. Shelves: Form from sheet steel with flanges on all sides and return hem on front and back flanges. Ends shall be formed to clear inside of upright offset panels. Shelves shall be independently adjustable. Provide all shelves with slots for file dividers.
  8. Canopy Tops: Same construction as shelf units.
  9. Shelf Supports: Form from heavy gauge steel sheet with four solid steel shoulder rivets, two per ear, that interlock with inner wall of uprights.
  10. Shelf Reinforcements: Provide as required
  11. Nominal Shelf Dimensions: Standard Width: 36 inches, with 30, 42, or 48 inch sections used to meet project requirements. Shelf edge vertical profile to be 3/4 inch maximum. Vertical adjustment increment to be 1-1/2 inches. Width of intermediate uprights to be 2 inches.
  12. Number of vertical shelf openings to be 3.
  13. Vertical shelf-to-shelf spacing to be 39 3/4" Clear.
  14. Total System Height 10feet- 9 inches.
  15. Provide 20" deep shelves.
  16. Provide Oblique Garment Rods, one per opening
  17. The painting process is an electrostatically applied powder coating system using an epoxy-polyester hybrid powder paint. All over spray is collected and reused within the

self-contained application booths with no venting or emissions to the environment. The film is applied to an average thickness of 1 to 1.5 mils. The coated parts are then oven cured for 20 minutes at up to 450 degrees to provide a furniture quality finish. The hot parts are cooled to ambient temperature prior to packaging. After curing, the paint finish is inert and no volatile emissions are present. There are no fugitive (stray) emissions in the finished product.

18. Color to be selected from manufacturers standard color card.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine floor surfaces with Installer present for compliance with requirements for installation tolerances and other conditions affecting performance of mobile storage units.
- B. Verify that building structural system is adequate for installing mobile storage units at locations indicated on approved shop drawings.
- C. Verify that intended installation locations of mobile storage units will not interfere with nor block established required exit paths or similar means of egress once units are installed.
- D. Prepare written report, endorsed by Installer, listing conditions detrimental to proper performance of mobile storage units, once installed.

#### 3.2 INSTALLATION

- A. Rails:
  1. Lay out rails using full length units to the maximum extent possible. Use cut lengths only at ends to attain total length required. Locate and position properly, following dimensions indicated on approved shop drawings. Verify thickness of finished floor materials to be installed (by others) and install level 1/6 inch above finished floor surfaces.
  2. Verify level, allowing for a minimum 1/4 inch of grout under high points. Position and support rails so that no movement occurs during grouting.
  3. Set rails in full grout bed, completely filling any voids entire length of all rails including rail connectors. Trim up sides flush with rails to ensure proper load transfer from rail to supporting floor. Using shims in lieu of full grouting is not permitted.
  4. Installation Tolerances: Do not exceed levelness of installed rails listed below:
    - a. Maximum Variation From True Level Within Any Module: 3/32 inch.
    - b. Maximum Variation between Adjacent (Parallel) Rails: 1/16 inch, perpendicular to rail direction.
    - c. Maximum Variation in Height: 1/32 inch, measured along any 10 foot rail length.
  5. Verify rail position and level; anchor to structural floor system with anchor type and spacing indicated on approved shop drawings.
- B. Shelving Units Installation:
  1. General: Follow layout and details shown on approved shop drawings and manufacturer's printed installation instructions. Position units level, plumb; at proper location relative to adjoining units and related work.

2. Carriages: Place movable carriages on rails. Ensure that all wheels track properly and centering wheels are properly seated on centering rails. Fasten multiple carriage units together to form single movable base where required. Position fixed carriage units to align with movable units.
3. Shelving Units: Permanently fasten shelving units to fixed and movable carriages with vibration-proof fasteners. Stabilize shelving units following manufacturer's written instructions. Reinforce shelving units to withstand the stress of movement where required and specified.
4. Shelving units to have a minimum clearance of 18 inches to bottom of fire sprinkler head.

### 3.3 FIELD QUALITY CONTROL

- A. Verify shelving unit alignment and plumb after installation. Correct if required following manufacturer's instructions. Remove components which are chipped, scratched, or otherwise damaged and which do not match adjoining work. Replace with new matching units, installed as specified.

### 3.4 CLEANING

- A. Immediately upon completion of installation, clean components and surfaces.
- B. Remove surplus materials, rubbish and debris resulting from installation upon completion of work and leave areas of installation in neat, clean condition.

### 3.5 DEMONSTRATION / TRAINING

- A. Schedule and conduct demonstration of installed equipment and features with Owner's personnel.
- B. Schedule and conduct maintenance training with Owner's maintenance personnel. Training session should include lecture and demonstration of all maintenance and repair procedures that end user personnel would normally perform.

### 3.6 PROTECTION

- A. Protect system against damage during remainder of construction period. Advise Owner of additional protection needed to ensure that system will be without damage or deterioration at time of substantial completion.

END OF SECTION 10 5620

SECTION 10 7500 - FLAGPOLES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes ground-set flagpoles made from aluminum.
- B. Related Sections include the following:
  - 1. Division 03 Section "Cast-in-Place Concrete" for concrete footings for flagpoles.
  - 2. Division 07 Section "Joint Sealants" for elastomeric sealant filling the top of the foundation tube.

1.3 PERFORMANCE REQUIREMENTS

- A. Structural Performance: Provide flagpole assemblies, including anchorages and supports, capable of withstanding the effects of wind loads, determined according to NAAMM FP 1001, "Guide Specifications for Design of Metal Flagpoles."
  - 1. Base flagpole design on nylon or cotton flags of maximum standard size suitable for use with flagpole or flag size indicated, whichever is more stringent.
  - 2. Basic Wind Speed: 85 mph (38 m/s)
  - 3. 3-second gust speed at 33 feet (10 m) aboveground: 100 mph (45 m/s)

1.4 SUBMITTALS

- A. Product Data: For each type of flagpole required.
- B. Shop Drawings: Include elevations and details showing general arrangement, jointing, fittings and accessories, grounding, and anchoring and supporting systems.
  - 1. Include details of foundation system for ground-set flagpoles.
- C. Structural Calculations: For flagpoles indicated to comply with design loads, include structural analysis data signed and sealed by the qualified professional engineer responsible for their preparation.
- D. Finish Samples for Verification: For each finished material used for flagpoles and accessories.
- E. Qualification Data: For professional engineer.

1.5 QUALITY ASSURANCE

- A. Source Limitations: Obtain each flagpole as a complete unit, including fittings, accessories, bases, and anchorage devices, from a single manufacturer.
  - 1. Obtain flagpoles through one source from a single manufacturer.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. General: Spiral wrap flagpoles with heavy paper and enclose in a hard fiber tube or other protective container.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. American Flagpole; a Kearney-National Inc. Company.
  - 2. Baartol Company Inc. (The)
  - 3. Concord Industries, Inc.
  - 4. Eder Flag Manufacturing Company, Inc.
  - 5. Ewing International.
  - 6. Lingo Inc.; Acme Flagpole Division.
  - 7. Michigan Flagpole Inc.
  - 8. Morgan-Francis Div.; Original Tractor Cab Co., Inc.
  - 9. PLP Composite Technologies, Inc.
  - 10. Pole-Tech Company Inc.

2.2 FLAGPOLES

- A. Flagpole Construction, General: Construct flagpoles in one piece if possible. If more than one piece is necessary, comply with the following:
  - 1. Fabricate shop and field joints without using fasteners, screw collars, or lead caulking.
  - 2. For tapered flagpoles, provide flush hairline joints using self-aligning, snug-fitting, internal sleeves.
- B. Exposed Height: 35 feet (10.7 m).
- C. Aluminum Flagpoles: Provide cone-tapered flagpoles fabricated from seamless extruded tubing complying with ASTM B 241/ (B 241M), Alloy 6063, with a minimum wall thickness of 3/16 inch (4.8 mm). Heat treat after fabrication to comply with ASTM B 597, Temper T6.

- D. Foundation Tube: Galvanized corrugated-steel foundation tube, 0.064-inch- (1.6-mm-) minimum nominal wall thickness. Provide with 3/16-inch (4.8-mm) steel bottom plate and support plate; 3/4-inch- (19-mm-) diameter, steel ground spike; and steel centering wedges all welded together. Galvanize steel parts, including foundation tube, after assembly. Provide loose hardwood wedges at top of foundation tube for plumbing pole.

1. Provide flashing collar of same material and finish as flagpole.

### 2.3 FITTINGS

- A. Finial Ball: Manufacturer's standard flush-seam ball, sized as indicated or, if not indicated, to match flagpole-butt diameter.

1. 0.063-inch (1.6-mm) spun aluminum, finished to match flagpole.

- B. External Halyard: Ball-bearing, nonfouling, revolving truck assembly of cast metal with continuous 5/16-inch- (8-mm-) diameter, braided polypropylene halyard and 9-inch (228-mm) cast-metal cleats with fasteners. Finish exposed metal surfaces to match flagpole.

1. Provide one halyard and one cleat at each flagpole.

- C. Halyard Flag Snaps: Provide two stainless-steel swivel snap hooks per halyard.

1. Provide with neoprene or vinyl covers.

### 2.4 MISCELLANEOUS MATERIALS

- A. Concrete: Comply with requirements in Division 03 Section "Cast-in-Place Concrete" for normal-weight, air-entrained, ready-mix concrete with a minimum 28-day compressive strength of 3000 psi (20 MPa, unless otherwise indicated.)

- B. Sand: ASTM C 33, fine aggregate.

### 2.5 FINISHES

- A. Metal Finishes, General: Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.

- B. Aluminum: Finish designations prefixed by AA comply with the system established by the Aluminum Association for designating aluminum finishes.

1. Class I, Clear Anodic Finish: AA-M12C22A41 (Mechanical Finish: nonspecular as fabricated; Chemical Finish: etched, medium matte; Anodic Coating: Architectural Class I, clear coating 0.018 mm or thicker) complying with AAMA 611.



PART 3 - EXECUTION

3.1 PREPARATION

- A. Prepare uncoated metal flagpoles that are set in foundation tubes by painting below-grade portions with a heavy coat of bituminous paint.
- B. Foundation Excavation: Excavate to neat clean lines in undisturbed soil. Remove loose soil and foreign matter from excavation and moisten earth before placing concrete.
- C. Provide forms where required due to unstable soil conditions and for perimeter of flagpole base at grade. Secure and brace forms and foundation tube, sleeve, or anchor bolts in position, to prevent displacement during concreting.
- D. Place concrete immediately after mixing. Compact concrete in place by using vibrators. Moisture cure exposed concrete for not less than seven days or use nonstaining curing compound.
- E. Trowel exposed concrete surfaces to a smooth, dense finish, free of trowel marks, and uniform in texture and appearance. Provide positive slope for water runoff to perimeter of concrete base.

3.2 FLAGPOLE INSTALLATION

- A. General: Install flagpoles where shown and according to manufacturer's written instructions.
- B. Foundation-Tube Installation: Install flagpole in foundation tube, seated on bottom plate between steel centering wedges. Plumb flagpole and install hardwood wedges to secure flagpole in place. Place and compact sand in foundation tube and remove hardwood wedges. Seal top of foundation tube with a 2-inch (50-mm) layer of elastomeric joint sealant and cover with flashing collar.

END OF SECTION 10 7500

## **DIVISION 11 – EQUIPMENT**



SECTION 11 1100 - COMMERCIAL LAUNDRY EQUIPMENT

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following types of commercial laundry equipment:
  - 1. Washer-extractors.
  - 2. Drying tumblers.
  - 3. Laundry chemical dispensing systems.
  - 4. Ozone generators.
- B. Related Sections: The following sections contain requirements that relate to this Section:
  - 1. Division 22 Sections for plumbing connection requirements for equipment.
  - 2. Division 23 Sections for ventilation connection requirements for equipment.
  - 3. Division 26 Sections for electrical service and connections for equipment.

1.3 SUBMITTALS

- A. General: Submit the following according to Conditions of the Contract and Division 1 Specification Sections.
- B. Product data: For each laundry equipment type required indicating compliance with requirements. Provide complete operating and maintenance instructions for each equipment item.
- C. Shop drawings: For each type of laundry equipment showing plans, installation layout of equipment, elevations, details and rough-in requirements for power, gas, air, water supply, waste and exhaust, as applicable.
  - 1. Include foundation bolt layout for washer-extractors.
  - 2. Wiring Diagrams: Detail power and control wiring. Differentiate between manufacturer-installed and field-installed wiring. Include:
    - a. System schematic.
    - b. Point-to-point wiring diagram including location of connections.
- D. Warranties: Special warranties specified in this Section.
- E. Maintenance data: Provide operation and maintenance manuals as specified in Division 1, Section "Operation and Maintenance Data."
  - 1. Include the following:
    - a. Name, address and telephone number of manufacturer's nearest authorized service representative.
    - b. Parts listing.
    - c. Copies of warranties.

- d. Recommended maintenance cycles.
- e. Inspection procedures.
- f. Shop drawings and product data.
- g. Instruction for care of material finishes.

#### 1.4 QUALITY ASSURANCE

- A. Energy Ratings: Provide laundry equipment that carry labels indicating energy cost and analysis (estimated annual operating costs) and efficiency information as required by Federal Trade Commission.
- B. UL and NEMA Compliance: Provide electrical components required as part of laundry equipment that are listed and labeled by UL and comply with applicable NEMA standards.
- C. AGA and ANSI Standards: Provide gas-burning equipment that carry the design certification seal of the American Gas Association (AGA) and comply with ANSI Z21-Series standards.
- D. Single-Source Responsibility: Obtain laundry equipment from a single supplier.
  - 1. Provide products from the same manufacturer for each type of equipment required.
- E. Installer Qualifications: An employer of workers trained and approved by manufacturer for installation and maintenance of units required for this Project.
- F. Manufacturer Qualifications: A qualified manufacturer. Maintain, within 150 miles (241 km) of Project site, a service center capable of providing training, parts, and emergency maintenance repairs.
- G. Design Criteria: The drawings indicate sizes and dimensional requirements of laundry equipment and are based on the specific types and models indicated. Appliances by other manufacturers may be considered, provided deviations in dimensions and profiles are minor and do not change the design concept as judged by the Architect-Engineer. The burden of proof of equality is on the proposer.

#### 1.5 DELIVERY, STORAGE AND HANDLING

- A. Deliver anchoring devices, which must be set in concrete for installation of equipment. Coordinate delivery with other work to avoid delay.
- B. Deliver laundry equipment to the Project site in the manufacturer's protective packaging undamaged.
- C. Delay delivery of laundry equipment until utility rough-in is complete and construction in the spaces to receive equipment is substantially complete and ready for installation.

#### 1.6 WARRANTIES

- A. Warranty: Submit written warranties executed by the manufacturer of each equipment item specified agreeing to repair or replace units or components that fail in materials or workmanship within the specified warranty period.
  - 1. Washer-Extractor: Five-year warranty on the shell, frame, cylinder, shaft assembly and bearings and seals, two years on other parts, 90 days labor.

2. Clothes Dryer: Two-year parts and 90 day labor warranty.

- B. Warranties specified above shall not deprive the Owner of other rights the Owner may have under other provisions of the Contract Documents and will be in addition to and run concurrent with other warranties made by the Contractor under requirements of the Contract Documents.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide laundry equipment manufactured by one of the following:
1. Washer-Extractors:
    - a. UniMac.
    - b. Milnor.
    - c. Dexter.
  2. Drying Tumblers:
    - a. UniMac.
    - b. Milnor.
    - c. Dexter.
  3. Air Compressor, Laundry Chemical Dispensing System and Ozone Generator:
    - a. Continental Girbau, Inc.
    - b. EDRO Corp., Dyna Wash Division.
    - c. IPSO USA.
    - d. Pellerin Milnor Corporation.
    - e. Speed Queen; Alliance Laundry System LLC.
    - f. UniMac.

### 2.2 RIGID-MOUNT WASHER-EXTRACTORS

- A. Washer-Extractor: Front loading washer-extractor with microprocessor controls and variable extract speeds.
1. Capacity: 35 lbs minimum as indicated on Drawings.
  2. G-Force Rating (Min): 300.
  3. Automatic Supply: Furnish automatic supply injection with minimum five fittings for connecting tubes from remote liquid supply system. In addition to liquid supply fittings, provide a machine mounted, five-compartment automatic flushing supply injection for dry or liquid supplies.
  4. Ozone Generator Connection: Provide provision for attachment to ozone generator.
  5. Microprocessor Controls: Controls shall provide a minimum of 30 programmable formulas including a minimum of 5 pre-set, automatic wash programs.
    - a. Controls to allow formulas to be programmed for type of step, type of bath, step time, water level temperature, supply closings, rotation time, number of chemical injections, duration of chemical injection, extract time, and extract speeds.
    - b. Alphanumeric display to provide operating information and error messages.
  6. Electrical Requirements: 208V/60 Hz/3 Phase.
  7. Motor Rating: 3.7 HP.
  8. Basis of Design:
    - a. Alliance Laundry Systems, UniMac, Model UWN035T3V.

### 2.3 LIGHT COMMERCIAL WASHER

- A. Washer: Top loading washer.
  - 1. Capacity: 3.26 cu. ft. Basket Volume.
  - 2. Electrical Requirements: 120V/60 Hz/1 phase, 15 amp
  - 3. Motor Design: 0.5 HP.
  - 4. Color: White
  - 5. Basis of Design:
    - a. Alliance Laundry Systems, UniMac, Model UWNMN2SP112CW01.

### 2.4 DRYING TUMBLERS

- A. Gas-Drying Tumblers: Provide freestanding, front-loading drying tumbler with variable temperature controls and self-cleaning lint screen.
  - 1. Capacity: 50 lbs minimum.
  - 2. Input rating: 120,000 BTU/HR
  - 3. Electrical Requirements: 208V/60 Hz/3 Phase, 4.3 amp.
  - 4. Air Outlet Diameter: 8 inches.
  - 5. Exhaust Air Flow: 750 CFM.
  - 6. Basis of Design:
    - a. Alliance Laundry Systems, UniMac, Model UTO50.

### 2.5 LIGHT COMMERCIAL DRYER

- A. Dryer: Front Load.
  - 1. Capacity: 7 cu. ft. Cylinder Volume.
  - 2. Electrical Requirements: 120/208V/60 Hz/1phase, 30 amp.
  - 3. Color: White.
  - 4. Horse Power: 1/3HP.
  - 5. Motor RPM: 60Hz 1725
  - 6. Heat Source: Gas.
  - 7. BTU per hour: 25,000.
  - 8. Basis of Design:
    - a. Alliance Laundry Systems, UniMac, Model UDE809\*F.

### 2.6 AIR COMPRESSOR

- A. Furnish air compressor as required for air driven equipment. Size compressor for equipment CFM plus an additional 80lb and 50lb machine plus 25 percent. Size tank size at 3 to 5 times the CFM requirement.
  - 1. Electrical Requirements: 208V/60Hz/3 Phase.

### 2.7 LAUNDRY CHEMICAL DISPENSING SYSTEM

- A. Furnish automatic injection system complete with pumps, mounting brackets, hoses, etc. System shall be capable of automatically measuring and dispensing any type of chemical or liquid or powdered detergent.
  - 1. Provide system capable of dispensing six different products.
  - 2. Electrical Requirements: 120V/60Hz/1 Phase, 20 amp circuit.
  - 3. See Material Safety Data Sheet for list of approved Laundry Detergents for use in chemical dispensing system at the end of this specification.

## 2.8 OZONE GENERATOR

- A. Furnish wall mounted direct injection ozone laundry system capable of supplying a controlled amount of ozone directly injected into washer-extractor.
  - 1. Furnish with all accessories as required for mounting to wall and connecting to washer extractors.
  - 2. Electrical Requirements: 120V/60Hz/1 Phase 20 amp dedicated circuit.
- B. Acceptable manufacturers and products:
  - 1. EnviroCleanse Systems, Inc.; "ESI Series 1."
  - 2. Pacific Ozone Technology; "eCycle Ozone Generator."
  - 3. Wet Tech; "EnviroSaver II Ozone System."
  - 4. Nutek International, Inc.; "Ozone Laundry Support System."

## PART 3 - EXECUTION

### 3.1 PREPARATION

- A. Coordinate and furnish anchorages, setting diagrams, templates and instructions for installing anchor bolts that are to be embedded in concrete construction.
- B. Coordinate with other trades for proper location of roughing-in services and service connections specified elsewhere.

### 3.2 INSTALLATION

- A. General: Comply with manufacturer's instructions and recommendations.
- B. Built-In Equipment: Securely anchor base pads of washer-extractors to foundation with anchor bolts furnished by the laundry equipment supplier.
- C. Freestanding Equipment: Place units in final locations after finishes have been completed in each area. Verify that clearances are adequate to properly operate equipment.
- D. Utilities: Refer to Divisions 22, 23 and 26 for ventilation, plumbing and electrical service requirements.
  - 1. Final connections will be made by the Mechanical and Electrical Contractors.

### 3.3 ADJUSTING AND CLEANING

- A. Testing: Test each item of laundry equipment to verify proper operation. Make necessary adjustments.
- B. Accessories: Verify that accessory items required have been furnished and installed.
- C. Cleaning: Remove packing material from laundry equipment items and leave units in clean condition, ready for operation.

### 3.4 DEMONSTRATION



- A. Engage a factory-authorized service representative to train Owner's personnel in proper use, operations and daily maintenance of laundry equipment. Review emergency procedures to be followed at time of failure in operation. Train Owner's personnel in procedures to follow in identifying sources of operational failures or malfunctions.
  - 1. Video tape training and furnish tape to Owner.

3.5 COMMISSIONING

- A. Equipment installation and testing shall meet project commissioning requirements. Refer to 019113, General Commissioning Requirements.

END OF SECTION 11 1100

## MATERIAL SAFETY DATA SHEET MSDS F-112 REVISION 28

THE DIAL CORPORATION CENTER FOR INNOVATION MEDICAL EMERGENCIES: 1-888-689-9082 15101 NORTH SCOTTSDALE ROAD CHEMTREC: 1-800-424-9300 (24 Hours Daily) SCOTTSDALE, ARIZONA 85254 OTHER INFORMATION: 1-888-468-6673

### SUBSTANCE IDENTIFICATION

SUBSTANCE: TRADE NAMES/SYNONYMS:

CHEMICAL FAMILY:

I.D. NUMBERS: LIQUID LAUNDRY DETERGENTS—CLASSIC AND ULTRA

**Liquid Purex® Classic All Temperature Detergent—Original Fresh Scent/Aroma Fresco Liquid Purex® Classic All Temperature Detergent With Bleach Alternative— Original Scent Liquid Purex® Ultra Laundry Detergent—Original Fresh Scent/Aroma Fresco Liquid Purex® Ultra Laundry Detergent With Bleach Alternative—Original Scent Liquid Purex® Classic All Temperature Detergent—Free & Clear Liquid Purex® Ultra Laundry Detergent--Free & Clear Liquid Purex® Classic All Temperature Detergent--Lemon Fresh Liquid Trend® Classic All Temperature Detergent Liquid Trend® Classic All Temperature Detergent With Bleach Alternative Liquid Purex® Ultra Concentrated Laundry Detergent--Mountain Breeze Liquid Purex® Ultra Concentrated Laundry Detergent With Bleach Alternative-Mountain Breeze Liquid Purex® Classic All Temperature Detergent—Mountain Breeze/ Aroma Brisa De La Montaña Liquid Purex® Classic All Temperature Detergent With Bleach Alternative-Mountain Breeze Liquid Purex® Classic Baby Soft Laundry Detergent Liquid Purex® Ultra Baby Laundry Detergent Liquid Purex® Classic All Temperature Detergent--After The Rain Liquid Purex® Ultra Laundry Detergent—After The Rain Liquid Purex® Classic All Temperature Detergent--Sunshine Clean Liquid Purex® Ultra Laundry Detergent--Sunshine Clean Liquid Trend® Classic All Temperature Detergent--Paradise Breeze Liquid Trend® Classic All Temperature Detergent--Mountain Meadow Liquid Purex® Detergent with Bleach Alternative Liquid Purex® Mountain Breeze Liquid Purex® Mountain Breeze with Bleach Alternative Liquid Purex® After The Rain Liquid Purex® Free and Clear Liquid Purex® Liquid Purex® Sunshine Clean Liquid Purex® Baby Liquid Purex® plus Renuzit Super Odor Neutralizer Liquid Purex® Lavender Fresh**

Mixture

930098, 930108 (Classic Trend); 930099, 930109 (Classic Trend w/ Bleach Alt.); 99100929, 99100908, 99100897 (Purex Classic; Aroma Fresco); 99100934, 99100905, 99100885 (Purex Ultra); 99100935, 99100906, 99100898 (Purex Ultra w/Bleach Alt.); 99100930, 99100909, 99100884 (Purex Classic w/Bleach Alt.); 99100931, 99100904, 99100894 (Purex Classic Free & Clear); 99100939, 99100907, 99100900 (Purex Ultra Free & Clear HDL); 99101081 (Purex Lemon Fresh); 99100940, 99100913, 99100886 MSDS F-112 (Rev. 28) (Purex Ultra Mountain Breeze); 99100941, 99100914, 99100887 (Purex Ultra Mountain Breeze w/Bleach Alternative); 99100932, 99100910, 99100888 (Classic Purex Mountain Breeze; Aroma Brisa De La Montaña); 99100933, 99100911, 99100889 (Purex Classic Mountain Breeze w/Bleach Alternative); 99100902 (Purex Classic Baby Soft); 99100901 (Purex Ultra Baby); 99100943, 99100919, 99100891 (Purex Classic After the Rain); 99100942, 99100917, 99100899 (Purex Ultra After the Rain); 99101228, 99101289, 99101292 (Purex Classic Sunshine Clean); 99101227, 99101288, 99101291 (Purex Ultra Sunshine Clean); 99101689, 99101696 (Classic Trend Paradise Breeze); 99101690, 99101697 (Classic Trend Mountain Meadow) 99101831, 99101840, 99101848 Purex Liquid Detergent with Bleach Alternative); 99101832, 99101841, 99101850 (Purex Mountain Breeze Liquid); 99101833, 99101842, 99101851 (Purex Mountain Breeze Alternative Liquid); 99101834, 99101843, 99101852 (Purex After the Rain Liquid Detergent); 99101835, 99101838, 99101849 (Purex Free and Clear); 99101836, 99101839, 99101847 (Purex Liquid); 99101837, 99101845 (Purex Sunshine Clean Liquid); 99101856 (Purex Baby Liquid); 99102193; 99102309 (Purex Liquid w/Renuzit); 99101941, 99101942, 99101943 (Lavender Fresh)

NFPA RATINGS (Scale 0-4, where 4=high degree of hazard): HEALTH=1 FLAMMABILITY= 0 REACTIVITY= 0 HMIS RATINGS (Scale 0-4, where 4=severe hazard): HEALTH=1 FLAMMABILITY= 0 REACTIVITY= 0

This product is labeled in accordance with regulations administered by the Consumer Product Safety Commission. The use pattern and exposure in the workplace are generally not consistent with those experienced by consumers. The requirements of the Occupational Safety and Health Administration applicable to this Material Safety Data Sheet differ from the requirements of the CPSC and as a result, this MSDS may contain additional health hazard information not pertinent to consumer use and not found on the product label.

### HAZARDOUS INGREDIENTS INFORMATION

Carcinogen status of components: Not listed as carcinogenic by NTP, IARC, or OSHA.

### PHYSICAL AND CHEMICAL DATA

DESCRIPTION: Clear to pale yellow or clear blue liquid with a pleasant odor.

COMPONENT: ALCOHOL ETHOXYLATE	CAS# 68551-12-2
COMPONENT: SODIUM CARBONATE	CAS# 497-19-8
COMPONENT: SODIUM DODECYLBENZENESULFONATE	CAS# 68584-22-5
COMPONENT: SODIUM LAURETH SULFATE	CAS# 9004-82-4
SPECIFIC GRAVITY: 1.040-1.065 @ 25 °C	VISCOSITY: 150-350 cps @ 25°C
pH: 10.1-11.1 (as is @ 25 °C)	SOLUBILITY IN WATER: Complete
CLOUD POINT: 0-45°F	

### FIRE AND EXPLOSION DATA

FIRE AND EXPLOSION HAZARD – Negligible fire hazard.

FIRE FIGHTING MEDIA -Dry chemical, carbon dioxide, water spray or regular foam.

FIRE FIGHTING -Move container from fire area if you can do it without risk. Do not scatter spilled material with high-pressure water streams. Dike fire-control water for later disposal. Use agents suitable for type of surrounding fire. Avoid breathing hazardous vapors, keep upwind.

COMPONENT: ALCOHOL ETHOXYLATE	CAS# 68551-12-2
COMPONENT: SODIUM CARBONATE	CAS# 497-19-8
COMPONENT: SODIUM DODECYLBENZENESULFONATE	CAS# 68584-22-5
COMPONENT: SODIUM LAURETH SULFATE	CAS# 9004-82-4
SPECIFIC GRAVITY: 1.040-1.065 @ 25 °C	VISCOSITY: 150-350 cps @ 25°C
	SOLUBILITY IN WATER: Complete

## HEALTH HAZARD DATA

NOTE: The acute health effects described below are those, which could potentially occur for the finished product. They are based on the toxicology information available for the finished product and/or each hazardous ingredient, and are consistent with the product type and the likelihood of a specific route of exposure. Known chronic health effects related to exposure to a specific ingredient are indicated.

**ACUTE HEALTH EFFECTS: INHALATION:** Unlikely to occur given the physical properties of the product. Mists may cause respiratory tract irritation. **SKIN CONTACT:** Repeated or prolonged excessive exposure can result in defatting and drying of the skin which may result in irritation and dermatitis. **EYE CONTACT:** May cause moderate to severe irritation, with possibility of corneal injury if not removed promptly.

**INGESTION:** Large quantities may cause nausea, vomiting, abdominal pain, diarrhea, and lethargy. **CHRONIC HEALTH EFFECTS:** None known. **MEDICAL CONDITIONS GENERALLY RECOGNIZED AS BEING AGGRAVATED BY EXPOSURE:** Persons with

history of chronic skin conditions.

## EMERGENCY AND FIRST AID PROCEDURES

**INHALATION:** Remove from exposure area to fresh air immediately. Keep affected person warm and at rest. Treat symptomatically and supportively. Contact physician or local poison control center. If breathing has stopped, give artificial respiration, and get medical attention immediately.

**SKIN CONTACT:** Rinse affected area with plenty of water until no evidence of product remains. Get medical attention if irritation persists.

**EYE CONTACT:** Immediately rinse eyes with plenty of water, occasionally lifting upper and lower lids, until no evidence of product remains. Get medical attention if pain or irritation persist.

**INGESTION:** Treat symptomatically and supportively. Maintain airway and respiration. If vomiting occurs, keep head below hips to prevent aspiration. Dilution by rinsing the mouth and giving water or milk to drink is generally recommended. If unconscious, the victim should not be given anything to drink. Contact physician or local poison control center.

## REACTIVITY

REACTIVITY -Stable under normal temperatures and pressures. INCOMPATIBILITIES -Strong oxidizers and reducing agents. DECOMPOSITION -Thermal decomposition products may include toxic oxides of sulfur and carbon, and hydrogen sulfide.

POLYMERIZATION -Hazardous polymerization has not been reported to occur under normal temperatures and pressures.

## STORAGE AND DISPOSAL

Store away from incompatible substances and excessive heat. Observe all federal, state and local regulations when storing or disposing of this substance.

## CONDITIONS TO AVOID

Avoid contact with incompatible substances or excessive heat.

## SPILL AND LEAK PROCEDURES

OCCUPATIONAL SPILL -Stop leak if you can do it without risk. For small spills, take up with sand or other absorbent material and place into clean, dry containers for later disposal. For larger spills, dike far ahead of spill for later disposal. Keep unnecessary people away and isolate hazard area.

## OCCUPATIONAL PROTECTIVE EQUIPMENT

VENTILATION -Provide local exhaust or general dilution ventilation to keep potential exposure to airborne contaminants as low as possible.

RESPIRATOR -None required under normal use conditions.

FOR FIRE FIGHTING AND OTHER IMMEDIATELY DANGEROUS TO LIFE OR HEALTH CONDITIONS Any self-contained breathing apparatus that has a full facepiece and is operated in a pressure-demand or other positive-pressure mode. Any supplied-air respirator that has a full facepiece and is operated in a pressure-demand or other positive-pressure mode in combination with an auxiliary self-contained breathing apparatus operated in pressure-demand or other positive-pressure mode.

CLOTHING -Protective clothing (impervious to liquids) is required where splashing of product may occur.

GLOVES -Chemical-resistant gloves are required where repeated or prolonged skin contact may occur.

EYE PROTECTION -Splash-proof safety glasses are required to prevent eye contact where splashing of product may occur.

## REGULATORY INFORMATION

DOT FLAMMABILITY CLASSIFICATION: Not applicable.

EPA -SARA TITLE III SECTION 313: Not applicable -Consumer product.

All components of this product are listed or are exempted or excluded from listing on the U.S. Toxic Substances Control Act (TSCA) chemical substance inventory.

The information contained herein is provided in good faith and is believed to be correct as of the date hereof. However, The Dial Corporation makes no representation as to the comprehensiveness or accuracy of the information. It is expected that individuals receiving the information will exercise their independent judgment in determining its appropriateness for a particular purpose. Accordingly, The Dial Corporation will not be responsible for damages of any kind resulting from the use of or reliance upon such information. No representations, or warranties, either expressed or implied of merchantability, fitness for a particular purpose or of any other nature are made hereunder with respect to the information set forth herein or to the product to which the information refers.

MSDS CREATION DATE: 02/04/94 SUPERCEDES: Rev. 27, 11/8/05 REVISION DATE: 3/20/06 REVISION: Added ID number and updated Physical and Chemical Data..

SECTION 11 400 – FOODSERVICE EQUIPMENT

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This section includes of furnishing all labor and material required to provide and deliver all food service equipment herein specified into the building, uncrate, assemble, set-in-place, level and completely install, exclusive of final utility connections.
- B. Furnish all material and labor required to completely provide, deliver and install all Food Service Equipment as specified herein and as shown on the drawings. This work shall be in strict accordance with the plans and specifications with all dimensions verified in the field prior to any fabrication.
  - 1. Coordinate the Food Service Equipment work with the respective trades performing preparatory work for the installation of the Food Service Equipment.
  - 2. Comply with all Federal, State and Municipal regulations which bear on the execution of this project. Food service aisles shall be a minimum of 36” wide and tray slides shall be mounted at 34” maximum above the finished floor. Food service equipment required to be accessible shall conform to all reach requirements in CDC 1104B-5, 1104B-6 and figures 11B-16 and 11B-17.
- C. Work Includes:
  - 1. Materials shown on the Food Service Equipment Schedule.
  - 2. Piping, valves, and plumbing accessories that is integral within the equipment.
  - 3. Furnishing control devices such as solenoid valves that are not integral with the equipment, for installation by Mechanical division 15 and/or Electrical Division 16.
  - 4. Wiring, wiring devices, controls and mechanical accessories that are integral in the equipment.
  - 5. Ventilating ducts, flues, controls and mechanical accessories that are integral in the equipment.
  - 6. Anchors, fasteners, fillers and sealants for mounting equipment securely in place.
  - 7. Cooperation with all other contractors on the job including the furnishing of information in the form of drawings, wiring diagrams and other data.
  - 8. Touch-up painting after the installation of the food service equipment.

- D. Related Sections include the following:

1. Division 15 Mechanical
2. Division 16 Electrical

### 1.3 QUALITY ASSURANCE

#### A. QUALIFICATIONS:

1. Installer: Regularly engaged in providing food service equipment from manufacturers of this type of equipment a minimum of 5 years with at least 5 installations of this size and type that are at least each 3 years old.

#### B. STANDARD OF MANUFACTURE

1. Food service equipment that is specified as "custom" having no manufacture name or model number shall be manufactured by a Food Service Equipment Fabricator with at least five (5) years' experience with engineering, design and fabrication of food service equipment. The manufacture shall be subject to the review of the Architect and/or Consultant and shall be approved by the National Sanitation Foundation. All Fabricated equipment shall be constructed in strict compliance with the latest standards of the National Sanitation Foundation and shall bear the mark of the National Sanitation Foundation in full compliance with all applicable codes and ordinances.
2. All electrically heated or operated equipment shall bear the seal of approval of the Underwriters Laboratories, and shall comply with the National Electrical Code and all local Codes and Ordinances.
3. All food service equipment that is specified as "buy-out" having a specific manufacture name and model number shall comply with the latest editions of the National Sanitation Foundation.
4. All Gas heated or operated equipment shall be the seal of approval of the American Gas Association (AGA)
5. All Steam heated or operated equipment shall conform to the standard of the American Society of Mechanical Engineers (ASME) and shall be ASME approved.
6. Food shields and Sneeze guards shall meet all the requirements of National Sanitation Foundation (NSF) Standard 2.

### 1.4 SUBMITTALS

- A. See Section 01300 - Administrative Requirements, for submittal procedures.

#### B. SHOP DRAWINGS / EQUIPMENT BROCHURES

1. No ordering or fabrication of equipment shall take place until such time as the equipment brochures and shop drawings have been reviewed in writing by the Architect and/or Consultant. Receipt of this review shall not relieve the Contractor from the responsibility of verifying all quantities and related dimensions, maintaining the specified quality of equipment, and verifying conditions of the job site.

2. Equipment Brochures; within twenty (20) calendar days after award of the contract, six (6) brochures containing manufacturers specification sheets, dimensioned drawings and/or other pertinent data describing all items of standard manufacture shall be submitted for review by the Architect and/or Consultant. Sheets with the notation "Fabricated Item" and name of the fabricated item, as well as any required mechanical, plumbing or electrical requirements shall be inserted between the manufacturer's specification sheets describing the "buy-out" equipment; thus giving a complete brochure with all times accounted for. These brochures shall have hard white covers with clear transparent overlays and locking rings. The name of the Contractor, Architect, Consultant and project clearly identified in large readable type. Failure to provide brochures in the manner as described above will be cause for rejection of said brochures.
3. Rough-in and Equipment Location Drawings; within thirty (20) calendar days after award of the contract, six (6) sets of bond prints of complete rough-in and details for electrical and plumbing services with both vertical and horizontal dimensions, from column center-lines or exterior walls for location said connection points and rough-in locations shall be submitted for review by the Architect and/or Consultant. Equipment location plans shall be drawn to scale of not less than 1/4" = 1'-0" and include a schedule of equipment clearly identifying all items. Minimum drawings size shall be 24"x 36".
4. Shop Drawings; within thirty (30) calendar days after award of the contract, six (6) sets of bond prints of shop fabrication drawings shall be submitted for review by the Architect and/or Consultant. Plans shall be drawn to scale of not less than 1/2"=1'-0". Additional plan views, elevations and sections at 3/4"=1'-0" shall be supplied of all counters and tables with complete dimensions. All shop practices regarding joints, gussets, bracing, tie-downs, supports, etc. shall be clearly defined as well as gauges and quality of metals and brands and model numbers of all miscellaneous fittings, plumbing and electrical trim. The drawings shall also show locations of blocking (supplied under another sections) for all wall and ceiling mounted Food Service Equipment. Minimum drawings size shall be 24"x36".

C. SAMPLES

1. Provide all samples if specification requested.

D. SUBSTITUTIONS:

1. Manufacturer's listed in this section are used as standards for quality. All Substitutions shall be approved by the Architect and/or Consultant prior to installation.
2. Refer to Division 1 - General Requirements for procedures governing substitutions
3. Only one substitution for each item will be considered.
4. Installation of any qualified substituted equipment is the Food Service Equipment Contractor's responsibility. Including any mechanical, electrical, structural changes required for the installation of qualified substitution shall be without additional cost to the Owner.

1.5 DISCREPANCIES:



- A. In the event of discrepancies within the Contract Documents, the Architect and/or Consultant shall be so notified in sufficient time prior to bid opening, ten (10) days to allow issuance of an addendum.
- B. In the event that time does not permit notification or clarification of discrepancies prior to the bid opening, following shall apply: The drawings and drawing schedules shall govern in matters of quantity; the specifications in matter of quality. In the event of conflict within drawings involving quantities, or within the specifications involving quality, the greater quantity and high quality shall apply. Such discrepancies shall be noted and clarified in the contractors bid. No additional allowances will be made because of errors, ambiguities or omissions which reasonable should have been discovered during the preparation of the bid.

1.6 RESPONSIBILITY:

- A. The work as specified in this division shall include assuring that all required submittals conform to the intent and meaning of the documents, conditions at the job site, and all local codes and ordinances.
- B. Visit the job site to field check actual wall dimensions and utility rough-ins. Be responsible for furnishing, fabricating, and installing the equipment in accordance with the available space and utility services as they exist on the job site.
- C. Check all door openings, passageways, elevators, etc., to verify that the equipment can be transported to its proper location within the building. If necessary check the possibility with the General Contractor of holding wall erection, placement of doorjamb, window, etc. for the purpose of moving equipment to its proper location.
- D. Notify the Architect and/or Consultant of any discrepancies between the plans and specification prior to fabrication of any equipment, to actual condition on the job.
- E. If any special hoisting equipment and operators are required, include cost as part of the bid for this work.

1.7 DELIVERY AND STORAGE

- A. All equipment specified herein shall be delivered to the job site; received and handled by the Contractor or his authorized agent. The Owner shall in no way be expected to store or handle any such equipment.
- B. All equipment shall be delivered in such a manner as to protect it against dirt, water, chemical or mechanical injury.
- C. Throughout the progress of the work, the Contractor shall keep the working area free of debris of all types resulting from his work.
- D. All packing material shall be removed from the project location by the Contractor.

1.8 COORDINATION

- A. Coordinate work with mechanical, electrical, plumbing, interiors and other trades whose work is in conjunction with equipment specified herein.

1.9 MEASUREMENTS

- A. Verify all dimensions shown on the drawings by taking field measurements at the job site prior to fabrication of equipment or ordering equipment. Proper fit and attachment of all parts is required and is the sole responsibility of the Food Service Contractor. If necessary, all equipment shall be fabricated so that it may be handled through finished door openings.

#### 1.10 GUARANTEE / WARRANTY

- A. All work shall be guaranteed by the Foodservice Equipment Contractor against all defects for a term of one (1) year from the date of notice of completion. This guarantee shall cover replacement of defective material at the Foodservice Equipment Contractor expense, including transportation and labor. This guarantee will not cover any cost for replacement of parts or work made necessary by carelessness or misuse of the equipment by others.
- B. The Food Service Equipment Contractor shall provide at his own expense the installation, start-up and service for one (1) year from the date of recording the notice of completion of the project; the replacement of all condensing units and other refrigeration devices supplied under this contract. In addition to this one (1) year free service, the condensing units shall have a five (5) year compressor warranty; said warranty commencing at the date of completion.

### PART 2 PRODUCTS

#### 2.1 MATERIALS

- A. Metal for construction purposes, where entirely concealed, shall be steel of wrought iron sections galvanized by the hot-drip process after fabrication. Bolts, screws, rivets, and similar attachments to this galvanized work shall be galvanized or brass. Exposed screw and rivet work shall be finished to match adjacent surfaces, flush and buffed smooth. Finished work shall be free of tool or construction marks, dents, or other imperfections; and at the completion of the work, all metal shall be gone over with a portable machine and buffed and dressed to perfect surfaces.
- B. All materials shall be new and of first grade. All gauges specified herein shall be minimum and shall be established after polishing. They shall refer to:
  - 1. U.S. Standard Gauge for sheets and plates.
  - 2. Stainless steel shall be manufactured by one of the following: Allegheny Ludlum Steel Corporation, American Rolling Mills, U.S. Steel Corporation.
- C. The Contractor will be required to furnish a certified copy of the mill analysis of materials to the Architect and/or Consultant.
- D. Stainless steel sheets shall conform to ASTM A240, Type 304 Condition A, 18-8 having a No. 4 finish. No.2B finish shall be acceptable on surfaces of equipment not exposed to view. All sheets shall be uniform throughout in color, finish and appearance.
- E. Stainless steel tubing and pipe shall be Type 304, 18-8, having a No. 4 finish, and shall conform to either ASTM A213 if seamless or ASTM A249 if welded.

- F. Galvanized steel shall be approved grade of copper-bearing steel sheets with a minimum copper content of 20%. All sheets to be commercial quality, stretcher leveled, bonderized and re-rolled to insure smooth surface. Galvanized steel shall not be allowed in the construction and fabrication of any "Fabricated Assembly" items.
- G. All millwork materials shall be free from defect impairing strength, durability, or appearance; straight and free from warpage; and the best grade for their particular function. All wood shall be well seasoned and kiln dried and shall have an average moisture content of 8%, a maximum of 10%, and a minimum of 5%.
- H. Plywood and other woodwork of treatable species, where required by code, shall be fire-retardant treated to result in a flame spread rating of 25 or less with no evidence of significant progressive combustion when tested for 30 minutes duration under ASTM E-84 and shall bear the testing laboratory mark on the surface to be concealed.
- I. Concealed softwood or hardwood lumber shall be of poplar, Douglas fir, basswood, red oak, birch, maple, beech or other stable wood and shall be select or better grade, unselected for color and grain, surfaced four sides, square-edged, and straight. Basswood may be used where fire-retardant treated materials are required.
- J. Face veneers shall be matched for color and grain to produce balance and continuity of character. Mineral streaks and other discolorations, wormholes, ruptured grain, loose texture, doze or shake will not be permitted. Face veneer leaves on each surface shall be full-length, book matched, center matched and sequence matched. Surfaces shall be sequenced and blueprint matched. Veneers not otherwise indicated shall be plain sliced. Backing veneers for concealed surfaces shall be of a species and thickness to balance the pull of the face veneers.
- K. Hardwood plywood for painted surfaces shall conform to U.S. Product Standard PS -51-71, Type I, and shall have sound birch, maple or other approved close grain hardwood faces suitable for paint finish.
- L. Plastic laminate surfaces shall be laminated with thermosetting decorative sheets in the color, pattern and style as selected by the Architect. Horizontal surfaces shall be laminated with sheets conforming to Federal Specifications L-P-508F, Style D, Type I (general purpose), Grade HP, Class I, 1/16" thick, satin finish with rough sanded backs. Vertical surfaces shall be laminated with sheets conforming to Federal Specification L-P-598F, Style D, Type II (vertical surface), Grade HP, Class I, conforming, satin finish, 1/32" thick or heavier. Balance sheets for backs in concealed locations shall be .020" thick laminate backing sheets conforming to Federal Specification L-P-00508E, Style ND, Type V (backing sheet), Grade HP.
- M. Adhesive for application of plastic laminate to wood surfaces of counter tops shall be phenolic, resorcinol or melamine adhesive conforming to Federal Specification MMM-A-181C and producing a waterproof bond. Adhesive for applying plastic laminate to vertical surfaces shall be either a waterproof type or a water-resistant type such as a modified urea formaldehyde resin liquid glue conforming to Federal Specification MMM-A-188C. Contact adhesive will not be acceptable.
- N. Plate glass shall be 1/2" thick safety glass with polished edges.
- O. Sealant shall be equal to that manufactured by General Electric. Silicone construction 1200 sealant; in either clear or approved color to match surrounding surfaces.

- P. Sound deadening material shall be equal to that manufactured by H.W. Mortell Co., Kankakee, Illinois, and shall be sprayed by use of a mechanical device to a thickness of not less than 1/8" thick.

## 2.2 FINISHES

- A. Paint and coatings shall be of an NSF approved type suitable for use in conjunction with food service equipment. Such paint or coating shall be durable, non-toxic, non-dusting, non-flaking and mildew resistant, shall comply with all governing regulations and shall be applied in accordance with the recommendations of the manufacturer.
- B. All exterior, galvanized parts, exposed members of framework where specified to be painted shall be cleaned, properly primed with rust inhibiting primer, degreased, and finished with two (2) coats of epoxy-based grey hammertone paint, unless otherwise specified.
- C. Stainless steel, where exposed, shall be polished to a #4 commercial finish. Where unexposed, finish shall be #2B. The grain of polishing shall run in the same direction wherever possible. Where surfaces are disturbed by the fabricating process, such surfaces shall be refinished to match adjacent undisturbed surfaces.

## 2.3 SHOP FABRICATED EQUIPMENT CONSTRUCTION

- A. Leg stands for open base tables or dish tables shall be constructed of 1-5/8" dia. 16 gauge stainless steel tubing, with stringer and cross braces of the same material. Joints between legs and cross braces shall be welded and ground smooth. Flattened ends on tube stretchers are not permitted. Mechanical fittings are also not permitted.
1. Stainless Steel Leg Sockets: Component Hardware Group, Inc. model A18-0206, or accepted equal; weld to underside of counter top framing or at bottom of enclosed cabinet unit, and fastened with flush set screw locking device.
  2. Sanitary Type Stainless Adjustable Foot: Component Hardware Group, Inc. model A10-0851, or accepted equal
- B. Table tops shall be 14-gauge stainless steel unless otherwise noted, with all shop seams and corners welded, ground smooth and polished. Tops of closed base fixtures shall be reinforced on the underside with a framework of 1-1/2" angles or 16-gauge stainless steel hat section; and on open pipe frames with a 4" channel at each pair of legs. The leg sockets shall be welded to this channel. The channel in turn stud welded to the top. Tops shall be reinforced so that there will be any noticeable deflection. Unless otherwise shown on the detail drawings, metal tops shall be turned down 2", and back at 15 degree angle, with 1-1/8" turn-under, except where adjacent to walls or other pieces of equipment. The wall side shall be turned up 10" and back 2" at a 45-degree angle. Ends of this splash are to be closed. Free corner of tops shall be spherical. All tops shall have 1/8" of sound-deadening material applied to the underside by use of spray equipment in an oven, smooth application for ease in cleaning.
- C. Enclosed bases or cabinet bodies shall be of the material and gauge hereinafter specified. They shall be enclosed on the ends and sides as required. The bases shall be reinforced at the top with a framework of 1-1/2" x 1-1/2" x 1/8" stainless steel angles fully welded to the base with the stainless steel angles 36" on center (maximum), with all corners of said framework mitered and fully welded. All vertical joints of the bases shall be fully welded, ground and polished. All free corners of enclosed bases or cabinet bodies and

all corners against walls and other fixtures shall be square. In the case of fixtures fitting against or between walls, the bodies shall be set in 1" from the wall line, but the tops shall be extended back to the wall line to permit adjustment to wall irregularities. A flush fitting vertical trim strip (extension of the vertical end mullion without vertical seam of the same material as the body shall be provided at each end of the body, and shall extend 1" to the wall line). These fixtures shall be constructed to set on bases or legs as hereinafter specified, and shall be set in mastic in a vermin-proof manner.

- D. Shelves, mullions and aprons shall be fabricated flush with the cabinet body, welded, ground, and polished. Butt joints are not acceptable.
- E. Drawers, to be furnished with stainless steel flush pull, Component Hardware Group Inc., model number P63-1012 or equal installed into the 18 gauge double-pan drawer front panel.
  - 1. Stainless steel locks, Component Hardware Group, Inc., model number P30-4781 or equal for each drawer. All drawers are to be keyed alike.
  - 2. Stainless Steel full extension slides, Component Hardware Group, Inc., model no S52-0024 or equal. Provide two (2) per drawer. Slides to be installed so drawer will roll closed when released.
  - 3. Stainless steel removable drawer pan, Component Hardware Group, Inc., model number, S81-1520 or equal one (1) per drawer set loosely in a channel frame so it can be easily lifted out for cleaning. This supporting frame shall be welded stainless steel channel.
  - 4. Drawer face panel to be constructed of 18 gauge stainless steel double pan construction. (Single metal thickness drawer faces are not be expectable.)
- F. Hinged doors in base cabinets shall be of double pan construction, insulated and constructed of 18 gauge stainless steel. Doors shall have wire type pull Component Hardware Group Inc., model number P46-1010 or equal installed as shown in elevations. Door pulls to be NSF and ADA compliant.
- G. Interior shelves shall be solid, non-removable 16-gauge stainless steel, with ends and backs provided with a 1-1/2" high turn-up against the body of the fixture and welded to the same. Front edge is to be turned down 1-1/2" and under 1/2", at the bottom shelf, beyond the edge of the base to prevent sagging and vermin collection.
- H. Under shelves on open tables shall be constructed of 16 gauge stainless steel, flanged down 90 degrees 1/2". The corners shall be welded to the legs. Under shelves shall be 10" from the floor. Backs shall be turned up 2".
- I. Elevated shelves shall be constructed of 16 gauges stainless steel with edges turned down in a square edge, and back 1/8"; except where shelves are adjacent to walls or other fixtures, where they shall be turned up 2". Corners shall be spherical, mounted on 14 gauge stainless steel support brackets.
- J. Sinks and drain boards shall be constructed of 14 gauge stainless steel. The working edge of the sink shall be provided with 5/8" radius sanitary rolled edge in one piece with rounded corners. The drain boards shall be made as an integral part of the sink; all vertical and horizontal corners shall be rounded with 5/8" radius; and the working front edges shall be maintained at one level, taking up the pitch of the drain boards by dropping the sink to allow for same. Depth of sink bowl shall be determined from the top

bowl. Sinks shall be provided with back and end splashes with top edge flanged back 2-1/4" at 45-degree angle, and attached to the building wall with "zee" clips. Splash back of sinks and drain boards shall be grained in the same direction. Suitable openings shall be cut for hot and cold water supplies and waste outlets. All surface plumbing trim as called for on the drawings and herein specified shall be provided. Bottom of each sink bowl with center drain connection shall be fitted with a 2" lever type action waste valve mounted into the sink and made absolutely watertight. Sink bowls and drain boards shall have 1/8" of sound-deadening material underneath, spray-applied.

- K. Rivets, bolts and screws shall not be permitted in any exposed location.
- L. All welding shall be of the heliarc method with welding rod of the same composition as the parts welded. Welds shall be complete, strong, and ductile with excess metal ground off and joints finished smooth to match adjoining surfaces. Welds shall be free of mechanical imperfections and shall be continuously welded so that the fixture shall appear as one-piece construction. Butt welds made by spot solder and finished by grinding are not acceptable.
- M. All exposed joints shall be ground flush with adjoining material and finished to harmonize therein. Whenever material has been sunk or depressed by welding operation, such depressions shall be suitably hammered and peened flush with the adjoining surface and, if necessary, again ground to eliminate low spots. In all cases, the grain of rough grinding shall be removed by successive fine polishing operations.
- N. All exposed welded joints in stainless steel construction shall be suitably coated with an approved metallic-based paint.
- O. After galvanized steel members have been welded, all welds and areas where galvanizing has been damaged shall have a zinc dust coating applied.
- P. Seams shall be continuous welds flush and ground smooth.
  - 1. Field Joints: Flush welded, ground smooth and polished on the job, solder or rivets not allowed.
  - 2. Counter Tops: Field joints in stainless steel counter tops and drain boards butt welded with welds ground flush and smooth and polished to match original finish.
  - 3. Pass windows: Provide a complete all welded seamless counter from inside area to the outside ledge at each pass window location. Mechanical joints, butt joints or lap joints will not be accepted.

#### 2.4 ELECTRICAL REQUIREMENTS

- A. Standard UL listed materials, devices and components shall be selected and installed in accordance with NEMA Standards and recommendations and as required for safe and efficient use and operation of the Food Service Equipment without objectionable noise, vibration, and sanitation problems.
- B. Motors up to and including 1/2 HP are to be wired for 120 volt, single phase. Fixtures totaling more than 1000 watts are to be wired for 208 volt, single phase. Fixtures having multiple number of heating elements, can be wired for three phase with the load balanced as equally as possible within the fixture.

- C. Heating elements having a connected load of up to and including 1000 watts are to be wired for 120 volt, single phase. Fixtures totaling more than 1000 watts are to be wired for 208 volt, single phase. Fixtures having multiple number of heating elements can be wired for three phase with the load balanced as equally as possible within the fixture.
- D. Equipment where applicable shall be furnished with three-wire cord and plug.

## 2.5 PLUMBING TRIM, SINKS

- A. All vegetable and pot washing sinks or other 14" deep sinks shall have Fisher Mfg. Co. Model 22209 series (2" drain size) quick opening drain. Fisher Mfg. Co. Model 60100 splash mounted faucet shall be mounted over each partition as shown on the drawings.
- B. All cook sinks, pantry sinks or other 10" or 12" deep sinks shall have Fisher Mfg. Co. Model 22209 series (2" drain size or as shown on the drawings) quick opening drain. Fisher Mfg Co. Model 57649 faucets mounted as shown on the drawings.
- C. All Fisher Mfg., Co. faucets to be furnished as stainless steel to comply with AD1953 Standards and conform to NSF 61 Standard 9.
- D. Provide gas pressure regulators for installation by the Plumbing Contractor.
- E. FIRE SUPPRESSION GAS SHUT/OFF VALVE: Gas valve to be furnished by the Foodservice Equipment Contractor and furnished to the Plumbing Contractor for installation. Foodservice Equipment Contractor is to verify with plumbing division for gas line size. Valve to be located in an accessible location and if necessary with access panel.

## 2.6 HARDWARE

- A. Elevated shelf brackets shall be as shown on the Drawings.
- B. Drawer and door handles shall be as shown on the Drawings.
- C. Hinges for all metal doors shall be Klein Hardware Co. 7870 series, finished in satin chrome.

## PART 3 INSTALLATION

### 3.1 POSITIONING OF EQUIPMENT

- A. Installation procedure, details and scheduling shall be so arranged that the work of other contractors may progress without unnecessary delay, interference or damage.
- B. The Contractor shall do all fitting, joining, fastening, scribing, caulking and adjusting necessary to install any fixed item of equipment in its designated location; and shall locate and/or store portable, non-fixed items as directed by the Architect and/or Consultant with due regard for the security and protection from damage of the items involved.

### 3.2 WORKMANSHIP

- A. Commencement of work shall constitute agreement with and acceptance of all conditions as found.
- B. Equipment shall be installed as shown on the plans. Where abutting, curved or irregularly shaped angles or projecting corners of walls occur, equipment shall be made to conform. Where several pieces of equipment are to be assembled in a group, the group shall be complete as whole, with all necessary filler or connecting pieces as may be required to make a complete, sanitary and vermin-proof group.
- C. Welded parts shall be non-porous and free of imperfections. Welds on galvanized metal shall be ground smooth, sandblasted and sprayed with molten zinc or 1200 degrees F to a thickness of .004". Tinning of welds will not be acceptable. Welds of stainless steel shall be ground and polished to the original finish and all grained in the same direction.
- D. All fixtures, unless made of stainless steel, shall be finished in sprayed lacquer in color as chosen by the architect; or if specifically stated, in "plastic laminate"; in pattern and/or color as selected by the Architect.

### 3.3 POST INSTALLATION PROCEDURES

- A. Prior to being offered for final acceptance, all equipment shall be thoroughly cleaned. This shall include removal of all stains, paint spots, protective wrapping and coatings, tapes, grease, oil, plaster, dust, polishing compounds, etc. and cleaning of floors in food service areas (broom clean) and signed off by the General Contractor with a copy to the Architect and/or Consultant.
- B. After installation at least ten (10) days prior to offering for acceptance, all equipment shall undergo a "Start-up" procedure by a Factory Authorized service dealer. Equipment is to be inspected, tested, calibrated and adjusted for normal operation conditions. If inspection or testing indicated defects, such defects shall be corrected and the inspection and test repeated to insure a perfect operation of all equipment, prior to final acceptance and for a period ninety days after final acceptance.
- C. Upon completion of the project, the Contractor shall furnish the Owner two (2) sets of dimensional prints, data sheets, spare parts lists and operating manuals for each piece of mechanical equipment; each set shall be neatly bound in a loose leaf binder, each set shall be complete with and index of equipment and with a complete list of service contracts with said agencies to perform these services. In addition to this list. The contractor shall submit for review of the Architect and/or Contractor and submittal to the Owner for his files, copies of service contracts with said agencies to perform these services. It shall be the responsibility of this contractor to fill out forward and all warranty forms as required.
- D. This contractor shall arrange demonstrations of the operation and maintenance of all buy-out" equipment by competent instructors. These demonstrations to take place within ten (10) days prior to the acceptance of the kitchen. All instruction periods shall be scheduled with the Architect and/or Consultant fourteen (14) days prior to commencement of same, and at times convenient to the Architect and/or consultant and Owner.

## PART 4 ITIMIZED EQUIPMENT SCHEDULE

### 4.1 FOOD SERVICE EQUIPMENT LIST AND DESCRIPTION

- A. Fabricated Equipment: Wherever the term "Fabricated Assembly" is used within the list noted below and description of Food Service Equipment, it shall be presumed to be followed by the phrase, "constructed to



the configuration, dimension, detail and design as shown on the drawings and specifications and with workmanship and materials as specified above” and shall meet the fabrication detail requirements of the latest edition of the Sheet Metal and Air Conditioning Contractors National Association (SMACNA), and National Sanitation Foundation (NSF Standard 2).

- B. All food service equipment shall be installed per the “Guidelines for Seismic Restraints of Kitchen Equipment” by the Sheet Metal and Air Conditioning Contractors National Association (SMACNA).
- C. All food service equipment shall comply with the standards of The California Administration Code, Title 24, Part No. 2.
- D. All food service equipment shall comply with the current California Energy Commission Appliance Efficiency Regulations.
- E. Equipment in the following schedule is listed by Item Numbers shown on Drawings.

1. SCHEDULED ITEMS:

ITEM 1 SPARE NO.

**ITEM 2 - WALK-IN FREEZER**

Quantity: One (1)

Thermo-Kool. Model FABRICATED ITEM

Assembly, shall consist of one (1) Freezer compartment; 13'-8" deep x 26'-6" wide x 9'-4" high clear interior dimensions. Assembly to form the configuration as shown on the drawings. Assembly shall be furnished as herein specified.

- A. Assemblies shall be N.S.F (Standard 7) approved and formed in the configuration as shown on the contract drawings.
- B. Panel Construction: Shall consist of exterior and interior die formed metal panels formed to insure proper size. Section edges must have lineup pines and double row of closed cell gaskets to insure panel alignment and proper seal at each joint. Corner panels to be 90 degree angles 12 inches in each direction. (No Wood Construction will be accepted).
- C. Insulation: Walls Ceiling and Floor panels 4" of “foamed-in place urethane insulation shall be used with a thermal conductivity of not more than 0.118 BTU per hour per square foot. U Factor shall not exceed 0.030. The insulation shall be rated self-extinguishing and fire retardant type as specified by UL. Insulation must remain stable at temperatures up to 260 degrees F.
- D. Section Fasteners: All wall, floor and ceiling sections joints shall be fastened together with steel cam action speed locks. These fasteners shall not exceed a 46" on center spacing. All locks shall be actuated from inside with a standard hex type Allen wrench. All socket ports shall be finished off with a ½" diameter snap cover to match the color of the panels.
- E. Hinged Walk-In Doors: Doors shall be installed as shown on the drawings. Doors shall be urethane insulated, flush-in fitting type 42" wide x 80" high (as shown on the drawings) with triple pane 1/4" thick plate glass 14"x24" view windows (freezer heated). Each door shall be furnished with door heater switch and mortise style lock. Doors to be stainless steel finish inside and out.

- F. Lights: Each door section shall be equipped with a flush mounted constant burning pilot light and switch on exterior and interior. Each compartment shall be provided with ceiling mounted vapor proof light fixture with clear prismatic injection molded polycarbonate diffuser Kason 48" long led or equal, see drawings for quantity. Light fixtures shall be factory wired to the light switch at the entrance door. Lighting level shall be a minimum of 10 foot candles measured 30" off the finished floor. Light control with back-up remote notification dry contacts, autolight control including inside illuminated switch/ panic alarm feature & sensor line.
- G. Finishes: Refer to drawings for interior and exterior finishes. Interior kitchen finish floor to meet interior floor panel of walk-in at same elevation for an even transition into walk-in.
- H. Accessories: Assembly shall be provided with the following accessories.
1. Trim Molding: Where unit abuts the building wall they shall be trimmed with a closure strip to match the exterior walk-in wall finish. Provide removable "drop-in" closure panels at ceiling. Provide vertical closure strips at all building wall junctures.
  2. Each compartment shall be provided with a high temperature alarm system, Modular Corporation model No. 75 FLUSH mounted. This unit to be provided complete with built-in N/O & N/C dry contacts and pulse output for remote notification.
  3. Dial Thermometer: Provide one (1) 4" dia. built into each walk-in door panel.
  4. Pressure Relief Port: One (1) for each compartment Kason No. 1832 heated at freezer only.
  5. Strip Curtains: each walk-in door shall have polyester reinforced clear vinyl strip curtains.
  6. Entrance Doors: Each door shall have a 1/8" thick sheet aluminum diamond plate kick panel 3'-0" high on the exterior and interior door panels and adjacent door jambs.
  7. The wall panels exposed to the kitchen shall have a 16 gauge stainless steel rub rail.
  8. Refer to drawings for additional accessories
  10. Provide heavy duty stainless steel rub rails on kitchen side entire length of box.
  11. Provide exterior kickplate 3/16" Aluminum tread plate, 48" high entire length of box.
- I. This assembly shall be installed by factory personal and or factory approved installers with written certification provided by the manufacturer to the Architect and Consultant.
- J. Walk-in assembly shall be installed into a recessed area as shown on the drawings. Kitchen Equipment Contractor is to verify finishes and thickness of kitchen floor and allow for proper clearance at walk-in door.
- K. All fasteners to be tamper proof

**ITEM 2.1 - DUNNAGE RACK**

Quantity: Three (3)

New Age Model 2054

Dunnage Rack, 42"W x 20"D x 12"H, all welded aluminum construction, 1-1/2" x 1-3/4" x 0.070 tubing, welded aluminum caps on feet, weight capacity 3000 lbs., NSF

Accessories:

3 ea Lifetime warranty against rust & corrosion, 5 year construction warranty, std.

**ITEM 2.2 - COLD STORAGE SHELVING**

Quantity: Eight (8)

Metro Model A2448NK3

Super Adjustable Super Erecta® Shelf, wire, 48"W x 24"D, Metroseal 3 (corrosion-resistant) finish, corner release system, with Microban® antimicrobial protection, NSF. Shelving to be 4 tier units with the bottom shelf at a minimum of 12" above finished floor.

Accessories:

- 32 ea. Model 63PK3 Super Erecta® SiteSelect™ Post, 62 9/16"H, adjustable leveling bolt, posts are grooved at 1" increments & numbered at 2" increments, double grooved every 8", Metroseal 3™ epoxy-coated corrosion-resistant finish with Microban® antimicrobial protection
- 16 ea. Model BCS Provide stainless steel post brackets at back posts as shown at upper locations.
- 32 ea. Post clamps as shown.

**ITEM 2.3 - COLD STORAGE SHELVING**

Quantity: Nine (9)

Metro Model A2442NK3

Super Adjustable Super Erecta® Shelf, wire, 42"W x 24"D, Metroseal 3 (corrosion-resistant) finish, corner release system, with Microban® antimicrobial protection, NSF. Shelving to be 4 tier units with the bottom shelf at a minimum of 12" above finished floor.

Accessories:

- 36 ea. Model 63PK3 Super Erecta® SiteSelect™ Post, 62 9/16"H, adjustable leveling bolt, posts are grooved at 1" increments & numbered at 2" increments, double grooved every 8", Metroseal 3™ epoxy-coated corrosion-resistant finish with Microban® antimicrobial protection
- 18 ea. Model BCS Provide stainless steel post brackets at back posts as shown at upper locations.
- 32 ea. Post clamps as shown.

**ITEM 2.4 - COLD STORAGE SHELVING**

Quantity: One (1)

Metro Model A2454NK3

Super Adjustable Super Erecta® Shelf, wire, 54"W x 24"D, Metroseal 3 (corrosion-resistant) finish, corner release system, with Microban® antimicrobial protection, NSF Shelving to be 4 tier units with the bottom shelf at a minimum of 12" above finished floor.

Accessories:

- 4 ea. Model 63PK3 Super Erecta® SiteSelect™ Post, 62 9/16"H, adjustable leveling bolt, posts are grooved at 1" increments & numbered at 2" increments, double grooved every 8", Metroseal 3™ epoxy-coated corrosion-resistant finish with Microban® antimicrobial protection
- 2 ea. Model BCS Provide stainless steel post brackets at back posts as shown at upper locations.
- 4 ea. Post clamps as shown.

**ITEM 2.5 -COLD STORAGE SHELVING**

Quantity: Four (4)

Metro Model 2436NK3

Super Erecta® Shelf, wire, 36"W x 24"D, plastic split sleeves are included in each carton, Metroseal 3™ epoxy-coated corrosion-resistant finish with Microban® antimicrobial protection, NSF. Shelving to be 4 tier units with the bottom shelf at a minimum of 12" above finished floor.

Accessories:

- 16 ea. Model 63PK3 Super Erecta® SiteSelect™ Post, 62 9/16"H, adjustable leveling bolt, posts are grooved at 1" increments & numbered at 2" increments, double grooved every 8", Metroseal 3™ epoxy-coated corrosion-resistant finish with Microban® antimicrobial protection
- 8 ea. Model BCS Provide stainless steel post brackets at back posts as shown at upper locations.
- 16 ea. Post clamps as shown.

**ITEM 3 - WALK-IN REFRIGERATOR**

Quantity: One (1)

Thermo-Kool. Model FABRICATED ITEM

Assembly, shall consist of one (1) Refrigerated compartment; 13'-8" deep x 17'-7" wide x 9'-4" high clear interior dimensions. Assembly to form the configuration as shown on the drawings. Assembly shall be furnished as herein specified in Item #2 and as shown on the drawings.

**ITEM 3.1 - COLD STORAGE SHELVING**

Quantity: Two (2)

Metro Model A2436NK3

Super Adjustable Super Erecta® Shelf, wire, 36"W x 24"D, Metroseal 3 (corrosion-resistant) finish, corner release system, with Microban® antimicrobial protection, NSF. Shelving to be 4 tier units with the bottom shelf at a minimum of 12" above finished floor.

Accessories:

- 8 ea Model 63PK3 Super Erecta® SiteSelect™ Post, 62 9/16"H, adjustable leveling bolt, posts are grooved at 1" increments & numbered at 2" increments, double grooved every 8", Metroseal 3™ epoxy-coated corrosion-resistant finish with Microban® antimicrobial protection
- 4 ea. Model BCS Provide stainless steel post brackets at back posts as shown at upper locations.
- 8 ea. Post clamps as shown.

**ITEM 3.2 - COLD STORAGE SHELVING**

Quantity: six (6)

Metro Model A2448NK3

Super Adjustable Super Erecta® Shelf, wire, 48"W x 24"D, Metroseal 3 (corrosion-resistant) finish, corner release system, with Microban® antimicrobial protection, NSF. Shelving to be 4 tier units with the bottom shelf at a minimum of 12" above finished floor.

Accessories:

- 24 ea Model 63PK3 Super Erecta® SiteSelect™ Post, 62 9/16"H, adjustable leveling bolt, posts are grooved at 1" increments & numbered at 2" increments, double grooved every 8", Metroseal 3™ epoxy-coated corrosion-resistant finish with Microban® antimicrobial protection
- 12 ea. Model BCS Provide stainless steel post brackets at back posts as shown at upper locations.
- 24 ea. Post clamps as shown.

**ITEM 3.3 - COLD STORAGE SHELVING**

Quantity: six (6)

Metro Model A2442NK3

Super Adjustable Super Erecta® Shelf, wire, 42"W x 24"D, Metroseal 3 (corrosion-resistant) finish, corner release system, with Microban® antimicrobial protection, NSF. Shelving to be 4 tier units with the bottom shelf at a minimum of 12" above finished floor.

Accessories:

- 24 ea Model 63PK3 Super Erecta® SiteSelect™ Post, 62 9/16"H, adjustable leveling bolt, posts are grooved at 1" increments & numbered at 2" increments, double grooved every 8", Metroseal 3™ epoxy-coated corrosion-resistant finish with Microban® antimicrobial protection
- 12 ea. Model BCS Provide stainless steel post brackets at back posts as shown at upper locations.
- 24 ea. Post clamps as shown.

**ITEM 3.4 - COLD STORAGE SHELVING**

Quantity: Two (2)

Metro Model A2454NK3

Super Adjustable Super Erecta® Shelf, wire, 54"W x 24"D, Metroseal 3 (corrosion-resistant) finish, corner release system, with Microban® antimicrobial protection, NSF. Shelving to be 4 tier units with the bottom shelf at a minimum of 12" above finished floor.

Accessories:

- 8 ea Model 63PK3 Super Erecta® SiteSelect™ Post, 62 9/16"H, adjustable leveling bolt, posts are grooved at 1" increments & numbered at 2" increments, double grooved every 8", Metroseal 3™ epoxy-coated corrosion-resistant finish with Microban® antimicrobial protection
- 4 ea. Model BCS Provide stainless steel post brackets at back posts as shown at upper locations.
- 8 ea. Post clamps as shown.

#### **ITEM 4 - WALL MOUNT HAND SINK**

Quantity: One (1)

Advance Tabco Model 7-PS-46

Physically Challenged Hand Sink, wall model, 14" wide x 16" front-to-back x 5" deep bowl, 18 gauge 304 series stainless steel, splash mount faucet with wrist handles, deck mounted soap dispenser (pump), undermounted paper towel dispenser, basket drain, wall brackets, NSF, cCSAus

Accessories:

- 1 ea This faucet complies with 2014 Federal no lead standards
- 1 ea Model 7-PS-15D Welded Side Splash, 12" tall, both sides, for handicapped hand sinks

#### **ITEM 5 - PREP SINK**

Quantity: One (1)

American Stainless Steel Corp. (303) 783-0005

Model FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following:

- A Work area top to be 14 gauge stainless steel with a 14 gauge stainless steel backsplash at back 2" thick with a 45 degree top edge to wall, turn down ½" at back. Top to be constructed with a "rolled" edge as shown. Drain boards are to slope per NSF guidelines to sinks.
  - B. One (1) 14 gauge stainless steel formed and welded sink 18" x 24" x 12" deep. (Die cast sink bowl is not acceptable). Provide welded 16 gauge stainless steel waste valve handle bracket as shown.
  - C. Legs to be 16 gauge stainless steel tubular, stainless steel welded leg sockets, stainless steel adjustable feet and stainless steel cross rail bracing. Provide 16 gauge stainless steel under shelf as shown.
  - D. Approximate size: 30" deep x 11'-0" as shown.
- Accessories:
- 1 ea Fisher model 60917 Faucet, 8" backsplash mount, with 10" swing spout, elbows, stainless steel.
  - 1 ea Fisher Model D50-7215 DrainKing Waste Valve, with flat strainer, and overflow assembly 12 GPM drain rate, cast red brass body.
  - 2 ea. Component Hardware Group Inc. Model R69-1633 GFI Outlet and S/S Coverplate.

#### **ITEM 6 - SPLASH MOUNT PRE-RINSE FAUCET**

Quantity: One (1)

Fisher Model 2210-WB

Pre-Rinse Assembly, 8" adjustable centers, wall-mounted mixing valve, with spring action flexible gooseneck, with spray head (1.15 gallons per minute @ 60 PSI), with wall bracket

#### **ITEM 7 - UTENSIL DRAWER UNIT**

Quantity: One (1)

American Stainless Steel Corp. (303) 783-0005

Model FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following: To be fabricated of 16 gauge stainless steel complete with the following hardware items.

- A. Provide stainless steel flush pull, Component Hardware Group, Inc., model no. P63-1012, installed into the 18 gauge double-pan drawer front panel.
- B. Provide stainless steel locks, Component Hardware Group, Inc., model no P30-4781 for each drawer. All drawers are to be keyed alike.
- C. Provide stainless steel full extension slides, Component Hardware Group, Inc., model No. S52-0024. Provide two (2) per drawer. Slides to be installed so drawer will roll closed when released.
- D. Provide stainless steel removable drawer pan. Provide Component Hardware Group, Inc., model No. S81-1520 one (1) per drawer. Pan should be easily lifted out of drawer frame for cleaning.
- E. Drawer face panel to be constructed of 16 gauge stainless steel double pan construction. Single metal drawer faces are not be acceptable.

#### **ITEM 8 - WALL SHELF**

Quantity: One (1)

American Stainless Steel Corp. (303) 783-0005

Model: FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following:

- A. To be 16 gauge stainless steel construction, 1 1/2" turn down in front and 2" turn up at back and right end and left ends. Provide 14 gauge stainless steel wall brackets as shown.
- B. Approximate size to be 12" deep x 5'-6" long.

#### **ITEM 9 - WALL SHELF**

Quantity: One (1)

American Stainless Steel Corp. (303) 783-0005

Model: FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following:

- A. To be 16 gauge stainless steel construction, 1 1/2" turn down in front and 2" turn up at back and right end and left ends. Provide 14 gauge stainless steel wall brackets as shown.
- B. Approximate size to be 12" deep x 5'-6" long.

#### **ITEM 10 - PREP SINK**

Quantity: One (1)

American Stainless Steel Corp. (303) 783-0005

Model: FABRICATED ITEM

- A. Work area top to be 14 gauge stainless steel with a 14 gauge stainless steel backsplash at back 2" thick with a 45 degree top edge to wall, turn down 1/2" at back. Top to be constructed with a "rolled" edge as shown. Drain boards are to slope per NSF guidelines to sinks.
- B. Two (2) 14 gauge stainless steel formed and welded sinks 18" x 24" x 12" deep. (Die cast sink bowl is not acceptable). Provide welded 16 gauge stainless steel waste valve handle bracket as shown.
- C. Legs to be 16 gauge stainless steel tubular, stainless steel welded leg sockets, stainless steel adjustable feet and stainless steel cross rail bracing. Provide 16 gauge stainless steel under shelf as shown.
- D. Approximate size: 30" deep x 15'-0" as shown.  
Accessories:

- 1 ea Fisher model 60917 Faucet, 8" backsplash mount, with 10" swing spout, elbows, stainless steel.
- 2 ea Fisher Model D50-7215 DrainKing Waste Valve, with flat strainer, and overflow assembly 12 GPM drain rate, cast red brass body.
- 4 ea. Component Hardware Group Inc. Model R69-1633 GFI Outlet and S/S Coverplate.

**ITEM 11 - SPLASH MOUNT PRE-RINSE FAUCET**

Quantity: One (1)

Fisher Model 2210-WB

Pre-Rinse Assembly, 8" adjustable centers, wall-mounted mixing valve, with spring action flexible gooseneck, with spray head (1.15 gallons per minute @ 60 PSI), with wall bracket

**ITEM 12 - UTENSIL DRAWER UNIT**

Quantity: One (1)

American Stainless Steel Corp. (303) 783-0005

Model FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following: To be fabricated of 16 gauge stainless steel complete with the following hardware items.

- A. Provide stainless steel flush pull, Component Hardware Group, Inc., model no. P63-1012, installed into the 18 gauge double-pan drawer front panel.
- B. Provide stainless steel locks, Component Hardware Group, Inc., model no P30-4781 for each drawer. All drawers are to be keyed alike.
- C. Provide stainless steel full extension slides, Component Hardware Group, Inc., model No. S52-0024. Provide two (2) per drawer. Slides to be installed so drawer will roll closed when released.
- D. Provide stainless steel removable drawer pan. Provide Component Hardware Group, Inc., model No. S81-1520 one (1) per drawer. Pan should be easily lifted out of drawer frame for cleaning.
- E. Drawer face panel to be constructed of 16 gauge stainless steel double pan construction. Single metal drawer faces are not acceptable.

**ITEM 13 - WALL SHELF**

Quantity: One (1)

American Stainless Steel Corp. (303) 783-0005

Model FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following:

- A. To be 16 gauge stainless steel construction, 1 1/2" turn down in front and 2" turn up at back and right end and left ends. Provide 14 gauge stainless steel wall brackets as shown.
- B. Approximate size to be 12" deep x 5'-6" long.

**ITEM 14 - TRASH CAN W/DOLLIE**

Quantity: One (1)

Rubbermaid Model FG262000GRAY

ProSave® BRUTE® Container, without lid, 20 gallon, 19-1/2"D x 22-7/8"H, round, reinforced rims, built in handles, double rimmed base, high-impact plastic construction, gray, NSF

Accessories:

- 1 ea Model FG261960BLA BRUTE® Container Lid, 19-7/8"D x 1-1/4"H, for 20 gallon trash can, heavy duty plastic, gray
- 1 ea Model FG264000BLA BRUTE® Dolly, 18-1/4"D x 6-5/8"H, heavy duty 3" casters, 250 lb. capacity, black.

**ITEM 15 - WORK TABLE**

Quantity: One (1)

American Stainless Steel Corp. (303) 783-0005

Model FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following:

- A. To be constructed of 14 gauge stainless steel complete with open leg base with crossrails.
  - B. Work top to be 14 gauge stainless steel with a 14 gauge stainless steel backsplash 2" thick with a 45 degree top edge to wall, turn down ½" at back. Front right and left edges to be turned down 2". Work counter to have a working ht. of 2'-10"
  - C. Cross rails to be 1 5/8" fully "fish mouthed" cut and welded. No crimp and tac will be accepted.
  - D. Provide 1 5/8" dia. stainless steel tube legs with Component Hardware Group, Inc. A10-0851 adjustable foot insert.
  - E. Approximate size: 2'-6" deep x 6'-6" Long.
- Accessories:
- 2 ea. Component Hardware Group Inc. Model R69-1633 GFI Outlet and S/S Cover plate.

**ITEM 16 - WALL SHELF**

Quantity: One (1)

American Stainless Steel Corp. (303) 783-0005

Model FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following:

- A. To be 16 gauge stainless steel construction, 1 1/2" turn down in front and 2" turn up at back and right end and left ends. Provide 14 gauge stainless steel wall brackets as shown.
- B. Approximate size to be 12" deep x 6'-5" long.

**ITEM 17 - WALL MOUNT HAND SINK**

Quantity: One (1)

Advance Tabco Model 7-PS-46

Physically Challenged Hand Sink, wall model, 14" wide x 16" front-to-back x 5" deep bowl, 18 gauge 304 series stainless steel, splash mount faucet with wrist handles, deck mounted soap dispenser (pump), undermounted paper towel dispenser, basket drain, wall brackets, NSF, cCSAus

Accessories:

- 1 ea Note: This faucet complies with 2014 Federal no lead standards
- 1 ea Model 7-PS-15D Welded Side Splash, 12" tall, both sides, for handicapped hand sinks

**ITEM 18 - FLOOR MIXER**

Quantity: One (1)

Hobart Model HL600-1STD

Mixer; with bowl, beater, "D" whip, and spiral dough arm

Accessories:

- 1 ea Model EXTEND-SST60G 60 qt. Bowl extension ring stainless steel
- 1 ea Model TRUCK-HL1486 Bowl Truck, for use with 60, 80 & 140 quart Legacy Mixers

**ITEM 19 - INGREDIENT BIN**

Quantity: Four (4)

Cambro Model IB44148

Ingredient Bin, mobile, 42-1/2 gallon capacity, molded polyethylene with sliding cover, w(4) 3" heavy duty casters (2 front swivel, 2 fixed), with bin securely attached to base plate, white, NSF



**ITEM 20 - WALL SHELF**

Quantity: One (1)

American Stainless Steel Corp. (303) 783-0005

Model FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following:

- A. To be 16 gauge stainless steel construction, 1 1/2" turn down in front and 2" turn up at back and right end and left ends. Provide 14 gauge stainless steel wall brackets as shown.
- B. Approximate size to be 12" deep x 18'-0" long.

**ITEM 21 - BAKERS TABLE**

Quantity: One (1)

Custom Model FABRICATED ITEM

American Stainless Steel Corp. (303) 783-0005

Fabricated assembly in length and configuration as shown on the drawings and shall include the following:

- A. To be constructed of 14 gauge stainless steel complete with open leg base with cross rails.
- B. Work top to be 14 gauge stainless steel with a 14 gauge stainless steel backsplash 2" thick with a 45 degree top edge to wall, turn down 1/2" at back. Front right and left edges to be turned down 2". Work counter to have a working ht. of 3'-0"
- C. Cross rails to be 1 5/8" fully "fish mouthed" cut and welded. No crimp and tac will be accepted.
- D. Provide 1 5/8" dia. stainless steel tube legs with Component Hardware Group, Inc. A10-0851 adjustable foot insert.
- E. Approximate size: 2'-6" deep x 18'-0" Long.  
Accessories:  
4 ea. Component Hardware Group Inc. Model R69-1633 GFI Outlet and S/S Cover plate.

**ITEM 22 - EXHAUST HOOD**

Quantity: One (1)

Captive-Aire Model 6042CND-2WI

Stainless steel type I exhaust hood. Hood to be 18 gauge stainless steel with removable Hige Velocity Cartridge filter. Filters to be supplied with a lockable filter rack and tamper proof screws in any exposed area. Hood to have a configuration of 2 sections of 11'-0" x 5'-0", 10'-0" x 5'-0" with built-in 3" airspace at back and built in utility cabinet for the fire system located on left end. Provide two (2) 4'-0" fluorescent lights pre-wired to one (1) point of connection per hood.

- A. 18 gauge stainless steel wall panels (minimum length to be 36") with 1" mineral wool blanket and wire mesh backing or ceramic fiber blanket and wire mesh backing spaced out 1" on non-combustible spacers per California Mechanical Code 2013 Chapter 5.
- B. Wall panels shall be installed horizontally and fluted vertically every 6" from top of floor base to bottom lip of hood.
- C. Wall lining shall be installed without exposed screws and bolts.
- D. Provide stainless steel "tees" and/or "ells" at each panel on both sides, bottom and top.
- E. The stainless steel wall lining shall extend the full length of wall as shown.
- F. Wall lining shall meet the requirements of NFPA-96 and all local codes and ordinances.
- G. Provide 22 gauge stainless steel closure skirting from top of hood to finish ceiling.
- H. Provide all hanging information to the Contractor including the total weight of the Hood.
- I. Provide 18 gauge stainless steel trim at opening in wall.

Furnish all necessary materials to support this assembly from the building structure. Assembly shall meet the requirements of NFPA-96 and the latest edition of the California Mechanical Code. This assembly shall be installed and tested with factory supervision with certification provided to the Architect and Consultant.

**ITEM 23 - DOUBLE STACK CONVECTION OVEN**

Quantity: Two (2)

Vulcan Model SG44

Convection Oven, gas, double-deck, solid state controls, electronic spark ignition, gentle bake mode selector switch, 60 minute timer with audible alarm, 150° to 500°F temperature range, stacking kit, (5) oven racks per section, independently operated doors with windows, porcelain enamel interior, stainless steel doors, front, sides, top and 8" legs, (2) 1/2 HP, (2) 60,000 BTU, CSA, NSF, ENERGY STAR®

Accessories:

- 2 ea. 1 year limited parts & labor warranty, standard
- 2 ea. Gas type to be specified
- 2 ea. (2)120v/60/1-ph, 16 amps, 1/2 HP, 6' cord & plug standard
- 2 ea. Gas manifold piping included with stacking kit to provide single point gas connection
- 4 ea. Prison Security Packages: exterior Security screws, perforated stainless steel hinged control covers w/locking for pad locks, oven door locks for pad lock (locks not included), top, bottom & rear screen enclosures
- 2 ea. 6" legs, adjustable, with seismic feet (set)
- 2 ea. Security Package

**ITEM 24 -GRIDDLE W/ STAND**

Quantity: One (1)

Vulcan Model 972RX

Heavy Duty Gas Griddle, 72" W x 24" D x 1" thick polished steel griddle plate, embedded mechanical snap action thermostat every 12", millivolt pilot safety, electric spark or manual ignition, front manifold gas shut-off valve, countertop, low profile, stainless steel front, sides, front top ledge with "Cool Bullnose", front grease trough, grease can, heavy gauge 4" back & tapered side splashes, 4" adjustable legs, 162,000 BTU, CSA, NSF

Accessories:

- 1 ea. 1 year limited parts & labor warranty, standard
- 1 ea. Gas type to be specified
- 1 ea. 120v/50/60/1-ph, NEMA 5-15P, standard
- 1 ea. Model LEGS-GRD6 6" Legs (installed by others)
- 1 ea. Model STAND/C-72 Equipment Stand, universal, 73" W x 24" H, 1/2" marine edge, undershelf, stainless steel, 5" casters
- 1 ea. 6" legs, adjustable, with seismic feet (set)
- 1 ea. Griddle Security Package: sealed chassis, lockable panel & grease can, Security screws

**ITEM 25 - TILT SKILLET**

Quantity: One (1)

Cleveland Range Model SGL40T1

PowerPan™ Tilting Skillet, gas, 40-gallon capacity, bead blasted cooking surface, 10° tilt cooking feature, with easy manual hand tilt, spring-assisted cover with vent, gallon & liter markings, food strainer, stainless steel construction with open leg frame, CE, NSF

Accessories:

- 1 ea. 1-year limited warranty, standard
- 1 ea. Gas type to be specified
- 1 ea. 120v/60/1-ph, 1.4 amp, standard
- 1 ea. 6" legs, adjustable, with seismic feet (set)

- 1 ea. Security Package

**ITEM 26 - FLOOR TROUGH**

Quantity: One (1)

IMC/Teddy, Model: SEC-CFT-1254-SG

Floor Trough, 12"W, 54"L, 4"D, 14 gauge 304 series stainless steel, includes stainless steel subway grating constructed from 3/16" x 1" bars, removable stainless steel strainer basket, 4" O.D. waste pipe 3"L, pitched towards waste. Security Floor Trough, 12" wide x 54" long x 4" deep, with drain & (SG-SEC ) security subway grating

Accessories:

- 4 ea. Standard width
- 1 ea. Model FSG-12 Seepage holes with flanges, for 12" width trough, (price per foot)
- 1 ea. Model FF-12 Flashing frame/clamping ring, for waterproof membrane, for 12" width trough (includes screws, price per foot)
- 1 ea. Model AFT-12 Angle frame trough, 14 gauge stainless steel, for 12" width trough

**ITEM 27 - FIRE SYSTEM**

Quantity: One (1)

Ansul Fire Protection Model R-102

Complete with a stainless steel control panel, remote pull station, all shut/down electric contractors. This assembly to be in compliance with NFPA 96 and UL-300.

- A. All exposed piping, fittings, nozzles, and trim shall be stainless steel or chrome plated finish.
- B. All conduit piping and boxes are to be concealed in the building wall or ventilator. Verify with contractors to coordinate installation in the wall areas.
- C. Furnish a mechanical gas shut-off valve of proper size to the Plumbing Contractor for installation. Verify with Electrical Contractor what type of electrical panel will be furnished, either for shunt trips or contactors, and provide all necessary information regarding the inter-lock conduit and wiring between this electrical panel and the fire suppression panel. This electrical work and all material to be supplied by the Electrical Contractor.
- D. Coordinate with the hood manufacturer to supply the proper access into the hood area for the fire suppression linkage and nozzle locations.
- E. Before installation of the fire suppression system is started, approved drawings and fitting lists must be approved by the Office of Regulation Services. Once the installation is completed a field test must be performed in the presence of the inspecting authority.

**ITEM 28 - MOBILE WARMING CABINET**

Quantity: One (1)

Cres Cor Model H-137-SUA-12D

Cabinet, Mobile Heated, insulated, top-mount heater assembly, recessed push/pull handles, magnetic latch, (12) sets chrome plated wire universal angle slides for 12" x 20" thru 18" x 26" pans on 4-1/2" centers, adjustable 1-1/2" centers, reversible Dutch doors, (4) heavy duty 5" swivel casters (2) braked, anti-microbial latches, stainless steel construction, NSF, ENERGY STAR®

Accessories:

- 1 ea. Standard Warranty: 1 yr. labor with 3 yr. parts warranty
- 1 ea. 120v/60/1-ph, 1500 w, 12.0 amp, 10 ft. power cord, NEMA 5-15P, standard
- 1 ea. Right-hand door swing, standard

**ITEM 29 - CHEFS COUNTER**

Quantity: Two (2)

American Stainless Steel Corp. Model FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following:

- A. Top to be 14 gauge stainless steel complete with 2" turn downs on 4 sides and a working height of 2'-10".
- B. Base section to be 16 gauge stainless steel formed metal construction complete with 16 gauge stainless steel bottom and mid shelves.
- C. Provide (2) Component Hardware Group, Inc., model No. R58-1020 double faced pedestal type electrical outlets with model No. R71-0721 stainless steel face plates.
- D. Provide 1 5/8" dia. Stainless steel tube legs with Component Hardware Group, Inc. A10-0851 adjustable foot insert.

### **ITEM 30 - CHEFS COUNTER OVERSHELF**

Quantity: Two (2)

American Stainless Steel Corp. Model FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following: To be 16 gauge stainless steel shelf (1) 16" x length of counter item 29. Mounted on 1 5/8" dia. 16 gauge stainless steel tubular uprights anchored to bottom of base cabinet Item No. 29 The shelf is to have 1 1/2 "turned-down edge on all sides. Counter top of Item No. 29 to be covered up around the tubular uprights where the uprights penetrate the top.

### **ITEM 31 - MOBILE WORK TABLE**

Quantity: Two (2)

Advance Tabco Model SS-249

Work Table, 24" wide top, without splash, 108" long, with adjustable undershelf, stainless steel frame & shelf, 14 gauge 304 series stainless steel top, stainless steel bullet feet

Accessories:

- 2 st. Model TA-25S-6 Casters, 5" diameter, set of 6 (2 with brakes) with stainless steel legs for standard working height (35.5") tables
- 2 ea. Model TA-25B Brakes, on all casters

### **ITEM 32 - CART, TRAY AND SILVER**

Quantity: Two (2)

Caddy Model T-301

Tray & Silver Caddy, single tier, 34" L X 22" W X 45-1/2" H, cutlery housing fitted w/double folding covers, 4 finish silver containers each 11-1/2" X 6" X 4", capacity: 190 trays up to 15" X 20"

Accessories:

- 2 st. Model ACC-38 Circular bumpers (4)
- 2 pr. Model ACC-41 Caster brakes 4" & 5" (pair)
- 2 ea. Model ACC-47 Vinyl drape cover, all models

### **ITEM 33 - REFRIGERATED COLD WELL**

Quantity: One (1)

Delfield Model 8169-EFN

LiquiTec™ Slim Line Drop-In Cool Food Unit, 3-pan size, 4" or 6" deep pans flush with counter top, insulated pan, stainless steel inner liner & top, galvanized outer liner, self-contained Eutectic fluid refrigerated system, cUL, UL, NSF 7, 1/4 hp

Accessories:

- 1 ea. 115v/60/1-ph, 7.5 amps, NEMA 5-15P, standard
- 1 ea. (1) year parts & (90) day labor warranty, standard

**ITEM 34 - HOT FOOD WELL**

Quantity: One (1)

Delfield Model N8746ND

Narrow Drop-In Hot Food Well Unit, Electric, individual pan design with drain, wet or dry type, 2-pan size for 12" x 20" pans, individual infinite temperature controls, stainless steel top & inner liner, galvanized outer liner, cUL, UL, NSF

Accessories:

- 1 ea. 120v/60/1-ph, 17.0 amps, NEMA 5-15P, standard
- 1 ea. (1) year parts & (90) day labor warranty, standard
- 1 ea. Autofill assembly kit (shipped loose), for N8700 series

**ITEM 35 - HOT FOOD WELL**

Quantity: One (1)

Delfield Model N8768ND

Narrow Drop-In Hot Food Well Unit, Electric, individual pan design with drain, wet or dry type, 3-pan size for 12" x 20" pans, individual infinite temperature controls, stainless steel top & inner liner, galvanized outer liner, cUL, UL, NSF

Accessories:

- 1 ea. 208v/60/1-ph, 16.0 amps, NEMA 5-15P, standard
- 1 ea. (1) year parts & (90) day labor warranty, standard
- 1 ea. Autofill assembly kit (shipped loose), for N8700 series

**ITEM 36 - WALL MOUNT HAND SINK**

Quantity: One (1)

Advance Tabco Model 7-PS-46

Physically Challenged Hand Sink, wall model, 14" wide x 16" front-to-back x 5" deep bowl, 18 gauge 304 series stainless steel, splash mount faucet with wrist handles, deck mounted soap dispenser (pump), undermounted paper towel dispenser, basket drain, wall brackets, NSF, cCSAus

Accessories:

- 1 ea. Note: This faucet complies with 2014 Federal no lead standards
- 1 ea. Model 7-PS-27D Bolted Side Splash, 7-3/4" tall, for handicapped hand sinks, in-field installation

**ITEM 37 - SOILED DISHTABLE**

Quantity: One (1)

American Stainless Steel Corporation Model FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following:

- A. Work area top to be 14 gauge stainless steel with a 14 gauge stainless steel backsplash at back 2" thick with a 45 degree top edge to wall, turn down 1/2" at back. Top to be constructed with a "rolled" edge as shown. Drain boards are to slope per NSF guidelines to dishwasher. Provide fully welded and polished pass ledge for tray drop off.
- B. Provide and install 16 gauge stainless steel tubular legs, stainless steel welded leg sockets, stainless steel adjustable feet and stainless steel cross rail bracing.
- C. Provide 16 gauge stainless steel undershelf with 1" turn up at back and 1 1/2" turn down on all other sides.
- D. Disposer cone item 39 to be fully welded into this counter top including control bracket to be mounted to underside on counter top.

**ITEM 38 - SPLASH MOUNT PRE-RINSE FAUCET**

Quantity: One (1)

Fisher Model 2210-WB

Pre-Rinse Assembly, 8" adjustable centers, wall-mounted mixing valve, with spring action flexible gooseneck, with spray head (1.15 gallons per minute @ 60 PSI), with wall bracket

**ITEM 39 - GARBAGE DISPOSER**

Quantity: One (1)

Salvajor Model 200-CA-ARSS-2

Disposer, with cone assembly (size to be specified), 2-HP motor, auto reversing magnetic, with start/stop push button, rubber scrap ring, vacuum breaker, solenoid with flow control & fixed nozzle, 6-1/2" inlet diameter, heat treated aluminum alloy housing, UL, SA, CE

Accessories:

1 ea. 2nd-year warranty (P/N 999183)

1 ea. 18" Cone to be fully welded into soiled dishtable item 37.

1 ea. Model 980137 Disposer prison package, includes disposer safety guard, security screws with tool for control

1 ea. Model 980100 Disposer safety guard

1 ea. Model 997101 Control padlock hasp

**ITEM 40 - DISHWASHER, CONVEYOR TYPE**

Quantity: One (1)

Hobart Model CL44E-2

R/L 15KW Tank Heat 208/60/3 30KW Booster Conveyor Dishwasher, single tank, 202 racks/hour, insulated hinged doors, .62 gallon/rack, stainless steel enclosure panels, Microprocessor controls with Low Temperature & Dirty Water Indicators, ENERGY STAR®

Accessories:

1 ea. Standard warranty - 1-Year parts, labor & travel time during normal working hours within the USA

1 ea. Model CL44E-FETSTD

**ITEM 41 - VAPOR HOOD**

Quantity: One (1)

Captive-Aire Model 4224VHB-G-REM1 Provide 18 gauge stainless steel clouser skirting from hood to ceiling at all sides. Provide 18 gauge stainless steel wall lining from end of item 43 to end of item 37. Wall lining to extent from bottom edge of vapor hood to top edge of dishtables as shown.

A. 18 gauge stainless steel wall panels (minimum length to be 36")

B. Wall panels shall be installed horizontally and fluted vertically every 6" from top of dishtable to bottom lip of hood.

C. Wall lining shall be installed without exposed screws and bolts.

D. Provide stainless steel "tees" and/or "ells" at each panel on both sides, bottom and top.

**ITEM 42 - HOSE REEL WITH CONTROL BOX**

Quantity: One (1)

Fisher Model 97098

Closed Reel Rinse, in wall-mounted, self-locking, with 30-ft reel hose, spray valve, stainless steel cover & control box with temperature adjusting valve, shut-off, in-line dual backflow preventer.

**ITEM 43 - CLEAN DISHTABLE**

Quantity: One (1)

American Stainless Steel Corporation Model FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following:

- A. Work area top to be 14 gauge stainless steel with a 14 gauge stainless steel backsplash at back 2" thick with a 45 degree top edge to wall, turn down ½" at back. Top to be constructed with a "rolled" edge as shown. Drain boards are to slope per NSF guidelines to dishwasher.
- B. Provide and install 16 gauge stainless steel tubular legs, stainless steel welded leg sockets, stainless steel adjustable feet.
- C. Provide 16 gauge stainless steel undershelf with 1" turn up at back and 1 ½" turn down on all other sides.
- D. Provide hose reel attachment bracket to underside of this dishtable. Provide additional bracing to attached bracket as shown.

**ITEM 44 - 3-COMPARTMENT POT SINK**

Quantity: One (1)

American Stainless Steel Corporation Model FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following:

- A. Work area top to be 14 gauge stainless steel with a 14 gauge stainless steel backsplash at back 2" thick with a 45 degree top edge to wall, turn down ½" at back. Top to be constructed with a "rolled" edge as shown. Drain boards are to slope per NSF guidelines to sinks.
- B. Two (2) 14 gauge stainless steel formed and welded sinks 24" x 24" x 12" deep. (Die cast sink bows are not acceptable). One (1) 14 gauge stainless steel formed and welded sinks 24" x 30" x 12" deep. (Die cast sink bows are not acceptable). ). Provide welded 16 gauge stainless steel waste valve handle bracket as shown.
- C. Provide and install 16 gauge stainless steel tubular legs, stainless steel welded leg sockets, stainless steel adjustable feet and stainless steel cross rail bracing.
- D. Provide 16 gauge stainless steel under shelf with 1 ½" turn down at front and 2" turn up at back.
- E. Provide 18 gauge stainless steel wall lining for full length of Item 44.
- F. 18 gauge stainless steel wall panels (minimum length to be 36")
- G. Wall panels shall be installed horizontally and fluted vertically every 6" from top of dishtable
- H. Wall lining shall be installed without exposed screws and bolts.
- I. Provide stainless steel "tees" and/or "ells" at each panel on both sides, bottom and top.
- E. Approximate size: 30" deep x 11'-7" Long.  
Accessories:  
2 ea Fisher Model 60100 Faucet, splash-mounted, 8" centers, 10" swing spout, 3/4" inlet.  
3 ea Fisher Model D50-7215 DrainKing Waste Valve, with flat strainer, and overflow assembly 12 GPM drain rate, cast red brass body.

**ITEM 45 - SPLASH MOUNT PRE-RINSE FAUCET**

Quantity: One (1)

Fisher Model 2210-WB

Pre-Rinse Assembly, 8" adjustable centers, wall-mounted mixing valve, with spring action flexible gooseneck, with spray head (1.15 gallons per minute @ 60 PSI), with wall bracket.

**ITEM 46 - SNEEZE GUARD, STATIONARY**

Quantity: Lot

Premier Brass Model FM2N

1 Guard™ Fixed Full-Service Sneeze Guard, single sided guard with top shelf, straight front, tempered glass with polished edges, end panels, front mount, 1" OD round stainless support posts, NSF & UL listed. Provide tamper proof fasteners.

Accessories:

- 1 ea. Brushed (#4), NSF
- 1 ea. 3/8" Glass, max 60" span
- 1 ea. Model 223 Mounting, through counter, standard when rear legs are not possible
- 1 ea. Both ends, standard

**ITEM 47 - MOBILE POT AND PAN STORAGE SHELVING**

Quantity: Three (3)

Metro Model N556MC

Super Erecta® Dolly Truck, wire, chrome shelves, 48"W x 24"D x 63" H posts, plated posts & aluminum dolly (4) shelves, posts, plastic split sleeves, truck dolly with wraparound bumper & with (2) - 6P & set BL6P, NSF

**ITEM 48 - REFRIGERATOR RACK, ROLL-IN**

Quantity: Four (4)

Cres Cor Model 208-1835-D

Rack, Roll-In Refrigerator, corrugated sidewalls, holds (35) 18" x 26" pans, slides on 1-1/2" centers, welded extruded channel aluminum frame, includes perimeter bumper and enclosed base

Accessories:

- 4 ea. Standard Warranty: 3 yr parts, 1-year labor warranty, Lifetime guarantee against rust & corrosion

**ITEM 49 - DRY STORAGE SHELVING**

Quantity: Nineteen (19)

Metro Model A2442NK3

Super Adjustable Super Erecta® Shelf, wire, 42"W x 24"D, Metroseal 3 (corrosion-resistant) finish, corner release system, with Microban® antimicrobial protection, NSF Shelving to be 5 tier units with the bottom shelf at a minimum of 12" above finished floor. Provide any necessary cross bracing at all freestanding shelving units.

Accessories:

- 76 ea. Model 74P Super Erecta® SiteSelect™ Post, 74-5/8"H, adjustable leveling bolt, posts are grooved at 1" increments & numbered at 2" increments, double grooved every 8", chrome finish.
- 152 ea. Provide 16 gauge stainless steel post brackets at back posts as shown at upper locations
- 38 ea. Model BCS wall bracket.
- 38 ea. Model 9993S foot plates

**ITEM 50 - DRY STORAGE SHELVING**

Quantity: Three (3)

Metro Model A2448NK3

Super Adjustable Super Erecta® Shelf, wire, 48"W x 24"D, Metroseal 3 (corrosion-resistant) finish, corner release system, with Microban® antimicrobial protection, NSF Shelving to be 5 tier units with the bottom shelf at a minimum of 12" above finished floor. Provide any necessary cross bracing at all freestanding shelving units.

Accessories:

- 12 ea. Model 74P Super Erecta® SiteSelect™ Post, 74-5/8"H, adjustable leveling bolt, posts are grooved at 1" increments & numbered at 2" increments, double grooved every 8", chrome finish.
- 24 ea. Provide 16 gauge stainless steel post brackets at back posts as shown at upper locations
- 6 ea. Model BCS wall bracket.
- 12 ea. Model 9993S foot plates



**ITEM 51 - DRY STORAGE SHELVING**

Quantity: Six (6)

Metro Model A2454NK3

Super Adjustable Super Erecta® Shelf, wire, 54"W x 24"D, Metroseal 3 (corrosion-resistant) finish, corner release system, with Microban® antimicrobial protection, NSF Shelving to be 5 tier units with the bottom shelf at a minimum of 12" above finished floor. Provide any necessary cross bracing at all freestanding shelving units.

Accessories:

- 24 ea. Model 74P Super Erecta® SiteSelect™ Post, 74-5/8"H, adjustable leveling bolt, posts are grooved at 1" increments & numbered at 2" increments, double grooved every 8", chrome finish.
- 48 ea. Provide 16 gauge stainless steel post brackets at back posts as shown at upper locations
- 12 ea. Model BCS wall bracket.
- 24 ea. Model 9993S foot plates

**ITEM 52 - DUNNAGE RACK**

Quantity: Four (4)

New Age Model 2054

Dunnage Rack, 42"W x 20"D x 12"H, all welded aluminum construction, 1-1/2" x 1-3/4" x 0.070 tubing, welded aluminum caps on feet, weight capacity 3000 lbs., NSF

Accessories:

- 4 ea Lifetime warranty against rust & corrosion, 5 year construction warranty, std.

**ITEM 53 - DETERGENT STORAGE SHELVING**

Quantity: Four (4)

Metro Model A1848NC

Super Adjustable Super Erecta® Shelf, wire, 48"W x 18"D, Metroseal 3 (corrosion-resistant) finish, corner release system, with Microban® antimicrobial protection, NSF Shelving to be 5 tier units with the bottom shelf at a minimum of 12" above finished floor. Provide any necessary cross bracing at all freestanding shelving units.

Accessories:

- 16 ea. Model 74P Super Erecta® SiteSelect™ Post, 74-5/8"H, adjustable leveling bolt, posts are grooved at 1" increments & numbered at 2" increments, double grooved every 8", chrome finish.
- 32 ea. Provide 16 gauge stainless steel post brackets at back posts as shown at upper locations
- 8 ea. Model BCS wall bracket.
- 16 ea. Model 9993S foot plates

**ITEM 54 - REMOTE REFRIGERATION SYSTEM (ON GRADE)**

Quantity: One (1)

Cooltec Refrigeration Model CRS-4

Remote refrigeration systems as manufactured by Cooltec Refrigeration Corp. Custom Multi-Circuited refrigeration package shall be furnished as complete refrigeration systems to service walk-in freezer item No. 2 and walk-in refrigerator Item no. 3 as shown.

Contractor shall furnish and install, where shown on plans, U.L." Air-cooled Remote Refrigeration Package as shown on drawings. Refrigeration system shall be housed in a weather protected enclosure. The frame, enclosure, and panels shall be fabricated of galvanized steel. Entire frame shall be pre-assembled, welded, cleaned, and painted with a prime coat of zinc chromate then finished with a coat of baked enamel epoxy based paint. The condenser shall be sectional, removable multi-circuited with rifled tube slotted finned and shall be designed for 20°F TD. Condenser fan motors shall be mounted on the top of the enclosure.

1. REFRIGERATION UNITS

- A. Air-cooled condensing units shall be hermetic/glacier scroll type (Copeland). Each unit shall be equipped with high-low pressure control, liquid drier, sight glass & head pressure control, time clocks and pump down solenoids.
- B. All compressor units shall be new factory assembled to operate with the refrigerant specified in the engineering summary sheet. Refrigerant R-404a shall be used on all commercial temperature units and low temperature units.

## 2. PRE-PIPING

- A. All refrigerant lines shall be extended to right side of the package in a neat and orderly manner. Suction lines must be insulated with Armaflex (1" thick for low temp, 3/4" thick for medium temp).
- B. All tubing shall be securely supported and anchored with clamps.
- C. Silver solder and/or sil-fos shall be used for all refrigerant piping. Soft solder is not acceptable.
- D. All piping to be pressure tested with nitrogen at 300 PSI. After the condensing unit and coil have been connected, the balance of the system shall be leak tested with all valves open.

## 3. CONTROL PANEL

- A. The package shall have factory mounted and pre-wired control panel complete with main disconnect breaker switch, compressor circuit breakers, fuses, contactors and time clocks wired for single point connection.
- B. Electrical contractor shall provide and install main power lines to panel and provide wire harness wiring for control and defrost heater between and the defrost clock and the refrigerant fixtures, all in accordance with the wiring diagram and local codes.

## 4. SAFETY CAUTION

- A. Each system and evaporator is shipped under nitrogen pressure. Use caution and exercise safety at all times when preparing for final hook-up.

## 5. EVAPORATOR COIL

- A. Evaporator coils shall be direct expansion type fabricated of copper tubes with aluminum fins. All evaporator coils shall be provided with solenoid valve, thermostatic expansion valve, and electronic thermostat, piped and wired to the junction box for positive pump down.
- B. Evaporative coils shall be equipped with energy saving "EC" motors.

## CONSTRUCTION NOTES FOR TRADES

1. CONTRACTOR

- A. Contractors shall verify all dimensions and coordinate with other trades.
- B. Contractor shall prepare and weather proof the platform and curbed openings for refrigeration piping and electrical conduit.
- C. Contractor to provide underground trenching including all backfill for conduits.

2. REFRIGERATION CONTRACTOR

- A. Contractor shall use only clean dehydrated, sealed refrigeration grade A.C.R. copper tubing. Use only long radius elbows to reduce flow resistance and line breakage. Do not use 45 degree elbows at all.
- B. Silver solder and/or sil-fos shall be used on all refrigerant piping. Soft solder is not acceptable. Use minimum 35 % silver solder for dissimilar metals.
- C. All piping must be supported with hangers that can withstand the combined weight of tubing, insulation, valves, and fluid in the tubing.
- D. Use dry hydrogen in the copper tubing during brazing to prevent formation of copper oxides. Liquid and suction lines must be free to expand independently of each other. Do not exceed 100 feet without a change in direction or an offset. Plan proper pitching, expansion allowance, and p-Traps at the base of all suction risers and at every 15 feet of every vertical rise. Install service valves at several locations for ease of maintenance. These valves must be approved for 450 PSI working pressure.
- E. All piping to be pressure tested with nitrogen at 100 PSI with all valves open and held for 12 hours. Electronic leak detectors shall be used to locate all leaks.
- F. Complete system shall be evacuated to 500 microns with vacuum pump before charging the system.
- G. Once system is charged and running, adjust all controls including pressure controls, expansion valves, thermostats, and time clocks. Return after 24 hours to verify proper operation of systems.
- H. Refrigeration contractor to provide and install drain line heater with insulation in freezer to be connected by the electrical contractor.
- I. Refrigerant suction lines outside of refrigerated compartments, not run in conduit, shall be insulated back to compressor with Armstrong Arma-Flex AP-25/50 foamed plastic insulation or equal in accord with direction of the manufacturer. Minimum thickness shall be  $\frac{3}{4}$ " inch for commercial temperature and 1" inch for low temperature. Seal all joints with Armstrong 520 adhesive, or equal. Insulation exposed to the weather shall be finished with two coats of Armstrong white Armaflex finish, or equal. Apply insulation in strict accordance with manufacturer's recommendations.

3. ELECTRICAL CONTRACTOR

- A. Electrical contractor provide power for refrigeration package and connect control and defrost system as called for in the wiring diagram.
- B. Electrical contractor to provide 5-wire color-coded service from the time clock at the refrigeration package to blower coil in fixture for automatic defrost.
- C. Electrical contractor to connect drain-line heater in freezer.
- D. All electrical wiring and installation shall be in accordance with the wiring diagram and local codes.

4. PLUMBING CONTRACTOR

- A. Plumbing contractor to provide type "M" copper drain lines for walk-in refrigerator and freezer, pitched 1/2" per foot of run. In freezer, heated drain line must be insulated to prevent freezing. Trap drain lines outside of refrigerated space to avoid entrance of warm and moist air.
- B. Plumbing contractor to provide individual drain line for each evaporator unless otherwise called for in the plans.
- C. All plumbing installation shall be in accordance with local codes.
  - 1. Factory personnel shall install this assembly with written certification provided by the manufacture to the Architect and Consultant.
  - 2. Condensing units shall be air cooled semi-hermetic compressors.
  - 3. Unit evaporators shall be sized and furnished as part of this item.
  - 4. The system shall be provided with a weather cover and mounting channel unit and shall be completely treated with a rust preventative and two coats of baked enamel paint in color as selected by the Architect and where required shall be removable.
  - 5. The condensing units shall be factory installed and factory wired to a common load center panel for one point field electrical connection. All wiring from the condensing units to the load center shall be through an electrical raceway.
  - 6. The load center control panel shall be U.L listed and N.E.C approved and weatherproof with individual breakers for each condensing unit and time clocks. All contractors, time clocks, relays, automatic starting switches and any necessary electrical components shall be installed with the load center panel.
  - 7. All condensing units shall be manufactured by Copeland.
  - 8. The system shall incorporate the following items:
    - a. Flexible vibration eliminator in the suction line.
    - b. Liquid line sight glass.
    - c. Liquid line dehydrator filter of ample capacity.

- d. Suction line filter of ample capacity.
  - e. Thermal expansion valve for evaporator.
  - f. Heat exchanger for evaporator.
  - g. Refrigeration lines, hard copper Type "L" with "Silfos" brazed joints.
  - h. Defrost timers and interlock relays as required.
  - I. Winter control package.
9. Circuit breakers, automatic starting switch, motor protectors and pressure limit switches, all enclosed with interconnecting wires installed in a control panel ready for final connection by the Electrical Contractor.
  10. Drain line heaters with insulated covers for all drain lines from unit evaporators to nearest indirect waste (floor sink).
  11. Start-up, adjustment, and one year parts and labor warranty. Five-year warranty on motor compressors.

5. REFRIGERATION PIPING:

- A. Copper tubing shall conform to ASTM B88, piping shall be type 'L' ARC, and refrigerant piping shall be exposed to view as required by the American Standard Safety Code for Mechanical Refrigeration.
- B. Suction lines shall be sized to give a minimum pressure drop from evaporator to machine of 2 lbs. For high temperature systems and 1 lbs. for low temperature systems and shall allow gas velocities of not less than 750 FPM in horizontal runs and 1500 FPM in vertical risers. Liquid lines shall be sized to give maximum pressure drop of 3 lbs. from receiver to evaporator.
- C. Tubing shall be graded to prevent trapping of oil.
- D. Refrigerant piping shall be properly secured with 'Uni-Strut' clamps located to conform to proper refrigerant piping practice.
- E. Insulation of refrigerant lines.
- F. Refrigerant suction lines outside of refrigerated compartments, not run in conduit shall be insulated with Armstrong FR/ARMAFLEX22. Minimum thickness of 1/2" for medium temperatures and 3/4" for low temperature units. Slitting of insulation shall not be permitted. Seal all joints with Armstrong 520 adhesive, or equal. Insulation exposed to the weather shall be finished with two coats of Armstrong white Armaflex finish, or equal. Apply insulation in strict accordance with manufacturer's recommendations.

6. TESTING and DEHYDRATING:

- A. Pressurized systems with nitrogen to 300 PSI, test for leaks, after with each system shall be subjected to a vacuum to 100 microns for a period of 24 hours.

7. CHARGING SYTEM:

- A. Provide refrigerant and oil, charge all systems and run an operational check for three (3) days duration.
- B. Work by other trades: Final wiring of connections, inter wiring of time clocks and defrost relays, drain tubing from unit evaporators to nearest indirect drain, building sleeves, penetrations, conduit and/ or pull boxes provided under applicable General, Plumbing and or Electrical Sections.
- C. Unit evaporators and condensing units as shown on the drawings and as specified are intended as a guide only and shall be verified and installed under the supervising of a competent refrigeration engineer.
- D. Provide a metal backed baked (black and white) enamel wiring diagram for the system mounted on the outside panel of the unit evaporator and condensing unit.
- E. Provide shop drawings and brochures for review, showing exact overall dimensions and weights, utility requirements, all accessories and piping diagrams, all conforming to all applicable codes and regulations.
- F. Provide all refrigeration 16 gauge galvanized pipe covers at horizontal run at refrigeration unit and at exterior building wall. Covers are to be painted to match adjacent surface.

Please note that the location of the condensing units are to be outside and are to be complete with "winter controls and covers". The location of these condensing units will not exceed a distance of more than 200 feet from the walk-in. Actual location to be verified with Architect or General Contractor. This unit to comply with all codes and standards of NSF, UL, ICI30, Class I material. Factory Mutual Insurance System. Provide and extended warranty of all refrigeration systems.

**ITEM 55 – SERVING COUNTER**

Quantity: One (1)

American Stainless Steel Corp. Model FABRICATED ITEM

Fabricated assembly in length and configuration as shown on the drawings and shall include the following:

- A. Top to be 14 gauge stainless steel complete with 2" turn downs on 4 sides and a working height of 2'-10".
- B. Base section to be 16 gauge stainless steel formed metal construction complete with 16 gauge stainless steel bottom and mid shelves.
- C. Provide 1 5/8" dia. Stainless steel tube legs with Component Hardware Group, Inc. A10-0851 adjustable foot insert.
- D. Provide front apron for controls of food wells items 34 and 35. Provide drain valve and manifolded drains for food wells.

END OF SECTION



SECTION 11 6623 – BASKETBALL HOOPS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes the following gymnasium equipment:
  - 1. Stationary post mounted backstop

1.3 SUBMITTALS

- A. Product Data: For each type of product indicated.
  - 1. If applicable, include assembly, disassembly, and storage instructions for removable equipment.
- B. Shop Drawings: For gymnasium equipment. Include plans, elevations, sections, details, attachments to other work, and the following:
  - 1. Method of field assembly for connections, installation details, mountings and attachments to other work.
- C. Structural analysis data signed and sealed by the qualified professional engineer responsible for their preparation including loads, point reactions, and locations for attachment of gymnasium equipment to structure.

1.4 QUALITY ASSURANCE

- A. Source Limitations: Obtain each type of gymnasium equipment through one source from a single manufacturer.

1.5 PROJECT CONDITIONS

- A. Field Measurements: Verify position and elevation of floor inserts and layout for gymnasium equipment.



1.6 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of gymnasium equipment that fail in materials or workmanship within specified warranty period.
  - 1. Failures include, but are not limited to, the following:
    - a. Basketball backboard failures.
  - 2. Warranty Period: Five years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 MATERIALS

2.2 BASKETBALL EQUIPMENT

- A. Basis-of-Design Product: Subject to compliance with requirements, provide one of the following:
  - 1. AALCO Manufacturing.
  - 2. Basketball Products International; a division of American Athletic, Inc.
  - 3. Institutional Products Inc.
  - 4. Performance Sports Systems.
  - 5. Porter Athletic Equipment Company.
  - 6. Score-Pro Inc.
- B. Stationary post mounted backstops (exterior): 4-1/2-inch O.D. galvanized pipe upright with aluminum fan shaped backboard with goal mounted to upright with 3-1/2-inch O.D. pipe extension arm similar to the following:
  - 1. Post: Porter 00175-310.
  - 2. Backboard: Porter 00234-300.
  - 3. Goal: Porter 00225-000.

2.3 INSTALLATION, GENERAL

- A. General: Comply with manufacturer's written installation instructions.
- B. Permanently Placed Gymnasium Equipment and Components: Rigid, level, plumb, square, and true; anchored securely to supporting structure; positioned at locations and elevations indicated on Shop Drawings; in proper relation to adjacent construction; and aligned with court layout.

END OF SECTION 116623

**DIVISION 12 – FURNISHINGS**



SECTION 12 2113 - HORIZONTAL LOUVER BLINDS

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

A. Section Includes:

- 1. Horizontal louver blinds with aluminum slats.

B. Related Requirements:

- 1. Section 061000 "Miscellaneous Rough Carpentry" for wood blocking and grounds for mounting horizontal louver blinds and accessories.

1.3 ACTION SUBMITTALS

A. Product Data: For each type of product.

B. Shop Drawings: Show fabrication and installation details for horizontal louver blinds.

C. Samples for Initial Selection: For each type and color of horizontal louver blind.

- 1. Include similar Samples of accessories involving color selection.

D. Samples for Verification: For each type and color of horizontal louver blind indicated.

- 1. Slat: Not less than 12 inches long.
- 2. Tapes: Full width, not less than 6 inches long.
- 3. Horizontal Louver Blind: Full-size unit, not less than 16 inches wide by 24 inches long.
- 4. Valance: Full-size unit, not less than 12 inches wide.

E. Window-Treatment Schedule: For horizontal louver blinds. Use same designations indicated on Drawings.

1.4 INFORMATIONAL SUBMITTALS

A. Product Certificates: For each type of horizontal louver blind.

1.5 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For horizontal louver blinds to include in maintenance manuals.

1.6 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials, from the same product run, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Horizontal Louver Blinds: Full-size units equal to 5 percent of quantity installed for each size, color, texture, pattern, and gloss indicated, but no fewer than two units.

1.7 QUALITY ASSURANCE

- A. Mockups: Build mockups to verify selections made under Sample submittals and to demonstrate aesthetic effects and set quality standards for fabrication and installation.
  - 1. Approval of mockups does not constitute approval of deviations from the Contract Documents contained in mockups unless Architect specifically approves such deviations in writing.
  - 2. Subject to compliance with requirements, approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.

1.8 DELIVERY, STORAGE, AND HANDLING

- A. Deliver horizontal louver blinds in factory packages, marked with manufacturer, product name, and location of installation using same designations indicated on Drawings.

1.9 FIELD CONDITIONS

- A. Environmental Limitations: Do not install horizontal louver blinds until construction and wet and finish work in spaces, including painting, is complete and dry and ambient temperature and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.
- B. Field Measurements: Where horizontal louver blinds are indicated to fit to other construction, verify dimensions of other construction by field measurements before fabrication and indicate measurements on Shop Drawings. Allow clearances for operating hardware of operable glazed units through entire operating range. Notify Architect of installation conditions that vary from Drawings. Coordinate fabrication schedule with construction progress to avoid delaying the Work.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Source Limitations: Obtain horizontal louver blinds from single source from single manufacturer.

2.2 HORIZONTAL LOUVER BLINDS, ALUMINUM SLATS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:

1. Hunter Douglas Contract.
2. Levolor Contract; a Newell Rubbermaid company.
3. Springs Window Fashions.

- B. Slats: Aluminum; alloy and temper recommended by producer for type of use and finish indicated; with crowned profile and radius corners.

1. Width: 1 inch.
2. Thickness: Not less than 0.008 inch.
3. Spacing: Manufacturer's standard.
4. Finish: Ionized antistatic, dust-repellent, baked polyester finish.
5. Features:
  - a. Lift-Cord Rout Holes: Minimum size required for lift cord and located near back (outside) edge of slat to maximize slat overlap and minimize light gaps between slats.
  - b. Perforated Slats: Openness factor of 6 to 7 percent.

- C. Headrail: Formed steel or extruded aluminum; long edges returned or rolled. Headrails fully enclose operating mechanisms on three sides.

1. Capacity: One blind per headrail unless otherwise indicated.
2. Ends: Manufacturer's standard
3. Manual Lift Mechanism:
  - a. Lift-Cord Lock: Variable; stops lift cord at user-selected position within blind full operating range.
  - b. Operator: Extension of lift cord(s) through lift-cord lock mechanism to form cord pull.
4. Manual Tilt Mechanism: Enclosed worm-gear mechanism and linkage rod that adjusts ladders.
  - a. Tilt: Full.
  - b. Tilt: One direction, positive stop or lockout limited at an angle of 60 degrees from horizontal, both directions.
  - c. Operator: Dual cord.
  - d. Over-Rotation Protection: Manufacturer's detachable operator or slip clutch to prevent over rotation of gear.

- D. Bottom Rail: Formed-steel or extruded-aluminum tube that secures and protects ends of ladders and lift cords and has plastic- or metal-capped ends.
  - 1. Type: Top contoured to match crowned shape of slat.
- E. Lift Cords: Manufacturer's standard braided cord.
- F. Ladders: Evenly spaced across headrail at spacing that prevents long-term slat sag.
  - 1. Type: Braided cord.
- G. Valance: Manufacturer's standard.
- H. Mounting Brackets: With spacers and shims required for blind placement and alignment indicated.
  - 1. Type: Two piece for pocket installation
  - 2. Intermediate Support: Provide intermediate support brackets to produce support spacing recommended by blind manufacturer for weight and size of blind.
- I. Hold-Down Brackets and Hooks or Pins: Manufacturer's standard.
- J. Side Channels and Perimeter Light Gap Seals: Manufacturer's standard.
- K. Colors, Textures, Patterns, and Gloss:
  - 1. Slats: As selected by Architect from manufacturer's full range.
  - 2. Components: Provide rails, cords, ladders, and materials exposed to view matching or coordinating with slat color unless otherwise indicated.

## 2.3 HORIZONTAL LOUVER BLIND FABRICATION

- A. Product Safety Standard: Fabricate horizontal louver blinds to comply with WCMA A 100.1 including requirements for corded, flexible, looped devices; lead content of components; and warning labels.
- B. Unit Sizes: Fabricate units in sizes to fill window and other openings as follows, measured at 74 deg F:
  - 1. Between (Inside) Jamb Installation: Width equal to jamb-to-jamb dimension of opening in which blind is installed less 1/4 inch (6 mm) per side or 1/2 inch (13 mm) total, plus or minus 1/8 inch (3.1 mm). Length equal to head-to-sill dimension of opening in which blind is installed less 1/4 inch (6 mm), plus or minus 1/8 inch (3.1 mm).
  - 2. Outside of Jamb Installation: Width and length as indicated, with terminations between blinds of end-to-end installations at centerlines of mullion or other defined vertical separations between openings.
- C. Concealed Components: Noncorrodible or corrosion-resistant-coated materials.
  - 1. Lift-and-Tilt Mechanisms: With permanently lubricated moving parts.

- D. Mounting and Intermediate Brackets: Designed for removal and reinstallation of blind without damaging blind and adjacent surfaces, for supporting blind components, and for bracket positions and blind placement indicated.
- E. Installation Fasteners: No fewer than two fasteners per bracket, fabricated from metal noncorrosive to brackets and adjoining construction; type designed for securing to supporting substrate; and supporting blinds and accessories under conditions of normal use.
- F. Color-Coated Finish:
  - 1. Metal: For components exposed to view, apply manufacturer's standard baked finish complying with manufacturer's written instructions for surface preparation including pretreatment, application, baking, and minimum dry film thickness.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances, operational clearances, and other conditions affecting performance.
  - 1. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 INSTALLATION

- A. Install horizontal louver blinds level and plumb, aligned and centered on openings, and aligned with adjacent units according to manufacturer's written instructions.
  - 1. Locate so exterior slat edges are not closer than 1 inch (25 mm) from interior faces of glass and not closer than 1/2 inch (13 mm) from interior faces of glazing frames through full operating ranges of blinds.
  - 2. Install mounting and intermediate brackets to prevent deflection of headrails.
  - 3. Install with clearances that prevent interference with adjacent blinds, adjacent construction, and operating hardware of glazed openings, other window treatments, and similar building components and furnishings.

#### 3.3 ADJUSTING

- A. Adjust horizontal louver blinds to operate free of binding or malfunction through full operating ranges.

#### 3.4 CLEANING AND PROTECTION

- A. Clean horizontal louver blind surfaces after installation according to manufacturer's written instructions.



- B. Provide final protection and maintain conditions in a manner acceptable to manufacturer and Installer and that ensures that horizontal louver blinds are without damage or deterioration at time of Substantial Completion.
- C. Replace damaged horizontal louver blinds that cannot be repaired in a manner approved by Architect before time of Substantial Completion.

END OF SECTION 12 2113

SECTION 12 4813 - ENTRANCE FLOOR MATS AND FRAMES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Resilient entrance mats.

1.3 COORDINATION

- A. Coordinate size and location of recesses in concrete to receive floor mats and frames.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for floor mats and frames.
- B. Samples: For the following products, in manufacturer's standard sizes:
  - 1. Floor Mat: Assembled sections of floor mat.

1.5 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For floor mats and frames to include in maintenance manuals.

PART 2 - PRODUCTS

2.1 ENTRANCE FLOOR MATS, GENERAL

- A. Regulatory Requirements: Comply with applicable provisions in the California Building Code, the U.S. Architectural & Transportation Barriers Compliance Board's ADA-ABA Accessibility Guidelines for Buildings and Facilities and ICC A117.1.

## 2.2 RESILIENT ENTRANCE MATS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
1. American Floor Products Company, Inc.
  2. American Mat & Rubber Company.
  3. Arden Architectural Specialties, Inc.
  4. Balco, Inc.
  5. Cactus Mat Mfg. Co.
  6. Consolidated Plastics Company, Inc.
  7. C/S Group.
  8. Durable Corporation.
  9. Flexco.
  10. Mats Inc.
  11. Musson Rubber Company.
  12. Pawling Corporation; Architectural Products Division.
  13. Sbemco International Inc.; Matting by Design.
  14. Tennessee Mat Company, Inc.
  15. Tepromark International, Inc.
  16. U.S. Mat & Rubber Corporation.
- B. Rubber Mats: 1/4-inch- (6.4-mm-) thick mats; with beveled edges for surface applications and with solid-sheet (no perforations) style top profile, and flat-base bottom surface.
1. Color: As selected by Architect from full range of manufacturer's colors.
  2. Mat Size: 48" wide by 96" long.

## 2.3 FABRICATION

- A. Floor Mats: Shop fabricate units to greatest extent possible in sizes indicated. Unless otherwise indicated, provide single unit for each mat installation; do not exceed manufacturer's recommended maximum sizes for units that are removed for maintenance and cleaning. Where joints in mats are necessary, space symmetrically and away from normal traffic lanes. Miter corner joints in framing elements with hairline joints or provide prefabricated corner units without joints.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. Install surface-type units to comply with manufacturer's written instructions at locations indicated; coordinate with entrance locations and traffic patterns.

3.3 PROTECTION

- A. After completing frame installation and concrete work, provide temporary filler of plywood or fiberboard in recesses and cover frames with plywood protective flooring. Maintain protection until construction traffic has ended and Project is near Substantial Completion.

END OF SECTION 12 4813

SECTION 12 5500 - DETENTION FURNITURE

PART 1 - GENERAL

1.1 GENERAL REQUIREMENTS

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This Section includes the following:

- 1. Detention Bunks
- 2. Detention Desks & Seats
- 3. Detention Tables
- 4. Detention Seating
- 5. Miscellaneous Detention Furniture and Accessories

- B. Related Sections include the following:

- 1. Division 013513.16 Section "Special Project Procedures for Detention Facilities" for general requirements for detention work, including responsibilities of a single-source detention specialist.
- 2. Division 033000 Section "Cast-in-Place Concrete" for building anchors into concrete construction.
- 3. Division 042200 Section "Concrete Unit Masonry" for building anchors into and grouting detention furnishings installed in masonry construction.

1.3 SUBMITTALS

- A. Product Data: Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for each type of detention furnishing indicated.
- B. Shop Drawings: For each type of detention furnishing. Include plans, elevations, sections, details, and attachments to other Work.
- C. Coordination Drawings: Drawings of each built-in anchor supporting detention furnishings, including those to be installed as work of other Sections, drawn to scale and coordinating anchorage with detention furnishings. Show the following:
  - 1. Locations, dimensions, and profiles of wall and floor reinforcements.
  - 2. Locations and installation details of built-in anchors.
  - 3. Elevations of each detention furnishing showing dimensions of furnishing, preparations for receiving anchors, and locations of anchorage.
  - 4. Details of attachment of each detention furnishing to built-in anchors.

- D. Samples for Initial Selection: For each type of detention furnishing with factory-applied color finishes.
- E. Product Certificates: For each type of detention furnishing, signed by product manufacturer.
- F. Welding certificates.
- G. Qualification Data: For Installer and manufacturer.
- H. Maintenance Data: For detention lockers and cabinets to include in maintenance manuals.
- I. Warranties: Sample of special warranties specified in this Section.
- J. Other Informational Submittals:
  - 1. Examination reports documenting inspections of substrates, areas, and conditions.
  - 2. Anchor inspection reports documenting inspections of built-in and cast-in anchors.

#### 1.4 QUALITY ASSURANCE

- A. Installer Qualifications: An authorized representative of detention furnishing manufacturer for installation and maintenance of units required for this Project.
- B. Source Limitations: Obtain each type and variety of detention furnishing through one source from a single manufacturer, unless otherwise indicated.
- C. Welding: Qualify procedures and personnel according to the following:
  - 1. AWS D1.1, "Structural Welding Code--Steel."
  - 2. AWS D1.3, "Structural Welding Code--Sheet Steel."
- D. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination."

#### 1.5 PROJECT CONDITIONS

- A. Field Measurements: Verify openings for recessed detention furnishings by field measurements before fabrication and indicate measurements on Shop Drawings.
  - 1. Established Dimensions: Where field measurements cannot be made without delaying the work, establish opening dimensions and proceed with fabricating detention furnishings without field measurements. Coordinate wall and floor construction to ensure that actual opening dimensions correspond to established dimensions.

1.6 COORDINATION

- A. Coordinate installation of anchorages for detention furnishings. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors that are to be embedded in concrete or masonry. Deliver such items to Project site in time for installation.

1.7 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of detention furnishings that fail in materials or workmanship within specified warranty period. Failures include, but are not limited to, the following:
  - 1. Structural failures including deflection exceeding 1/4 inch (6 mm).
  - 2. Faulty operation of hardware.
  - 3. Deterioration of metals, metal finishes, and other materials beyond normal detention use.
- B. Warranty Period: Two years from date of Substantial Completion.

1.8 MAINTENANCE TOOLS

- A. Tool Kit: Provide six sets of tools for use with security fasteners, each packaged in a compartmented kit configured for easy handling and storage.

1.9 EXTRA MATERIALS

- A. Furnish extra materials described below that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Security Fasteners: Furnish not less twenty fasteners of each type and size of security fastener installed.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply for product selection:
  - 1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, the products specified.

2.2 MATERIALS

- A. Steel Plates, Shapes, and Bars: ASTM A 36/A 36M.



- B. Steel Sheet: ASTM A 569/A 569M, Type B, unless otherwise indicated.
- C. Steel Tubing: ASTM A 513, Type B, unless otherwise indicated; thickness indicated or required by structural loads.
- D. Steel Pipe: ASTM A 53, Standard Weight (Schedule 40), unless another weight is indicated or required by structural loads.
- E. Stainless-Steel Sheet, Strip, Plate, and Flat Bars: ASTM A 666, Type 304.
- F. Security Fasteners: Operable only by tools produced for use on specific type of fastener by fastener manufacturer or other licensed fabricator. Drive system type, head style, material, and protective coating as required for assembly, installation, and strength, and as follows:
  - 1. Drive System Types: Pinned Torx-Plus or pinned Torx.
  - 2. Socket Flat Countersunk Head Fasteners:
    - a. Heat-treated alloy steel, ASTM F 835 (ASTM F 835M).
    - b. Stainless steel, ASTM F 879 (ASTM F 879M), Group 1 CW.
  - 3. Socket Button Head Fasteners:
    - a. Heat-treated alloy steel, ASTM F 835 (ASTM F 835M).
    - b. Stainless steel, ASTM F 879 (ASTM F 879M), Group 1 CW.
  - 4. Socket Head Cap Fasteners:
    - a. Heat-treated alloy steel, ASTM A 574 (ASTM A 574M).
    - b. Stainless steel, ASTM F 837 (ASTM F 837M), Group 1 CW.
  - 5. Protective Coatings for Heat-Treated Alloy Steel:
    - a. Zinc chromate, ASTM F 1135, Grade 3 or 4; for exterior applications and interior applications where indicated.
    - b. Zinc phosphate with oil, ASTM F 1137, Grade I, or black oxide, unless otherwise indicated.
  - 6. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Camcar Textron Inc.
    - b. Holo-Krome; a Danaher Corporation.
    - c. Safety Socket Screw Corporation.
    - d. Tamper-Pruf Screws, Inc.
    - e. Tanner Bolt & Nut Co.
- G. Concealed Bolts: ASTM A 325, Grade A, unless otherwise indicated.
- H. Cast-in-Place Anchors in Concrete: Anchors of type indicated below, fabricated from corrosion-resistant materials capable of sustaining, without failure, a load equal to 4 times the load imposed, as determined by testing per ASTM E 488, conducted by a qualified independent testing agency.
  - 1. Threaded or wedge type; galvanized ferrous castings, either ASTM A 47 (ASTM A 47M), malleable iron or ASTM A 27/A 27M, cast steel. Provide bolts, washers, and shims as needed, hot-dip galvanized per ASTM A 153/A 153M.
- I. Embedded Plate Anchors: Fabricated from steel shapes and plates, minimum 3/16 inch (4.8 mm) thick; with minimum 1/2-inch- (12.7-mm-) diameter, headed studs welded to back of plate.

- J. Welding Rods and Bare Electrodes: Select according to AWS specifications for metal alloy welded.

## 2.3 ACCESSORIES

### A. Deal Trays (DDT):

- 1. Acceptable Products:
  - a. Creative Industries, Inc.; Model 1210S. (Trussbilt)
  - b. Norshield Security Products; Series 670000 deal tray.
  - c. Safeguard Security Services, Inc.; Armortex Dip Tray Model RMDT-1012.
  - d. North American Bullet Proof; Shotgard MDT 812.
  - e. Norix; Deal tray Model IDT-100
- 2. Construction: Minimum 0.053-inch (1.3 mm) thick stainless steel deal tray with flanges for mounting in countertop.
- 3. Mounting Depth: 1-3/4 inches (45 mm).

### B. Speaker Port (DSP):

- 1. Acceptable Products:
  - a. Creative Industries, Inc.; No. 6-FR Talk-thru.
  - b. Safeguard Security Services, Inc.; Armortex Universal Security Speaker Model SSS-7D-3.
  - c. Peterson Enterprises, Inc.; Speaking Device #SSSD1000.
  - d. Viking
  - e. Norix; Speaker Port Model ISP-100
- 2. Construction: Minimum 0.093-inch (2.3 mm) thick stainless steel, nominal 6 inch (150 mm) diameter, with offset holes in front and back plates that allow for natural voice transmission.
- 3. Fasteners: Security screws.

### C. Pass Hopper (DPH):

- 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
  - a. PSI, LLC; Passhopper.
  - b. FASCO Security Products.
  - c. Norix; Passhopper Model IPH-200
  - d. Peterson Detention, Inc.; RFP-1000 Series Rifle Pass.
- 2. Level 1 ballistic steel hopper with pull handle, slide bolt latch and minimum 1/2 inch (13 mm) diameter pivot pins and flanges for wall mounting.
- 3. Size: Nominal 9 inches (229 mm) deep x 11 inches (279 mm) high x 40 inches (1016 mm) long.
- 4. Finish: Prime coated.
- 5.

D. Tilt-Out, Six-Compartment Pistol Locker (DTPL):

1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
  - a. Folger Adam Detention Products; Pistol Locker, Model 405P-6.
  - b. Southern Folger; Pistol Locker (Tilt-out), #605.
  - c. Sweeper Metal Fabricators Corp.; Recessed Pistol Locker.
  - d. Tiffin Metal Products; Sidearm Locker.
  - e. Willo Products Company Inc.; Wall Mounted Pistol Locker, #770.
  - f. Peterson Detention, Inc.; 2000 Series Pistol Locker
  - g. Norix; Pistol locker model IPL-600
2. Cabinet: Minimum 39 inches (991 mm) wide by 15 inches (381 mm) high by 6 inches (152 mm) deep; formed from 0.1265-inch- (3.2-mm-) thick steel sheet. Line each compartment with moth-proofed felt or nonabsorbing, closed-cell padding.
3. Doors: Formed from same material as cabinet, supported by continuous bottom hinge, with attached tilt-out compartment with formed metal sides.
4. Locks: Cylinder type, keyed differently and master keyed; provide one lock for each compartment.
5. Mounting: Surface
6. Finish: Baked enamel.

E. Wall Mount Key Panel (DWKP)

1. Basis-of-Design Product: Subject to compliance with requirements, provide Chief Industries, Inc., Custom Products; consisting of 1-KC9090 Wall Mount Panel, 4-KC9091 Hinged Key Panel and 2-KC9092 Wall Mounted Rack or comparable product by one of the following:
  - a. Southern Folger
  - b. Sweeper Metal Fabricators Corp.
  - c. Willo Products Company, Inc.
  - d. Peterson Detention, Inc.
2. Wall Mount Panel: Nominal 19 inch wide x 22 inch high (48 x 56 mm) 0.123 inch (3.1 mm) thick steel panel with 25-0.125 inch (3.2 mm) thick stainless steel key pegs and 4-9/16 inch (14mm) mounting holes.
3. Hinged Key Panel: Nominal 22 inch (56 mm) square 0.123 inch (3.1 mm) thick steel panel with 25-0.125 inch (3.2 mm) thick stainless steel key pegs each side and 2-3/8 inch (9.5 mm) hinge pins.
4. Wall Mounted Rack: Nominal 12 inch long by 2 inch high (30 x 50 mm) 0.123 inch (3.1 mm) thick steel plate with 4-3/8 inch (9.5 mm) steel hinge barrels and 3-9/16 inch (14 mm) mounting holes.
5. Finish: Baked enamel.

2.4 DETENTION BUNKS

A. Freestanding Floor Mounted Single Bunk (DFSB):

1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
  - a. Norix – Attenda Space Saver 31” x 79”

- b. Color: As selected from Mfr's standard colors.
- c. One (1) bunk to be provided for a cell mock-up.

## 2.5 DETENTION DESKS

### A. Bolt to Wall Desk (DDSK):

- 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
  - a. Norix: Endurance Desk with bolt to wall application.
  - b. Color: As selected from Mfr's standard colors.
  - c. One (1) desk to be provided for a cell mock-up.

## 2.6 Detention Stool

### A. Bolt to Floor Stool (DFS):

- 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
  - a. Norix: Attenda Stool with bolt to floor application.
  - b. Color: As selected from Mfr's standard colors.
  - c. One (1) stool to be provided for a cell mock-up.

## 2.7 DETENTION TABLES

### A. Four-Legged Table (DLT):

- 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
  - a. Norix: Max-Master table with bolt to floor application.
  - b. Color: As selected from Mfr's standard colors.

### B. Folding Table, (DFT):

- 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
  - a. Norix: CorrecTable Folding table Model T245-321.
  - b. Color: As selected from Mfr's standard colors.

### C. Four-Legged Table, Accessible (DLT-A):

- 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
  - a. Norix: Max-Master table with bolt to floor application.
  - b. Color: As selected from Mfr's standard colors.

- D. Four-Legged Table, Accessible (DMT):
  - 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Norix: X-Base Series table.
    - b. Color: As selected from Mfr's standard colors.

## 2.8 DETENTION SEATING

- A. Dayroom Lounge Chair (DLC):
  - 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Norix Group, Inc., Hondo Lounge Armchair.
  - 2. Construction: One piece injection molded high impact fire retardant polypropylene with U.V. stabilizers.
  - 3. Color: As selected by Architect/Engineer.
- B. Lounge Cube (LC):
  - 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Norix Group, Inc., Hondo Cube
  - 2. Construction: One piece injection molded high impact fire retardant polypropylene with U.V. stabilizers.
  - 3. Color: As selected by Architect/Engineer.
- C. Beam Seating (BS):
  - 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Norix Group, Inc., Boulder Beam Seating (Bolt Down)
  - 2. Construction: Powder coated tube steel frames with welded steel plate seat supports.
  - 3. Seat: Washable molded polyethylene seats
  - 4. Color: As selected by Architect/Engineer.
- D. Detention Chair (DC):
  - 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
    - 2. Norix: Integra Series
    - 3. Color: As selected from Mfr's standard colors.

2.9 FABRICATION

- A. Shop Assembly: Preassemble items in shop to greatest extent possible to minimize field splicing and assembly. Disassemble units only as necessary for shipping and handling limitations. Use connections that maintain structural value of joined pieces. Clearly mark units for reassembly and coordinated installation.
- B. Coordinate dimensions and attachment methods of detention furnishings with those of adjoining construction to produce integrated assemblies with closely fitting joints and with edges and surfaces aligned, unless otherwise indicated.
- C. Shear and punch metals cleanly and accurately. Remove burrs.
- D. Form edges and corners to be free of sharp edges or rough areas. Fold back and crimp exposed edges of unsupported sheet metal to form a 1/2-inch- (12.7-mm-) wide hem on the concealed side; ease edges of metal plate to a radius of approximately 1/32 inch (0.8 mm).
  - 1. Fabricate detention furnishings with no more than 1/32-inch (0.8-mm) gap between component materials. Weld edges that cannot be crimped to meet tolerance so as to provide a seamless joint with no places for concealment of contraband.
- E. Form metal in maximum lengths to minimize joints. Form bent-metal corners to smallest radius possible without causing grain separation or otherwise impairing work.
- F. Weld corners and seams continuously to comply with referenced AWS standard and the following:
  - 1. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
  - 2. Obtain fusion without undercut or overlap.
  - 3. Remove welding flux immediately.
  - 4. At exposed connections, finish exposed welds and surfaces smooth and blended so no roughness shows after finishing and contour of welded surface matches that of adjacent surface.
  - 5. Provide smoothly finished eased edges of 1/32" minimum at outside corners.
  - 6. Weld before finishing components to greatest extent possible. Remove weld spatter and welding oxides from exposed surfaces by descaling or grinding.
- G. Provide for anchorage of type indicated; coordinate with supporting structure. Fabricate and space anchoring devices to secure metal fabrications rigidly in place and to support expected loads. Build in straps, plates, and brackets as needed to support and anchor fabricated items to adjoining construction. Reinforce formed-metal units as needed to attach and support other construction.
- H. Cut, reinforce, drill, and tap metal fabrications to receive hardware, security fasteners, and similar items.
- I. Form exposed work true to line and level with accurate angles and surfaces and straight sharp edges.

- J. Form exposed connections with hairline joints, flush and smooth, using concealed fasteners where possible. Use exposed security fasteners of type indicated or, if not indicated, flat-head (countersunk) security fasteners. Locate joints where least conspicuous.

## 2.10 FINISHES, GENERAL

- A. Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Finish detention furnishings after assembly.

## 2.11 STEEL FINISHES

- A. Surface Preparation: Remove mill scale and rust, if present, from uncoated steel, complying with SSPC-SP 5/NACE No. 1, "White Metal Blast Cleaning," or SSPC-SP 8, "Pickling."
- B. Baked-Enamel Finish: Immediately after cleaning and pretreating, apply manufacturer's standard two-coat, baked-enamel finish consisting of prime coat and thermosetting topcoat. Comply with paint manufacturer's written instructions for applying and baking to achieve a minimum dry film thickness of 1.2 mils (0.03 mm).
  - 1. Color and Gloss: As selected by Architect from manufacturer's full range.

## 2.12 STAINLESS-STEEL FINISHES

- A. General: Remove tool and die marks and stretch lines or blend into finish. Grind and polish surfaces to produce uniform, directionally textured, polished finish indicated, free of cross scratches. Run grain with long dimension of each piece.
- B. Intermediate Polish Finish: No. 3 finish, unless otherwise indicated.
- C. When polishing is completed, passivate and rinse surfaces. Remove embedded foreign matter and leave surfaces chemically clean.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of detention furnishings.
  - 1. Examine roughing-in for embedded and built-in anchors to verify actual locations of detention furnishing connections before detention furnishing installation.
  - 2. For the record, prepare written report, endorsed by Installer, listing conditions detrimental to performance of detention furnishings.

- B. Inspect built-in and cast-in anchor installations before installing detention furnishings to verify that anchor installations comply with requirements. Prepare inspection reports.
  - 1. Remove and replace anchors where inspections indicate that they do not comply with specified requirements. Reinspect after repairs or replacements are made.
  - 2. Perform additional inspections to determine compliance of replaced or additional work. Prepare inspection reports.
- C. Verify locations of detention furnishings with those indicated on Coordination Drawings.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. Fastening to In-Place Construction: Provide anchorage devices and fasteners where necessary for securing detention furnishings to in-place construction. Include threaded fasteners for concrete and masonry inserts, security fasteners, and other connectors.
- B. Cutting, Fitting, and Placement: Obtain manufacturer's written approval for cutting, drilling, and fitting required for installing detention furnishings. Set detention furnishings accurately in location, alignment, and elevation; with edges and surfaces level, plumb, true, and free of rack; and measured from established lines and levels.
- C. Provide temporary bracing or anchors in formwork for items that are to be built into concrete or masonry or similar construction.
- D. Fit exposed connections accurately together to form hairline joints. Weld connections that are not to be left as exposed joints but cannot be shop welded because of shipping size limitations.
- E. Field Welding: Comply with the following requirements:
  - 1. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
  - 2. Obtain fusion without undercut or overlap.
  - 3. Remove welding flux immediately.
  - 4. At exposed connections, finish exposed welds and surfaces smooth and blended so no roughness shows after finishing and contour of welded surface matches that of adjacent surface.
  - 5. Fillet Welds: Minimum size of 1/8 inch by 1-1/2 inches (3 mm by 38 mm) long, spaced not greater than 12 inches (305 mm) o. c.
- F. Assemble detention furniture that requires field assembly with security fasteners, with no exposed fasteners on exposed faces and frames.
- G. Furnish and install one detention mattress for each detention bunk.



3.3 FIELD QUALITY CONTROL

- A. Inspect installed products to verify compliance with requirements. Prepare inspection reports and indicate compliance with and deviations from the Contract Documents.
- B. Remove and replace detention work where inspections indicate that work does not comply with specified requirements.
- C. Perform additional inspections to determine compliance of replaced or additional work. Prepare inspection reports.
- D. Prepare field quality-control certification that states installed products and their installation comply with requirements in the Contract Documents.

3.4 CLEANING AND PROTECTION

- A. Touchup Painting: Immediately after erection, clean field welds, bolted connections, and abraded areas of shop paint, and paint exposed areas with same material as used for shop painting to comply with SSPC-PA 1 for touching up shop-painted surfaces.
- B. Touchup Painting: Cleaning and touchup painting of field welds, bolted connections, and abraded areas of shop paint are specified in Division 09 painting Sections.

END OF SECTION 12 5500

SECTION 12 93 00 – SITE FURNISHING

PART 1 - GENERAL

1.1 General Requirements

- A. Drawings and Conditions of Contract, including General and Supplementary Conditions and Division 1 Administration Sections, apply to this Division.

1.2 SUMMARY

- A. This section includes the following:

1. Site furnishing - Seating
2. Site furnishing - Tables
3. Miscellaneous site furniture and accessories

- B. Related Requirements:

1. Section 03 3000 “Cast-in-Place Concrete”.
2. Section 31 2000 “Earth Moving for excavation for installing concrete footings.

1.3 SUBMITTALS

- A. Product Data: Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for each type of furnishing indicated.
- B. Shop Drawings: For each type of site furnishing. Include plans, elevations, sections, details, and attachments to other Work.
- C. Coordination Drawings: Drawings of each built-in anchor supporting site furnishings, including those to be installed as work of other Sections, drawn to scale and coordinating anchorage with site furnishings. Show the following:
1. Locations, dimensions, and profiles of reinforcements.
  2. Locations and installation details of built-in anchors or sleeves.
  3. Elevations of each site furnishing showing dimensions of site furnishing, preparations for receiving anchors or sleeves, and locations of anchorage or sleeves.
  4. Details of attachment of each site furnishing to built-in anchors or sleeves.
- D. Samples for Initial Selection: For each type of site furnishing with factory-applied color finishes.
- E. Product Certificates: For each type of site furnishing, signed by product manufacturer.
- F. Qualification Data: For Installer and manufacturer.
- G. Warranties: Sample of special warranties specified in this Section.

H. Other Informational Submittals:

1. Examination reports documenting inspections of substrates, areas, and conditions.
2. Anchor inspection reports documenting inspections of built-in and cast-in anchors or sleeves.

1.4 QUALITY ASSURANCE

- I. Source Limitations: Obtain each type and variety of site furnishing through one source from a single manufacturer, unless otherwise indicated.
- J. Welding: Qualify procedures and personnel according to the following:
1. AWS D1.1, "Structural Welding Code--Steel."
  2. AWS D1.3, "Structural Welding Code--Sheet Steel."
- K. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination."

1.5 PROJECT CONDITIONS

- L. Field Measurements: Verify field measurements before fabrication and indicate measurements on Shop Drawings.

1.6 COORDINATION

- M. Coordinate installation of anchorages for site furnishings. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors that are to be embedded in concrete or masonry. Deliver such items to Project site in time for installation.

1.7 WARRANTY

- N. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of furnishings that fail in materials or workmanship within specified warranty period. Failures include, but are not limited to, the following:
1. Structural failures including deflection exceeding 1/4 inch (6 mm).
  2. Deterioration of metals, metal finishes, and other materials .
- O. Warranty Period: Two years from date of Substantial Completion.

PART 2 – PRODUCTS

2.1 MANUFACTURERS – Site Furnishings: Tables and seating

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply for product selection:
  - 1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, the products specified.
    - a. DuMor Site Furnishings, Mifflintown, PA
- B. Basis-of-Design Product: Subject to compliance with requirements, DuMor:
  - a. Table: 448-34
  - b. Table: 448-33

## 2.2 MATERIALS

- A. Steel tubing – ASTM A513, Type B, unless otherwise indicated, thickness per manufacturer.
- B. Steel pipe – ASTM A53, standard weight (schedule 40), per manufacturer.
- C. Fasteners: Operable only by tools produced for use on specific type of fastener by fastener manufacturer or other licensed fabricator.
- D. Cast-in-place Anchors in concrete: Anchors of type indicated by manufacturer, fabricated from corrosion-resistant materials capable of sustaining, without failure per manufacturer's requirements.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- P. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of site furnishings.
  - 1. Examine roughing-in for embedded and built-in anchors to verify actual locations of site furnishing connections before site furnishing installation.
  - 2. For the record, prepare written report, endorsed by Installer, listing conditions detrimental to performance of site furnishings.
- Q. Inspect built-in and cast-in anchor installations before installing site furnishings to verify that anchor installations comply with requirements. Prepare inspection reports.
  - 1. Remove and replace anchors where inspections indicate that they do not comply with specified requirements. Reinspect after repairs or replacements are made.
  - 2. Perform additional inspections to determine compliance of replaced or additional work. Prepare inspection reports.
- R. Verify locations of site furnishings with those indicated on Coordination Drawings.
- S. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. Comply with manufacturer's written installation instructions unless more stringent requirements are indicated. Complete field assembly of site furnishings where required.
- B. Unless otherwise indicated, install site furnishings after landscaping and paving have been completed.
- C. Install site furnishings level, plumb, true, and securely anchored at locations indicated on Drawings.
- D. Provide temporary bracing or anchors in formwork for items that are to be built into concrete or masonry or similar construction.

### 1.2 FIELD QUALITY CONTROL

- A. Inspect installed products to verify compliance with requirements. Prepare inspection reports and indicate compliance with and deviations from the Contract Documents.
- B. Remove and replace work where inspections indicate that work does not comply with specified requirements.
- C. Perform additional inspections to determine compliance of replaced or additional work. Prepare inspection reports.
- D. Prepare field quality-control certification that states installed products and their installation comply with requirements in the Contract Documents.

### 1.3 CLEANING AND PROTECTION

- A. Touchup Painting: Immediately after erection, clean field welds, bolted connections, and abraded areas of shop paint, and paint exposed areas with same material as used for shop painting to comply with SSPC-PA 1 for touching up shop-painted surfaces.
- B. Touchup Painting: Cleaning and touchup painting of field welds, bolted connections, and abraded areas of shop paint are specified in Division 09 painting Sections.

END OF SECTION 129300

SECTION 12 93 13 - BICYCLE RACKS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Bicycle racks.

1.02 RELATED REQUIREMENTS

- A. Section 03 3000 - Cast-in-Place Concrete: Mounting surface for bicycle racks.
- B. Section 05 5000 - Metal Fabrications: Custom metal outdoor furnishings.

1.03 REFERENCE STANDARDS

- A. ASTM A 53/A 53M - Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless; 2007.
- B. ASTM A 500/A 500M - Standard Specification for Cold-Formed Welded and Seamless Carbon Steel Structural Tubing in Rounds and Shapes; 2010.

1.04 SUBMITTALS

- A. See Section 01 3300 - Administrative Requirements, for submittal procedures.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
  - 1. Preparation instructions and recommendations.
  - 2. Storage and handling requirements and recommendations.
  - 3. Installation methods.
- C. Selection Samples: For each finish product specified, color chips representing manufacturer's full range of available colors and patterns.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Handle racks with sufficient care to prevent scratches and other damage to the finish.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Outdoor Bicycle Racks:
  - 1. Columbia Cascade Company: [www.timberform.com](http://www.timberform.com).
  - 2. Creative Pipe, Inc: [www.creativepipe.com](http://www.creativepipe.com).
  - 3. Highland Products Group, LLC: [www.indoorbikeracks.net](http://www.indoorbikeracks.net).
  - 4. Substitutions: See Section 01 6000 - Product Requirements.

2.02 BICYCLE RACKS

- A. Exterior Bicycle Racks: Device allows user provided lock to simultaneously secure one wheel and part of the frame on each bicycle parked or racked.
  - 1. Style: Serpentine rack formed from a continuous round pipe.
  - 2. Capacity: four (4) bicycles.
  - 3. Mounting, Ground: In-ground anchor.
  - 4. Finish: Powder coat, maintenance-free and weather-resistant.
  - 5. Color: As selected by Architect from manufacturer's standard range.
  - 6. Accessories: In-ground grout cover.

PART 3 EXECUTION

3.01 PREPARATION

- A. Ensure surfaces to receive bicycle racks are clean, flat, and level.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install bicycle racks level, plumb, square, and correctly located as indicated on the drawings.
- C. In-Ground Anchor Installation:
  - 1. Prepare holes in size according to manufacturer's instructions.
  - 2. Place anchoring bolts through the holes in the pipe.
  - 3. Lower rack into holes, ensuring the bottom of lower bends are at least 1-1/2 inch from the ground.
  - 4. Pour concrete and level rack.
  - 5. Support until dry.

3.03 CLEANING

- A. Clean installed work to like-new condition. Do not use cleaning materials or methods that could damage finish.

3.04 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

END OF SECTION

**DIVISION 21 – FIRE SUPPRESSION**



SECTION 210517 - SLEEVES AND SLEEVE SEALS FOR FIRE-SUPPRESSION PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Sleeves.
  - 2. Stack-sleeve fittings.
  - 3. Sleeve-seal systems.
  - 4. Sleeve-seal fittings.
  - 5. Grout.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.

PART 2 - PRODUCTS

2.1 SLEEVES

- A. Cast-Iron Wall Pipes: Cast or fabricated of cast or ductile iron and equivalent to ductile-iron pressure pipe, with plain ends and integral waterstop unless otherwise indicated.
- B. Galvanized-Steel Wall Pipes: ASTM A 53/A 53M, Schedule 40, with plain ends and welded steel collar; zinc coated.
- C. Galvanized-Steel-Pipe Sleeves: ASTM A 53/A 53M, Type E, Grade B, Schedule 40, zinc coated, with plain ends.
- D. PVC-Pipe Sleeves: ASTM D 1785, Schedule 40.
- E. Galvanized-Steel-Sheet Sleeves: 0.0239-inch (0.6-mm) minimum thickness; round tube closed with welded longitudinal joint.
- F. Molded-PE or -PP Sleeves: Removable, tapered-cup shaped, and smooth outer surface with nailing flange for attaching to wooden forms.
- G. Molded-PVC Sleeves: With nailing flange for attaching to wooden forms.

2.2 STACK-SLEEVE FITTINGS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
1. Smith, Jay R. Mfg. Co.
  2. Zurn Industries, LLC.
- B. Description: Manufactured, cast-iron sleeve with integral clamping flange. Include clamping ring, bolts, and nuts for membrane flashing.
1. Underdeck Clamp: Clamping ring with setscrews.

2.3 SLEEVE-SEAL SYSTEMS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
1. Advance Products & Systems, Inc.
  2. CALPICO, Inc.
  3. Metraflex Company (The).
  4. Pipeline Seal and Insulator, Inc.
  5. Proco Products, Inc.
- B. Description: Modular sealing-element unit, designed for field assembly, for filling annular space between piping and sleeve.
1. Sealing Elements: **[EPDM-rubber]** **[NBR]** interlocking links shaped to fit surface of pipe. Include type and number required for pipe material and size of pipe.
  2. Pressure Plates: **[Carbon steel]** **[Plastic]** **[Stainless steel]**.
  3. Connecting Bolts and Nuts: **[Carbon steel, with corrosion-resistant coating,]** **[Stainless steel]** of length required to secure pressure plates to sealing elements.

2.4 SLEEVE-SEAL FITTINGS

- A. Manufacturers: Subject to compliance with requirements, provide products by the following:
1. HOLDRITE.
- B. Description: Manufactured plastic, sleeve-type, waterstop assembly made for imbedding in concrete slab or wall. Unit has plastic or rubber waterstop collar with center opening to match piping OD.

2.5 GROUT

- A. Standard: ASTM C 1107/C 1107M, Grade B, post-hardening and volume-adjusting, dry, hydraulic-cement grout.
- B. Characteristics: Nonshrink; recommended for interior and exterior applications.

- C. Design Mix: 5000-psi (34.5-MPa), 28-day compressive strength.
- D. Packaging: Premixed and factory packaged.

### PART 3 - EXECUTION

#### 3.1 SLEEVE INSTALLATION

- A. Install sleeves for piping passing through penetrations in floors, partitions, roofs, and walls.
- B. For sleeves that will have sleeve-seal system installed, select sleeves of size large enough to provide 1-inch (25-mm) annular clear space between piping and concrete slabs and walls.
  - 1. Sleeves are not required for core-drilled holes.
- C. Install sleeves in concrete floors, concrete roof slabs, and concrete walls as new slabs and walls are constructed.
  - 1. Permanent sleeves are not required for holes in slabs formed by molded-PE or -PP sleeves.
  - 2. Cut sleeves to length for mounting flush with both surfaces.
    - a. Exception: Extend sleeves installed in floors of mechanical equipment areas or other wet areas 2 inches (50 mm) above finished floor level.
  - 3. Using grout, seal the space outside of sleeves in slabs and walls without sleeve-seal system.
- D. Install sleeves for pipes passing through interior partitions.
  - 1. Cut sleeves to length for mounting flush with both surfaces.
  - 2. Install sleeves that are large enough to provide 1/4-inch (6.4-mm) annular clear space between sleeve and pipe or pipe insulation.
  - 3. Seal annular space between sleeve and piping or piping insulation; use joint sealants appropriate for size, depth, and location of joint. Comply with requirements for sealants specified in Section 079200 "Joint Sealants."
- E. Fire-Barrier Penetrations: Maintain indicated fire rating of walls, partitions, ceilings, and floors at pipe penetrations. Seal pipe penetrations with firestop materials. Comply with requirements for firestopping specified in Section 078413 "Penetration Firestopping."

#### 3.2 STACK-SLEEVE-FITTING INSTALLATION

- A. Install stack-sleeve fittings in new slabs as slabs are constructed.
  - 1. Install fittings that are large enough to provide 1/4-inch (6.4-mm) annular clear space between sleeve and pipe or pipe insulation.

2. Secure flashing between clamping flanges for pipes penetrating floors with membrane waterproofing. Comply with requirements for flashing specified in Section 076200 "Sheet Metal Flashing and Trim."
3. Install section of cast-iron soil pipe to extend sleeve to 2 inches (50 mm) above finished floor level.
4. Extend cast-iron sleeve fittings below floor slab as required to secure clamping ring if ring is specified.
5. Using grout, seal the space around outside of stack-sleeve fittings.

- B. Fire-Barrier Penetrations: Maintain indicated fire rating of floors at pipe penetrations. Seal pipe penetrations with firestop materials. Comply with requirements for firestopping specified in Section 078413 "Penetration Firestopping."

### 3.3 SLEEVE-SEAL-SYSTEM INSTALLATION

- A. Install sleeve-seal systems in sleeves in exterior concrete walls and slabs-on-grade at service piping entries into building.
- B. Select type, size, and number of sealing elements required for piping material and size and for sleeve ID or hole size. Position piping in center of sleeve. Center piping in penetration, assemble sleeve-seal system components, and install in annular space between piping and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make a watertight seal.

### 3.4 SLEEVE-SEAL-FITTING INSTALLATION

- A. Install sleeve-seal fittings in new walls and slabs as they are constructed.
- B. Assemble fitting components of length to be flush with both surfaces of concrete slabs and walls. Position waterstop flange to be centered in concrete slab or wall.
- C. Secure nailing flanges to concrete forms.
- D. Using grout, seal the space around outside of sleeve-seal fittings.

### 3.5 SLEEVE AND SLEEVE-SEAL SCHEDULE

- A. Use sleeves and sleeve seals for the following piping-penetration applications:
1. Exterior Concrete Walls above Grade:
    - a. Piping Smaller Than NPS 6 (DN 150): Cast-iron wall sleeves Galvanized-steel wall sleeves Galvanized-steel-pipe sleeves Sleeve-seal fittings.
    - b. Piping NPS 6 (DN 150) and Larger: Cast-iron wall sleeves Galvanized-steel wall sleeves Galvanized-steel-pipe sleeves.
  2. Exterior Concrete Walls below Grade:

- a. Piping Smaller Than NPS 6 (DN 150): Cast-iron wall sleeves with sleeve-seal system Galvanized-steel wall sleeves with sleeve-seal system Galvanized-steel-pipe sleeves with sleeve-seal system Sleeve-seal fittings.
    - 1) Select sleeve size to allow for 1-inch (25-mm) annular clear space between piping and sleeve for installing sleeve-seal system.
  - b. Piping NPS 6 (DN 150) and Larger: Cast-iron wall sleeves with sleeve-seal system Galvanized-steel wall sleeves with sleeve-seal system Galvanized-steel-pipe sleeves with sleeve-seal system.
    - 1) Select sleeve size to allow for 1-inch (25-mm) annular clear space between piping and sleeve for installing sleeve-seal system.
3. Concrete Slabs-on-Grade:
- a. Piping Smaller Than NPS 6 (DN 150): Cast-iron wall sleeves with sleeve-seal system Galvanized-steel wall sleeves with sleeve-seal system Galvanized-steel-pipe sleeves with sleeve-seal system Sleeve-seal fittings.
    - 1) Select sleeve size to allow for 1-inch (25-mm) annular clear space between piping and sleeve for installing sleeve-seal system.
  - b. Piping NPS 6 (DN 150) and Larger: Cast-iron wall sleeves with sleeve-seal system Galvanized-steel wall sleeves with sleeve-seal system Galvanized-steel-pipe sleeves with sleeve-seal system Galvanized-steel-pipe sleeves.
    - 1) Select sleeve size to allow for 1-inch (25-mm) annular clear space between piping and sleeve for installing sleeve-seal system.
4. Concrete Slabs above Grade:
- a. Piping Smaller Than NPS 6 (DN 150): Galvanized-steel-pipe sleeves PVC-pipe sleeves Stack-sleeve fittings Sleeve-seal fittings Molded-PE or -PP sleeves Molded-PVC sleeves.
  - b. Piping NPS 6 (DN 150) and Larger: [**Galvanized-steel-pipe sleeves**] [**PVC-pipe sleeves**] [**Stack-sleeve fittings**].
5. Interior Partitions:
- a. Piping Smaller Than NPS 6 (DN 150): [**Galvanized-steel-pipe sleeves**] [**PVC-pipe sleeves**].
  - b. Piping NPS 6 (DN 150) and Larger: Galvanized-steel-sheet sleeves.

END OF SECTION 210517

SECTION 210518 - ESCUTCHEONS FOR FIRE-SUPPRESSION PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Escutcheons.
  - 2. Floor plates.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.

PART 2 - PRODUCTS

2.1 ESCUTCHEONS

- A. One-Piece, Cast-Brass Type: With polished, chrome-plated and rough-brass finish and setscrew fastener.
- B. One-Piece, Deep-Pattern Type: Deep-drawn, box-shaped brass with chrome-plated finish and spring-clip fasteners.
- C. One-Piece, Stamped-Steel Type: With chrome-plated finish and spring-clip fasteners.
- D. Split-Casting Brass Type: With polished, chrome-plated and rough-brass finish and with concealed hinge and setscrew.
- E. Split-Plate, Stamped-Steel Type: With chrome-plated finish, concealed hinge, and spring-clip fasteners.

2.2 FLOOR PLATES

- A. One-Piece Floor Plates: Cast-iron flange with holes for fasteners.
- B. Split-Casting Floor Plates: Cast brass with concealed hinge.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install escutcheons for piping penetrations of walls, ceilings, and finished floors.
- B. Install escutcheons with ID to closely fit around pipe, tube, and insulation of piping and with OD that completely covers opening.
  - 1. Escutcheons for New Piping:
    - a. Piping with Fitting or Sleeve Protruding from Wall: One-piece, deep-pattern type.
    - b. Chrome-Plated Piping: One-piece, cast-brass or split-casting brass type with polished, chrome-plated finish.
    - c. Insulated Piping: One-piece, stamped-steel type or split-plate, stamped-steel type with concealed hinge.
    - d. Bare Piping at Wall and Floor Penetrations in Finished Spaces: One-piece, cast-brass or split-casting brass type with polished, chrome-plated finish.
    - e. Bare Piping at Wall and Floor Penetrations in Finished Spaces: One-piece, stamped-steel type or split-plate, stamped-steel type with concealed hinge.
    - f. Bare Piping at Ceiling Penetrations in Finished Spaces: One-piece, cast-brass or split-casting brass type with polished, chrome-plated finish.
    - g. Bare Piping at Ceiling Penetrations in Finished Spaces: One-piece, stamped-steel type or split-plate, stamped-steel type with concealed hinge.
    - h. Bare Piping in Unfinished Service Spaces: One-piece, cast-brass or split-casting brass type with polished, chrome-plated rough-brass finish.
    - i. Bare Piping in Unfinished Service Spaces: One-piece, stamped-steel type or split-plate, stamped-steel type with concealed hinge.
    - j. Bare Piping in Equipment Rooms: One-piece, cast-brass or split-casting brass type with rough-brass finish.
    - k. Bare Piping in Equipment Rooms: One-piece, stamped-steel type or split-plate, stamped-steel type with concealed hinge.
  - 2. Escutcheons for Existing Piping:
    - a. Chrome-Plated Piping: Split-casting brass type with polished, chrome-plated finish.
    - b. Insulated Piping: Split-plate, stamped-steel type with concealed or exposed-rivet hinge.
    - c. Bare Piping at Wall and Floor Penetrations in Finished Spaces: Split-casting brass type with polished, chrome-plated finish.
    - d. Bare Piping at Wall and Floor Penetrations in Finished Spaces: Split-plate, stamped-steel type with concealed or exposed-rivet hinge.
    - e. Bare Piping at Ceiling Penetrations in Finished Spaces: Split-casting brass type with polished, chrome-plated finish.
    - f. Bare Piping at Ceiling Penetrations in Finished Spaces: Split-plate, stamped-steel type with concealed or exposed-rivet hinge.
    - g. Bare Piping in Unfinished Service Spaces: Split-casting brass type with polished, chrome-plated rough-brass finish.



- h. Bare Piping in Unfinished Service Spaces: Split-plate, stamped-steel type with concealed or exposed-rivet hinge.
    - i. Bare Piping in Equipment Rooms: Split-casting brass type with polished, chrome-plated rough-brass finish.
    - j. Bare Piping in Equipment Rooms: Split-plate, stamped-steel type with concealed or exposed-rivet hinge.
  - C. Install floor plates for piping penetrations of equipment-room floors.
  - D. Install floor plates with ID to closely fit around pipe, tube, and insulation of piping and with OD that completely covers opening.
    - 1. New Piping: One-piece, floor-plate type.
    - 2. Existing Piping: Split-casting, floor-plate type.
- 3.2 FIELD QUALITY CONTROL
  - A. Replace broken and damaged escutcheons and floor plates using new materials.

END OF SECTION 210518

SECTION 210523 - GENERAL-DUTY VALVES FOR WATER-BASED FIRE-SUPPRESSION PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Two-piece ball valves with indicators.
  - 2. Bronze butterfly valves with indicators.
  - 3. Iron butterfly valves with indicators.
  - 4. Check valves.
  - 5. Bronze OS&Y gate valves.
  - 6. Iron OS&Y gate valves.
  - 7. NRS gate valves.
  - 8. Indicator posts.
  - 9. Trim and drain valves.

1.3 DEFINITIONS

- A. NBR: Acrylonitrile-butadiene, Buna-N, or nitrile rubber.
- B. NRS: Nonrising stem.
- C. OS&Y: Outside screw and yoke.
- D. SBR: Styrene-butadiene rubber.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of valve.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Prepare valves for shipping as follows:
  - 1. Protect internal parts against rust and corrosion.
  - 2. Protect threads, flange faces, and weld ends.
  - 3. Set valves open to minimize exposure of functional surfaces.

- B. Use the following precautions during storage:
  - 1. Maintain valve end protection.
  - 2. Store valves indoors and maintain at higher than ambient dew point temperature. If outdoor storage is necessary, store valves off the ground in watertight enclosures.
- C. Use sling to handle large valves; rig sling to avoid damage to exposed parts. Do not use operating handles or stems as lifting or rigging points.
- D. Protect flanges and specialties from moisture and dirt.

## PART 2 - PRODUCTS

### 2.1 GENERAL REQUIREMENTS FOR VALVES

- A. UL Listed: Valves shall be listed in UL's "Online Certifications Directory" under the headings listed below and shall bear UL mark:
  - 1. Main Level: HAMV - Fire Main Equipment.
    - a. Level 1: HCBZ - Indicator Posts, Gate Valve.
    - b. Level 1: HLOT - Valves.
      - 1) Level 3: HLUG - Ball Valves, System Control.
      - 2) Level 3: HLXS - Butterfly Valves.
      - 3) Level 3: HMER - Check Valves.
      - 4) Level 3: HMRZ - Gate Valves.
  - 2. Main Level: VDGT - Sprinkler System & Water Spray System Devices.
    - a. Level 1: VQGU - Valves, Trim and Drain.
- B. FM Global Approved: Valves shall be listed in its "Approval Guide," under the headings listed below:
  - 1. Automated Sprinkler Systems:
    - a. Indicator posts.
    - b. Valves.
      - 1) Gate valves.
      - 2) Check valves.
        - a) Single check valves.
      - 3) Miscellaneous valves.
- C. Source Limitations for Valves: Obtain valves for each valve type from single manufacturer.
- D. ASME Compliance:

1. ASME B16.1 for flanges on iron valves.
  2. ASME B1.20.1 for threads for threaded-end valves.
  3. ASME B31.9 for building services piping valves.
- E. AWWA Compliance: Comply with AWWA C606 for grooved-end connections.
- F. NFPA Compliance: Comply with NFPA 24 for valves.
- G. Valve Pressure Ratings: Not less than the minimum pressure rating indicated or higher as required by system pressures.
- H. Valve Sizes: Same as upstream piping unless otherwise indicated.
- I. Valve Actuator Types:
1. Worm-gear actuator with handwheel for quarter-turn valves, except for trim and drain valves.
  2. Handwheel: For other than quarter-turn trim and drain valves.
  3. Handlever: For quarter-turn trim and drain valves NPS 2 (DN 50) and smaller.

## 2.2 TWO-PIECE BALL VALVES WITH INDICATORS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
1. NIBCO INC.
  2. Victaulic Company.
- B. Description:
1. UL 1091, except with ball instead of disc and FM Global standard for indicating valves (butterfly or ball type), Class Number 1112.
  2. Minimum Pressure Rating: 175 psig (1200 kPa).
  3. Body Design: Two piece.
  4. Body Material: Forged brass or bronze.
  5. Port Size: Full or standard.
  6. Seats: PTFE.
  7. Stem: Bronze or stainless steel.
  8. Ball: Chrome-plated brass.
  9. Actuator: Worm gear or traveling nut.
  10. Supervisory Switch: Internal or external.
  11. End Connections for Valves NPS 1 (DN 25) through NPS 2 (DN 50): Threaded ends.
  12. End Connections for Valves NPS 2-1/2 (DN 65): Grooved ends.

## 2.3 BRONZE BUTTERFLY VALVES WITH INDICATORS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Fivalco Inc.
2. Globe Fire Sprinkler Corporation.
3. Milwaukee Valve Company.

B. Description:

1. Standard: UL 1091 and FM Global standard for indicating valves, (butterfly or ball type), Class Number 1112.
2. Minimum: Pressure rating: 175 psig (1200 kPa).
3. Body Material: Bronze.
4. Seat Material: EPDM.
5. Stem Material: Bronze or stainless steel.
6. Disc: Bronze with EPDM coating.
7. Actuator: Worm gear or traveling nut.
8. Supervisory Switch: Internal or external.
9. Ends Connections for Valves NPS 1 (DN 25) through NPS 2 (DN 50): Threaded ends.
10. Ends Connections for Valves NPS 2-1/2 (DN 65): Grooved ends.

#### 2.4 IRON BUTTERFLY VALVES WITH INDICATORS

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Kennedy Valve Company; a division of McWane, Inc.
2. NIBCO INC.
3. Tyco Fire & Building Products LP.
4. Victaulic Company.

B. Description:

1. Standard: UL 1091 and FM Global standard for indicating valves, (butterfly or ball type), Class Number 112.
2. Minimum Pressure Rating: 175 psig (1200 kPa).
3. Body Material: Cast or ductile iron with nylon, EPDM, epoxy, or polyamide coating.
4. Seat Material: EPDM.
5. Stem: Stainless steel.
6. Disc: Ductile iron, nickel plated and EPDM or SBR coated.
7. Actuator: Worm gear or traveling nut.
8. Supervisory Switch: Internal or external.
9. Body Design: Lug or wafer Grooved-end connections.

#### 2.5 CHECK VALVES

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Globe Fire Sprinkler Corporation.
2. Kennedy Valve Company; a division of McWane, Inc.
3. NIBCO INC.

4. Victaulic Company.

B. Description:

1. Standard: UL 312 and FM Global standard for swing check valves, Class Number 1210.
2. Minimum Pressure Rating: 175 psig (1200 kPa).
3. Type: Single swing check.
4. Body Material: Cast iron, ductile iron, or bronze.
5. Clapper: Bronze, ductile iron, or stainless steel with elastomeric seal.
6. Clapper Seat: Brass, bronze, or stainless steel.
7. Hinge Shaft: Bronze or stainless steel.
8. Hinge Spring: Stainless steel.
9. End Connections: Flanged, grooved, or threaded.

2.6 BRONZE OS&Y GATE VALVES

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Milwaukee Valve Company.
2. NIBCO INC.
3. Zurn Industries, LLC.

B. Description:

1. Standard: UL 262 and FM Global standard for fire-service water control valves (OS&Y- and NRS-type gate valves).
2. Minimum Pressure Rating: 175 psig (1200 kPa).
3. Body and Bonnet Material: Bronze or brass.
4. Wedge: One-piece bronze or brass.
5. Wedge Seat: Bronze.
6. Stem: Bronze or brass.
7. Packing: Non-asbestos PTFE.
8. Supervisory Switch: External.
9. End Connections: Threaded.

2.7 IRON OS&Y GATE VALVES

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Kennedy Valve Company; a division of McWane, Inc.
2. NIBCO INC.
3. Victaulic Company.
4. Watts; a Watts Water Technologies company.
5. Zurn Industries, LLC.

B. Description:

1. Standard: UL 262 and FM Global standard for fire-service water control valves (OS&Y- and NRS-type gate valves).
2. Minimum Pressure Rating: 175 psig (1200 kPa).
3. Body and Bonnet Material: Cast or ductile iron.
4. Wedge: Cast or ductile iron, or bronze with elastomeric coating.
5. Wedge Seat: Cast or ductile iron, or bronze with elastomeric coating.
6. Stem: Brass or bronze.
7. Packing: Non-asbestos PTFE.
8. Supervisory Switch: External.
9. End Connections: Flanged Grooved Threaded.

## 2.8 NRS GATE VALVES

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. American Cast Iron Pipe Company.
2. Kennedy Valve Company; a division of McWane, Inc.
3. Mueller Co.
4. NIBCO INC.
5. Victaulic Company.

B. Description:

1. Standard: UL 262 and FM Global standard for fire-service water control valves (OS&Y- and NRS-type gate valves).
2. Minimum Pressure Rating: 175 psig (1200 kPa).
3. Body and Bonnet Material: Cast or ductile iron.
4. Wedge: Cast or ductile iron with elastomeric coating.
5. Wedge Seat: Cast or ductile iron, or bronze with elastomeric coating.
6. Stem: Brass or bronze.
7. Packing: Non-asbestos PTFE.
8. Supervisory Switch: External.
9. End Connections: Flanged Grooved Threaded.

## 2.9 INDICATOR POSTS

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. American Cast Iron Pipe Company.
2. Kennedy Valve Company; a division of McWane, Inc.
3. Mueller Co.
4. NIBCO INC.

B. Description:

1. Standard: UL 789 and FM Global standard for indicator posts.
2. Type: Underground.



3. Base Barrel Material: Cast or ductile iron.
4. Extension Barrel: Cast or ductile iron.
5. Cap: Cast or ductile iron.
6. Operation: Wrench Handwheel.

## 2.10 TRIM AND DRAIN VALVES

### A. Ball Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Fire Protection Products, Inc.
  - b. Milwaukee Valve Company.
  - c. NIBCO INC.
  - d. Potter Roemer LLC.
2. Description:
  - a. Pressure Rating: 175 psig (1200 kPa).
  - b. Body Design: Two piece.
  - c. Body Material: Forged brass or bronze.
  - d. Port size: Full or standard.
  - e. Seats: PTFE.
  - f. Stem: Bronze or stainless steel.
  - g. Ball: Chrome-plated brass.
  - h. Actuator: Handlever.
  - i. End Connections for Valves NPS 1 (DN 25) through NPS 2-1/2 (DN 65): Threaded ends.
  - j. End Connections for Valves NPS 1-1/4 and NPS 2-1/2 (DN 32 and DN 65): Grooved ends.

### B. Angle Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Fire Protection Products, Inc.
  - b. NIBCO INC.
  - c. United Brass Works, Inc.
2. Description:
  - a. Pressure Rating: 175 psig (1200 kPa).
  - b. Body Material: Brass or bronze.
  - c. Ends: Threaded.
  - d. Stem: Bronze.
  - e. Disc: Bronze.
  - f. Packing: Asbestos free.
  - g. Handwheel: Malleable iron, bronze, or aluminum.

C. Globe Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. NIBCO INC.
  - b. United Brass Works, Inc.
2. Description:
  - a. Pressure Rating: 175 psig (1200 kPa).
  - b. Body Material: Bronze with integral seat and screw-in bonnet.
  - c. Ends: Threaded.
  - d. Stem: Bronze.
  - e. Disc Holder and Nut: Bronze.
  - f. Disc Seat: Nitrile.
  - g. Packing: Asbestos free.
  - h. Handwheel: Malleable iron, bronze, or aluminum.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine valve interior for cleanliness, freedom from foreign matter, and corrosion. Remove special packing materials, such as blocks, used to prevent disc movement during shipping and handling.
- B. Operate valves in positions from fully open to fully closed. Examine guides and seats made accessible by such operations.
- C. Examine threads on valve and mating pipe for form and cleanliness.
- D. Examine mating flange faces for conditions that might cause leakage. Check bolting for proper size, length, and material. Verify that gasket is of proper size, that its material composition is suitable for service, and that it is free from defects and damage.
- E. Do not attempt to repair defective valves; replace with new valves.

3.2 GENERAL REQUIREMENTS FOR VALVE INSTALLATION

- A. Comply with requirements in the following Sections for specific valve installation requirements and applications:
  1. Section 211100 "Facility Fire-Suppression Water-Service Piping" for application of valves in fire-suppression water-service piping outside the building.
  2. Section 211200 "Fire-Suppression Standpipes" for application of valves in fire-suppression standpipes.

3. Section 211313 "Wet-Pipe Sprinkler Systems" for application of valves in wet-pipe, fire-suppression sprinkler systems.
  4. Section 211316 "Dry-Pipe Sprinkler Systems" for application of valves in dry-pipe, fire-suppression sprinkler systems.
  5. Section 211339 "Foam-Water Systems" for application of valves in AFFF piping.
- B. Install listed fire-protection shutoff valves supervised-open, located to control sources of water supply except from fire-department connections. Install permanent identification signs indicating portion of system controlled by each valve.
  - C. Install check valve in each water-supply connection. Install backflow preventers instead of check valves in potable-water-supply sources.
  - D. Install valves having threaded connections with unions at each piece of equipment arranged to allow easy access, service, maintenance, and equipment removal without system shutdown. Provide separate support where necessary.
  - E. Install valves in horizontal piping with stem at or above the pipe center.
  - F. Install valves in position to allow full stem movement.
  - G. Install valve tags. Comply with requirements in Section 210553 "Identification for Fire-Suppression Piping and Equipment" for valve tags and schedules and signs on surfaces concealing valves; and the NFPA standard applying to the piping system in which valves are installed. Install permanent identification signs indicating the portion of system controlled by each valve.
  - H. Install listed fire-protection shutoff valves supervised-open, located to control sources of water supply except from fire-department connections.
  - I. Install check valve in each water-supply connection. Install backflow preventers instead of check valves in potable-water-supply sources.

END OF SECTION 210523

SECTION 210548 - VIBRATION AND SEISMIC CONTROLS FOR FIRE-SUPPRESSION PIPING  
AND EQUIPMENT

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Elastomeric isolation pads.
2. Elastomeric isolation mounts.
3. Restrained elastomeric isolation mounts.
4. Pipe-riser resilient supports.
5. Resilient pipe guides.
6. Elastomeric hangers.
7. Snubbers.
8. Restraint channel bracings.
9. Seismic-restraint accessories.
10. Mechanical anchor bolts.
11. Adhesive anchor bolts.

B. Related Requirements:

1. Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment" for devices for plumbing equipment and systems.
2. Section 230548 "Vibration and Seismic Controls for HVAC" for devices for HVAC equipment and systems.

1.3 DEFINITIONS

- A. IBC: International Building Code.
- B. ICC-ES: ICC-Evaluation Service.
- C. OSHPD: Office of Statewide Health Planning & Development (for the State of California).

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.

1. Include rated load, rated deflection, and overload capacity for each vibration isolation device.
2. Illustrate and indicate style, material, strength, fastening provision, and finish for each type and size of vibration isolation device and seismic-restraint component required.
  - a. Tabulate types and sizes of seismic restraints, complete with report numbers and rated strength in tension and shear as evaluated by an evaluation service member of ICC-ES an agency acceptable to authorities having jurisdiction.
  - b. Annotate to indicate application of each product submitted and compliance with requirements.
3. Interlocking Snubbers: Include ratings for horizontal, vertical, and combined loads.

B. Delegated-Design Submittal: For each vibration isolation and seismic-restraint device.

1. Include design calculations and details for selecting vibration isolators and seismic restraints complying with performance requirements, design criteria, and analysis data signed and sealed by the qualified professional engineer responsible for their preparation.
2. Design Calculations: Calculate static and dynamic loading due to equipment weight and operation, due to seismic forces required to select vibration isolators, and due to seismic restraints.
3. Riser Supports: Include riser diagrams and calculations showing anticipated expansion and contraction at each support point, initial and final loads on building structure, spring deflection changes, and seismic loads. Include certification that riser system was examined for excessive stress and that none exists.
4. Seismic-Restraint Details:
  - a. Design Analysis: To support selection and arrangement of seismic restraints. Include calculations of combined tensile and shear loads.
  - b. Details: Indicate fabrication and arrangement. Detail attachments of restraints to the restrained items and to the structure. Show attachment locations, methods, and spacings. Identify components, list their strengths, and indicate directions and values of forces transmitted to the structure during seismic events. Indicate association with vibration isolation devices.
  - c. Coordinate seismic-restraint and vibration isolation details with wind-restraint details required for equipment mounted outdoors. Comply with requirements in other Sections for equipment mounted outdoors.
  - d. Preapproval and Evaluation Documentation: By an evaluation service member of ICC-ES an agency acceptable to authorities having jurisdiction, showing maximum ratings of restraint items and the basis for approval (tests or calculations).

1.5 INFORMATIONAL SUBMITTALS

- A. Coordination Drawings: Show coordination of vibration isolation device installation and seismic bracing for fire-suppression piping and equipment with other systems and equipment in the vicinity, including other supports and restraints, if any.
- B. Qualification Data: For professional engineer and testing agency.
- C. Welding certificates.

- D. Field quality-control reports.

## 1.6 QUALITY ASSURANCE

- A. Testing Agency Qualifications: An independent agency, with the experience and capability to conduct the testing indicated, that is an NRTL as defined by OSHA in 29 CFR 1910.7 and that is acceptable to authorities having jurisdiction.
- B. Comply with seismic-restraint requirements in the IBC unless requirements in this Section are more stringent.
- C. Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code - Steel."
- D. Seismic-restraint devices shall have horizontal and vertical load testing and analysis and shall bear anchorage preapproval OPA number from OSHPD, preapproval by ICC-ES, or preapproval by another agency acceptable to authorities having jurisdiction, showing maximum seismic-restraint ratings. Ratings based on independent testing are preferred to ratings based on calculations. If preapproved ratings are unavailable, submittals based on independent testing are preferred. Calculations (including combining shear and tensile loads) to support seismic-restraint designs must be signed and sealed by a qualified professional engineer.

## PART 2 - PRODUCTS

### 2.1 PERFORMANCE REQUIREMENTS

- A. Seismic-Restraint Loading:
  - 1. Site Class as Defined in the IBC: C.
  - 2. Assigned Seismic Use Group or Building Category as Defined in the IBC: I II III.
    - a. Component Importance Factor: 1.5.
    - b. Component Response Modification Factor: 1.5 2.5.
    - c. Component Amplification Factor: 1.0 2.5.
  - 3. Design Spectral Response Acceleration at Short Periods (0.2 Second): .
  - 4. Design Spectral Response Acceleration at 1.0-Second Period: .
  - 5. Rated strengths, features, and applications shall be as defined in reports by an evaluation service member of ICC-ES an agency acceptable to authorities having jurisdiction.
    - a. Structural Safety Factor: Allowable strength in tension, shear, and pullout force of components shall be at least four times the maximum seismic forces to which they are subjected.

### 2.2 ELASTOMERIC ISOLATION PADS

- A. Elastomeric Isolation Pads: .

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Ace Mountings Co., Inc.
  - b. California Dynamics Corporation.
  - c. Mason Industries, Inc.
2. Fabrication: Single or multiple layers of sufficient durometer stiffness for uniform loading over pad area.
3. Size: Factory or field cut to match requirements of supported equipment.
4. Pad Material: Oil and water resistant with elastomeric properties.
5. Surface Pattern: Smooth Ribbed Waffle pattern.
6. Infused nonwoven cotton or synthetic fibers.
7. Load-bearing metal plates adhered to pads.
8. Sandwich-Core Material: Resilient and elastomeric.
  - a. Surface Pattern: Smooth Ribbed Waffle pattern.
  - b. Infused nonwoven cotton or synthetic fibers.

## 2.3 ELASTOMERIC ISOLATION MOUNTS

### A. Double-Deflection, Elastomeric Isolation Mounts: .

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Ace Mountings Co., Inc.
  - b. Kinetics Noise Control, Inc.
  - c. Mason Industries, Inc.
2. Mounting Plates:
  - a. Top Plate: Encapsulated steel load transfer top plates, factory drilled and threaded with threaded studs or bolts.
  - b. Baseplate: Encapsulated steel bottom plates with holes provided for anchoring to support structure.
3. Elastomeric Material: Molded, oil-resistant rubber, neoprene, or other elastomeric material.

## 2.4 RESTRAINED ELASTOMERIC ISOLATION MOUNTS

### A. Restrained Elastomeric Isolation Mounts:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Ace Mountings Co., Inc.



- b. Kinetics Noise Control, Inc.
  - c. Mason Industries, Inc.
2. Description: All-directional isolator with seismic restraints containing two separate and opposing elastomeric elements that prevent central threaded element and attachment hardware from contacting the housing during normal operation.
    - a. Housing: Cast-ductile iron or welded steel.
    - b. Elastomeric Material: Molded, oil-resistant rubber, neoprene or other elastomeric material.

## 2.5 PIPE-RISER RESILIENT SUPPORT

- A. Description: All-directional, acoustical pipe anchor consisting of two steel tubes separated by a minimum 1/2-inch- (13-mm-) thick neoprene.
  1. Vertical-Limit Stops: Steel and neoprene vertical-limit stops arranged to prevent vertical travel in both directions.
  2. Maximum Load Per Support: 500 psig (3.45 MPa) on isolation material providing equal isolation in all directions.

## 2.6 RESILIENT PIPE GUIDES

- A. Description: Telescopic arrangement of two steel tubes or post-and-sleeve arrangement separated by a minimum 1/2-inch- (13-mm-) thick neoprene.
  1. Factory-Set Height Guide with Shear Pin: Shear pin shall be removable and reinsertable to allow for selection of pipe movement. Guides shall be capable of motion to meet location requirements.

## 2.7 ELASTOMERIC HANGERS

- A. Elastomeric Mount in a Steel Frame with Upper and Lower Steel Hanger Rods: .
  1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Ace Mountings Co., Inc.
    - b. Kinetics Noise Control, Inc.
    - c. Mason Industries, Inc.
  2. Frame: Steel, fabricated with a connection for an upper threaded hanger rod and an opening on the underside to allow for a maximum of 30 degrees of angular lower hanger-rod misalignment without binding or reducing isolation efficiency.
  3. Dampening Element: Molded, oil-resistant rubber, neoprene, or other elastomeric material with a projecting bushing for the underside opening preventing steel to steel contact.

2.8 SNUBBERS

- A. <Double click here to find, evaluate, and insert list of manufacturers and products.>
- B. Description: Factory fabricated using welded structural-steel shapes and plates, anchor bolts, and replaceable resilient isolation washers and bushings.
  - 1. Anchor bolts for attaching to concrete shall be seismic-rated, drill-in, and stud-wedge or female-wedge type.
  - 2. Resilient Isolation Washers and Bushings: Oil- and water-resistant neoprene.
  - 3. Maximum 1/4-inch (6-mm) air gap, and minimum 1/4-inch- (6-mm-) thick resilient cushion.

2.9 RESTRAINT CHANNEL BRACINGS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. B-line, an Eaton business.
  - 2. Hilti, Inc.
  - 3. Mason Industries, Inc.
  - 4. Unistrut; Part of Atkore International.
- B. Description: MFMA-4, shop- or field-fabricated bracing assembly made of slotted steel channels with accessories for attachment to braced component at one end and to building structure at the other end and other matching components and with corrosion-resistant coating; rated in tension, compression, and torsion forces.

2.10 SEISMIC-RESTRAINT ACCESSORIES

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Kinetics Noise Control, Inc.
  - 2. Mason Industries, Inc.
  - 3. TOLCO.
- B. Hanger-Rod Stiffener: Steel tube or steel slotted-support-system sleeve with internally bolted connections Reinforcing steel angle clamped to hanger rod.
- C. Hinged and Swivel Brace Attachments: Multifunctional steel connectors for attaching hangers to rigid channel bracings.
- D. Bushings for Floor-Mounted Equipment Anchor Bolts: Neoprene bushings designed for rigid equipment mountings, and matched to type and size of anchor bolts and studs.
- E. Bushing Assemblies for Wall-Mounted Equipment Anchorage: Assemblies of neoprene elements and steel sleeves designed for rigid equipment mountings, and matched to type and size of attachment devices used.

- F. Resilient Isolation Washers and Bushings: One-piece, molded, oil- and water-resistant neoprene, with a flat washer face.

#### 2.11 MECHANICAL ANCHOR BOLTS

- A. <Double click here to find, evaluate, and insert list of manufacturers and products.>
- B. Mechanical Anchor Bolts: Drilled-in and stud-wedge or female-wedge type in zinc-coated steel for interior applications and stainless steel for exterior applications. Select anchor bolts with strength required for anchor and as tested according to ASTM E 488.

#### 2.12 ADHESIVE ANCHOR BOLTS

- A. <Double click here to find, evaluate, and insert list of manufacturers and products.>
- B. Adhesive Anchor Bolts: Drilled-in and capsule anchor system containing PVC or urethane methacrylate-based resin and accelerator, or injected polymer or hybrid mortar adhesive. Provide anchor bolts and hardware with zinc-coated steel for interior applications and stainless steel for exterior applications. Select anchor bolts with strength required for anchor and as tested according to ASTM E 488.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine areas and equipment to receive vibration isolation and seismic-control devices for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Examine roughing-in of reinforcement and cast-in-place anchors to verify actual locations before installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 APPLICATIONS

- A. Multiple Pipe Supports: Secure pipes to trapeze member with clamps approved for application by an evaluation service member of ICC-ES an agency acceptable to authorities having jurisdiction.
- B. Hanger-Rod Stiffeners: Install hanger-rod stiffeners where indicated or scheduled on Drawings to receive them and where required to prevent buckling of hanger rods due to seismic forces.
- C. Strength of Support and Seismic-Restraint Assemblies: Where not indicated, select sizes of components so strength is adequate to carry present and future static and seismic loads within specified loading limits.

### 3.3 VIBRATION CONTROL AND SEISMIC-RESTRAINT DEVICE INSTALLATION

- A. Coordinate the location of embedded connection hardware with supported equipment attachment and mounting points and with requirements for concrete reinforcement and formwork specified in Section 033000 "Cast-in-Place Concrete." Section 033053 "Miscellaneous Cast-in-Place Concrete."
- B. Installation of vibration isolators must not cause any change of position of equipment, piping, or ductwork resulting in stresses or misalignment.
- C. Comply with requirements in Section 077200 "Roof Accessories" for installation of equipment supports and roof penetrations.
- D. Equipment Restraints:
  - 1. Install seismic snubbers on fire-suppression equipment mounted on vibration isolators. Locate snubbers as close as possible to vibration isolators and bolt to equipment base and supporting structure.
  - 2. Install resilient bolt isolation washers on equipment anchor bolts where clearance between anchor and adjacent surface exceeds 0.125 inch (3.2 mm).
  - 3. Install seismic-restraint devices using methods approved by an evaluation service member of ICC-ES an agency acceptable to authorities having jurisdiction that provides required submittals for component.
- E. Piping Restraints:
  - 1. Comply with requirements in MSS SP-127.
  - 2. Space lateral supports a maximum of 40 feet (12 m) o.c., and longitudinal supports a maximum of 80 feet (24 m) o.c.
  - 3. Brace a change of direction longer than 12 feet (3.7 m).
- F. Install seismic-restraint devices using methods approved by an evaluation service member of ICC-ES an agency acceptable to authorities having jurisdiction that provides required submittals for component.
- G. Install bushing assemblies for anchor bolts for floor-mounted equipment, arranged to provide resilient media between anchor bolt and mounting hole in concrete base.
- H. Install bushing assemblies for mounting bolts for wall-mounted equipment, arranged to provide resilient media where equipment or equipment-mounting channels are attached to wall.
- I. Attachment to Structure: If specific attachment is not indicated, anchor bracing to structure at flanges of beams, at upper truss chords of bar joists, or at concrete members.
- J. Drilled-in Anchors:
  - 1. Identify position of reinforcing steel and other embedded items prior to drilling holes for anchors. Do not damage existing reinforcing or embedded items during coring or drilling. Notify the structural engineer if reinforcing steel or other embedded items are encountered during drilling. Locate and avoid prestressed tendons, electrical and telecommunications conduit, and gas lines.

2. Do not drill holes in concrete or masonry until concrete, mortar, or grout has achieved full design strength.
3. Wedge Anchors: Protect threads from damage during anchor installation. Heavy-duty sleeve anchors shall be installed with sleeve fully engaged in the structural element to which anchor is to be fastened.
4. Adhesive Anchors: Clean holes to remove loose material and drilling dust prior to installation of adhesive. Place adhesive in holes proceeding from the bottom of the hole and progressing toward the surface in such a manner as to avoid introduction of air pockets in the adhesive.
5. Set anchors to manufacturer's recommended torque, using a torque wrench.
6. Install zinc-coated steel anchors for interior and stainless-steel anchors for exterior applications.

### 3.4 ACCOMMODATION OF DIFFERENTIAL SEISMIC MOTION

- A. Install flexible connections in piping where they cross seismic joints, where adjacent sections or branches are supported by different structural elements, and where the connections terminate with connection to equipment that is anchored to a different structural element from the one supporting the connections as they approach equipment. Comply with requirements in Section 211200 "Fire-Suppression Standpipes," Section 211313 "Wet-Pipe Sprinkler Systems," and Section 211316 "Dry-Pipe Sprinkler Systems" for piping flexible connections.

### 3.5 FIELD QUALITY CONTROL

- A. Testing Agency: Owner will engage a qualified testing agency to perform tests and inspections.
- B. Perform tests and inspections.
- C. Tests and Inspections:
  1. Provide evidence of recent calibration of test equipment by a testing agency acceptable to authorities having jurisdiction.
  2. Schedule test with Owner, through Architect, before connecting anchorage device to restrained component (unless postconnection testing has been approved), and with at least seven days' advance notice.
  3. Obtain Architect's approval before transmitting test loads to structure. Provide temporary load-spreading members.
  4. Test at least four of each type and size of installed anchors and fasteners selected by Architect.
  5. Test to 90 percent of rated proof load of device.
  6. Measure isolator restraint clearance.
  7. Measure isolator deflection.
  8. Verify snubber minimum clearances.
- D. Remove and replace malfunctioning units and retest as specified above.
- E. Prepare test and inspection reports.

END OF SECTION 210548

SECTION 210548.13 - VIBRATION CONTROLS FOR FIRE-SUPPRESSION PIPING AND EQUIPMENT

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

- 1. Pipe-riser resilient supports.
- 2. Resilient pipe guides.

B. Related Requirements:

- 1. Section 220548.13 "Vibration Controls for Plumbing Piping and Equipment" for devices for plumbing equipment and systems.
- 2. Section 230548.13 "Vibration Controls for HVAC" for devices for HVAC equipment and systems.

1.3 ACTION SUBMITTALS

A. Product Data: For each type of product.

- 1. Include rated load, rated deflection, and overload capacity for each vibration isolation device.
- 2. Illustrate and indicate style, material, strength, fastening provision, and finish for each type and size of vibration isolation device type required.

B. Delegated-Design Submittal: For each vibration isolation device.

- 1. Include design calculations for selecting vibration isolators.

1.4 INFORMATIONAL SUBMITTALS

A. Coordination Drawings: Show coordination of vibration isolation device installation for fire-suppression piping and equipment with other systems and equipment in the vicinity, including other supports and restraints, if any.

B. Qualification Data: For testing agency.

C. Welding certificates.

1.5 QUALITY ASSURANCE

- A. Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code - Steel."

PART 2 - PRODUCTS

2.1 PIPE-RISER RESILIENT SUPPORTS

- A. Description: All-directional, acoustical pipe anchor consisting of two steel tubes separated by a minimum 1/2-inch- (13-mm-) thick neoprene.
  - 1. Vertical-Limit Stops: Steel and neoprene vertical-limit stops arranged to prevent vertical travel in both directions.
  - 2. Maximum Load Per Support: 500 psig (3.45 MPa) on isolation material providing equal isolation in all directions.

2.2 RESILIENT PIPE GUIDES

- A. Description: Telescopic arrangement of 2 steel tubes or post and sleeve arrangement separated by a minimum 1/2-inch- (13-mm-) thick neoprene.
  - 1. Factory-Set Height Guide with Shear Pin: Shear pin shall be removable and reinsertable to allow for selection of pipe movement. Guides shall be capable of motion to meet location requirements.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas and equipment to receive vibration isolation control devices for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Examine roughing-in of reinforcement and cast-in-place anchors to verify actual locations before installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 VIBRATION CONTROL DEVICE INSTALLATION

- A. Coordinate the location of embedded connection hardware with supported equipment attachment and mounting points and with requirements for concrete reinforcement and formwork specified in [Section 033000 "Cast-in-Place Concrete."] [Section 033053 "Miscellaneous Cast-in-Place Concrete."]



- B. Installation of vibration isolators must not cause any change of position of equipment, piping, or ductwork resulting in stresses or misalignment.

END OF SECTION 210548.13

SECTION 210553 - IDENTIFICATION FOR FIRE-SUPPRESSION PIPING AND EQUIPMENT

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Equipment labels.
  - 2. Warning signs and labels.
  - 3. Pipe labels.
  - 4. Stencils.
  - 5. Valve tags.
  - 6. Warning tags.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Samples: For color, letter style, and graphic representation required for each identification material and device.
- C. Equipment-Label Schedule: Include a listing of all equipment to be labeled and the proposed content for each label.
- D. Valve Schedules: Valve numbering scheme.

PART 2 - PRODUCTS

2.1 EQUIPMENT LABELS

- A. Metal Labels for Equipment:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Carlton Industries, LP.
    - b. Champion America.

2. Material and Thickness: Brass, 0.032 inch (0.8 mm) stainless steel, 0.025 inch (0.64 mm) aluminum, 0.032 inch (0.8 mm) or anodized aluminum, 0.032 inch (0.8 mm) thick, with predrilled holes for attachment hardware.
3. Letter Color: Black Red White.
4. Background Color: Black Red White Insert color.
5. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch (64 by 19 mm).
6. Minimum Letter Size: 1/4 inch (6.4 mm) for name of units if viewing distance is less than 24 inches (600 mm), 1/2 inch (13 mm) for viewing distances up to 72 inches (1830 mm), and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
7. Fasteners: Stainless-steel rivets or self-tapping screws.
8. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.

B. Plastic Labels for Equipment:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Champion America.
  - b. Craftmark Pipe Markers.
  - c. Kolbi Pipe Marker Co.
2. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/16 inch (1.6 mm) 1/8 inch (3.2 mm) thick, with predrilled holes for attachment hardware.
3. Letter Color: Black Red White.
4. Background Color: Black Red White.
5. Maximum Temperature: Able to withstand temperatures up to 160 deg F (71 deg C).
6. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch (64 by 19 mm).
7. Minimum Letter Size: 1/4 inch (6.4 mm) for name of units if viewing distance is less than 24 inches (600 mm), 1/2 inch (13 mm) for viewing distances up to 72 inches (1830 mm), and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
8. Fasteners: Stainless-steel rivets or self-tapping screws.
9. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.

C. Label Content: Include equipment's Drawing designation or unique equipment number, Drawing numbers where equipment is indicated (plans, details, and schedules), and the Specification Section number and title where equipment is specified.

D. Equipment-Label Schedule: For each item of equipment to be labeled, on 8-1/2-by-11-inch (A4) bond paper. Tabulate equipment identification number and identify Drawing numbers where equipment is indicated (plans, details, and schedules) and the Specification Section number and title where equipment is specified. Equipment schedule shall be included in operation and maintenance data.

## 2.2 WARNING SIGNS AND LABELS

- A. <Double click here to find, evaluate, and insert list of manufacturers and products.>
- B. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, [**1/16 inch (1.6 mm)**] [**1/8 inch (3.2 mm)**] **<Insert dimension>** thick, with predrilled holes for attachment hardware.
- C. Letter Color: [**Black**] [**Blue**] [**Red**] [**White**] [**Yellow**] **<Insert color>**.
- D. Background Color: [**Black**] [**Blue**] [**Red**] [**White**] [**Yellow**] **<Insert color>**.
- E. Maximum Temperature: Able to withstand temperatures up to 160 deg F (71 deg C).
- F. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch (64 by 19 mm).
- G. Minimum Letter Size: 1/4 inch (6.4 mm) for name of units if viewing distance is less than 24 inches (600 mm), 1/2 inch (13 mm) for viewing distances up to 72 inches (1830 mm), and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
- H. Fasteners: Stainless-steel [**rivets**] [**or**] [**self-tapping screws**].
- I. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- J. Label Content: Include caution and warning information, plus emergency notification instructions.

## 2.3 PIPE LABELS

- A. <Double click here to find, evaluate, and insert list of manufacturers and products.>
- B. General Requirements for Manufactured Pipe Labels: Preprinted, color-coded, with lettering indicating service and showing flow direction according to ASME A13.1.
- C. Pretensioned Pipe Labels: Precoiled, semirigid plastic formed to [**partially cover**] [**cover full**] circumference of pipe and to attach to pipe without fasteners or adhesive.
- D. Self-adhesive Pipe Labels: Printed plastic with contact-type, permanent-adhesive backing.
- E. Pipe-Label Contents: Include identification of piping service using same designations or abbreviations as used on Drawings, pipe size, and an arrow indicating flow direction.
  - 1. Flow-Direction Arrows: Integral with piping-system service lettering to accommodate both directions or as separate unit on each pipe label to indicate flow direction.
  - 2. Lettering Size: [**Size letters according to ASME A13.1 for piping**] [**At least 1/2 inch (13 mm) for viewing distances up to 72 inches (1830 mm) and proportionately larger lettering for greater viewing distances**].
- F. Pipe-Label Colors:

1. Background Color: Safety Red.
2. Letter Color: White.

## 2.4 STENCILS

### A. Stencils for Piping:

1. <Double click here to find, evaluate, and insert list of manufacturers and products.>
2. Lettering Size: **[Size letters according to ASME A13.1 for piping] [At least 1/2 inch (13 mm) for viewing distances up to 72 inches (1830 mm) and proportionately larger lettering for greater viewing distances].**
3. Stencil Material: **[Aluminum] [Brass] [Fiberboard] [Fiberboard or metal] <Insert material>**.
4. Stencil Paint: Safety Red, exterior, gloss, **[alkyd enamel] [acrylic enamel] <Insert paint type>**. Paint may be in pressurized spray-can form.
5. Identification Paint: White, exterior, **[alkyd enamel] [acrylic enamel] <Insert paint type>**. Paint may be in pressurized spray-can form.

## 2.5 VALVE TAGS

### A. <Double click here to find, evaluate, and insert list of manufacturers and products.>

### B. Description: Stamped or engraved with 1/4-inch (6.4-mm) letters for piping-system abbreviation and 1/2-inch (13-mm) numbers.

1. Tag Material: **[Brass, 0.032 inch (0.8 mm)] [stainless steel, 0.025 inch (0.64 mm)] [aluminum, 0.032 inch (0.8 mm)] [or] [anodized aluminum, 0.032 inch (0.8 mm)]** thick, with predrilled holes for attachment hardware.
2. Fasteners: Brass **[wire-link chain] [beaded chain] [or] [S-hook]**.
3. Valve-Tag Color: Safety Red.
4. Letter Color: White.

### C. Valve Schedules: For each piping system, on 8-1/2-by-11-inch (A4) bond paper. Tabulate valve number, piping system, system abbreviation (as shown on valve tag), location of valve (room or space), normal-operating position (open, closed, or modulating), and variations for identification. Mark valves for emergency shutoff and similar special uses.

1. Valve-tag schedule shall be included in operation and maintenance data.

## 2.6 WARNING TAGS

### A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Carlton Industries, LP.
2. Champion America.

- B. Description: Preprinted or partially preprinted, accident-prevention tags, of plasticized card stock with matte finish suitable for writing.
  - 1. Size: 3 by 5-1/4 inches (75 by 133 mm) minimum Approximately 4 by 7 inches (100 by 178 mm).
  - 2. Fasteners: Brass grommet and wire Reinforced grommet and wire or string.
  - 3. Nomenclature: Large-size primary caption such as "DANGER," "CAUTION," or "DO NOT OPERATE."
  - 4. Color: Safety Yellow background with black lettering.

### PART 3 - EXECUTION

#### 3.1 PREPARATION

- A. Clean piping and equipment surfaces of incompatible primers, paints, and encapsulants, as well as dirt, oil, grease, release agents, and other substances that could impair bond of identification devices.

#### 3.2 GENERAL INSTALLATION REQUIREMENTS

- A. Coordinate installation of identifying devices with completion of covering and painting of surfaces where devices are to be installed.
- B. Coordinate installation of identifying devices with locations of access panels and doors.
- C. Install identifying devices before installing acoustical ceilings and similar concealment.

#### 3.3 EQUIPMENT LABEL INSTALLATION

- A. Install or permanently fasten labels on each major item of mechanical equipment.
- B. Locate equipment labels where accessible and visible.

#### 3.4 PIPE LABEL INSTALLATION

- A. Piping: Painting of piping is specified in Section 099123 "Interior Painting."
- B. Stenciled Pipe-Label Option: Stenciled labels may be provided instead of manufactured pipe labels, at Installer's option. Install stenciled pipe labels, complying with ASME A13.1, with painted, color-coded bands or rectangles on each piping system.
  - 1. Identification Paint: Use for contrasting background.
  - 2. Stencil Paint: Use for pipe marking.
- C. Pipe-Label Locations: Locate pipe labels where piping is exposed or above accessible ceilings in finished spaces; machine rooms; accessible maintenance spaces such as shafts, tunnels, and plenums; and exterior exposed locations as follows:

1. Near each valve and control device.
  2. Near each branch connection excluding short takeoffs. Where flow pattern is not obvious, mark each pipe at branch.
  3. Near penetrations and on both sides of through walls, floors, ceilings, and inaccessible enclosures.
  4. At access doors, manholes, and similar access points that permit a view of concealed piping.
  5. Near major equipment items and other points of origination and termination.
  6. Spaced at maximum intervals of 50 feet (15 m) along each run. Reduce intervals to 25 feet (7.6 m) in areas of congested piping and equipment.
  7. On piping above removable acoustical ceilings. Omit intermediately spaced labels.
- D. Directional Flow Arrows: Arrows shall be used to indicate direction of flow in pipes including pipes where flow is allowed in both directions.

### 3.5 VALVE-TAG INSTALLATION

- A. Install tags on valves and control devices in fire-suppression piping systems. List tagged valves in a valve-tag schedule.
- B. Valve-Tag Application Schedule: Tag valves according to size, shape, and with captions similar to those indicated in "Valve-Tag Size and Shape" Subparagraph below:
1. Valve-Tag Size and Shape:
    - a. Fire-Suppression Standpipe: 1-1/2 inches (38 mm) 2 inches (50 mm), round.
    - b. Wet-Pipe Sprinkler System: 1-1/2 inches (38 mm) 2 inches (50 mm), round.
    - c. Dry-Pipe Sprinkler System: 1-1/2 inches (38 mm) 2 inches (50 mm), round.
    - d. Foam-Water System: 1-1/2 inches (38 mm) 2 inches (50 mm), round.
    - e. Clean-Agent Fire-Extinguishing System: 1-1/2 inches (38 mm) 2 inches (50 mm), round.

### 3.6 WARNING-TAG INSTALLATION

- A. Write required message on, and attach warning tags to, equipment and other items where required.

END OF SECTION 210553

SECTION 211119 - FIRE-DEPARTMENT CONNECTIONS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Exposed-type fire-department connections.
  - 2. Flush-type fire-department connections.
  - 3. Yard-type fire-department connections.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for each fire-department connection.

PART 2 - PRODUCTS

2.1 EXPOSED-TYPE FIRE-DEPARTMENT CONNECTION

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. American Fire Hose & Cabinet.
  - 2. Fire Protection Products, Inc.
  - 3. Guardian Fire Equipment, Inc.
- B. Standard: UL 405.
- C. Type: Exposed, projecting, for wall mounting.
- D. Pressure Rating: 175 psig (1200 kPa) minimum.
- E. Body Material: Corrosion-resistant metal.



- F. Inlets: Brass with threads according to NFPA 1963 and matching local fire-department sizes and threads. Include extension pipe nipples, brass lugged swivel connections, and check devices or clappers.
- G. Caps: Brass, lugged type, with gasket and chain.
- H. Escutcheon Plate: Round, brass, wall type.
- I. Outlet: Back, with pipe threads.
- J. Number of Inlets: Two.
- K. Escutcheon Plate Marking: Similar to "AUTO SPKR & STANDPIPE."
- L. Finish: Polished chrome plated Rough brass or bronze Rough chrome plated.
- M. Outlet Size: NPS 4 (DN 100) NPS 5 (DN 125) NPS 6 (DN 150).

## 2.2 FLUSH-TYPE FIRE-DEPARTMENT CONNECTION

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. American Fire Hose & Cabinet.
  - 2. Guardian Fire Equipment, Inc.
  - 3. Potter Roemer LLC.
- B. Standard: UL 405.
- C. Type: Flush, for wall mounting.
- D. Pressure Rating: 175 psig (1200 kPa) minimum.
- E. Body Material: Corrosion-resistant metal.
- F. Inlets: Brass with threads according to NFPA 1963 and matching local fire-department sizes and threads. Include extension pipe nipples, brass lugged swivel connections, and check devices or clappers.
- G. Caps: Brass, lugged type, with gasket and chain.
- H. Escutcheon Plate: Rectangular, brass, wall type.
- I. Outlet: With pipe threads.
- J. Body Style: Horizontal.
- K. Number of Inlets: Two.
- L. Outlet Location: Left side Right side Top.

- M. Escutcheon Plate Marking: Similar to "AUTO SPKR & STANDPIPE."
- N. Finish: Polished chrome plated Rough brass or bronze Rough chrome plated.
- O. Outlet Size: NPS 4 (DN 100) NPS 5 (DN 125) NPS 6 (DN 150).

### 2.3 YARD-TYPE FIRE-DEPARTMENT CONNECTION

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Fire Protection Products, Inc.
  - 2. Guardian Fire Equipment, Inc.
  - 3. Potter Roemer LLC.
- B. Standard: UL 405.
- C. Type: Exposed, freestanding.
- D. Pressure Rating: 175 psig (1200 kPa) minimum.
- E. Body Material: Corrosion-resistant metal.
- F. Inlets: Brass with threads according to NFPA 1963 and matching local fire-department sizes and threads. Include extension pipe nipples, brass lugged swivel connections, and check devices or clappers.
- G. Caps: Brass, lugged type, with gasket and chain.
- H. Escutcheon Plate: Round, brass, floor type.
- I. Outlet: Bottom, with pipe threads.
- J. Number of Inlets: Two.
- K. Sleeve: Brass.
- L. Sleeve Height: 18 inches (460 mm).
- M. Escutcheon Plate Marking: Similar to "AUTO SPKR & STANDPIPE."
- N. Finish, Including Sleeve: Polished chrome plated Rough brass or bronze Rough chrome plated.
- O. Outlet Size: NPS 4 (DN 100) NPS 5 (DN 125) [**NPS 6 (DN 150)**].

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of fire-department connections.
- B. Examine roughing-in for fire-suppression standpipe system to verify actual locations of piping connections before fire-department connection installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Install wall-type fire-department connections.
- B. Install yard-type fire-department connections in concrete slab support. Comply with requirements for concrete in Section 033000 "Cast-in-Place Concrete."
- C. Install two protective pipe bollards around each fire-department connection. Comply with requirements for bollards in Section 055000 "Metal Fabrications."
- D. Install automatic (ball-drip) drain valve at each check valve for fire-department connection.

END OF SECTION 211119

## SECTION 211313 - WET-PIPE SPRINKLER SYSTEMS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:

1. Pipes, fittings, and specialties.
2. Cover system for sprinkler piping.
3. Specialty valves.
4. Sprinklers.
5. Alarm devices.
6. Manual control stations.
7. Control panels.
8. Pressure gages.

- B. Related Requirements:

1. Section 211119 "Fire Department Connections" for exposed-, flush-, and yard-type fire department connections.
2. Section 230523 "General-Duty Valves for Water-Based Fire-Suppression Piping" for ball, butterfly, check, gate, post-indicator, and trim and drain valves.

#### 1.3 DEFINITIONS

- A. High-Pressure Sprinkler Piping: Wet-pipe sprinkler system piping designed to operate at working pressure higher than standard 175 psig (1200 kPa), but not higher than 250 psig (1725 kPa).
- B. Standard-Pressure Sprinkler Piping: Wet-pipe sprinkler system piping designed to operate at working pressure of 175-psig (1200-kPa) maximum.

#### 1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.

1. Include rated capacities, operating characteristics, electrical characteristics, and furnished specialties and accessories.

- B. LEED Submittals:

1. Product Data for Credit EQ 4.1: For solvent cements and adhesive primers, including printed statement of VOC content and chemical components.
- C. Shop Drawings: For wet-pipe sprinkler systems.
1. Include plans, elevations, sections, and attachment details.
  2. Include diagrams for power, signal, and control wiring.
- D. Delegated-Design Submittal: For wet-pipe sprinkler systems indicated to comply with performance requirements and design criteria, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation.

#### 1.5 INFORMATIONAL SUBMITTALS

- A. Coordination Drawings: Sprinkler systems, drawn to scale, on which the following items are shown and coordinated with each other, using input from installers of the items involved:
1. Domestic water piping.
  2. Compressed air piping.
  3. HVAC hydronic piping.
  4. Items penetrating finished ceiling include the following:
    - a. Lighting fixtures.
    - b. Air outlets and inlets.
- B. Qualification Data: For qualified Installer and professional engineer.
- C. Approved Sprinkler Piping Drawings: Working plans, prepared according to NFPA 13, that have been approved by authorities having jurisdiction, including hydraulic calculations if applicable.
- D. Welding certificates.
- E. Fire-hydrant flow test report.
- F. Field Test Reports and Certificates: Indicate and interpret test results for compliance with performance requirements and as described in NFPA 13. Include "Contractor's Material and Test Certificate for Aboveground Piping."
- G. Field quality-control reports.

#### 1.6 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For wet-pipe sprinkler systems and specialties to include in emergency, operation, and maintenance manuals.

1.7 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Sprinkler Cabinets: Finished, wall-mounted, steel cabinet with hinged cover, and with space for minimum of six spare sprinklers plus sprinkler wrench. Include number of sprinklers required by NFPA 13 and sprinkler wrench. Include separate cabinet with sprinklers and wrench for each type of sprinkler used on Project.

1.8 QUALITY ASSURANCE

- A. Installer Qualifications:
  - 1. Installer's responsibilities include designing, fabricating, and installing sprinkler systems and providing professional engineering services needed to assume engineering responsibility. Base calculations on results of fire-hydrant flow test.
    - a. Engineering Responsibility: Preparation of working plans, calculations, and field test reports by a qualified professional engineer.
- B. Welding Qualifications: Qualify procedures and operators according to 2010 ASME Boiler and Pressure Vessel Code.

1.9 FIELD CONDITIONS

- A. Interruption of Existing Sprinkler Service: Do not interrupt sprinkler service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary sprinkler service according to requirements indicated:
  - 1. Notify Architect Owner no fewer than two days in advance of proposed interruption of sprinkler service.
  - 2. Do not proceed with interruption of sprinkler service without Architect's Owner's written permission.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Sprinkler system equipment, specialties, accessories, installation, and testing shall comply with the following:
  - 1. NFPA 13.
  - 2. NFPA 13R.
- B. Standard-Pressure Piping System Component: Listed for 175-psig (1200-kPa) minimum working pressure.

- C. High-Pressure Piping System Component: Listed for 250-psig (1725-kPa) minimum working pressure.
- D. Delegated Design: Engage a qualified professional engineer, as defined in Section 014000 "Quality Requirements," to design wet-pipe sprinkler systems.
  - 1. Sprinkler system design shall be approved by authorities having jurisdiction.
    - a. Margin of Safety for Available Water Flow and Pressure: 10 percent, including losses through water-service piping, valves, and backflow preventers.
    - b. Sprinkler Occupancy Hazard Classifications:
      - 1) Automobile Parking Areas: Ordinary Hazard, Group 1.
      - 2) Building Service Areas: Ordinary Hazard, Group 1.
      - 3) Electrical Equipment Rooms: Ordinary Hazard, Group 1.
      - 4) Laundries: Ordinary Hazard, Group 1.
      - 5) Mechanical Equipment Rooms: Ordinary Hazard, Group 1.
      - Office and Public Areas: Light Hazard.
  - 2. Minimum Density for Automatic-Sprinkler Piping Design:
    - a. Light-Hazard Occupancy: 0.10 gpm over 1500-sq. ft. (4.1 mm/min. over 139-sq. m) area.
    - b. Ordinary-Hazard, Group 1 Occupancy: 0.15 gpm over 1500-sq. ft. (6.1 mm/min. over 139-sq. m) area.
    - c. Ordinary-Hazard, Group 2 Occupancy: 0.20 gpm over 1500-sq. ft. (8.1 mm/min. over 139-sq. m) area.
- E. Seismic Performance: Sprinkler piping shall withstand the effects of earthquake motions determined according to NFPA 13 and ASCE/SEI 7.

## 2.2 STEEL PIPE AND FITTINGS

- A. Standard-Weight, Galvanized- and Black-Steel Pipe: ASTM A 53/A 53M, Type E, Grade B. Pipe ends may be factory or field formed to match joining method.
- B. Schedule 40 Galvanized- and Black-Steel Pipe: ASTM A 135/A 135M; or ASTM A 795/A 795M, or ASME B36.10M wrought steel, with wall thickness not less than Schedule 30 and not more than Schedule 40. Pipe ends may be factory or field formed to match joining method.
- C. Galvanized- and Uncoated-Steel Couplings: ASTM A 865/A 865M, threaded.
- D. Malleable- or Ductile-Iron Unions: UL 860.
- E. Cast-Iron Flanges: ASME 16.1, Class 125.
- F. Steel Flanges and Flanged Fittings: ASME B16.5, Class 150.
  - 1. Pipe-Flange Gasket Materials: AWWA C110, rubber, flat face, 1/8 inch (3.2 mm) thick ASME B16.21, nonmetallic and asbestos free or EPDM rubber gasket.

- a. Class 125 and Class 250, Cast-Iron, Flat-Face Flanges: Full-face gaskets.
  - b. Class 150 and Class 300, Ductile-Iron or -Steel, Raised-Face Flanges: Ring-type gaskets.
2. Metal, Pipe-Flange Bolts and Nuts: Carbon steel unless otherwise indicated.
- G. Steel Welding Fittings: ASTM A 234/A 234M and ASME B16.9.
1. Welding Filler Metals: Comply with AWS D10.12M/D10.12 for welding materials appropriate for wall thickness and chemical analysis of steel pipe being welded.
- H. Grooved-Joint, Steel-Pipe Appurtenances:
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Smith-Cooper International.
    - b. Tyco Fire & Building Products LP.
    - c. Victaulic Company.
  2. Pressure Rating: 175-psig (1200-kPa) minimum.
  3. Galvanized Painted Uncoated Grooved-End Fittings for Steel Piping: ASTM A 47/A 47M, malleable-iron casting or ASTM A 536, ductile-iron casting, with dimensions matching steel pipe.
  4. Grooved-End-Pipe Couplings for Steel Piping: AWWA C606 and UL 213 rigid pattern, unless otherwise indicated, for steel-pipe dimensions. Include ferrous housing sections, EPDM-rubber gasket, and bolts and nuts.
- I. Steel Pressure-Seal Fittings: UL 213, FM Global-approved, 175-psig (1200-kPa) pressure rating with steel housing, rubber O-rings, and pipe stop; for use with fitting manufacturers' pressure-seal tools.
1. Manufacturers: Subject to compliance with requirements, provide products by the following:
    - a. Victaulic Company.
- 2.3 SPECIALTY VALVES
- A. Listed in UL's "Fire Protection Equipment Directory" or FM Global's "Approval Guide."
  - B. Pressure Rating:
    1. Standard-Pressure Piping Specialty Valves: 175-psig (1200-kPa) minimum.
    2. High-Pressure Piping Specialty Valves: 250-psig (1725-kPa) minimum.
  - C. Body Material: Cast or ductile iron.
  - D. Size: Same as connected piping.



- E. End Connections: Flanged or grooved.
- F. Alarm Valves:
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Tyco Fire & Building Products LP.
    - b. Victaulic Company.
    - c. Viking Corporation.
  2. Standard: UL 193.
  3. Design: For horizontal or vertical installation.
  4. Include trim sets for bypass, drain, electrical sprinkler alarm switch, pressure gages, retarding chamber, and fill-line attachment with strainer.
  5. Drip Cup Assembly: Pipe drain without valves and separate from main drain piping.
  6. Drip Cup Assembly: Pipe drain with check valve to main drain piping.
  7. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application
- G. Deluge Valves:
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. CLA-VAL Automatic Control Valves.
    - b. Kidde Fire Fighting; A UTC Business Unit.
    - c. Tyco Fire & Building Products LP.
    - d. Victaulic Company.
    - e. Viking Corporation.
  2. Standard: UL 260.
  3. Design: Hydraulically operated, differential-pressure type.
  4. Include trim sets for alarm-test bypass, drain, electrical water-flow alarm switch, pressure gages, drip cup assembly piped without valves and separate from main drain line, and fill-line attachment with strainer.
  5. Wet, Pilot-Line Trim Set: Include gage to read diaphragm-chamber pressure and manual control station for manual operation of deluge valve, and connection for actuation device.
- H. Automatic (Ball Drip) Drain Valves:
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Reliable Automatic Sprinkler Co., Inc. (The).
    - b. Tyco Fire & Building Products LP.
  2. Standard: UL 1726.

3. Pressure Rating: 175-psig (1200-kPa) minimum.
4. Type: Automatic draining, ball check.
5. Size: NPS 3/4 (DN 20).
6. End Connections: Threaded.

## 2.4 SPRINKLER PIPING SPECIALTIES

### A. Branch Outlet Fittings:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. National Fittings, Inc.
  - b. Tyco Fire & Building Products LP.
  - c. Victaulic Company.
2. Standard: UL 213.
3. Pressure Rating: 175-psig (1200-kPa) minimum.
4. Body Material: Ductile-iron housing with EPDM seals and bolts and nuts.
5. Type: Mechanical-tee and -cross fittings.
6. Configurations: Snap-on and strapless, ductile-iron housing with branch outlets.
7. Size: Of dimension to fit onto sprinkler main and with outlet connections as required to match connected branch piping.
8. Branch Outlets: Grooved, plain-end pipe, or threaded.

### B. Flow Detection and Test Assemblies:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Reliable Automatic Sprinkler Co., Inc. (The).
  - b. Tyco Fire & Building Products LP.
  - c. Victaulic Company.
2. Standard: UL's "Fire Protection Equipment Directory" or FM Global's "Approval Guide."
3. Pressure Rating: 175-psig (1200-kPa) minimum.
4. Body Material: Cast- or ductile-iron housing with orifice, sight glass, and integral test valve.
5. Size: Same as connected piping.
6. Inlet and Outlet: Threaded or grooved.

### C. Branch Line Testers:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Elkhart Brass Mfg. Co., Inc.
  - b. Fire-End & Croker Corporation.

- c. Potter Roemer LLC.
  2. Standard: UL 199.
  3. Pressure Rating: 175 psig (1200 kPa).
  4. Body Material: Brass.
  5. Size: Same as connected piping.
  6. Inlet: Threaded.
  7. Drain Outlet: Threaded and capped.
  8. Branch Outlet: Threaded, for sprinkler.
- D. Sprinkler Inspector's Test Fittings:
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Tyco Fire & Building Products LP.
    - b. Victaulic Company.
    - c. Viking Corporation.
  2. Standard: UL's "Fire Protection Equipment Directory" or FM Global's "Approval Guide."
  3. Pressure Rating: 175-psig (1200-kPa) minimum.
  4. Body Material: Cast- or ductile-iron housing with sight glass.
  5. Size: Same as connected piping.
  6. Inlet and Outlet: Threaded.
- E. Adjustable Drop Nipples:
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Aegis Technologies, Inc.
    - b. Corcoran Piping System Co.
    - c. Merit Manufacturing.
  2. Standard: UL 1474.
  3. Pressure Rating: 250-psig (1725-kPa) minimum.
  4. Body Material: Steel pipe with EPDM-rubber O-ring seals.
  5. Size: Same as connected piping.
  6. Length: Adjustable.
  7. Inlet and Outlet: Threaded.
- F. Flexible Sprinkler Hose Fittings:
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Fivalco Inc.
    - b. FlexHead Industries, Inc.

- c. Gateway Tubing, Inc.
  - d. Victaulic Company.
2. Standard: UL 1474.
  3. Type: Flexible hose for connection to sprinkler, and with bracket for connection to ceiling grid.
  4. Pressure Rating: 175-psig (1200-kPa) minimum.
  5. Size: Same as connected piping, for sprinkler.

## 2.5 SPRINKLERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  1. Reliable Automatic Sprinkler Co., Inc. (The).
  2. Tyco Fire & Building Products LP.
  3. Victaulic Company.
  4. Viking Corporation.
- B. Listed in UL's "Fire Protection Equipment Directory" or FM Global's "Approval Guide."
- C. Pressure Rating for Residential Sprinklers: 175-psig (1200-kPa) maximum.
- D. Pressure Rating for Automatic Sprinklers: 175-psig (1200-kPa) minimum.
- E. Pressure Rating for High-Pressure Automatic Sprinklers: 250-psig (1725-kPa) minimum.
- F. Automatic Sprinklers with Heat-Responsive Element:
  1. Early-Suppression, Fast-Response Applications: UL 1767.
  2. Nonresidential Applications: UL 199.
  3. Characteristics: Nominal 1/2-inch (12.7-mm) orifice with Discharge Coefficient K of 5.6, and for "Ordinary" temperature classification rating unless otherwise indicated or required by application.
- G. Open Sprinklers with Heat-Responsive Element Removed: UL 199.
  1. Nominal Orifice: 1/2 inch (12.7 mm), with discharge coefficient K between 5.3 and 5.8.
  2. Nominal Orifice: 17/32 inch (13.5 mm) with discharge coefficient K between 7.4 and 8.2.
- H. Sprinkler Finishes: Chrome plated bronze and painted.
- I. Special Coatings: Wax lead and corrosion-resistant paint.
- J. Sprinkler Escutcheons: Materials, types, and finishes for the following sprinkler mounting applications. Escutcheons for concealed, flush, and recessed-type sprinklers are specified with sprinklers.

1. Ceiling Mounting: Chrome-plated steel, one piece, flat Chrome-plated steel, two piece, with 1-inch (25-mm) vertical adjustment Plastic, white finish, one piece, flat.
2. Sidewall Mounting: Chrome-plated steel Plastic, white finish, one piece, flat.

K. Sprinkler Guards:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Tyco Fire & Building Products LP.
  - b. Victaulic Company.
  - c. Viking Corporation.
2. Standard: UL 199.
3. Type: Wire cage with fastening device for attaching to sprinkler.

2.6 ALARM DEVICES

A. Alarm-device types shall match piping and equipment connections.

B. Water-Motor-Operated Alarm:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Tyco Fire & Building Products LP.
  - b. Victaulic Company.
  - c. Viking Corporation.
2. Standard: UL 753.
3. Type: Mechanically operated, with Pelton wheel.
4. Alarm Gong: Cast aluminum with red-enamel factory finish.
5. Size: 8-1/2-inches (216-mm) diameter.
6. Components: Shaft length, bearings, and sleeve to suit wall construction.
7. Inlet: NPS 3/4 (DN 20).
8. Outlet: NPS 1 (DN 25) drain connection.

C. Electrically Operated Alarm Bell:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Fire-Lite Alarms, Inc.; a Honeywell International company.
  - b. Notifier.
  - c. Potter Electric Signal Company, LLC.
2. Standard: UL 464.

3. Type: Vibrating, metal alarm bell.
4. Size: 6-inch (150-mm) minimum- diameter.
5. Finish: Red-enamel factory finish, suitable for outdoor use.
6. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application

D. Water-Flow Indicators:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. ADT Security Services, Inc.
  - b. McDonnell & Miller.
  - c. Potter Electric Signal Company, LLC.
  - d. Viking Corporation.
2. Standard: UL 346.
3. Water-Flow Detector: Electrically supervised.
4. Components: Two single-pole, double-throw circuit switches for isolated alarm and auxiliary contacts, 7 A, 125-V ac and 0.25 A, 24-V dc; complete with factory-set, field-adjustable retard element to prevent false signals and tamperproof cover that sends signal if removed.
5. Type: Paddle operated.
6. Pressure Rating: 250 psig (1725 kPa).
7. Design Installation: Horizontal or vertical.

E. Pressure Switches:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Barksdale, Inc.
  - b. Detroit Switch, Inc.
  - c. Potter Electric Signal Company, LLC.
  - d. System Sensor.
  - e. Tyco Fire & Building Products LP.
  - f. Viking Corporation.
2. Standard: UL 346.
3. Type: Electrically supervised water-flow switch with retard feature.
4. Components: Single-pole, double-throw switch with normally closed contacts.
5. Design Operation: Rising pressure signals water flow.

F. Valve Supervisory Switches:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Fire-Lite Alarms, Inc.; a Honeywell International company.

- b. Kennedy Valve Company; a division of McWane, Inc.
- c. Potter Electric Signal Company, LLC.
- d. System Sensor.

2. Standard: UL 346.
3. Type: Electrically supervised.
4. Components: Single-pole, double-throw switch with normally closed contacts.
5. Design: Signals that controlled valve is in other than fully open position.
6. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application

## 2.7 MANUAL CONTROL STATIONS

- A. Listed in UL's "Fire Protection Equipment Directory" or FM Global's "Approval Guide" for hydraulic operation, with union, NPS 1/2 (DN 15) pipe nipple, and bronze ball valve.
- B. Include metal enclosure labeled "MANUAL CONTROL STATION," with operating instructions and cover held closed by breakable strut to prevent accidental opening.

## 2.8 CONTROL PANELS

- A. Description: Single-area, two-area, or single-area cross-zoned control panel as indicated, including NEMA ICS 6, Type 1 enclosure, detector, alarm, and solenoid-valve circuitry for operation of deluge valves.
  1. Listed in UL's "Fire Protection Equipment Directory" or FM Global's "Approval Guide" when used with thermal detectors and Class A detector circuit wiring.
  2. Electrical characteristics are 120-V ac, 60 Hz, with 24-V dc rechargeable batteries.
  3. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application
- B. Manual Control Stations: Electric operation, metal enclosure, labeled "MANUAL CONTROL STATION," with operating instructions and cover held closed by breakable strut to prevent accidental opening.
- C. Manual Control Stations: Hydraulic operation, with union, NPS 1/2 (DN 15) pipe nipple, and bronze ball valve. Include metal enclosure labeled "MANUAL CONTROL STATION," with operating instructions and cover held closed by breakable strut to prevent accidental opening.
- D. Panels Components:
  1. Power supply.
  2. Battery charger.
  3. Standby batteries.
  4. Field-wiring terminal strip.
  5. Electrically supervised solenoid valves and polarized fire-alarm bell.
  6. Lamp test facility.
  7. Single-pole, double-throw auxiliary alarm contacts.

8. Rectifier.

## 2.9 PRESSURE GAGES

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  1. AMETEK, Inc.
  2. Ashcroft Inc.
  3. Brecco Corporation.
- B. Standard: UL 393.
- C. Dial Size: 3-1/2- to 4-1/2-inch (90- to 115-mm) diameter.
- D. Pressure Gage Range: 0- to 250-psig (0- to 1725-kPa) minimum.
- E. Label: Include "WATER" label on dial face.

## PART 3 - EXECUTION

### 3.1 PREPARATION

- A. Perform fire-hydrant flow test according to NFPA 13 and NFPA 291. Use results for system design calculations required in "Quality Assurance" Article.
- B. Report test results promptly and in writing.

### 3.2 SERVICE-ENTRANCE PIPING

- A. Connect sprinkler piping to water-service piping for service entrance to building. Comply with requirements for exterior piping in Section 211100 "Facility Fire-Suppression Water-Service Piping" for exterior piping.
- B. Install shutoff valve, backflow preventer, pressure gage, drain, and other accessories indicated at connection to water-service piping. Comply with requirements for backflow preventers in Section 211100 "Facility Fire-Suppression Water-Service Piping."
- C. Install shutoff valve, check valve, pressure gage, and drain at connection to water service.

### 3.3 WATER-SUPPLY CONNECTIONS

- A. Connect sprinkler piping to building's interior water-distribution piping. Comply with requirements for interior piping in Section 221116 "Domestic Water Piping."



- B. Install shutoff valve, backflow preventer, pressure gage, drain, and other accessories indicated at connection to water-distribution piping. Comply with requirements for backflow preventers in Section 221119 "Domestic Water Piping Specialties."
- C. Install shutoff valve, check valve, pressure gage, and drain at connection to water supply.

### 3.4 PIPING INSTALLATION

- A. Locations and Arrangements: Drawing plans, schematics, and diagrams indicate general location and arrangement of piping. Install piping as indicated on approved working plans.
  - 1. Deviations from approved working plans for piping require written approval from authorities having jurisdiction. File written approval with Architect before deviating from approved working plans.
  - 2. Coordinate layout and installation of sprinklers with other construction that penetrates ceilings, including light fixtures, HVAC equipment, and partition assemblies.
- B. Piping Standard: Comply with NFPA 13 requirements for installation of sprinkler piping.
- C. Install seismic restraints on piping. Comply with NFPA 13 requirements for seismic-restraint device materials and installation.
- D. Use listed fittings to make changes in direction, branch takeoffs from mains, and reductions in pipe sizes.
- E. Install unions adjacent to each valve in pipes NPS 2 (DN 50) and smaller.
- F. Install flanges, flange adapters, or couplings for grooved-end piping on valves, apparatus, and equipment having NPS 2-1/2 (DN 65) and larger end connections.
- G. Install "Inspector's Test Connections" in sprinkler system piping, complete with shutoff valve, and sized and located according to NFPA 13.
- H. Install sprinkler piping with drains for complete system drainage.
- I. Install sprinkler control valves, test assemblies, and drain risers adjacent to standpipes when sprinkler piping is connected to standpipes.
- J. Install automatic (ball drip) drain valve at each check valve for fire-department connection, to drain piping between fire-department connection and check valve. Install drain piping to and spill over floor drain or to outside building.
- K. Install alarm devices in piping systems.
- L. Install hangers and supports for sprinkler system piping according to NFPA 13. Comply with requirements for hanger materials in NFPA 13. In seismic-rated areas, refer to Section 210548 "Vibration and Seismic Controls for Fire-Suppression Piping and Equipment."
- M. Install pressure gages on riser or feed main, at each sprinkler test connection, and at top of each standpipe. Include pressure gages with connection not less than NPS 1/4 (DN 8) and with soft-

metal seated globe valve, arranged for draining pipe between gage and valve. Install gages to permit removal, and install where they are not subject to freezing.

- N. Pressurize and check preaction sprinkler system piping and air-pressure maintenance devices.
- O. Fill sprinkler system piping with water.
- P. Install electric heating cables and pipe insulation on sprinkler piping in areas subject to freezing. Comply with requirements for heating cables in Section 210533 "Heat Tracing for Fire-Suppression Piping" and for piping insulation in Section 210700 "Fire-Suppression Systems Insulation."
- Q. Install sleeves for piping penetrations of walls, ceilings, and floors. Comply with requirements for sleeves specified in Section 210517 "Sleeves and Sleeve Seals for Fire-Suppression Piping."
- R. Install sleeve seals for piping penetrations of concrete walls and slabs. Comply with requirements for sleeve seals specified in Section 210517 "Sleeves and Sleeve Seals for Fire-Suppression Piping."
- S. Install escutcheons for piping penetrations of walls, ceilings, and floors. Comply with requirements for escutcheons specified in Section 210518 "Escutcheons for Fire-Suppression Piping."

### 3.5 JOINT CONSTRUCTION

- A. Install couplings, flanges, flanged fittings, unions, nipples, and transition and special fittings that have finish and pressure ratings same as or higher than system's pressure rating for aboveground applications unless otherwise indicated.
- B. Install unions adjacent to each valve in pipes NPS 2 (DN 50) and smaller.
- C. Install flanges, flange adapters, or couplings for grooved-end piping on valves, apparatus, and equipment having NPS 2-1/2 (DN 65) and larger end connections.
- D. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
- E. Remove scale, slag, dirt, and debris from inside and outside of pipes, tubes, and fittings before assembly.
- F. Flanged Joints: Select appropriate gasket material in size, type, and thickness suitable for water service. Join flanges with gasket and bolts according to ASME B31.9.
- G. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1. Cut threads full and clean using sharp dies. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:
  - 1. Apply appropriate tape or thread compound to external pipe threads.
  - 2. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged.

- H. Twist-Locked Joints: Insert plain end of steel pipe into plain-end-pipe fitting. Rotate retainer lugs one-quarter turn or tighten retainer pin.
- I. Steel-Piping, Pressure-Sealed Joints: Join lightwall steel pipe and steel pressure-seal fittings with tools recommended by fitting manufacturer.
- J. Welded Joints: Construct joints according to AWS D10.12M/D10.12, using qualified processes and welding operators according to "Quality Assurance" Article.
  - 1. Shop weld pipe joints where welded piping is indicated. Do not use welded joints for galvanized-steel pipe.
- K. Steel-Piping, Cut-Grooved Joints: Cut square-edge groove in end of pipe according to AWWA C606. Assemble coupling with housing, gasket, lubricant, and bolts. Join steel pipe and grooved-end fittings according to AWWA C606 for steel-pipe joints.
- L. Steel-Piping, Roll-Grooved Joints: Roll rounded-edge groove in end of pipe according to AWWA C606. Assemble coupling with housing, gasket, lubricant, and bolts. Join steel pipe and grooved-end fittings according to AWWA C606 for steel-pipe grooved joints.
- M. Steel-Piping, Pressure-Sealed Joints: Join Schedule 5 steel pipe and steel pressure-seal fittings with tools recommended by fitting manufacturer.
- N. Brazed Joints: Join copper tube and fittings according to CDA's "Copper Tube Handbook," "Braze Joints" Chapter.
- O. Copper-Tubing Grooved Joints: Roll rounded-edge groove in end of tube according to AWWA C606. Assemble coupling with housing, gasket, lubricant, and bolts. Join copper tube and grooved-end fittings according to AWWA C606 for steel-pipe grooved joints.
- P. Copper-Tubing, Pressure-Sealed Joints: Join copper tube and copper pressure-seal fittings with tools recommended by fitting manufacturer.
- Q. Extruded-Tee Connections: Form tee in copper tube according to ASTM F 2014. Use tool designed for copper tube; drill pilot hole, form collar for outlet, dimple tube to form seating stop, and braze branch tube into collar.
- R. Dissimilar-Material Piping Joints: Make joints using adapters compatible with materials of both piping systems.
- S. Plastic-Piping, Solvent-Cement Joints: Clean and dry joining surfaces. Join pipe and fittings according to the following:
  - 1. Comply with ASTM F 402 for safe-handling practice of cleaners, primers, and solvent cements. Apply primer.
  - 2. CPVC Piping: Join according to ASTM D 2846/D 2846M Appendix.

3.6 INSTALLATION OF COVER SYSTEM FOR SPRINKLER PIPING

- A. Install cover system, brackets, and cover components for sprinkler piping according to manufacturer's "Installation Manual" and NFPA 13 or NFPA 13R for supports.

3.7 VALVE AND SPECIALTIES INSTALLATION

- A. Install listed fire-protection valves, trim and drain valves, specialty valves and trim, controls, and specialties according to NFPA 13 and authorities having jurisdiction.
- B. Install listed fire-protection shutoff valves supervised open, located to control sources of water supply except from fire-department connections. Install permanent identification signs indicating portion of system controlled by each valve.
- C. Install check valve in each water-supply connection. Install backflow preventers instead of check valves in potable-water-supply sources.
- D. Specialty Valves:
  - 1. Install valves in vertical position for proper direction of flow, in main supply to system.
  - 2. Install alarm valves with bypass check valve and retarding chamber drain-line connection.
  - 3. Install deluge valves in vertical position, in proper direction of flow, and in main supply to deluge system. Install trim sets for drain, priming level, alarm connections, ball drip valves, pressure gages, priming chamber attachment, and fill-line attachment.

3.8 SPRINKLER INSTALLATION

- A. Install sprinklers in suspended ceilings in center of narrow dimension of acoustical ceiling panels.
- B. Install dry-type sprinklers with water supply from heated space. Do not install pendent or sidewall, wet-type sprinklers in areas subject to freezing.
- C. Install sprinklers into flexible, sprinkler hose fittings, and install hose into bracket on ceiling grid.

3.9 IDENTIFICATION

- A. Install labeling and pipe markers on equipment and piping according to requirements in NFPA 13.
- B. Identify system components, wiring, cabling, and terminals. Comply with requirements for identification specified in Section 260553 "Identification for Electrical Systems."

3.10 FIELD QUALITY CONTROL

- A. Perform the following tests and inspections with the assistance of a factory-authorized service representative:
  - 1. Leak Test: After installation, charge systems and test for leaks. Repair leaks and retest until no leaks exist.
  - 2. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
  - 3. Flush, test, and inspect sprinkler systems according to NFPA 13, "Systems Acceptance" Chapter.
  - 4. Energize circuits to electrical equipment and devices.
  - 5. Coordinate with fire-alarm tests. Operate as required.
  - 6. Coordinate with fire-pump tests. Operate as required.
  - 7. Verify that equipment hose threads are same as local fire department equipment.
- B. Sprinkler piping system will be considered defective if it does not pass tests and inspections.
- C. Prepare test and inspection reports.

3.11 CLEANING

- A. Clean dirt and debris from sprinklers.
- B. Only sprinklers with their original factory finish are acceptable. Remove and replace any sprinklers that are painted or have any other finish than their original factory finish.

3.12 DEMONSTRATION

- A. Train Owner's maintenance personnel to adjust, operate, and maintain specialty valves and pressure-maintenance pumps.

3.13 PIPING SCHEDULE

- A. Piping between Fire Department Connections and Check Valves: Galvanized, standard-weight steel pipe with threaded ends, cast-iron threaded fittings, and threaded grooved ends, grooved-end fittings, grooved-end-pipe couplings, and grooved joints.
- B. Sprinkler specialty fittings may be used, downstream of control valves, instead of specified fittings.
- C. Copper-tube, extruded-tee connections may be used for tee branches in copper tubing instead of specified copper fittings. Branch-connection joints must be brazed.
- D. Standard-pressure, wet-pipe sprinkler system, NPS 2 (DN 50) and smaller, shall be one of the following:

1. Standard-weight, black-steel pipe with threaded ends; uncoated, gray-iron threaded fittings; and threaded joints.
2. Standard-weight, galvanized-steel pipe with threaded ends; galvanized, gray-iron threaded fittings; and threaded joints.
3. Standard-weight, black-steel pipe with plain ends; uncoated, plain-end-pipe fittings; and twist-locked joints.
4. Standard-weight, galvanized-steel pipe with plain ends; galvanized, plain-end-pipe fittings; and twist-locked joints.
5. Standard-weight, galvanized-steel pipe with cut-grooved ends; galvanized, grooved-end fittings for steel piping; grooved-end-pipe couplings for steel piping; and grooved joints.
6. Standard-weight, black-steel pipe with plain ends; steel welding fittings; and welded joints.

E. Standard-pressure, wet-pipe sprinkler system, NPS 2-1/2 to NPS 4 (DN 65 to DN 100), shall be one of the following:

1. Standard-weight, black-steel pipe with threaded ends; uncoated, gray-iron threaded fittings; and threaded joints.
2. Standard-weight, galvanized-steel pipe with threaded ends; galvanized, gray-iron threaded fittings; and threaded joints.
3. Standard-weight, black-steel pipe with cut- or roll-grooved ends; uncoated, grooved-end fittings for steel piping; grooved-end-pipe couplings for steel piping; and grooved joints.
4. Standard-weight, galvanized-steel pipe with cut-grooved ends; galvanized, grooved-end fittings for steel piping; grooved-end-pipe couplings for steel piping; and grooved joints.
5. Standard-weight, black-steel pipe with plain ends; steel welding fittings; and welded joints.

F. Standard-pressure, wet-pipe sprinkler system, NPS 5 (DN 125) and larger, shall be one of the following:

1. Standard-weight, black-steel pipe with threaded ends; uncoated, gray-iron threaded fittings; and threaded joints.
2. Standard-weight, galvanized-steel pipe with threaded ends; galvanized, gray-iron threaded fittings; and threaded joints.
3. Standard-weight, black-steel pipe with cut- or roll-grooved ends; uncoated, grooved-end fittings for steel piping; grooved-end-pipe couplings for steel piping; and grooved joints.
4. Standard-weight, galvanized-steel pipe with cut-grooved ends; galvanized, grooved-end fittings for steel piping; grooved-end-pipe couplings for steel piping; and grooved joints.
5. Standard-weight, black-steel pipe with plain ends; steel welding fittings; and welded joints.

### 3.14 SPRINKLER SCHEDULE

A. Use sprinkler types in subparagraphs below for the following applications:

1. Rooms without Ceilings: Upright sprinklers.
2. Rooms with Suspended Ceilings: Pendent sprinklers Recessed sprinklers Flush sprinklers Concealed sprinklers Pendent, recessed, flush, and concealed sprinklers as indicated.
3. Wall Mounting: Sidewall sprinklers.

4. Spaces Subject to Freezing: Upright sprinklers Pendent, dry sprinklers Sidewall, dry sprinklers Upright, pendent, dry sprinklers; and sidewall, dry sprinklers as indicated.
5. Deluge-Sprinkler Systems: Upright and pendent, open sprinklers.
6. Special Applications: Extended-coverage, flow-control, and quick-response sprinklers where indicated Institutional space sprinklers.

B. Provide sprinkler types in subparagraphs below with finishes indicated.

1. Concealed Sprinklers: Rough brass, with factory-painted white cover plate.
2. Flush Sprinklers: Bright chrome, with painted white escutcheon.
3. Recessed Sprinklers: Bright chrome, with bright chrome escutcheon.
4. Residential Sprinklers: Dull chrome.
5. Upright Pendent and Sidewall Sprinklers: Chrome plated in finished spaces exposed to view; rough bronze in unfinished spaces not exposed to view; wax coated where exposed to acids, chemicals, or other corrosive fumes.

END OF SECTION 211313

**DIVISION 22 – PLUMBING**



## SECTION 220513 - COMMON MOTOR REQUIREMENTS FOR PLUMBING EQUIPMENT

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes general requirements for single-phase and polyphase, general-purpose, horizontal, small and medium, squirrel-cage induction motors for use on ac power systems up to 600 V and installed at equipment manufacturer's factory or shipped separately by equipment manufacturer for field installation.

#### 1.3 COORDINATION

- A. Coordinate features of motors, installed units, and accessory devices to be compatible with the following:
  - 1. Motor controllers.
  - 2. Torque, speed, and horsepower requirements of the load.
  - 3. Ratings and characteristics of supply circuit and required control sequence.
  - 4. Ambient and environmental conditions of installation location.

### PART 2 - PRODUCTS

#### 2.1 GENERAL MOTOR REQUIREMENTS

- A. Comply with NEMA MG 1 unless otherwise indicated.
- B. Comply with IEEE 841 for severe-duty motors.

#### 2.2 MOTOR CHARACTERISTICS

- A. Duty: Continuous duty at ambient temperature of 40 deg C and at altitude of 3300 feet (1000 m) above sea level.
- B. Capacity and Torque Characteristics: Sufficient to start, accelerate, and operate connected loads at designated speeds, at installed altitude and environment, with indicated operating sequence, and without exceeding nameplate ratings or considering service factor.

## 2.3 POLYPHASE MOTORS

- A. Description: NEMA MG 1, Design B, medium induction motor.
- B. Efficiency: Energy efficient, as defined in NEMA MG 1.
- C. Service Factor: 1.15.
- D. Multispeed Motors: Variable torque.
  - 1. For motors with 2:1 speed ratio, consequent pole, single winding.
  - 2. For motors with other than 2:1 speed ratio, separate winding for each speed.
- E. Multispeed Motors: Separate winding for each speed.
- F. Rotor: Random-wound, squirrel cage.
- G. Bearings: Regreasable, shielded, antifriction ball bearings suitable for radial and thrust loading.
- H. Temperature Rise: Match insulation rating.
- I. Insulation: Class F.
- J. Code Letter Designation:
  - 1. Motors 15 HP and Larger: NEMA starting Code F or Code G.
  - 2. Motors Smaller than 15 HP: Manufacturer's standard starting characteristic.
- K. Enclosure Material: Cast iron for motor frame sizes 324T and larger; rolled steel for motor frame sizes smaller than 324T.

## 2.4 POLYPHASE MOTORS WITH ADDITIONAL REQUIREMENTS

- A. Motors Used with Reduced-Voltage and Multispeed Controllers: Match wiring connection requirements for controller with required motor leads. Provide terminals in motor terminal box, suited to control method.
- B. Motors Used with Variable Frequency Controllers: Ratings, characteristics, and features coordinated with and approved by controller manufacturer.
  - 1. Windings: Copper magnet wire with moisture-resistant insulation varnish, designed and tested to resist transient spikes, high frequencies, and short time rise pulses produced by pulse-width modulated inverters.
  - 2. Energy- and Premium-Efficient Motors: Class B temperature rise; Class F insulation.
  - 3. Inverter-Duty Motors: Class F temperature rise; Class H insulation.
  - 4. Thermal Protection: Comply with NEMA MG 1 requirements for thermally protected motors.
- C. Severe-Duty Motors: Comply with IEEE 841, with 1.15 minimum service factor.

2.5 SINGLE-PHASE MOTORS

- A. Motors larger than 1/20 hp shall be one of the following, to suit starting torque and requirements of specific motor application:
  - 1. Permanent-split capacitor.
  - 2. Split phase.
  - 3. Capacitor start, inductor run.
  - 4. Capacitor start, capacitor run.
- B. Multispeed Motors: Variable-torque, permanent-split-capacitor type.
- C. Bearings: Prelubricated, antifriction ball bearings or sleeve bearings suitable for radial and thrust loading.
- D. Motors 1/20 HP and Smaller: Shaded-pole type.
- E. Thermal Protection: Internal protection to automatically open power supply circuit to motor when winding temperature exceeds a safe value calibrated to temperature rating of motor insulation. Thermal-protection device shall automatically reset when motor temperature returns to normal range.

PART 3 - EXECUTION (Not Applicable)

END OF SECTION 220513

SECTION 220517 - SLEEVES AND SLEEVE SEALS FOR PLUMBING PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Sleeves.
  - 2. Stack-sleeve fittings.
  - 3. Sleeve-seal systems.
  - 4. Sleeve-seal fittings.
  - 5. Grout.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.

PART 2 - PRODUCTS

2.1 SLEEVES

- A. Cast-Iron Wall Pipes: Cast or fabricated of cast or ductile iron and equivalent to ductile-iron pressure pipe, with plain ends and integral waterstop unless otherwise indicated.
- B. Galvanized-Steel Wall Pipes: ASTM A 53/A 53M, Schedule 40, with plain ends and welded steel collar; zinc coated.
- C. Galvanized-Steel-Pipe Sleeves: ASTM A 53/A 53M, Type E, Grade B, Schedule 40, zinc coated, with plain ends.
- D. PVC-Pipe Sleeves: ASTM D 1785, Schedule 40.
- E. Galvanized-Steel-Sheet Sleeves: 0.0239-inch (0.6-mm) minimum thickness; round tube closed with welded longitudinal joint.
- F. Molded-PE or -PP Sleeves: Removable, tapered-cup shaped, and smooth outer surface with nailing flange for attaching to wooden forms.

- G. Molded-PVC Sleeves: With nailing flange for attaching to wooden forms.

## 2.2 STACK-SLEEVE FITTINGS

- A. Stack-sleeve fittings in this article can be used in concrete floor and roof slabs, but are without seepage holes; therefore, they cannot be used as replacements for floor drains. Using grout, fill the annular space between fitting and slab opening. These fittings are available in NPS 1-1/2 to NPS 12 (DN 40 to DN 300).
- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Smith, Jay R. Mfg. Co.
  - 2. Zurn Industries, LLC.
- C. Description: Manufactured, cast-iron sleeve with integral clamping flange. Include clamping ring, bolts, and nuts for membrane flashing.
  - 1. Underdeck Clamp: Clamping ring with setscrews.

## 2.3 SLEEVE-SEAL SYSTEMS

- A. Sleeve-seal systems in this article are used for piping penetrations in slabs-on-grade and below grade in exterior walls. These systems are available for NPS 1/2 to NPS 48 (DN 15 to DN 1200) piping.
- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Advance Products & Systems, Inc.
  - 2. CALPICO, Inc.
  - 3. Metraflex Company (The).
  - 4. Pipeline Seal and Insulator, Inc.
  - 5. Proco Products, Inc.
- C. Description: Modular sealing-element unit, designed for field assembly, for filling annular space between piping and sleeve.
  - 1. Sealing Elements: EPDM-rubber interlocking links shaped to fit surface of pipe. Include type and number required for pipe material and size of pipe.
  - 2. Pressure Plates: Carbon steel.
  - 3. Connecting Bolts and Nuts: Carbon steel, with corrosion-resistant coating, of length required to secure pressure plates to sealing elements.

## 2.4 SLEEVE-SEAL FITTINGS

- A. Sleeve-seal fittings in this article are used for piping penetrations in slabs-on-grade and in exterior walls. These fittings are made to match piping OD, so they must be selected to match the penetrating piping size. They are available for NPS 1/2 to NPS 6 (DN 15 to DN 150) piping.
- B. Manufacturers: Subject to compliance with requirements, provide products by the following:
  - 1. HOLDRITE.
- C. Description: Manufactured plastic, sleeve-type, waterstop assembly made for imbedding in concrete slab or wall. Unit has plastic or rubber waterstop collar with center opening to match piping OD.

## 2.5 GROUT

- A. Standard: ASTM C 1107/C 1107M, Grade B, post-hardening and volume-adjusting, dry, hydraulic-cement grout.
- B. Characteristics: Nonshrink; recommended for interior and exterior applications.
- C. Design Mix: 5000-psi (34.5-MPa), 28-day compressive strength.
- D. Packaging: Premixed and factory packaged.

## PART 3 - EXECUTION

### 3.1 SLEEVE INSTALLATION

- A. Install sleeves for piping passing through penetrations in floors, partitions, roofs, and walls.
- B. For sleeves that will have sleeve-seal system installed, select sleeves of size large enough to provide 1-inch (25-mm) annular clear space between piping and concrete slabs and walls.
  - 1. Sleeves are not required for core-drilled holes.
- C. Install sleeves in concrete floors, concrete roof slabs, and concrete walls as new slabs and walls are constructed.
  - 1. Permanent sleeves are not required for holes in slabs formed by molded-PE or -PP sleeves.
  - 2. Cut sleeves to length for mounting flush with both surfaces.

- a. Exception: Extend sleeves installed in floors of mechanical equipment areas or other wet areas 2 inches (50 mm) above finished floor level.
  3. Using grout, seal the space outside of sleeves in slabs and walls without sleeve-seal system.
- D. Install sleeves for pipes passing through interior partitions.
1. Cut sleeves to length for mounting flush with both surfaces.
  2. Install sleeves that are large enough to provide 1/4-inch (6.4-mm) annular clear space between sleeve and pipe or pipe insulation.
  3. Seal annular space between sleeve and piping or piping insulation; use joint sealants appropriate for size, depth, and location of joint. Comply with requirements for sealants specified in Section 079200 "Joint Sealants."
- E. Fire-Barrier Penetrations: Maintain indicated fire rating of walls, partitions, ceilings, and floors at pipe penetrations. Seal pipe penetrations with firestop materials. Comply with requirements for firestopping specified in Section 078413 "Penetration Firestopping."

### 3.2 STACK-SLEEVE-FITTING INSTALLATION

- A. Install stack-sleeve fittings in new slabs as slabs are constructed.
1. Install fittings that are large enough to provide 1/4-inch (6.4-mm) annular clear space between sleeve and pipe or pipe insulation.
  2. Secure flashing between clamping flanges for pipes penetrating floors with membrane waterproofing. Comply with requirements for flashing specified in Section 076200 "Sheet Metal Flashing and Trim."
  3. Install section of cast-iron soil pipe to extend sleeve to 2 inches (50 mm) above finished floor level.
  4. Extend cast-iron sleeve fittings below floor slab as required to secure clamping ring if ring is specified.
  5. Using grout, seal the space around outside of stack-sleeve fittings.
- B. Fire-Barrier Penetrations: Maintain indicated fire rating of floors at pipe penetrations. Seal pipe penetrations with firestop materials. Comply with requirements for firestopping specified in Section 078413 "Penetration Firestopping."

### 3.3 SLEEVE-SEAL-SYSTEM INSTALLATION

- A. Install sleeve-seal systems in sleeves in exterior concrete walls and slabs-on-grade at service piping entries into building.
- B. Select type, size, and number of sealing elements required for piping material and size and for sleeve ID or hole size. Position piping in center of sleeve. Center piping in penetration, assemble sleeve-seal system components, and install in annular space between piping and



sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make a watertight seal.

### 3.4 SLEEVE-SEAL-FITTING INSTALLATION

- A. Install sleeve-seal fittings in new walls and slabs as they are constructed.
- B. Assemble fitting components of length to be flush with both surfaces of concrete slabs and walls. Position waterstop flange to be centered in concrete slab or wall.
- C. Secure nailing flanges to concrete forms.
- D. Using grout, seal the space around outside of sleeve-seal fittings.

### 3.5 SLEEVE AND SLEEVE-SEAL SCHEDULE

- A. Use sleeves and sleeve seals for the following piping-penetration applications:
  - 1. Exterior Concrete Walls above Grade:
    - a. Piping Smaller Than NPS 6 (DN 150): Cast-iron wall sleeves.
    - b. Piping NPS 6 (DN 150) and Larger: Cast-iron wall sleeves.
  - 2. Exterior Concrete Walls below Grade:
    - a. Piping Smaller Than NPS 6 (DN 150): Cast-iron wall sleeves with sleeve-seal system.
      - 1) Select sleeve size to allow for 1-inch (25-mm) annular clear space between piping and sleeve for installing sleeve-seal system.
    - b. Piping NPS 6 (DN 150) and Larger: Cast-iron wall sleeves with sleeve-seal system.
      - 1) Select sleeve size to allow for 1-inch (25-mm) annular clear space between piping and sleeve for installing sleeve-seal system.
  - 3. Concrete Slabs-on-Grade:
    - a. Piping Smaller Than NPS 6 (DN 150): Cast-iron wall sleeves with sleeve-seal system.
      - 1) Select sleeve size to allow for 1-inch (25-mm) annular clear space between piping and sleeve for installing sleeve-seal system.
    - b. Piping NPS 6 (DN 150) and Larger: Cast-iron wall sleeves with sleeve-seal system.

- 1) Select sleeve size to allow for 1-inch (25-mm) annular clear space between piping and sleeve for installing sleeve-seal system.
4. Concrete Slabs above Grade:
  - a. Piping Smaller Than NPS 6 (DN 150): Galvanized-steel-pipe sleeves.
  - b. Piping NPS 6 (DN 150) and Larger: Galvanized-steel-pipe sleeves.
5. Interior Partitions:
  - a. Piping Smaller Than NPS 6 (DN 150): Galvanized-steel-pipe sleeves.
  - b. Piping NPS 6 (DN 150) and Larger: Galvanized-steel-sheet sleeves.

END OF SECTION 220517

SECTION 220518 - ESCUTCHEONS FOR PLUMBING PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Escutcheons.
  - 2. Floor plates.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.

PART 2 - PRODUCTS

2.1 ESCUTCHEONS

- A. One-Piece, Cast-Brass Type: With polished, chrome-plated and rough-brass finish and setscrew fastener.
- B. One-Piece, Deep-Pattern Type: Deep-drawn, box-shaped brass with chrome-plated finish and spring-clip fasteners.
- C. One-Piece, Stamped-Steel Type: With chrome-plated finish and spring-clip fasteners.
- D. Split-Casting Brass Type: With polished, chrome-plated and rough-brass finish and with concealed hinge and setscrew.
- E. Split-Plate, Stamped-Steel Type: With chrome-plated finish, concealed and exposed-rivet hinge, and spring-clip fasteners.

2.2 FLOOR PLATES

- A. One-Piece Floor Plates: Cast-iron flange with holes for fasteners.
- B. Split-Casting Floor Plates: Cast brass with concealed hinge.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION

- A. Install escutcheons for piping penetrations of walls, ceilings, and finished floors.
- B. Install escutcheons with ID to closely fit around pipe, tube, and insulation of insulated piping and with OD that completely covers opening.
  1. Escutcheons for New Piping:
    - a. Piping with Fitting or Sleeve Protruding from Wall: One-piece, deep-pattern type.
    - b. Chrome-Plated Piping: One-piece, cast-brass or split-casting brass type with polished, chrome-plated finish.
    - c. Insulated Piping: One-piece, stamped-steel type or split-plate, stamped-steel type with concealed hinge or split-plate, stamped-steel type with exposed-rivet hinge.
    - d. Bare Piping at Wall and Floor Penetrations in Finished Spaces: One-piece, cast-brass or split-casting brass type with polished, chrome-plated finish.
    - e. Bare Piping at Wall and Floor Penetrations in Finished Spaces: One-piece, stamped-steel type or split-plate, stamped-steel type with concealed hinge or split-plate, stamped-steel type with exposed-rivet hinge.
    - f. Bare Piping at Ceiling Penetrations in Finished Spaces: One-piece, cast-brass or split-casting brass type with polished, chrome-plated finish.
    - g. Bare Piping at Ceiling Penetrations in Finished Spaces: One-piece, stamped-steel type or split-plate, stamped-steel type with concealed hinge or split-plate, stamped-steel type with exposed-rivet hinge.
    - h. Bare Piping in Unfinished Service Spaces: One-piece, cast-brass or split-casting brass type with polished, chrome-plated rough-brass finish.
    - i. Bare Piping in Unfinished Service Spaces: One-piece, stamped-steel type or split-plate, stamped-steel type with concealed hinge or split-plate, stamped-steel type with exposed-rivet hinge.
    - j. Bare Piping in Equipment Rooms: One-piece, cast-brass or split-casting brass type with polished, chrome-plated rough-brass finish.
    - k. Bare Piping in Equipment Rooms: One-piece, stamped-steel type or split-plate, stamped-steel type with concealed hinge or split-plate, stamped-steel type with exposed-rivet hinge.
  2. Escutcheons for Existing Piping:
    - a. Chrome-Plated Piping: Split-casting brass type with polished, chrome-plated finish.
    - b. Insulated Piping: Split-plate, stamped-steel type with concealed or exposed-rivet hinge.
    - c. Bare Piping at Wall and Floor Penetrations in Finished Spaces: Split-casting brass type with polished, chrome-plated finish.
    - d. Bare Piping at Wall and Floor Penetrations in Finished Spaces: Split-plate, stamped-steel type with concealed or exposed-rivet hinge.
    - e. Bare Piping at Ceiling Penetrations in Finished Spaces: Split-casting brass type with polished, chrome-plated finish.

- f. Bare Piping at Ceiling Penetrations in Finished Spaces: Split-plate, stamped-steel type with concealed or exposed-rivet hinge.
  - g. Bare Piping in Unfinished Service Spaces: Split-casting brass type with polished, chrome-plated rough-brass finish.
  - h. Bare Piping in Unfinished Service Spaces: Split-plate, stamped-steel type with concealed or exposed-rivet hinge.
  - i. Bare Piping in Equipment Rooms: Split-casting brass type with polished, chrome-plated rough-brass finish.
  - j. Bare Piping in Equipment Rooms: Split-plate, stamped-steel type with concealed or exposed-rivet hinge.
- C. Install floor plates for piping penetrations of equipment-room floors.
- D. Install floor plates with ID to closely fit around pipe, tube, and insulation of piping and with OD that completely covers opening.
- 1. New Piping: One-piece, floor-plate type.
  - 2. Existing Piping: Split-casting, floor-plate type.

### 3.2 FIELD QUALITY CONTROL

- A. Replace broken and damaged escutcheons and floor plates using new materials.

END OF SECTION 220518

SECTION 220519 - METERS AND GAGES FOR PLUMBING PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

B. Plumbing Drawings

C. California Water Code, (Title 17, Division 1, Chapter 5)

D. Section 220000, General Plumbing Requirements

1.2 SUMMARY

A. Section Includes:

1. Automated metering for piping for potable water service
2. Automated metering for gas service
3. Automated Meter Reading System, including but not limited to Transmitters, Receivers, Data Servers, and Software, that will be furnished to the site and installed by the Contractor. Contractor shall also provide training and demonstration of the complete system to building operators and maintenance personnel.

1.3 ACTION SUBMITTALS

A. Product Data: For each type of product indicated.

1.4 SUBMITTALS

- A. General: Submit the following according to Conditions of the Contract and Division Specification Sections.
- B. Product data for: transmitters, antennas, data servers, meters, cables, and software.
- C. Preliminary drawings showing basic location of meters, transmitters, data servers, and antennas
- D. Performance information including pressure drop versus flow curves for meters.
- E. Performance information for antennas.
- F. Maintenance data for: meters, transmitters, and data server.
- G. Provide all O&M and installation manuals with submittals.

1.5 QUALITY ASSURANCE

- A. Provide technical support telephone number and telephone number of local representatives for all products provided including: meters, antennas, transmitters, and data server. Technical support specialist shall have experience with product and work in area which allows on-site

technical support within 24 hours.

## 1.6 PROJECT CONDITIONS

- A. Proposed installation on existing buildings: Contractor is to coordinate with County of Monterey Facilities representative for all antennas, data server, and transmitter location and scheduling for access purposes.
- B. Electrical installation: Contractor is responsible for the installation of standard electrical power (110V) to operate one transmitting station in the prisoner loading area and the data server and receiver in the Administration penthouse. Contractor shall coordinate with County of Monterey Facilities for location of appropriate power connection points.
- C. Contractor shall install transmitter antennas on exterior of buildings as applicable and as shown on contract drawings. Transmitter antennas for the water sub-meter will be installed at the water meter location. Receiving antennas will be located on the Administration building roof.  
The data server will be located in the Administration building mechanical penthouse.
- D. Contractor shall install wiring from gas sub-meter transmitter to antenna in prisoner loading area and between receivers and data server in Administration building mechanical penthouse and between data server and County of Monterey furnished computer. Cable between computer and data server is a CAT 5 Ethernet cable.
- E. All roof penetrations to be water tight installation.

## 1.7 SYSTEM PERFORMANCE REQUIREMENTS

- A. The meter reading system shall be capable of automatic data collection consisting of a transmitter, receiver, data server, meter, and front end software to be installed on County of Monterey provided computer.
  - 1. System shall operate in the 900MHz frequency
  - 2. System shall be able to be ready automatically with end user software.
  - 3. Transmitter shall transmit data from local meters at least once every 15 minutes.
  - 4. Transmitter shall be able to have multi-port capabilities as well as multi-utility capabilities (i.e. water and gas).
  - 5. Transmitter shall be weatherized.
  - 6. Batteries must last minimum of 5 years before replacement with normal use.
  - 7. System shall be expandable by adding transmitters without adding additional receivers.
  - 8. Transmitter for local meters (except prisoner loading area) shall be battery powered with optional solar power available.
  - 9. Front end software shall be compatible with Windows 7 operating system.
  - 10. System shall store 90 days of data in data server in standard .csv format.
  - 11. Front end software shall provide billing format data and enable trend analysis by user for each connected meter.
  - 12. Front end software shall be available for both single user and multiple user applications.
  - 13. Meter registers shall use three wire connectivity.
  - 14. Register shall have glass lens and be permanently sealed to eliminate moisture, dirt, and other contaminants.



## 1.8 SEQUENCING AND SCHEDULING

- A. Coordinate with meter installation.
- B. Coordinate with meter sizes and locations or meter.
- C. Coordinate with Monterey County Facilities for software installation.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated in the Work include, but are not limited to, the following:
  - 1. Meter Wireless Network
    - a. Obvius  
20497 SW Teton Avenue  
Tualatin, OR 97062  
503-601-2099
  - 2. Gas Meter options as applicable
    - a. American Meter AL-1000 with Honeywell Mercury MiniMax corrector/pulser
    - b. Dresser Roots 7M175 with Micro corrector/pulser IMC/W2
    - c. Dresser Roots 11M175 with Micro corrector/pulser IMC/W2
  - 3. Water Meter
    - a. Badger Recordall Bronze Disc with Transmitter Register (RTR)

## PART 3 - EXECUTION

### 3.1 TRANSMITTER, RECEIVER, DATA SERVER, ANTENNAS, METERS

- A. Install per manufactures specifications

### 3.2 FIELD QUALITY CONTROL

- A. Transmitter – All meter transmitter shall be able to transmit signal to receiver directly (all water meters and gas meters except one located in prisoner loading area) or through an additional antenna (for the one located in the prisoner loading area)
- B. Conduct a complete transmitter to front end software duration test (minimum 4 hours) to verify collection of all water and gas meter information:

END OF SECTION 220519

SECTION 220523.12 - BALL VALVES FOR PLUMBING PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Brass ball valves.
  - 2. Bronze ball valves.
  - 3. Steel ball valves.
  - 4. Iron ball valves.

1.3 DEFINITIONS

- A. CWP: Cold working pressure.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of valve.
  - 1. Certification that products comply with NSF 61 Annex G and NSF 372.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Prepare valves for shipping as follows:
  - 1. Protect internal parts against rust and corrosion.
  - 2. Protect threads, flange faces, and soldered ends.
  - 3. Set ball valves open to minimize exposure of functional surfaces.
- B. Use the following precautions during storage:
  - 1. Maintain valve end protection.
  - 2. Store valves indoors and maintain at higher-than-ambient-dew-point temperature. If outdoor storage is necessary, store valves off the ground in watertight enclosures.

- C. Use sling to handle large valves; rig sling to avoid damage to exposed parts. Do not use operating handles or stems as lifting or rigging points.

## PART 2 - PRODUCTS

### 2.1 GENERAL REQUIREMENTS FOR VALVES

- A. Source Limitations for Valves: Obtain each type of valve from single source from single manufacturer.
- B. ASME Compliance:
  - 1. ASME B1.20.1 for threads for threaded end valves.
  - 2. ASME B16.1 for flanges on iron valves.
  - 3. ASME B16.5 for flanges on steel valves.
  - 4. ASME B16.10 and ASME B16.34 for ferrous valve dimensions and design criteria.
  - 5. ASME B16.18 for solder-joint connections.
  - 6. ASME B31.9 for building services piping valves.
- C. NSF Compliance: NSF 61 Annex G and NSF 372 for valve materials for potable-water service.
- D. Bronze valves shall be made with dezincification-resistant materials. Bronze valves made with copper alloy (brass) containing more than 15 percent zinc are not permitted.
- E. Valve Pressure-Temperature Ratings: Not less than indicated and as required for system pressures and temperatures.
- F. Valve Sizes: Same as upstream piping unless otherwise indicated.
- G. Valve Actuator Types:
  - 1. Gear Actuator: For quarter-turn valves NPS 4 (DN 100) and larger.
  - 2. Handlever: For quarter-turn valves smaller than NPS 4 (DN 100).
- H. Valves in Insulated Piping:
  - 1. Include 2-inch (50-mm) stem extensions.
  - 2. Extended operating handles of nonthermal-conductive material and protective sleeves that allow operation of valves without breaking vapor seals or disturbing insulation.
  - 3. Memory stops that are fully adjustable after insulation is applied.

### 2.2 BRASS BALL VALVES

- A. One-Piece, Brass Ball Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by the following:
    - a. KITZ Corporation.
  2. Description:
    - a. Standard: MSS SP-110.
    - b. CWP Rating: 400 psig (2760 kPa).
    - c. Body Design: One piece.
    - d. Body Material: Forged brass or bronze.
    - e. Ends: Threaded and soldered.
    - f. Seats: PTFE.
    - g. Stem: Brass or stainless steel.
    - h. Ball: Chrome-plated brass or stainless steel.
    - i. Port: Reduced.
- B. Two-Piece, Brass Ball Valves with Full Port and Brass Trim:
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. American Valve, Inc.
    - b. Crane; Crane Energy Flow Solutions.
    - c. Milwaukee Valve Company.
    - d. NIBCO INC.
    - e. Watts; a Watts Water Technologies company.
  2. Description:
    - a. Standard: MSS SP-110.
    - b. CWP Rating: 600 psig (4140 kPa).
    - c. Body Design: Two piece.
    - d. Body Material: Forged brass.
    - e. Ends: Threaded and soldered.
    - f. Seats: PTFE.
    - g. Stem: Brass.
    - h. Ball: Chrome-plated brass.
    - i. Port: Full.
- C. Three-Piece, Brass Ball Valves with Full Port and Brass Trim:
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Jomar Valve.
    - b. KITZ Corporation.
    - c. Watts; a Watts Water Technologies company.
  2. Description:
    - a. Standard: MSS SP-110.

- b. CWP Rating: 600 psig (4140 kPa).
- c. Body Design: Three piece.
- d. Body Material: Forged brass.
- e. Ends: Threaded and soldered.
- f. Seats: PTFE.
- g. Stem: Brass.
- h. Ball: Chrome-plated brass.
- i. Port: Full.

### 2.3 BRONZE BALL VALVES

#### A. One-Piece, Bronze Ball Valves with Bronze Trim:

- 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Conbraco Industries, Inc.
  - b. NIBCO INC.
  - c. Watts; a Watts Water Technologies company.
- 2. Description:
  - a. Standard: MSS SP-110.
  - b. CWP Rating: 400 psig (2760 kPa).
  - c. Body Design: One piece.
  - d. Body Material: Bronze.
  - e. Ends: Threaded.
  - f. Seats: PTFE.
  - g. Stem: Bronze.
  - h. Ball: Chrome-plated brass.
  - i. Port: Reduced.

#### B. Two-Piece, Bronze Ball Valves with Full Port, and Bronze or Brass Trim:

- 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Crane; Crane Energy Flow Solutions.
  - b. Milwaukee Valve Company.
  - c. NIBCO INC.
  - d. Watts; a Watts Water Technologies company.
  - e. Zurn Industries, LLC.
- 2. Description:
  - a. Standard: MSS SP-110.
  - b. CWP Rating: 600 psig (4140 kPa).
  - c. Body Design: Two piece.
  - d. Body Material: Bronze.
  - e. Ends: Threaded and soldered.

- f. Seats: PTFE.
- g. Stem: Bronze or brass.
- h. Ball: Chrome-plated brass.
- i. Port: Full.

C. Two-Piece, Bronze Ball Valves with Regular Port and Bronze or Brass Trim:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Milwaukee Valve Company.
  - b. NIBCO INC.
  - c. Watts; a Watts Water Technologies company.
2. Description:
  - a. Standard: MSS SP-110.
  - b. CWP Rating: 600 psig (4140 kPa).
  - c. Body Design: Two piece.
  - d. Body Material: Bronze.
  - e. Ends: Threaded.
  - f. Seats: PTFE.
  - g. Stem: Bronze or brass.
  - h. Ball: Chrome-plated brass.
  - i. Port: Regular.

D. Three-Piece, Bronze Ball Valves with Full Port and Bronze or Brass Trim:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Milwaukee Valve Company.
  - b. NIBCO INC.
  - c. Watts; a Watts Water Technologies company.
2. Description:
  - a. Standard: MSS SP-110.
  - b. CWP Rating: 600 psig (4140 kPa).
  - c. Body Design: Three piece.
  - d. Body Material: Bronze.
  - e. Ends: Threaded.
  - f. Seats: PTFE.
  - g. Stem: Bronze or brass.
  - h. Ball: Chrome-plated brass.
  - i. Port: Full.

E. Three-Piece, Bronze Ball Valves with Regular Port and Bronze Trim:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- a. Conbraco Industries, Inc.
  - b. Jamesbury; Metso.
  - c. NIBCO INC.
2. Description:
- a. Standard: MSS SP-110.
  - b. CWP Rating: 600 psig (4140 kPa).
  - c. Body Design: Three piece
  - d. Body Material: Bronze
  - e. Ends: Threaded or soldered.
  - f. Seats: PTFE.
  - g. Stem: Bronze.
  - h. Ball: Chrome-plated brass.
  - i. Port: Regular.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine valve interior for cleanliness, freedom from foreign matter, and corrosion. Remove special packing materials, such as blocks, used to prevent disc movement during shipping and handling.
- B. Operate valves in positions from fully open to fully closed. Examine guides and seats made accessible by such operations.
- C. Examine threads on valve and mating pipe for form and cleanliness.
- D. Examine mating flange faces for conditions that might cause leakage. Check bolting for proper size, length, and material. Verify that gasket is of proper size, that its material composition is suitable for service, and that it is free from defects and damage.
- E. Do not attempt to repair defective valves; replace with new valves.

#### 3.2 VALVE INSTALLATION

- A. Install valves with unions or flanges at each piece of equipment arranged to allow service, maintenance, and equipment removal without system shutdown.
- B. Locate valves for easy access and provide separate support where necessary.
- C. Install valves in horizontal piping with stem at or above center of pipe.
- D. Install valves in position to allow full stem movement.
- E. Install valve tags. Comply with requirements in Section 220553 "Identification for Plumbing Piping and Equipment" for valve tags and schedules.

### 3.3 GENERAL REQUIREMENTS FOR VALVE APPLICATIONS

- A. If valves with specified CWP ratings are unavailable, the same types of valves with higher CWP ratings may be substituted.
- B. Select valves with the following end connections:
  - 1. For Copper Tubing, NPS 2 (DN 50) and Smaller: Threaded ends except where solder-joint valve-end option is indicated in valve schedules below.
  - 2. For Copper Tubing, NPS 2-1/2 to NPS 4 (DN 65 to DN 100): Flanged ends except where threaded valve-end option is indicated in valve schedules below.
  - 3. For Copper Tubing, NPS 5 (DN 125) and Larger: Flanged ends.
  - 4. For Steel Piping, NPS 2 (DN 50) and Smaller: Threaded ends.
  - 5. For Steel Piping, NPS 2-1/2 to NPS 4 (DN 65 to DN 100): Flanged ends except where threaded valve-end option is indicated in valve schedules below.
  - 6. For Steel Piping, NPS 5 (DN 125) and Larger: Flanged ends.

### 3.4 LOW-PRESSURE, COMPRESSED-AIR VALVE SCHEDULE (150 PSIG OR LESS)

- A. Pipe NPS 2 (DN 50) and Smaller:
  - 1. Bronze and Brass Valves: May be provided with solder-joint ends instead of threaded ends.
  - 2. One piece, brass ball valve.
  - 3. One piece, bronze ball valve with bronze trim.
  - 4. Two-piece, brass ball valves with full port and brass trim.
  - 5. Two-piece, bronze ball valves with full port and bronze or brass trim.
  - 6. Three-piece, brass ball valves with full port and brass trim.
  - 7. Three-piece, bronze ball valves with full port and bronze or brass trim.
  - 8. Two-piece, bronze ball valves with regular port and bronze trim.
- B. Pipe NPS 2-1/2 (DN 65) and Larger:
  - 1. Steel and Iron Valves, NPS 2-1/2 to NPS 4 (DN 65 to DN 100): May be provided with threaded ends instead of flanged ends.
  - 2. Class 150, steel ball valves with full port.
  - 3. Class 150, iron ball valves.

### 3.5 HIGH-PRESSURE, COMPRESSED-AIR VALVE SCHEDULE (150 TO 200 PSIG)

- A. Pipe NPS 2 (DN 50) and Smaller:
  - 1. Bronze and Brass Valves: May be provided with solder-joint ends instead of threaded ends.
  - 2. One piece, brass ball valve.
  - 3. One piece, bronze ball valve with bronze trim.
  - 4. Two-piece, brass ball valves with full port and brass trim.



5. Two-piece, bronze ball valves with full port and bronze or brass trim.
6. Three-piece, brass ball valves with full port and brass trim.
7. Three-piece, bronze ball valves with full port and bronze or brass trim.
8. Two-piece, bronze ball valves with regular port and bronze trim.

B. Pipe NPS 2-1/2 (DN 65) and Larger:

1. Steel and Iron Valves, NPS 2-1/2 to NPS 4 (DN 65 to DN 100): May be provided with threaded ends instead of flanged ends.
2. Class 150, steel ball valves with full port.
3. Class 150, iron ball valves.

3.6 DOMESTIC HOT- AND COLD-WATER VALVE SCHEDULE

A. Pipe NPS 2 (DN 50) and Smaller:

1. Bronze and Brass Valves: May be provided with solder-joint ends instead of threaded ends.
2. One piece, brass ball valve.
3. One piece, bronze ball valve with bronze trim.
4. Two-piece, brass ball valves with full port and brass trim.
5. Two-piece, bronze ball valves with full port and bronze or brass trim.
6. Three-piece, brass ball valves with full port and brass trim.
7. Three-piece, bronze ball valves with full port and bronze or brass trim.
8. Two-piece, bronze ball valves with regular port and bronze trim.

B. Pipe NPS 2-1/2 (DN 65) and Larger:

1. Steel and Iron Valves, NPS 2-1/2 to NPS 4 (DN 65 to DN 100): May be provided with threaded ends instead of flanged ends.
2. Class 150, steel ball valves with full port.
3. Class 150, iron ball valves.

END OF SECTION 220523.12

SECTION 220523.14 - CHECK VALVES FOR PLUMBING PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Bronze lift check valves.
  - 2. Bronze swing check valves.
  - 3. Iron swing check valves.
  - 4. Iron swing check valves with closure control.
  - 5. Iron, grooved-end swing check valves.
  - 6. Iron, center-guided check valves.
  - 7. Iron, plate-type check valves.

1.3 DEFINITIONS

- A. CWP: Cold working pressure.
- B. EPDM: Ethylene propylene-diene terpolymer rubber.
- C. NBR: Acrylonitrile-butadiene, Buna-N, or nitrile rubber.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of valve.
  - 1. Certification that products comply with NSF 61 Annex G and NSF 372.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Prepare valves for shipping as follows:
  - 1. Protect internal parts against rust and corrosion.
  - 2. Protect threads, flange faces, grooves, and weld ends.
  - 3. Set check valves in either closed or open position.

- B. Use the following precautions during storage:
  - 1. Maintain valve end protection.
  - 2. Store valves indoors and maintain at higher-than-ambient-dew-point temperature. If outdoor storage is necessary, store valves off the ground in watertight enclosures.
- C. Use sling to handle large valves; rig sling to avoid damage to exposed parts. Do not use handwheels or stems as lifting or rigging points.

## PART 2 - PRODUCTS

### 2.1 GENERAL REQUIREMENTS FOR VALVES

- A. Source Limitations for Valves: Obtain each type of valve from single source from single manufacturer.
- B. ASME Compliance:
  - 1. ASME B1.20.1 for threads for threaded end valves.
  - 2. ASME B16.1 for flanges on iron valves.
  - 3. ASME B16.10 and ASME B16.34 for ferrous valve dimensions and design criteria.
  - 4. ASME B16.18 for solder joint.
  - 5. ASME B31.9 for building services piping valves.
- C. AWWA Compliance: Comply with AWWA C606 for grooved-end connections.
- D. NSF Compliance: NSF 61 Annex G and NSF 372 for valve materials for potable-water service.
- E. Bronze valves shall be made with dezincification-resistant materials. Bronze valves made with copper alloy (brass) containing more than 15 percent zinc are not permitted.
- F. Valve Pressure-Temperature Ratings: Not less than indicated and as required for system pressures and temperatures.
- G. Valve Sizes: Same as upstream piping unless otherwise indicated.
- H. Valve Bypass and Drain Connections: MSS SP-45.

### 2.2 BRONZE LIFT CHECK VALVES

- A. Class 125, Lift Check Valves with Bronze Disc:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Crane; Crane Energy Flow Solutions.

- b. Jenkins Valves; Crane Energy Flow Solutions.
- c. Stockham; Crane Energy Flow Solutions.
- 2. Description:
  - a. Standard: MSS SP-80, Type 1.
  - b. CWP Rating: 200 psig (1380 kPa).
  - c. Body Design: Vertical flow.
  - d. Body Material: ASTM B 61 or ASTM B 62, bronze.
  - e. Ends: Threaded or soldered. See valve schedule articles.
  - f. Disc: Bronze.

B. Class 125, Lift Check Valves with Nonmetallic Disc:

- 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Flo Fab inc.
  - b. KITZ Corporation.
  - c. Milwaukee Valve Company.
  - d. NIBCO INC.
  - e. Watts; a Watts Water Technologies company.
- 2. Description:
  - a. Standard: MSS SP-80, Type 2.
  - b. CWP Rating: 200 psig (1380 kPa).
  - c. Body Design: Vertical flow.
  - d. Body Material: ASTM B 61 or ASTM B 62, bronze.
  - e. Ends: Threaded or soldered. See valve schedule articles.
  - f. Disc: NBR, PTFE.

2.3 BRONZE SWING CHECK VALVES

A. Class 125, Bronze, Swing Check Valves with Bronze Disc:

- 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. American Valve, Inc.
  - b. Crane; Crane Energy Flow Solutions.
  - c. Jenkins Valves; Crane Energy Flow Solutions.
  - d. KITZ Corporation.
  - e. NIBCO INC.
  - f. Watts; a Watts Water Technologies company.
- 2. Description:
  - a. Standard: MSS SP-80, Type 3.
  - b. CWP Rating: 200 psig (1380 kPa).
  - c. Body Design: Horizontal flow.

- d. Body Material: ASTM B 62, bronze.
- e. Ends: Threaded or soldered. See valve schedule articles.
- f. Disc: Bronze.
- g. Disc: PTFE.

B. Class 150, Bronze Swing Check Valves with Bronze Disc:

- 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. American Valve, Inc.
  - b. Crane; Crane Energy Flow Solutions.
  - c. Jenkins Valves; Crane Energy Flow Solutions.
  - d. KITZ Corporation.
  - e. Milwaukee Valve Company.
  - f. NIBCO INC.
- 2. Description:
  - a. Standard: MSS SP-80, Type 3.
  - b. CWP Rating: 300 psig (2070 kPa).
  - c. Body Design: Horizontal flow.
  - d. Body Material: ASTM B 62, bronze.
  - e. Ends: Threaded or soldered. See valve schedule articles.
  - f. Disc: Bronze.

2.4 IRON SWING CHECK VALVES

A. Class 125, Iron Swing Check Valves with Metal Seats:

- 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Crane; Crane Energy Flow Solutions.
  - b. Jenkins Valves; Crane Energy Flow Solutions.
  - c. KITZ Corporation.
  - d. Milwaukee Valve Company.
  - e. NIBCO INC.
  - f. Watts; a Watts Water Technologies company.
- 2. Description:
  - a. Standard: MSS SP-71, Type I.
  - b. CWP Rating: 200 psig (1380 kPa).
  - c. Body Design: Clear or full waterway.
  - d. Body Material: ASTM A 126, gray iron with bolted bonnet.
  - e. Ends: Flanged or threaded. See valve schedule articles.
  - f. Trim: Bronze.
  - g. Gasket: Asbestos free.

B. Class 250, Iron Swing Check Valves with Metal Seats:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Crane; Crane Energy Flow Solutions.
  - b. Jenkins Valves; Crane Energy Flow Solutions.
  - c. Milwaukee Valve Company.
  - d. NIBCO INC.
  - e. Watts; a Watts Water Technologies company.
2. Description:
  - a. Standard: MSS SP-71, Type I.
  - b. CWP Rating: 500 psig (3450 kPa).
  - c. Body Design: Clear or full waterway.
  - d. Body Material: ASTM A 126, gray iron with bolted bonnet.
  - e. Ends: Flanged or threaded. See valve schedule articles.
  - f. Trim: Bronze.
  - g. Gasket: Asbestos free.

2.5 IRON SWING CHECK VALVES WITH CLOSURE CONTROL

A. Class 125, Iron Swing Check Valves with Lever- and Spring-Closure Control:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Crane; Crane Energy Flow Solutions.
  - b. Jenkins Valves; Crane Energy Flow Solutions.
  - c. Milwaukee Valve Company.
  - d. NIBCO INC.
  - e. Watts; a Watts Water Technologies company.
2. Description:
  - a. Standard: MSS SP-71, Type I.
  - b. CWP Rating: 200 psig (1380 kPa).
  - c. Body Design: Clear or full waterway.
  - d. Body Material: ASTM A 126, gray iron with bolted bonnet.
  - e. Ends: Flanged or threaded. See valve schedule articles.
  - f. Trim: Bronze.
  - g. Gasket: Asbestos free.
  - h. Closure Control: Factory-installed exterior lever and weight.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine valve interior for cleanliness, freedom from foreign matter, and corrosion. Remove special packing materials, such as blocks, used to prevent disc movement during shipping and handling.
- B. Operate valves in positions from fully open to fully closed. Examine guides and seats made accessible by such operations.
- C. Examine threads on valve and mating pipe for form and cleanliness.
- D. Examine mating flange faces for conditions that might cause leakage. Check bolting for proper size, length, and material. Verify that gasket is of proper size, that its material composition is suitable for service, and that it is free from defects and damage.
- E. Do not attempt to repair defective valves; replace with new valves.

#### 3.2 VALVE INSTALLATION

- A. Install valves with unions or flanges at each piece of equipment arranged to allow service, maintenance, and equipment removal without system shutdown.
- B. Locate valves for easy access and provide separate support where necessary.
- C. Install valves in horizontal piping with stem at or above center of pipe.
- D. Install valves in position to allow full stem movement.
- E. Install check valves for proper direction of flow and as follows:
  - 1. Swing Check Valves: In horizontal position with hinge pin level.
  - 2. Center-Guided and Plate-Type Check Valves: In horizontal or vertical position, between flanges.
  - 3. Lift Check Valves: With stem upright and plumb.
- F. Install valve tags. Comply with requirements in Section 220553 "Identification for Plumbing Piping and Equipment" for valve tags and schedules.

#### 3.3 ADJUSTING

- A. Adjust or replace valve packing after piping systems have been tested and put into service but before final adjusting and balancing. Replace valves if persistent leaking occurs.

3.4 GENERAL REQUIREMENTS FOR VALVE APPLICATIONS

- A. If valve applications are not indicated, use the following:
1. Pump-Discharge Check Valves:
    - a. NPS 2 (DN 50) and Smaller: Bronze swing check valves with bronze disc.
    - b. NPS 2-1/2 (DN 65) and Larger for Domestic Water: Iron swing check valves with lever and weight or spring; or iron, center-guided, metal-seat check valves.
    - c. NPS 2-1/2 (DN 65) and Larger for Sanitary Waste and Storm Drainage: Iron swing check valves with lever and weight or spring.
- B. If valves with specified CWP ratings are unavailable, the same types of valves with higher CWP ratings may be substituted.
- C. End Connections:
1. For Copper Tubing, NPS 2 (DN 50) and Smaller: Threaded or soldered.
  2. For Copper Tubing, NPS 2-1/2 to NPS 4 (DN 65 to DN 100): Flanged or threaded.
  3. For Copper Tubing, NPS 5 (DN 125) and Larger: Flanged.
  4. For Steel Piping, NPS 2 (DN 50) and Smaller: Threaded.
  5. For Steel Piping, NPS 2-1/2 to NPS 4 (DN 65 to DN 100): Flanged or threaded.
  6. For Steel Piping, NPS 5 (DN 125) and Larger: Flanged.
  7. For Grooved-End Copper Tubing and Steel Piping: Grooved.

3.5 LOW-PRESSURE, COMPRESSED-AIR VALVE SCHEDULE (150 PSIG (1035 kPa) OR LESS)

- A. Pipe NPS 2 (DN 50) and Smaller:
1. Vertical, Upflow Applications Only: Bronze lift check valves, Class 125, bronze disc with soldered end connections.
  2. Horizontal and Vertical Applications: Bronze swing check valves, Class 125, bronze disc with soldered end connections.
- B. Pipe NPS 2-1/2 (DN 65) and Larger:
1. Iron swing check valves, Class 125, metal seats with threaded or flanged end connections.
  2. Iron, grooved-end swing check valves, 300 CWP.
  3. Iron, dual-plate check valves, Class 125, metal seat with threaded or flanged end connections.
  4. Iron, single-plate check valves, Class 125, resilient seat with threaded or flanged end connections.



3.6 HIGH-PRESSURE, COMPRESSED-AIR VALVE SCHEDULE (150 TO 200 PSIG (1035 TO 1380 kPa))

A. Pipe NPS 2 (DN 50) and Smaller:

1. Vertical, Upflow Applications Only: Bronze lift check valves, Class 125, bronze disc with soldered or threaded end connections.
2. Horizontal and Vertical Applications: Bronze swing check valves, Class 125, bronze disc with soldered or threaded end connections.

B. Pipe NPS 2-1/2 (DN 65) and Larger:

1. Iron swing check valves, Class 125, metal seats with threaded or flanged end connections.
2. Iron, grooved-end swing check valves, 300 CWP with threaded or flanged end connections.
3. Iron, dual-plate check valves, Class 125, metal seat with threaded or flanged end connections.
4. Iron, single-plate check valves, Class 125, resilient seat with threaded or flanged end connections.

3.7 DOMESTIC HOT- AND COLD-WATER VALVE SCHEDULE

A. Pipe NPS 2 (DN 50) and Smaller: Bronze swing check valves, Class 125, bronze disc with soldered or threaded end connections.

B. Pipe NPS 2-1/2 (DN 65) and Larger:

1. Iron swing check valves, Class 125, metal seats with threaded or flanged end connections.
2. Iron swing check valves with closure control, Class 125, lever and spring with threaded or flanged end connections.
3. Iron, grooved-end swing check valves, 300 CWP.
4. Iron, center-guided check valves, Class 125, compact wafer.
5. Iron, center-guided check valves, Class 125, globe, seat with threaded or flanged end connections.
6. Iron, dual-plate check valves, Class 125, metal seat with threaded or flanged end connections.
7. Iron, single-plate check valves, Class 125, resilient seat with threaded or flanged end connections.

END OF SECTION 220523.14

SECTION 220523.15 - GATE VALVES FOR PLUMBING PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Bronze gate valves.

1.3 DEFINITIONS

- A. CWP: Cold working pressure.
- B. NRS: Nonrising stem.
- C. OS&Y: Outside screw and yoke.
- D. RS: Rising stem.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of valve.
  - 1. Certification that products comply with NSF 61 Annex G and NSF 372.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Prepare valves for shipping as follows:
  - 1. Protect internal parts against rust and corrosion.
  - 2. Protect threads, flange faces, grooves, and weld ends.
  - 3. Set gate valves closed to prevent rattling.
- B. Use the following precautions during storage:
  - 1. Maintain valve end protection.

2. Store valves indoors and maintain at higher-than-ambient-dew-point temperature. If outdoor storage is necessary, store valves off the ground in watertight enclosures.
- C. Use sling to handle large valves; rig sling to avoid damage to exposed parts. Do not use handwheels or stems as lifting or rigging points.

## PART 2 - PRODUCTS

### 2.1 GENERAL REQUIREMENTS FOR VALVES

- A. Source Limitations for Valves: Obtain each type of valve from single source from single manufacturer.
- B. ASME Compliance:
1. ASME B1.20.1 for threads for threaded end valves.
  2. ASME B16.1 for flanges on iron valves.
  3. ASME B16.10 and ASME B16.34 for ferrous valve dimensions and design criteria.
  4. ASME B16.18 for solder joint.
  5. ASME B31.9 for building services piping valves.
- C. NSF Compliance: NSF 61 Annex G and NSF 372 for valve materials for potable-water service.
- D. Bronze valves shall be made with dezincification-resistant materials. Bronze valves made with copper alloy (brass) containing more than 15 percent zinc are not permitted.
- E. Valve Pressure-Temperature Ratings: Not less than indicated and as required for system pressures and temperatures.
- F. Valve Sizes: Same as upstream piping unless otherwise indicated.
- G. RS Valves in Insulated Piping: With 2-inch (50-mm) stem extensions.
- H. Valve Bypass and Drain Connections: MSS SP-45.

### 2.2 BRONZE GATE VALVES

- A. Class 125, NRS, Bronze Gate Valves:
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. American Valve, Inc.
    - b. Crane; Crane Energy Flow Solutions.
    - c. Jenkins Valves; Crane Energy Flow Solutions.
    - d. KITZ Corporation.

- e. Milwaukee Valve Company.
  - f. NIBCO INC.
  - g. Watts; a Watts Water Technologies company.
2. Description:
- a. Standard: MSS SP-80, Type 1.
  - b. CWP Rating: 200 psig (1380 kPa).
  - c. Body Material: Bronze with integral seat and screw-in bonnet.
  - d. Ends: Threaded or solder joint.
  - e. Stem: Bronze.
  - f. Disc: Solid wedge; bronze.
  - g. Packing: Asbestos free.
  - h. Handwheel: Malleable iron, bronze, or aluminum.
- B. Class 125, RS, Bronze Gate Valves:
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
- a. American Valve, Inc.
  - b. Crane; Crane Energy Flow Solutions.
  - c. KITZ Corporation.
  - d. Milwaukee Valve Company.
  - e. NIBCO INC.
  - f. Watts; a Watts Water Technologies company.
2. Description:
- a. Standard: MSS SP-80, Type 2.
  - b. CWP Rating: 200 psig (1380 kPa).
  - c. Body Material: Bronze with integral seat and screw-in bonnet.
  - d. Ends: Threaded or solder joint.
  - e. Stem: Bronze.
  - f. Disc: Solid wedge; bronze.
  - g. Packing: Asbestos free.
  - h. Handwheel: Malleable iron, bronze, or aluminum.
- C. Class 150, NRS, Bronze Gate Valves:
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
- a. KITZ Corporation.
  - b. Milwaukee Valve Company.
  - c. NIBCO INC.
  - d. Watts; a Watts Water Technologies company.
2. Description:
- a. Standard: MSS SP-80, Type 1.
  - b. CWP Rating: 300 psig (2070 kPa).

- c. Body Material: Bronze with integral seat and union-ring bonnet.
- d. Ends: Threaded.
- e. Stem: Bronze.
- f. Disc: Solid wedge; bronze.
- g. Packing: Asbestos free.
- h. Handwheel: Malleable iron, bronze, or aluminum.

D. Class 150, RS, Bronze Gate Valves:

- 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Crane; Crane Energy Flow Solutions.
  - b. KITZ Corporation.
  - c. Milwaukee Valve Company.
  - d. NIBCO INC.
  - e. Watts; a Watts Water Technologies company.
- 2. Description:
  - a. Standard: MSS SP-80, Type 2.
  - b. CWP Rating: 300 psig (2070 kPa).
  - c. Body Material: Bronze with integral seat and union-ring bonnet.
  - d. Ends: Threaded.
  - e. Stem: Bronze.
  - f. Disc: Solid wedge; bronze.
  - g. Packing: Asbestos free.
  - h. Handwheel: Malleable iron, bronze, or aluminum.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine valve interior for cleanliness, freedom from foreign matter, and corrosion. Remove special packing materials, such as blocks, used to prevent disc movement during shipping and handling.
- B. Operate valves in positions from fully open to fully closed. Examine guides and seats made accessible by such operations.
- C. Examine threads on valve and mating pipe for form and cleanliness.
- D. Examine mating flange faces for conditions that might cause leakage. Check bolting for proper size, length, and material. Verify that gasket is of proper size, that its material composition is suitable for service, and that it is free from defects and damage.
- E. Do not attempt to repair defective valves; replace with new valves.

### 3.2 VALVE INSTALLATION

- A. Install valves with unions or flanges at each piece of equipment arranged to allow service, maintenance, and equipment removal without system shutdown.
- B. Locate valves for easy access and provide separate support where necessary.
- C. Install valves in horizontal piping with stem at or above center of pipe.
- D. Install valves in position to allow full stem movement.
- E. Install chainwheels on operators for gate valves NPS 4 (DN 100) and larger and more than 96 inches (2400 mm) above floor. Extend chains to 60 inches (1520 mm) above finished floor.
- F. Install valve tags. Comply with requirements in Section 220553 "Identification for Plumbing Piping and Equipment" for valve tags and schedules.

### 3.3 ADJUSTING

- A. Adjust or replace valve packing after piping systems have been tested and put into service but before final adjusting and balancing. Replace valves if persistent leaking occurs.

### 3.4 GENERAL REQUIREMENTS FOR VALVE APPLICATIONS

- A. Use gate valves for shutoff service only.
- B. If valves with specified CWP ratings are unavailable, the same types of valves with higher CWP ratings may be substituted.
- C. For Grooved-End Copper Tubing and Steel Piping: Valve ends may be grooved.

### 3.5 LOW-PRESSURE, COMPRESSED-AIR VALVE SCHEDULE (150 PSIG (1035 kPa) OR LESS)

- A. Pipe NPS 2 (DN 50) and Smaller: Bronze gate valves, Class 125, with soldered ends.
- B. Pipe NPS 2-1/2 (DN 65) and Larger: Iron gate valves, Class 125, with flanged ends.

### 3.6 HIGH-PRESSURE, COMPRESSED-AIR VALVE SCHEDULE (150 TO 200 PSIG (1035 TO 1380 kPa))

- A. Pipe NPS 2 (DN 50) and Smaller: Bronze gate valves, Class 125, with soldered ends.
- B. Pipe NPS 2-1/2 (DN 65) and Larger: Iron gate valves, Class 125, with flanged ends.

3.7 DOMESTIC HOT- AND COLD-WATER VALVE SCHEDULE

- A. Pipe NPS 2 (DN 50) and Smaller: Bronze gate valves, Class 125, with soldered ends.
- B. Pipe NPS 2-1/2 (DN 65) and Larger: Iron gate valves, Class 125, with flanged ends.

END OF SECTION 220523.15

SECTION 220529 - HANGERS AND SUPPORTS FOR PLUMBING PIPING AND EQUIPMENT

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:

1. Metal pipe hangers and supports.
2. Trapeze pipe hangers.
3. Fiberglass pipe hangers.
4. Metal framing systems.
5. Fiberglass strut systems.
6. Thermal-hanger shield inserts.
7. Fastener systems.
8. Pipe stands.
9. Pipe positioning systems.
10. Equipment supports.

- B. Related Sections:

1. Section 055000 "Metal Fabrications" for structural-steel shapes and plates for trapeze hangers for pipe and equipment supports.
2. Section 220516 "Expansion Fittings and Loops for Plumbing Piping" for pipe guides and anchors.
3. Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment" Section 220548.13 "Vibration Controls for Plumbing Piping and Equipment" for vibration isolation devices.

1.3 DEFINITIONS

- A. MSS: Manufacturers Standardization Society of The Valve and Fittings Industry Inc.

1.4 PERFORMANCE REQUIREMENTS

- A. Delegated Design: Design trapeze pipe hangers and equipment supports, including comprehensive engineering analysis by a qualified professional engineer, using performance requirements and design criteria indicated.



- B. Structural Performance: Hangers and supports for plumbing piping and equipment shall withstand the effects of gravity loads and stresses within limits and under conditions indicated according to ASCE/SEI 7.
  - 1. Design supports for multiple pipes, including pipe stands, capable of supporting combined weight of supported systems, system contents, and test water.
  - 2. Design equipment supports capable of supporting combined operating weight of supported equipment and connected systems and components.
  - 3. Design seismic-restraint hangers and supports for piping and equipment and obtain approval from authorities having jurisdiction.

#### 1.5 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: Signed and sealed by a qualified professional engineer. Show fabrication and installation details and include calculations for the following; include Product Data for components:
  - 1. Trapeze pipe hangers.
  - 2. Metal framing systems.
  - 3. Fiberglass strut systems.
  - 4. Pipe stands.
  - 5. Equipment supports.
- C. Delegated-Design Submittal: For trapeze hangers indicated to comply with performance requirements and design criteria, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation.
  - 1. Detail fabrication and assembly of trapeze hangers.
  - 2. Design Calculations: Calculate requirements for designing trapeze hangers.

#### 1.6 INFORMATIONAL SUBMITTALS

- A. Welding certificates.

#### 1.7 QUALITY ASSURANCE

- A. Structural Steel Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code - Steel."
- B. Pipe Welding Qualifications: Qualify procedures and operators according to ASME Boiler and Pressure Vessel Code.

## PART 2 - PRODUCTS

### 2.1 METAL PIPE HANGERS AND SUPPORTS

#### A. Carbon-Steel Pipe Hangers and Supports:

1. Description: MSS SP-58, Types 1 through 58, factory-fabricated components.
2. Galvanized Metallic Coatings: Pregalvanized or hot dipped.
3. Nonmetallic Coatings: Plastic coating, jacket, or liner.
4. Padded Hangers: Hanger with fiberglass or other pipe insulation pad or cushion to support bearing surface of piping.
5. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.

#### B. Stainless-Steel Pipe Hangers and Supports:

1. Description: MSS SP-58, Types 1 through 58, factory-fabricated components.
2. Padded Hangers: Hanger with fiberglass or other pipe insulation pad or cushion to support bearing surface of piping.
3. Hanger Rods: Continuous-thread rod, nuts, and washer made of stainless steel.

#### C. Copper Pipe Hangers:

1. Description: MSS SP-58, Types 1 through 58, copper-coated-steel, factory-fabricated components.
2. Hanger Rods: Continuous-thread rod, nuts, and washer made of copper-coated steel.

### 2.2 TRAPEZE PIPE HANGERS

- A. Description: MSS SP-69, Type 59, shop- or field-fabricated pipe-support assembly made from structural carbon-steel shapes with MSS SP-58 carbon-steel hanger rods, nuts, saddles, and U-bolts.

### 2.3 METAL FRAMING SYSTEMS

#### A. MFMA Manufacturer Metal Framing Systems:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Allied Tube & Conduit; a part of Atkore International.
  - b. B-line, an Eaton business.
  - c. Flex-Strut Inc.
  - d. Thomas & Betts Corporation, A Member of the ABB Group.
  - e. Unistrut; Part of Atkore International.
  - f. Wesanco, Inc.

2. Description: Shop- or field-fabricated pipe-support assembly for supporting multiple parallel pipes.
3. Standard: MFMA-4.
4. Channels: Continuous slotted steel channel with inturned lips.
5. Channel Nuts: Formed or stamped steel nuts or other devices designed to fit into channel slot and, when tightened, prevent slipping along channel.
6. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.
7. Metallic Coating: Electroplated zinc.
8. Paint Coating: Vinyl.
9. Plastic Coating: PVC.

B. Non-MFMA Manufacturer Metal Framing Systems:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Anvil International.
  - b. Empire Industries, Inc.
  - c. ERICO International Corporation.
  - d. Haydon Corporation.
  - e. NIBCO INC.
  - f. PHD Manufacturing, Inc.
  - g. PHS Industries, Inc.
2. Description: Shop- or field-fabricated pipe-support assembly made of steel channels, accessories, fittings, and other components for supporting multiple parallel pipes.
3. Standard: Comply with MFMA-4.
4. Channels: Continuous slotted steel channel with inturned lips.
5. Channel Nuts: Formed or stamped steel nuts or other devices designed to fit into channel slot and, when tightened, prevent slipping along channel.
6. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.
7. Coating: Zinc.

2.4 FASTENER SYSTEMS

- A. Powder-Actuated Fasteners: Threaded-steel stud, for use in hardened portland cement concrete with pull-out, tension, and shear capacities appropriate for supported loads and building materials where used.
- B. Mechanical-Expansion Anchors: Insert-wedge-type, zinc-coated steel anchors, for use in hardened portland cement concrete; with pull-out, tension, and shear capacities appropriate for supported loads and building materials where used.

2.5 PIPE STANDS

- A. General Requirements for Pipe Stands: Shop- or field-fabricated assemblies made of manufactured corrosion-resistant components to support roof-mounted piping.

- B. Compact Pipe Stand: One-piece plastic unit with integral-rod roller, pipe clamps, or V-shaped cradle to support pipe, for roof installation without membrane penetration.
- C. Low-Type, Single-Pipe Stand: One-piece plastic base unit with plastic roller, for roof installation without membrane penetration.
- D. High-Type, Single-Pipe Stand:
  - 1. Description: Assembly of base, vertical and horizontal members, and pipe support, for roof installation without membrane penetration.
  - 2. Base: Plastic.
  - 3. Vertical Members: Two or more cadmium-plated-steel or stainless-steel, continuous-thread rods.
  - 4. Horizontal Member: Cadmium-plated-steel or stainless-steel rod with plastic or stainless-steel, roller-type pipe support.
- E. High-Type, Multiple-Pipe Stand:
  - 1. Description: Assembly of bases, vertical and horizontal members, and pipe supports, for roof installation without membrane penetration.
  - 2. Bases: One or more; plastic.
  - 3. Vertical Members: Two or more protective-coated-steel channels.
  - 4. Horizontal Member: Protective-coated-steel channel.
  - 5. Pipe Supports: Galvanized-steel, clevis-type pipe hangers.
- F. Curb-Mounting-Type Pipe Stands: Shop- or field-fabricated pipe supports made from structural-steel shapes, continuous-thread rods, and rollers, for mounting on permanent stationary roof curb.

## 2.6 PIPE POSITIONING SYSTEMS

- A. Description: IAPMO PS 42, positioning system of metal brackets, clips, and straps for positioning piping in pipe spaces; for plumbing fixtures in commercial applications.

## 2.7 EQUIPMENT SUPPORTS

- A. Description: Welded, shop- or field-fabricated equipment support made from structural carbon-steel shapes.

## 2.8 MISCELLANEOUS MATERIALS

- A. Structural Steel: ASTM A 36/A 36M, carbon-steel plates, shapes, and bars; black and galvanized.
- B. Grout: ASTM C 1107, factory-mixed and -packaged, dry, hydraulic-cement, nonshrink and nonmetallic grout; suitable for interior and exterior applications.

1. Properties: Nonstaining, noncorrosive, and nongaseous.
2. Design Mix: 5000-psi (34.5-MPa), 28-day compressive strength.

### PART 3 - EXECUTION

#### 3.1 HANGER AND SUPPORT INSTALLATION

- A. Metal Pipe-Hanger Installation: Comply with MSS SP-69 and MSS SP-89. Install hangers, supports, clamps, and attachments as required to properly support piping from the building structure.
- B. Metal Trapeze Pipe-Hanger Installation: Comply with MSS SP-69 and MSS SP-89. Arrange for grouping of parallel runs of horizontal piping, and support together on field-fabricated trapeze pipe hangers.
  1. Pipes of Various Sizes: Support together and space trapezes for smallest pipe size or install intermediate supports for smaller diameter pipes as specified for individual pipe hangers.
  2. Field fabricate from ASTM A 36/A 36M, carbon-steel shapes selected for loads being supported. Weld steel according to AWS D1.1/D1.1M.
- C. Fiberglass Pipe-Hanger Installation: Comply with applicable portions of MSS SP-69 and MSS SP-89. Install hangers and attachments as required to properly support piping from building structure.
- D. Metal Framing System Installation: Arrange for grouping of parallel runs of piping, and support together on field-assembled metal framing systems.
- E. Fiberglass Strut System Installation: Arrange for grouping of parallel runs of piping, and support together on field-assembled fiberglass struts.
- F. Thermal-Hanger Shield Installation: Install in pipe hanger or shield for insulated piping.
- G. Fastener System Installation:
  1. Install powder-actuated fasteners for use in lightweight concrete or concrete slabs less than 4 inches (100 mm) thick in concrete after concrete is placed and completely cured. Use operators that are licensed by powder-actuated tool manufacturer. Install fasteners according to powder-actuated tool manufacturer's operating manual.
  2. Install mechanical-expansion anchors in concrete after concrete is placed and completely cured. Install fasteners according to manufacturer's written instructions.
- H. Pipe Stand Installation:
  1. Pipe Stand Types except Curb-Mounted Type: Assemble components and mount on smooth roof surface. Do not penetrate roof membrane.

2. Curb-Mounted-Type Pipe Stands: Assemble components or fabricate pipe stand and mount on permanent, stationary roof curb. See Section 077200 "Roof Accessories" for curbs.
- I. Pipe Positioning-System Installation: Install support devices to make rigid supply and waste piping connections to each plumbing fixture.
- J. Install hangers and supports complete with necessary attachments, inserts, bolts, rods, nuts, washers, and other accessories.
- K. Equipment Support Installation: Fabricate from welded-structural-steel shapes.
- L. Install hangers and supports to allow controlled thermal and seismic movement of piping systems, to permit freedom of movement between pipe anchors, and to facilitate action of expansion joints, expansion loops, expansion bends, and similar units.
- M. Install lateral bracing with pipe hangers and supports to prevent swaying.
- N. Install building attachments within concrete slabs or attach to structural steel. Install additional attachments at concentrated loads, including valves, flanges, and strainers, NPS 2-1/2 (DN 65) and larger and at changes in direction of piping. Install concrete inserts before concrete is placed; fasten inserts to forms and install reinforcing bars through openings at top of inserts.
- O. Load Distribution: Install hangers and supports so that piping live and dead loads and stresses from movement will not be transmitted to connected equipment.
- P. Pipe Slopes: Install hangers and supports to provide indicated pipe slopes and to not exceed maximum pipe deflections allowed by ASME B31.9 for building services piping.
- Q. Insulated Piping:
  1. Attach clamps and spacers to piping.
    - a. Piping Operating above Ambient Air Temperature: Clamp may project through insulation.
    - b. Piping Operating below Ambient Air Temperature: Use thermal-hanger shield insert with clamp sized to match OD of insert.
    - c. Do not exceed pipe stress limits allowed by ASME B31.9 for building services piping.
  2. Install MSS SP-58, Type 39, protection saddles if insulation without vapor barrier is indicated. Fill interior voids with insulation that matches adjoining insulation.
    - a. Option: Thermal-hanger shield inserts may be used. Include steel weight-distribution plate for pipe NPS 4 (DN 100) and larger if pipe is installed on rollers.
  3. Install MSS SP-58, Type 40, protective shields on cold piping with vapor barrier. Shields shall span an arc of 180 degrees.

- a. Option: Thermal-hanger shield inserts may be used. Include steel weight-distribution plate for pipe NPS 4 (DN 100) and larger if pipe is installed on rollers.
4. Shield Dimensions for Pipe: Not less than the following:
  - a. NPS 1/4 to NPS 3-1/2 (DN 8 to DN 90): 12 inches (305 mm) long and 0.048 inch (1.22 mm) thick.
  - b. NPS 4 (DN 100): 12 inches (305 mm) long and 0.06 inch (1.52 mm) thick.
  - c. NPS 5 and NPS 6 (DN 125 and DN 150): 18 inches (457 mm) long and 0.06 inch (1.52 mm) thick.
  - d. NPS 8 to NPS 14 (DN 200 to DN 350): 24 inches (610 mm) long and 0.075 inch (1.91 mm) thick.
  - e. NPS 16 to NPS 24 (DN 400 to DN 600): 24 inches (610 mm) long and 0.105 inch (2.67 mm) thick.
5. Pipes NPS 8 (DN 200) and Larger: Include wood or reinforced calcium-silicate-insulation inserts of length at least as long as protective shield.
6. Thermal-Hanger Shields: Install with insulation same thickness as piping insulation.

### 3.2 EQUIPMENT SUPPORTS

- A. Fabricate structural-steel stands to suspend equipment from structure overhead or to support equipment above floor.
- B. Grouting: Place grout under supports for equipment and make bearing surface smooth.
- C. Provide lateral bracing, to prevent swaying, for equipment supports.

### 3.3 METAL FABRICATIONS

- A. Cut, drill, and fit miscellaneous metal fabrications for trapeze pipe hangers and equipment supports.
- B. Fit exposed connections together to form hairline joints. Field weld connections that cannot be shop welded because of shipping size limitations.
- C. Field Welding: Comply with AWS D1.1/D1.1M procedures for shielded, metal arc welding; appearance and quality of welds; and methods used in correcting welding work; and with the following:
  1. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
  2. Obtain fusion without undercut or overlap.
  3. Remove welding flux immediately.
  4. Finish welds at exposed connections so no roughness shows after finishing and so contours of welded surfaces match adjacent contours.

### 3.4 ADJUSTING

- A. Hanger Adjustments: Adjust hangers to distribute loads equally on attachments and to achieve indicated slope of pipe.
- B. Trim excess length of continuous-thread hanger and support rods to 1-1/2 inches (40 mm).

### 3.5 PAINTING

- A. Touchup: Clean field welds and abraded areas of shop paint. Paint exposed areas immediately after erecting hangers and supports. Use same materials as used for shop painting. Comply with SSPC-PA 1 requirements for touching up field-painted surfaces.
  - 1. Apply paint by brush or spray to provide a minimum dry film thickness of 2.0 mils (0.05 mm).
- B. Touchup: Cleaning and touchup painting of field welds, bolted connections, and abraded areas of shop paint on miscellaneous metal are specified in Section 099113 "Exterior Painting."
- C. Galvanized Surfaces: Clean welds, bolted connections, and abraded areas and apply galvanizing-repair paint to comply with ASTM A 780.

### 3.6 HANGER AND SUPPORT SCHEDULE

- A. Specific hanger and support requirements are in Sections specifying piping systems and equipment.
- B. Comply with MSS SP-69 for pipe-hanger selections and applications that are not specified in piping system Sections.
- C. Use hangers and supports with galvanized metallic coatings for piping and equipment that will not have field-applied finish.
- D. Use nonmetallic coatings on attachments for electrolytic protection where attachments are in direct contact with copper tubing.
- E. Use carbon-steel pipe hangers and supports and metal framing systems and attachments for general service applications.
- F. Use stainless-steel pipe hangers and or corrosion-resistant attachments for hostile environment applications.
- G. Use copper-plated pipe hangers and copper attachments for copper piping and tubing.
- H. Use padded hangers for piping that is subject to scratching.
- I. Use thermal-hanger shield inserts for insulated piping and tubing.



- J. Horizontal-Piping Hangers and Supports: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Adjustable, Steel Clevis Hangers (MSS Type 1): For suspension of noninsulated or insulated, stationary pipes NPS 1/2 to NPS 30 (DN 15 to DN 750).
  2. Yoke-Type Pipe Clamps (MSS Type 2): For suspension of up to 1050 deg F (566 deg C), pipes NPS 4 to NPS 24 (DN 100 to DN 600), requiring up to 4 inches (100 mm) of insulation.
  3. Carbon- or Alloy-Steel, Double-Bolt Pipe Clamps (MSS Type 3): For suspension of pipes NPS 3/4 to NPS 36 (DN 20 to DN 900), requiring clamp flexibility and up to 4 inches (100 mm) of insulation.
  4. Steel Pipe Clamps (MSS Type 4): For suspension of cold and hot pipes NPS 1/2 to NPS 24 (DN 15 to DN 600) if little or no insulation is required.
  5. Pipe Hangers (MSS Type 5): For suspension of pipes NPS 1/2 to NPS 4 (DN 15 to DN 100), to allow off-center closure for hanger installation before pipe erection.
  6. Adjustable, Swivel Split- or Solid-Ring Hangers (MSS Type 6): For suspension of noninsulated, stationary pipes NPS 3/4 to NPS 8 (DN 20 to DN 200).
  7. Adjustable, Steel Band Hangers (MSS Type 7): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8 (DN 15 to DN 200).
  8. Adjustable Band Hangers (MSS Type 9): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8 (DN 15 to DN 200).
  9. Adjustable, Swivel-Ring Band Hangers (MSS Type 10): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8 (DN 15 to DN 200).
  10. Split Pipe Ring with or without Turnbuckle Hangers (MSS Type 11): For suspension of noninsulated, stationary pipes NPS 3/8 to NPS 8 (DN 10 to DN 200).
  11. Extension Hinged or Two-Bolt Split Pipe Clamps (MSS Type 12): For suspension of noninsulated, stationary pipes NPS 3/8 to NPS 3 (DN 10 to DN 80).
  12. U-Bolts (MSS Type 24): For support of heavy pipes NPS 1/2 to NPS 30 (DN 15 to DN 750).
  13. Clips (MSS Type 26): For support of insulated pipes not subject to expansion or contraction.
  14. Pipe Saddle Supports (MSS Type 36): For support of pipes NPS 4 to NPS 36 (DN 100 to DN 900), with steel-pipe base stanchion support and cast-iron floor flange or carbon-steel plate.
  15. Pipe Stanchion Saddles (MSS Type 37): For support of pipes NPS 4 to NPS 36 (DN 100 to DN 900), with steel-pipe base stanchion support and cast-iron floor flange or carbon-steel plate, and with U-bolt to retain pipe.
  16. Adjustable Pipe Saddle Supports (MSS Type 38): For stanchion-type support for pipes NPS 2-1/2 to NPS 36 (DN 65 to DN 900) if vertical adjustment is required, with steel-pipe base stanchion support and cast-iron floor flange.
  17. Single-Pipe Rolls (MSS Type 41): For suspension of pipes NPS 1 to NPS 30 (DN 25 to DN 750), from two rods if longitudinal movement caused by expansion and contraction might occur.
  18. Adjustable Roller Hangers (MSS Type 43): For suspension of pipes NPS 2-1/2 to NPS 24 (DN 65 to DN 600), from single rod if horizontal movement caused by expansion and contraction might occur.

19. Complete Pipe Rolls (MSS Type 44): For support of pipes NPS 2 to NPS 42 (DN 50 to DN 1050) if longitudinal movement caused by expansion and contraction might occur but vertical adjustment is not necessary.
  20. Pipe Roll and Plate Units (MSS Type 45): For support of pipes NPS 2 to NPS 24 (DN 50 to DN 600) if small horizontal movement caused by expansion and contraction might occur and vertical adjustment is not necessary.
  21. Adjustable Pipe Roll and Base Units (MSS Type 46): For support of pipes NPS 2 to NPS 30 (DN 50 to DN 750) if vertical and lateral adjustment during installation might be required in addition to expansion and contraction.
- K. Vertical-Piping Clamps: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Extension Pipe or Riser Clamps (MSS Type 8): For support of pipe risers NPS 3/4 to NPS 24 (DN 24 to DN 600).
  2. Carbon- or Alloy-Steel Riser Clamps (MSS Type 42): For support of pipe risers NPS 3/4 to NPS 24 (DN 20 to DN 600) if longer ends are required for riser clamps.
- L. Hanger-Rod Attachments: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Steel Turnbuckles (MSS Type 13): For adjustment up to 6 inches (150 mm) for heavy loads.
  2. Steel Clevises (MSS Type 14): For 120 to 450 deg F (49 to 232 deg C) piping installations.
  3. Swivel Turnbuckles (MSS Type 15): For use with MSS Type 11, split pipe rings.
  4. Malleable-Iron Sockets (MSS Type 16): For attaching hanger rods to various types of building attachments.
  5. Steel Weldless Eye Nuts (MSS Type 17): For 120 to 450 deg F (49 to 232 deg C) piping installations.
- M. Building Attachments: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Steel or Malleable Concrete Inserts (MSS Type 18): For upper attachment to suspend pipe hangers from concrete ceiling.
  2. Top-Beam C-Clamps (MSS Type 19): For use under roof installations with bar-joint construction, to attach to top flange of structural shape.
  3. Side-Beam or Channel Clamps (MSS Type 20): For attaching to bottom flange of beams, channels, or angles.
  4. Center-Beam Clamps (MSS Type 21): For attaching to center of bottom flange of beams.
  5. Welded Beam Attachments (MSS Type 22): For attaching to bottom of beams if loads are considerable and rod sizes are large.
  6. C-Clamps (MSS Type 23): For structural shapes.
  7. Top-Beam Clamps (MSS Type 25): For top of beams if hanger rod is required tangent to flange edge.
  8. Side-Beam Clamps (MSS Type 27): For bottom of steel I-beams.

9. Steel-Beam Clamps with Eye Nuts (MSS Type 28): For attaching to bottom of steel I-beams for heavy loads.
  10. Linked-Steel Clamps with Eye Nuts (MSS Type 29): For attaching to bottom of steel I-beams for heavy loads, with link extensions.
  11. Malleable-Beam Clamps with Extension Pieces (MSS Type 30): For attaching to structural steel.
  12. Welded-Steel Brackets: For support of pipes from below or for suspending from above by using clip and rod. Use one of the following for indicated loads:
    - a. Light (MSS Type 31): 750 lb (340 kg).
    - b. Medium (MSS Type 32): 1500 lb (680 kg).
    - c. Heavy (MSS Type 33): 3000 lb (1360 kg).
  13. Side-Beam Brackets (MSS Type 34): For sides of steel or wooden beams.
  14. Plate Lugs (MSS Type 57): For attaching to steel beams if flexibility at beam is required.
  15. Horizontal Travelers (MSS Type 58): For supporting piping systems subject to linear horizontal movement where headroom is limited.
- N. Saddles and Shields: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Steel-Pipe-Covering Protection Saddles (MSS Type 39): To fill interior voids with insulation that matches adjoining insulation.
  2. Protection Shields (MSS Type 40): Of length recommended in writing by manufacturer to prevent crushing insulation.
  3. Thermal-Hanger Shield Inserts: For supporting insulated pipe.
- O. Spring Hangers and Supports: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Restraint-Control Devices (MSS Type 47): Where indicated to control piping movement.
  2. Spring Cushions (MSS Type 48): For light loads if vertical movement does not exceed 1-1/4 inches (32 mm).
  3. Spring-Cushion Roll Hangers (MSS Type 49): For equipping Type 41, roll hanger with springs.
  4. Spring Sway Braces (MSS Type 50): To retard sway, shock, vibration, or thermal expansion in piping systems.
  5. Variable-Spring Hangers (MSS Type 51): Preset to indicated load and limit variability factor to 25 percent to allow expansion and contraction of piping system from hanger.
  6. Variable-Spring Base Supports (MSS Type 52): Preset to indicated load and limit variability factor to 25 percent to allow expansion and contraction of piping system from base support.
  7. Variable-Spring Trapeze Hangers (MSS Type 53): Preset to indicated load and limit variability factor to 25 percent to allow expansion and contraction of piping system from trapeze support.
  8. Constant Supports: For critical piping stress and if necessary to avoid transfer of stress from one support to another support, critical terminal, or connected

equipment. Include auxiliary stops for erection, hydrostatic test, and load-adjustment capability. These supports include the following types:

- a. Horizontal (MSS Type 54): Mounted horizontally.
  - b. Vertical (MSS Type 55): Mounted vertically.
  - c. Trapeze (MSS Type 56): Two vertical-type supports and one trapeze member.
- P. Comply with MSS SP-69 for trapeze pipe-hanger selections and applications that are not specified in piping system Sections.
- Q. Comply with MFMA-103 for metal framing system selections and applications that are not specified in piping system Sections.
- R. Use powder-actuated fasteners or mechanical-expansion anchors instead of building attachments where required in concrete construction.
- S. Use pipe positioning systems in pipe spaces behind plumbing fixtures to support supply and waste piping for plumbing fixtures.

END OF SECTION 220529

SECTION 220719 - PLUMBING PIPING INSULATION

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes insulating the following plumbing piping services:
  - 1. Domestic cold-water piping.
  - 2. Domestic hot-water piping.
  - 3. Domestic recirculating hot-water piping.
  - 4. Domestic chilled-water piping for drinking fountains.
  - 5. Sanitary waste piping exposed to freezing conditions.
  - 6. Storm-water piping exposed to freezing conditions.
  - 7. Roof drains and rainwater leaders.
  - 8. Supplies and drains for handicap-accessible lavatories and sinks.
- B. Related Sections:
  - 1. Section 220716 "Plumbing Equipment Insulation."

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated. Include thermal conductivity, water-vapor permeance thickness, and jackets (both factory- and field-applied, if any).
- B. LEED Submittals:
  - 1. Product Data for Credit IEQ 4.1: For adhesives and sealants, documentation including printed statement of VOC content and chemical components.
  - 2. Laboratory Test Reports for Credit IEQ 4: For adhesives and sealants, documentation indicating that product complies with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- C. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
  - 1. Detail application of protective shields, saddles, and inserts at hangers for each type of insulation and hanger.
  - 2. Detail attachment and covering of heat tracing inside insulation.
  - 3. Detail insulation application at pipe expansion joints for each type of insulation.

4. Detail insulation application at elbows, fittings, flanges, valves, and specialties for each type of insulation.
  5. Detail removable insulation at piping specialties, equipment connections, and access panels.
  6. Detail application of field-applied jackets.
  7. Detail application at linkages of control devices.
- D. Samples: For each type of insulation and jacket indicated. Identify each Sample, describing product and intended use. Sample sizes are as follows:
1. Preformed Pipe Insulation Materials: 12 inches (300 mm) long by NPS 2 (DN 50).
  2. Jacket Materials for Pipe: 12 inches (300 mm) long by NPS 2 (DN 50).
  3. Sheet Jacket Materials: 12 inches (300 mm) square.
  4. Manufacturer's Color Charts: For products where color is specified, show the full range of colors available for each type of finish material.

#### 1.4 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For qualified Installer.
- B. Material Test Reports: From a qualified testing agency acceptable to authorities having jurisdiction indicating, interpreting, and certifying test results for compliance of insulation materials, sealers, attachments, cements, and jackets, with requirements indicated. Include dates of tests and test methods employed.
- C. Field quality-control reports.

#### 1.5 QUALITY ASSURANCE

- A. Installer Qualifications: Skilled mechanics who have successfully completed an apprenticeship program or another craft training program certified by the Department of Labor, Bureau of Apprenticeship and Training.
- B. Surface-Burning Characteristics: For insulation and related materials, as determined by testing identical products according to ASTM E 84 by a testing agency acceptable to authorities having jurisdiction. Factory label insulation and jacket materials and adhesive, mastic, tapes, and cement material containers, with appropriate markings of applicable testing agency.
  1. Insulation Installed Indoors: Flame-spread index of 25 or less, and smoke-developed index of 50 or less.
  2. Insulation Installed Outdoors: Flame-spread index of 75 or less, and smoke-developed index of 150 or less.
- C. Mockups: Before installing insulation, build mockups for each type of insulation and finish listed below to demonstrate quality of insulation application and finishes. Build mockups in the location indicated or, if not indicated, as directed by Architect. Use materials indicated for the completed Work.

1. Piping Mockups:
    - a. One 10-foot (3-m) section of NPS 2 (DN 50) straight pipe.
    - b. One each of a 90-degree threaded, welded, and flanged elbow.
    - c. One each of a threaded, welded, and flanged tee fitting.
    - d. One NPS 2 (DN 50) or smaller valve, and one NPS 2-1/2 (DN 65) or larger valve.
    - e. Four support hangers including hanger shield and insert.
    - f. One threaded strainer and one flanged strainer with removable portion of insulation.
    - g. One threaded reducer and one welded reducer.
    - h. One pressure temperature tap.
    - i. One mechanical coupling.
  2. For each mockup, fabricate cutaway sections to allow observation of application details for insulation materials, adhesives, mastics, attachments, and jackets.
  3. Notify Architect seven days in advance of dates and times when mockups will be constructed.
  4. Obtain Architect's approval of mockups before starting insulation application.
  5. Approval of mockups does not constitute approval of deviations from the Contract Documents contained in mockups unless Architect specifically approves such deviations in writing.
  6. Maintain mockups during construction in an undisturbed condition as a standard for judging the completed Work.
  7. Demolish and remove mockups when directed.
- D. Comply with the following applicable standards and other requirements specified for miscellaneous components:
1. Supply and Drain Protective Shielding Guards: ICC A117.1.

#### 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Packaging: Insulation material containers shall be marked by manufacturer with appropriate ASTM standard designation, type and grade, and maximum use temperature.

#### 1.7 COORDINATION

- A. Coordinate sizes and locations of supports, hangers, and insulation shields specified in Section 220529 "Hangers and Supports for Plumbing Piping and Equipment."
- B. Coordinate clearance requirements with piping Installer for piping insulation application. Before preparing piping Shop Drawings, establish and maintain clearance requirements for installation of insulation and field-applied jackets and finishes and for space required for maintenance.
- C. Coordinate installation and testing of heat tracing.



1.8 SCHEDULING

- A. Schedule insulation application after pressure testing systems and, where required, after installing and testing heat tracing. Insulation application may begin on segments that have satisfactory test results.
- B. Complete installation and concealment of plastic materials as rapidly as possible in each area of construction.

PART 2 - PRODUCTS

2.1 INSULATION MATERIALS

- A. Comply with requirements in "Piping Insulation Schedule, General," "Indoor Piping Insulation Schedule," "Outdoor, Aboveground Piping Insulation Schedule," and "Outdoor, Underground Piping Insulation Schedule" articles for where insulating materials shall be applied.
- B. Products shall not contain asbestos, lead, mercury, or mercury compounds.
- C. Products that come in contact with stainless steel shall have a leachable chloride content of less than 50 ppm when tested according to ASTM C 871.
- D. Insulation materials for use on austenitic stainless steel shall be qualified as acceptable according to ASTM C 795.
- E. Foam insulation materials shall not use CFC or HCFC blowing agents in the manufacturing process.
- F. Cellular Glass: Inorganic, incombustible, foamed or cellulated glass with annealed, rigid, hermetically sealed cells. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.
  - 1. Manufacturers: Subject to compliance with requirements, provide products by the following:
    - a. Pittsburgh Corning Corporation.
  - 2. Block Insulation: ASTM C 552, Type I.
  - 3. Special-Shaped Insulation: ASTM C 552, Type III.
  - 4. Preformed Pipe Insulation without Jacket: Comply with ASTM C 552, Type II, Class 1.
  - 5. Preformed Pipe Insulation with Factory-Applied ASJ ASJ-SSL: Comply with ASTM C 552, Type II, Class 2.
  - 6. Factory fabricate shapes according to ASTM C 450 and ASTM C 585.
- G. Flexible Elastomeric Insulation: Closed-cell, sponge- or expanded-rubber materials. Comply with ASTM C 534, Type I for tubular materials.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Aeroflex USA, Inc.
    - b. Armacell LLC.
    - c. K-Flex USA.
  
  - H. Mineral-Fiber Blanket Insulation: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 553, Type II and ASTM C 1290, Type I. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.
    1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
      - a. CertainTeed Corporation.
      - b. Johns Manville; a Berkshire Hathaway company.
      - c. Knauf Insulation.
      - d. Manson Insulation Inc.
      - e. Owens Corning.
  
  - I. Phenolic:
    1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
      - a. Kingspan Tarec Industrial Insulation NV.
      - b. Resolco International BV.
  
    2. Preformed pipe insulation of rigid, expanded, closed-cell structure. Comply with ASTM C 1126, Type III, Grade 1.
  
    3. Block insulation of rigid, expanded, closed-cell structure. Comply with ASTM C 1126, Type II, Grade 1.
  
    4. Factory fabricate shapes according to ASTM C 450 and ASTM C 585.
  
    5. Factory-Applied Jacket: ASJ. Requirements are specified in "Factory-Applied Jackets" Article.
  
  - J. Polyolefin: Unicellular, polyethylene thermal plastic insulation. Comply with ASTM C 534 or ASTM C 1427, Type I, Grade 1 for tubular materials.
    1. <Double click here to find, evaluate, and insert list of manufacturers and products.>
- 2.2 INSULATING CEMENTS
- A. Mineral-Fiber Insulating Cement: Comply with ASTM C 195.
    1. <Double click here to find, evaluate, and insert list of manufacturers and products.>
  
  - B. Expanded or Exfoliated Vermiculite Insulating Cement: Comply with ASTM C 196.

1. <Double click here to find, evaluate, and insert list of manufacturers and products.>

C. Mineral-Fiber, Hydraulic-Setting Insulating and Finishing Cement: Comply with ASTM C 449.

1. <Double click here to find, evaluate, and insert list of manufacturers and products.>

### 2.3 ADHESIVES

A. Materials shall be compatible with insulation materials, jackets, and substrates and for bonding insulation to itself and to surfaces to be insulated, unless otherwise indicated.

B. Cellular-Glass Adhesive: Two-component, thermosetting urethane adhesive containing no flammable solvents, with a service temperature range of minus 100 to plus 200 deg F (minus 73 to plus 93 deg C).

1. <Double click here to find, evaluate, and insert list of manufacturers and products.>

2. For indoor applications, adhesive shall have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

3. Adhesive shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

C. Flexible Elastomeric and Polyolefin Adhesive: Comply with MIL-A-24179A, Type II, Class I.

1. <Double click here to find, evaluate, and insert list of manufacturers and products.>

2. For indoor applications, adhesive shall have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

3. Adhesive shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

D. Mineral-Fiber Adhesive: Comply with MIL-A-3316C, Class 2, Grade A.

1. <Double click here to find, evaluate, and insert list of manufacturers and products.>

2. For indoor applications, adhesive shall have a VOC content of 80 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

3. Adhesive shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

E. Phenolic Adhesive: Solvent-based resin adhesive, with a service temperature range of minus 75 to plus 300 deg F (minus 59 to plus 149 deg C).

1. <Double click here to find, evaluate, and insert list of manufacturers and products.>

2. For indoor applications, adhesive shall have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  3. Adhesive shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- F. ASJ Adhesive, and FSK Jacket Adhesive: Comply with MIL-A-3316C, Class 2, Grade A for bonding insulation jacket lap seams and joints.
1. <Double click here to find, evaluate, and insert list of manufacturers and products.>
  2. For indoor applications, adhesive shall have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  3. Adhesive shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- G. PVC Jacket Adhesive: Compatible with PVC jacket.
1. <Double click here to find, evaluate, and insert list of manufacturers and products.>
  2. For indoor applications, adhesive shall have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  3. Adhesive shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- 2.4 MASTICS
- A. Materials shall be compatible with insulation materials, jackets, and substrates; comply with MIL-PRF-19565C, Type II.
1. For indoor applications, use mastics that have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- B. Vapor-Barrier Mastic: Water based; suitable for indoor use on below-ambient services.
1. <Double click here to find, evaluate, and insert list of manufacturers and products.>
  2. Water-Vapor Permeance: ASTM E 96/E 96M, Procedure B, 0.013 perm (0.009 metric perm) at 43-mil (1.09-mm) dry film thickness.
  3. Service Temperature Range: Minus 20 to plus 180 deg F (Minus 29 to plus 82 deg C).
  4. Solids Content: ASTM D 1644, 58 percent by volume and 70 percent by weight.
  5. Color: White.
- C. Vapor-Barrier Mastic: Solvent based; suitable for indoor use on below-ambient services.
1. <Double click here to find, evaluate, and insert list of manufacturers and products.>
  2. Water-Vapor Permeance: ASTM F 1249, 0.05 perm (0.03 metric perm) at 35-mil (0.9-mm) dry film thickness.

3. Service Temperature Range: 0 to 180 deg F (Minus 18 to plus 82 deg C).
4. Solids Content: ASTM D 1644, 44 percent by volume and 62 percent by weight.
5. Color: White.

D. Vapor-Barrier Mastic: Solvent based; suitable for outdoor use on below-ambient services.

1. [<Double click here to find, evaluate, and insert list of manufacturers and products.>](#)
2. Water-Vapor Permeance: ASTM F 1249, 0.05 perm (0.033 metric perm) at 30-mil (0.8-mm) dry film thickness.
3. Service Temperature Range: Minus 50 to plus 220 deg F (Minus 46 to plus 104 deg C).
4. Solids Content: ASTM D 1644, 33 percent by volume and 46 percent by weight.
5. Color: White.

E. Breather Mastic: Water based; suitable for indoor and outdoor use on above-ambient services.

1. [<Double click here to find, evaluate, and insert list of manufacturers and products.>](#)
2. Water-Vapor Permeance: ASTM F 1249, 1.8 perms (1.2 metric perms) at 0.0625-inch (1.6-mm) dry film thickness.
3. Service Temperature Range: Minus 20 to plus 180 deg F (Minus 29 to plus 82 deg C).
4. Solids Content: 60 percent by volume and 66 percent by weight.
5. Color: White.

## 2.5 LAGGING ADHESIVES

A. Description: Comply with MIL-A-3316C, Class I, Grade A, and shall be compatible with insulation materials, jackets, and substrates.

1. For indoor applications, use lagging adhesives that have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
2. [<Double click here to find, evaluate, and insert list of manufacturers and products.>](#)
3. Fire-resistant, water-based lagging adhesive and coating for use indoors to adhere fire-resistant lagging cloths over pipe insulation.
4. Service Temperature Range: 0 to plus 180 deg F (Minus 18 to plus 82 deg C).
5. Color: White.

## 2.6 SEALANTS

A. Joint Sealants:

1. [<Double click here to find, evaluate, and insert list of manufacturers and products.>](#)
2. Materials shall be compatible with insulation materials, jackets, and substrates.
3. Permanently flexible, elastomeric sealant.
4. Service Temperature Range: Minus 100 to plus 300 deg F (Minus 73 to plus 149 deg C).
5. Color: White or gray.
6. For indoor applications, sealants shall have a VOC content of 420 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

7. Sealants shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

B. FSK and Metal Jacket Flashing Sealants:

1. <Double click here to find, evaluate, and insert list of manufacturers and products.>
2. Materials shall be compatible with insulation materials, jackets, and substrates.
3. Fire- and water-resistant, flexible, elastomeric sealant.
4. Service Temperature Range: Minus 40 to plus 250 deg F (Minus 40 to plus 121 deg C).
5. Color: Aluminum.
6. For indoor applications, sealants shall have a VOC content of 420 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
7. Sealants shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

C. ASJ Flashing Sealants, and Vinyl, PVDC, and PVC Jacket Flashing Sealants:

1. <Double click here to find, evaluate, and insert list of manufacturers and products.>
2. Materials shall be compatible with insulation materials, jackets, and substrates.
3. Fire- and water-resistant, flexible, elastomeric sealant.
4. Service Temperature Range: Minus 40 to plus 250 deg F (Minus 40 to plus 121 deg C).
5. Color: White.
6. For indoor applications, sealants shall have a VOC content of 420 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
7. Sealants shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

## 2.7 FACTORY-APPLIED JACKETS

A. Insulation system schedules indicate factory-applied jackets on various applications. When factory-applied jackets are indicated, comply with the following:

1. ASJ: White, kraft-paper, fiberglass-reinforced scrim with aluminum-foil backing; complying with ASTM C 1136, Type I.
2. ASJ-SSL: ASJ with self-sealing, pressure-sensitive, acrylic-based adhesive covered by a removable protective strip; complying with ASTM C 1136, Type I.
3. FSK Jacket: Aluminum-foil, fiberglass-reinforced scrim with kraft-paper backing; complying with ASTM C 1136, Type II.

## 2.8 FIELD-APPLIED FABRIC-REINFORCING MESH

A. Woven Glass-Fiber Fabric: Approximately 2 oz./sq. yd. (68 g/sq. m) with a thread count of 10 strands by 10 strands/sq. in. (4 strands by 4 strands/sq. mm) for covering pipe and pipe fittings.

1. Manufacturers: Subject to compliance with requirements, provide products by the following:

a. Childers Brand; H. B. Fuller Construction Products.

B. Woven Polyester Fabric: Approximately 1 oz./sq. yd. (34 g/sq. m) with a thread count of 10 strands by 10 strands/sq. in. (4 strands by 4 strands/sq. mm), in a Leno weave, for pipe.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

a. Foster Brand; H. B. Fuller Construction Products.

b. Vimasco Corporation.

## 2.9 FIELD-APPLIED CLOTHS

A. Woven Glass-Fiber Fabric: Comply with MIL-C-20079H, Type I, plain weave, and presized a minimum of 8 oz./sq. yd. (271 g/sq. m).

1. Manufacturers: Subject to compliance with requirements, provide products by the following:

a. Alpha Associates, Inc.

## 2.10 FIELD-APPLIED JACKETS

A. Field-applied jackets shall comply with ASTM C 921, Type I, unless otherwise indicated.

B. PVC Jacket: High-impact-resistant, UV-resistant PVC complying with ASTM D 1784, Class 16354-C; thickness as scheduled; roll stock ready for shop or field cutting and forming. Thickness is indicated in field-applied jacket schedules.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

a. Johns Manville; a Berkshire Hathaway company.

b. P.I.C. Plastics, Inc.

c. Proto Corporation.

d. Speedline Corporation.

2. Adhesive: As recommended by jacket material manufacturer.

3. Color: Color-code jackets based on system. Color as selected by Architect.

4. Factory-fabricated fitting covers to match jacket if available; otherwise, field fabricate.

a. Shapes: 45- and 90-degree, short- and long-radius elbows, tees, valves, flanges, unions, reducers, end caps, soil-pipe hubs, traps, mechanical joints, and P-trap and supply covers for lavatories.

C. Metal Jacket:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Childers Brand; H. B. Fuller Construction Products.
  - b. ITW Insulation Systems; Illinois Tool Works, Inc.
  - c. RPR Products, Inc.
2. Aluminum Jacket: Comply with ASTM B 209 (ASTM B 209M), Alloy 3003, 3005, 3105, or 5005, Temper H-14.
  - a. Sheet and roll stock ready for shop or field sizing.
  - b. Finish and thickness are indicated in field-applied jacket schedules.
  - c. Moisture Barrier for Indoor Applications: 1-mil- (0.025-mm-) thick, heat-bonded polyethylene and kraft paper 3-mil- (0.075-mm-) thick, heat-bonded polyethylene and kraft paper 2.5-mil- (0.063-mm-) thick polysurlyn.
  - d. Moisture Barrier for Outdoor Applications: 3-mil- (0.075-mm-) thick, heat-bonded polyethylene and kraft paper 2.5-mil- (0.063-mm-) thick polysurlyn.
  - e. Factory-Fabricated Fitting Covers:
    - 1) Same material, finish, and thickness as jacket.
    - 2) Preformed 2-piece or gore, 45- and 90-degree, short- and long-radius elbows.
    - 3) Tee covers.
    - 4) Flange and union covers.
    - 5) End caps.
    - 6) Beveled collars.
    - 7) Valve covers.
3. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Pittsburgh Corning Corporation.
  - b. Polyguard Products, Inc.

2.11 TAPES

- A. ASJ Tape: White vapor-retarder tape matching factory-applied jacket with acrylic adhesive, complying with ASTM C 1136.
  1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Avery Dennison Corporation, Specialty Tapes Division.
    - b. Compac Corporation.
    - c. Ideal Tape Co., Inc., an American Biltrite Company.
    - d. Knauf Insulation.
    - e. Venture Tape.



2. Width: 3 inches (75 mm).
  3. Thickness: 11.5 mils (0.29 mm).
  4. Adhesion: 90 ounces force/inch (1.0 N/mm) in width.
  5. Elongation: 2 percent.
  6. Tensile Strength: 40 lbf/inch (7.2 N/mm) in width.
  7. ASJ Tape Disks and Squares: Precut disks or squares of ASJ tape.
- B. FSK Tape: Foil-face, vapor-retarder tape matching factory-applied jacket with acrylic adhesive; complying with ASTM C 1136.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Avery Dennison Corporation, Specialty Tapes Division.
    - b. Compac Corporation.
    - c. Ideal Tape Co., Inc., an American Biltrite Company.
    - d. Knauf Insulation.
    - e. Venture Tape.
  2. Width: 3 inches (75 mm).
  3. Thickness: 6.5 mils (0.16 mm).
  4. Adhesion: 90 ounces force/inch (1.0 N/mm) in width.
  5. Elongation: 2 percent.
  6. Tensile Strength: 40 lbf/inch (7.2 N/mm) in width.
  7. FSK Tape Disks and Squares: Precut disks or squares of FSK tape.
- C. PVC Tape: White vapor-retarder tape matching field-applied PVC jacket with acrylic adhesive; suitable for indoor and outdoor applications.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Compac Corporation.
    - b. Ideal Tape Co., Inc., an American Biltrite Company.
    - c. Venture Tape.
  2. Width: 2 inches (50 mm).
  3. Thickness: 6 mils (0.15 mm).
  4. Adhesion: 64 ounces force/inch (0.7 N/mm) in width.
  5. Elongation: 500 percent.
  6. Tensile Strength: 18 lbf/inch (3.3 N/mm) in width.
- D. Aluminum-Foil Tape: Vapor-retarder tape with acrylic adhesive.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- a. Avery Dennison Corporation, Specialty Tapes Division.
  - b. Compac Corporation.
  - c. Ideal Tape Co., Inc., an American Biltrite Company.
  - d. Knauf Insulation.
  - e. Venture Tape.
2. Width: 2 inches (50 mm).
  3. Thickness: 3.7 mils (0.093 mm).
  4. Adhesion: 100 ounces force/inch (1.1 N/mm) in width.
  5. Elongation: 5 percent.
  6. Tensile Strength: 34 lbf/inch (6.2 N/mm) in width.

## 2.12 SECUREMENTS

### A. Bands:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. ITW Insulation Systems; Illinois Tool Works, Inc.
  - b. RPR Products, Inc.
2. Stainless Steel: ASTM A 167 or ASTM A 240/A 240M, Type 304 or Type 316; 0.015 inch (0.38 mm) thick, 1/2 inch (13 mm) 3/4 inch (19 mm) wide with wing seal or closed seal.
3. Aluminum: ASTM B 209 (ASTM B 209M), Alloy 3003, 3005, 3105, or 5005; Temper H-14, 0.020 inch (0.51 mm) thick, 1/2 inch (13 mm) 3/4 inch (19 mm) wide with wing seal or closed seal.

### B. Staples: Outward-clinching insulation staples, nominal 3/4-inch- (19-mm-) wide, stainless steel or Monel.

### C. Wire: 0.080-inch (2.0-mm) nickel-copper alloy 0.062-inch (1.6-mm) soft-annealed, stainless steel 0.062-inch (1.6-mm) soft-annealed, galvanized steel.

1. Manufacturers: Subject to compliance with requirements, provide products by the following:
  - a. C & F Wire.

## 2.13 PROTECTIVE SHIELDING GUARDS

### A. Protective Shielding Pipe Covers,

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- a. Engineered Brass Company.
  - b. Insul-Tect Products Co.
  - c. McGuire Manufacturing.
  - d. Plumberex Specialty Products, Inc.
  - e. Truebro.
  - f. Zurn Industries, LLC.
2. Description: Manufactured plastic wraps for covering plumbing fixture hot-water supply and trap and drain piping. Comply with Americans with Disabilities Act (ADA) requirements.
- B. Protective Shielding Piping Enclosures,:
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Truebro.
    - b. Zurn Industries, LLC.
  2. Description: Manufactured plastic enclosure for covering plumbing fixture hot- and cold-water supplies and trap and drain piping. Comply with ADA requirements.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine substrates and conditions for compliance with requirements for installation tolerances and other conditions affecting performance of insulation application.
  1. Verify that systems to be insulated have been tested and are free of defects.
  2. Verify that surfaces to be insulated are clean and dry.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 PREPARATION

- A. Surface Preparation: Clean and dry surfaces to receive insulation. Remove materials that will adversely affect insulation application.
- B. Surface Preparation: Clean and prepare surfaces to be insulated. Before insulating, apply a corrosion coating to insulated surfaces as follows:
  1. Stainless Steel: Coat 300 series stainless steel with an epoxy primer 5 mils (0.127 mm) thick and an epoxy finish 5 mils (0.127 mm) thick if operating in a temperature range between 140 and 300 deg F (60 and 149 deg C). Consult coating manufacturer for appropriate coating materials and application methods for operating temperature range.

2. Carbon Steel: Coat carbon steel operating at a service temperature between 32 and 300 deg F (0 and 149 deg C) with an epoxy coating. Consult coating manufacturer for appropriate coating materials and application methods for operating temperature range.
- C. Coordinate insulation installation with the trade installing heat tracing. Comply with requirements for heat tracing that apply to insulation.
- D. Mix insulating cements with clean potable water; if insulating cements are to be in contact with stainless-steel surfaces, use demineralized water.

### 3.3 GENERAL INSTALLATION REQUIREMENTS

- A. Install insulation materials, accessories, and finishes with smooth, straight, and even surfaces; free of voids throughout the length of piping including fittings, valves, and specialties.
- B. Install insulation materials, forms, vapor barriers or retarders, jackets, and thicknesses required for each item of pipe system as specified in insulation system schedules.
- C. Install accessories compatible with insulation materials and suitable for the service. Install accessories that do not corrode, soften, or otherwise attack insulation or jacket in either wet or dry state.
- D. Install insulation with longitudinal seams at top and bottom of horizontal runs.
- E. Install multiple layers of insulation with longitudinal and end seams staggered.
- F. Do not weld brackets, clips, or other attachment devices to piping, fittings, and specialties.
- G. Keep insulation materials dry during application and finishing.
- H. Install insulation with tight longitudinal seams and end joints. Bond seams and joints with adhesive recommended by insulation material manufacturer.
- I. Install insulation with least number of joints practical.
- J. Where vapor barrier is indicated, seal joints, seams, and penetrations in insulation at hangers, supports, anchors, and other projections with vapor-barrier mastic.
  1. Install insulation continuously through hangers and around anchor attachments.
  2. For insulation application where vapor barriers are indicated, extend insulation on anchor legs from point of attachment to supported item to point of attachment to structure. Taper and seal ends at attachment to structure with vapor-barrier mastic.
  3. Install insert materials and install insulation to tightly join the insert. Seal insulation to insulation inserts with adhesive or sealing compound recommended by insulation material manufacturer.
  4. Cover inserts with jacket material matching adjacent pipe insulation. Install shields over jacket, arranged to protect jacket from tear or puncture by hanger, support, and shield.

- K. Apply adhesives, mastics, and sealants at manufacturer's recommended coverage rate and wet and dry film thicknesses.
- L. Install insulation with factory-applied jackets as follows:
  - 1. Draw jacket tight and smooth.
  - 2. Cover circumferential joints with 3-inch- (75-mm-) wide strips, of same material as insulation jacket. Secure strips with adhesive and outward clinching staples along both edges of strip, spaced 4 inches (100 mm) o.c.
  - 3. Overlap jacket longitudinal seams at least 1-1/2 inches (38 mm). Install insulation with longitudinal seams at bottom of pipe. Clean and dry surface to receive self-sealing lap. Staple laps with outward clinching staples along edge at 2 inches (50 mm) o.c.
    - a. For below-ambient services, apply vapor-barrier mastic over staples.
  - 4. Cover joints and seams with tape, according to insulation material manufacturer's written instructions, to maintain vapor seal.
  - 5. Where vapor barriers are indicated, apply vapor-barrier mastic on seams and joints and at ends adjacent to pipe flanges and fittings.
- M. Cut insulation in a manner to avoid compressing insulation more than 75 percent of its nominal thickness.
- N. Finish installation with systems at operating conditions. Repair joint separations and cracking due to thermal movement.
- O. Repair damaged insulation facings by applying same facing material over damaged areas. Extend patches at least 4 inches (100 mm) beyond damaged areas. Adhere, staple, and seal patches similar to butt joints.
- P. For above-ambient services, do not install insulation to the following:
  - 1. Vibration-control devices.
  - 2. Testing agency labels and stamps.
  - 3. Nameplates and data plates.
  - 4. Cleanouts.

### 3.4 PENETRATIONS

- A. Insulation Installation at Roof Penetrations: Install insulation continuously through roof penetrations.
  - 1. Seal penetrations with flashing sealant.
  - 2. For applications requiring only indoor insulation, terminate insulation above roof surface and seal with joint sealant. For applications requiring indoor and outdoor insulation, install insulation for outdoor applications tightly joined to indoor insulation ends. Seal joint with joint sealant.
  - 3. Extend jacket of outdoor insulation outside roof flashing at least 2 inches (50 mm) below top of roof flashing.

4. Seal jacket to roof flashing with flashing sealant.
  - B. Insulation Installation at Underground Exterior Wall Penetrations: Terminate insulation flush with sleeve seal. Seal terminations with flashing sealant.
  - C. Insulation Installation at Aboveground Exterior Wall Penetrations: Install insulation continuously through wall penetrations.
    1. Seal penetrations with flashing sealant.
    2. For applications requiring only indoor insulation, terminate insulation inside wall surface and seal with joint sealant. For applications requiring indoor and outdoor insulation, install insulation for outdoor applications tightly joined to indoor insulation ends. Seal joint with joint sealant.
    3. Extend jacket of outdoor insulation outside wall flashing and overlap wall flashing at least 2 inches (50 mm).
    4. Seal jacket to wall flashing with flashing sealant.
  - D. Insulation Installation at Interior Wall and Partition Penetrations (That Are Not Fire Rated): Install insulation continuously through walls and partitions.
  - E. Insulation Installation at Fire-Rated Wall and Partition Penetrations: Install insulation continuously through penetrations of fire-rated walls and partitions.
    1. Comply with requirements in Section 078413 "Penetration Firestopping" for firestopping and fire-resistive joint sealers.
  - F. Insulation Installation at Floor Penetrations:
    1. Pipe: Install insulation continuously through floor penetrations.
    2. Seal penetrations through fire-rated assemblies. Comply with requirements in Section 078413 "Penetration Firestopping."
- 3.5 GENERAL PIPE INSULATION INSTALLATION

- A. Requirements in this article generally apply to all insulation materials except where more specific requirements are specified in various pipe insulation material installation articles.
- B. Insulation Installation on Fittings, Valves, Strainers, Flanges, and Unions:
  1. Install insulation over fittings, valves, strainers, flanges, unions, and other specialties with continuous thermal and vapor-retarder integrity unless otherwise indicated.
  2. Insulate pipe elbows using preformed fitting insulation or mitered fittings made from same material and density as adjacent pipe insulation. Each piece shall be butted tightly against adjoining piece and bonded with adhesive. Fill joints, seams, voids, and irregular surfaces with insulating cement finished to a smooth, hard, and uniform contour that is uniform with adjoining pipe insulation.
  3. Insulate tee fittings with preformed fitting insulation or sectional pipe insulation of same material and thickness as used for adjacent pipe. Cut sectional pipe insulation to fit. Butt

- each section closely to the next and hold in place with tie wire. Bond pieces with adhesive.
4. Insulate valves using preformed fitting insulation or sectional pipe insulation of same material, density, and thickness as used for adjacent pipe. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker. For valves, insulate up to and including the bonnets, valve stuffing-box studs, bolts, and nuts. Fill joints, seams, and irregular surfaces with insulating cement.
  5. Insulate strainers using preformed fitting insulation or sectional pipe insulation of same material, density, and thickness as used for adjacent pipe. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker. Fill joints, seams, and irregular surfaces with insulating cement. Insulate strainers so strainer basket flange or plug can be easily removed and replaced without damaging the insulation and jacket. Provide a removable reusable insulation cover. For below-ambient services, provide a design that maintains vapor barrier.
  6. Insulate flanges and unions using a section of oversized preformed pipe insulation. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker.
  7. Cover segmented insulated surfaces with a layer of finishing cement and coat with a mastic. Install vapor-barrier mastic for below-ambient services and a breather mastic for above-ambient services. Reinforce the mastic with fabric-reinforcing mesh. Trowel the mastic to a smooth and well-shaped contour.
  8. For services not specified to receive a field-applied jacket except for flexible elastomeric and polyolefin, install fitted PVC cover over elbows, tees, strainers, valves, flanges, and unions. Terminate ends with PVC end caps. Tape PVC covers to adjoining insulation facing using PVC tape.
  9. Stencil or label the outside insulation jacket of each union with the word "union." Match size and color of pipe labels.
- C. Insulate instrument connections for thermometers, pressure gages, pressure temperature taps, test connections, flow meters, sensors, switches, and transmitters on insulated pipes. Shape insulation at these connections by tapering it to and around the connection with insulating cement and finish with finishing cement, mastic, and flashing sealant.
- D. Install removable insulation covers at locations indicated. Installation shall conform to the following:
1. Make removable flange and union insulation from sectional pipe insulation of same thickness as that on adjoining pipe. Install same insulation jacket as adjoining pipe insulation.
  2. When flange and union covers are made from sectional pipe insulation, extend insulation from flanges or union long at least two times the insulation thickness over adjacent pipe insulation on each side of flange or union. Secure flange cover in place with stainless-steel or aluminum bands. Select band material compatible with insulation and jacket.
  3. Construct removable valve insulation covers in same manner as for flanges, except divide the two-part section on the vertical center line of valve body.
  4. When covers are made from block insulation, make two halves, each consisting of mitered blocks wired to stainless-steel fabric. Secure this wire frame, with its attached insulation, to flanges with tie wire. Extend insulation at least 2 inches (50 mm) over

adjacent pipe insulation on each side of valve. Fill space between flange or union cover and pipe insulation with insulating cement. Finish cover assembly with insulating cement applied in two coats. After first coat is dry, apply and trowel second coat to a smooth finish.

5. Unless a PVC jacket is indicated in field-applied jacket schedules, finish exposed surfaces with a metal jacket.

### 3.6 INSTALLATION OF CELLULAR-GLASS INSULATION

#### A. Insulation Installation on Straight Pipes and Tubes:

1. Secure each layer of insulation to pipe with wire or bands and tighten bands without deforming insulation materials.
2. Where vapor barriers are indicated, seal longitudinal seams, end joints, and protrusions with vapor-barrier mastic and joint sealant.
3. For insulation with factory-applied jackets on above-ambient services, secure laps with outward clinched staples at 6 inches (150 mm) o.c.
4. For insulation with factory-applied jackets on below-ambient services, do not staple longitudinal tabs. Instead, secure tabs with additional adhesive as recommended by insulation material manufacturer and seal with vapor-barrier mastic and flashing sealant.

#### B. Insulation Installation on Pipe Flanges:

1. Install preformed pipe insulation to outer diameter of pipe flange.
2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with cut sections of cellular-glass block insulation of same thickness as pipe insulation.
4. Install jacket material with manufacturer's recommended adhesive, overlap seams at least 1 inch (25 mm), and seal joints with flashing sealant.

#### C. Insulation Installation on Pipe Fittings and Elbows:

1. Install preformed sections of same material as straight segments of pipe insulation when available. Secure according to manufacturer's written instructions.
2. When preformed sections of insulation are not available, install mitered sections of cellular-glass insulation. Secure insulation materials with wire or bands.

#### D. Insulation Installation on Valves and Pipe Specialties:

1. Install preformed sections of cellular-glass insulation to valve body.
2. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
3. Install insulation to flanges as specified for flange insulation application.



### 3.7 INSTALLATION OF FLEXIBLE ELASTOMERIC INSULATION

- A. Seal longitudinal seams and end joints with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- B. Insulation Installation on Pipe Flanges:
  - 1. Install pipe insulation to outer diameter of pipe flange.
  - 2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
  - 3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with cut sections of sheet insulation of same thickness as pipe insulation.
  - 4. Secure insulation to flanges and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- C. Insulation Installation on Pipe Fittings and Elbows:
  - 1. Install mitered sections of pipe insulation.
  - 2. Secure insulation materials and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- D. Insulation Installation on Valves and Pipe Specialties:
  - 1. Install preformed valve covers manufactured of same material as pipe insulation when available.
  - 2. When preformed valve covers are not available, install cut sections of pipe and sheet insulation to valve body. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
  - 3. Install insulation to flanges as specified for flange insulation application.
  - 4. Secure insulation to valves and specialties and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.

### 3.8 INSTALLATION OF MINERAL-FIBER INSULATION

- A. Insulation Installation on Straight Pipes and Tubes:
  - 1. Secure each layer of preformed pipe insulation to pipe with wire or bands and tighten bands without deforming insulation materials.
  - 2. Where vapor barriers are indicated, seal longitudinal seams, end joints, and protrusions with vapor-barrier mastic and joint sealant.
  - 3. For insulation with factory-applied jackets on above-ambient surfaces, secure laps with outward clinched staples at 6 inches (150 mm) o.c.
  - 4. For insulation with factory-applied jackets on below-ambient surfaces, do not staple longitudinal tabs. Instead, secure tabs with additional adhesive as recommended by insulation material manufacturer and seal with vapor-barrier mastic and flashing sealant.
- B. Insulation Installation on Pipe Flanges:

1. Install preformed pipe insulation to outer diameter of pipe flange.
2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with mineral-fiber blanket insulation.
4. Install jacket material with manufacturer's recommended adhesive, overlap seams at least 1 inch (25 mm), and seal joints with flashing sealant.

C. Insulation Installation on Pipe Fittings and Elbows:

1. Install preformed sections of same material as straight segments of pipe insulation when available.
2. When preformed insulation elbows and fittings are not available, install mitered sections of pipe insulation, to a thickness equal to adjoining pipe insulation. Secure insulation materials with wire or bands.

D. Insulation Installation on Valves and Pipe Specialties:

1. Install preformed sections of same material as straight segments of pipe insulation when available.
2. When preformed sections are not available, install mitered sections of pipe insulation to valve body.
3. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
4. Install insulation to flanges as specified for flange insulation application.

### 3.9 INSTALLATION OF PHENOLIC INSULATION

A. General Installation Requirements:

1. Secure single-layer insulation with stainless-steel bands at 12-inch (300-mm) intervals and tighten bands without deforming insulation materials.
2. Install 2-layer insulation with joints tightly butted and staggered at least 3 inches (75 mm). Secure inner layer with 0.062-inch (1.6-mm) wire spaced at 12-inch (300-mm) intervals. Secure outer layer with stainless-steel bands at 12-inch (300-mm) intervals.

B. Insulation Installation on Straight Pipes and Tubes:

1. Secure each layer of insulation to pipe with wire or bands and tighten bands without deforming insulation materials.
2. Where vapor barriers are indicated, seal longitudinal seams, end joints, and protrusions with vapor-barrier mastic and joint sealant.
3. For insulation with factory-applied jackets on above-ambient services, secure laps with outward clinched staples at 6 inches (150 mm) o.c.
4. For insulation with factory-applied jackets with vapor retarders on below-ambient services, do not staple longitudinal tabs. Instead, secure tabs with additional adhesive as recommended by insulation material manufacturer and seal with vapor-barrier mastic and flashing sealant.

C. Insulation Installation on Pipe Flanges:

1. Install preformed pipe insulation to outer diameter of pipe flange.
2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with cut sections of block insulation of same material and thickness as pipe insulation.

D. Insulation Installation on Pipe Fittings and Elbows:

1. Install preformed insulation sections of same material as straight segments of pipe insulation. Secure according to manufacturer's written instructions.

E. Insulation Installation on Valves and Pipe Specialties:

1. Install preformed insulation sections of same material as straight segments of pipe insulation. Secure according to manufacturer's written instructions.
2. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
3. Install insulation to flanges as specified for flange insulation application.

3.10 INSTALLATION OF POLYOLEFIN INSULATION

A. Insulation Installation on Straight Pipes and Tubes:

1. Seal split-tube longitudinal seams and end joints with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.

B. Insulation Installation on Pipe Flanges:

1. Install pipe insulation to outer diameter of pipe flange.
2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with cut sections of polyolefin sheet insulation of same thickness as pipe insulation.
4. Secure insulation to flanges and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.

C. Insulation Installation on Pipe Fittings and Elbows:

1. Install mitered sections of polyolefin pipe insulation.
2. Secure insulation materials and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.

D. Insulation Installation on Valves and Pipe Specialties:

1. Install cut sections of polyolefin pipe and sheet insulation to valve body.
2. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
3. Install insulation to flanges as specified for flange insulation application.
4. Secure insulation to valves and specialties, and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.

### 3.11 FIELD-APPLIED JACKET INSTALLATION

- A. Where glass-cloth jackets are indicated, install directly over bare insulation or insulation with factory-applied jackets.
  1. Draw jacket smooth and tight to surface with 2-inch (50-mm) overlap at seams and joints.
  2. Embed glass cloth between two 0.062-inch- (1.6-mm-) thick coats of lagging adhesive.
  3. Completely encapsulate insulation with coating, leaving no exposed insulation.
- B. Where FSK jackets are indicated, install as follows:
  1. Draw jacket material smooth and tight.
  2. Install lap or joint strips with same material as jacket.
  3. Secure jacket to insulation with manufacturer's recommended adhesive.
  4. Install jacket with 1-1/2-inch (38-mm) laps at longitudinal seams and 3-inch- (75-mm-) wide joint strips at end joints.
  5. Seal openings, punctures, and breaks in vapor-retarder jackets and exposed insulation with vapor-barrier mastic.
- C. Where PVC jackets are indicated, install with 1-inch (25-mm) overlap at longitudinal seams and end joints. Seal with manufacturer's recommended adhesive.
  1. Apply two continuous beads of adhesive to seams and joints, one bead under lap and the finish bead along seam and joint edge.
- D. Where metal jackets are indicated, install with 2-inch (50-mm) overlap at longitudinal seams and end joints. Overlap longitudinal seams arranged to shed water. Seal end joints with weatherproof sealant recommended by insulation manufacturer. Secure jacket with stainless-steel bands 12 inches (300 mm) o.c. and at end joints.

### 3.12 FINISHES

- A. Insulation with ASJ, Glass-Cloth, or Other Paintable Jacket Material: Paint jacket with paint system identified below and as specified in Section 099113 "Exterior Painting" and Section 099123 "Interior Painting."
  1. Flat Acrylic Finish: Two finish coats over a primer that is compatible with jacket material and finish coat paint. Add fungicidal agent to render fabric mildew proof.
    - a. Finish Coat Material: Interior, flat, latex-emulsion size.

- B. Flexible Elastomeric Thermal Insulation: After adhesive has fully cured, apply two coats of insulation manufacturer's recommended protective coating.
- C. Color: Final color as selected by Architect. Vary first and second coats to allow visual inspection of the completed Work.
- D. Do not field paint aluminum or stainless-steel jackets.

### 3.13 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. Perform tests and inspections.
- C. Tests and Inspections:
  - 1. Inspect pipe, fittings, strainers, and valves, randomly selected by Architect, by removing field-applied jacket and insulation in layers in reverse order of their installation. Extent of inspection shall be limited to three locations of straight pipe, three locations of threaded fittings, three locations of welded fittings, two locations of threaded strainers, two locations of welded strainers, three locations of threaded valves, and three locations of flanged valves for each pipe service defined in the "Piping Insulation Schedule, General" Article.
- D. All insulation applications will be considered defective Work if sample inspection reveals noncompliance with requirements.

### 3.14 PIPING INSULATION SCHEDULE, GENERAL

- A. Acceptable preformed pipe and tubular insulation materials and thicknesses are identified for each piping system and pipe size range. If more than one material is listed for a piping system, selection from materials listed is Contractor's option.
- B. Items Not Insulated: Unless otherwise indicated, do not install insulation on the following:
  - 1. Drainage piping located in crawl spaces.
  - 2. Underground piping.
  - 3. Chrome-plated pipes and fittings unless there is a potential for personnel injury.

### 3.15 INDOOR PIPING INSULATION SCHEDULE

- A. Domestic Cold Water:
  - 1. NPS 1 (DN 25) and Smaller: Insulation shall be one of the the following:
    - a. Cellular Glass: 1-1/2 inches (38 mm) thick.
    - b. Flexible Elastomeric: 3/4 inch (19 mm) thick.
    - c. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1/2 inch (13 mm) thick.

- d. Phenolic: 1 inch (25 mm) thick.
  - e. Polyolefin: 3/4 inch (19 mm) thick.
2. NPS 1-1/4 (DN 32) and Larger: Insulation shall be one of the following:
- a. Cellular Glass: 1-1/2 inches (38 mm) thick.
  - b. Flexible Elastomeric: 1 inch (25 mm) thick.
  - c. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1 inch (25 mm) thick.
  - d. Phenolic: 1 inch (25 mm) thick.
  - e. Polyolefin: 1 inch (25 mm) thick.
- B. Domestic Hot and Recirculated Hot Water:
1. NPS 1-1/4 (DN 32) and Smaller: Insulation shall be one of the following:
- a. Cellular Glass: 1-1/2 inches (38 mm) thick.
  - b. Flexible Elastomeric: 1 inch (25 mm) thick.
  - c. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1 inch (25 mm) thick.
  - d. Phenolic: 1 inch (25 mm) thick.
  - e. Polyolefin: 1 inch (25 mm) thick.
2. NPS 1-1/2 (DN 40) and Larger: Insulation shall be one of the following:
- a. Cellular Glass: 1-1/2 inches (38 mm) thick.
  - b. Flexible Elastomeric: 1 inch (25 mm) thick.
  - c. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1 inch (25 mm) thick.
  - d. Phenolic: 1 inch (25 mm) thick.
  - e. Polyolefin: 1 inch (25 mm) thick.
- C. Domestic Chilled Water (Potable):
1. All Pipe Sizes: Insulation shall be one of the following:
- a. Cellular Glass: 1-1/2 inches (38 mm) thick.
  - b. Flexible Elastomeric: 1 inch (25 mm) thick.
  - c. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1 inch (25 mm) thick.
  - d. Phenolic: 1 inch (25 mm) thick.
  - e. Polyolefin: 1 inch (25 mm) thick.
  - f.
- D. Exposed Sanitary Drains, Domestic Water, Domestic Hot Water, and Stops for Plumbing Fixtures for People with Disabilities:
1. All Pipe Sizes: Insulation shall be one of the following:
- a. Flexible Elastomeric: **3/4 inch (19 mm)] [1 inch (25 mm)]**.
  - b. Mineral-Fiber, Preformed Pipe Insulation, Type I: **1 inch (25 mm)** thick.
  - c. Polyolefin: 1 inch (25 mm) thick.
- E. Sanitary Waste Piping Where Heat Tracing Is Installed:

1. All Pipe Sizes: Insulation shall be one of the following:
  - a. Cellular Glass: 2 inches (50 mm) thick.
  - b. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1-1/2 inches (38 mm) thick.
  - c. Phenolic: 1-1/2 inches (38 mm) thick.

F. Floor Drains, Traps, and Sanitary Drain Piping within 10 Feet (3 m) of Drain Receiving Condensate and Equipment Drain Water below 60 Deg F (16 Deg C):

1. All Pipe Sizes: Insulation shall be one of the following:
  - a. Cellular Glass: 1-1/2 inches (38 mm) thick.
  - b. Flexible Elastomeric: 1 inch (25 mm) thick.
  - c. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1 inch (25 mm) thick.
  - d. Phenolic: 1 inch (25 mm) thick.
  - e. Polyolefin: 1 inch (25 mm) thick.

G. Hot Service Drains:

1. All Pipe Sizes: Insulation shall be one of the following:
  - a. Cellular Glass: 1-1/2 inches (38 mm) thick.
  - b. Mineral-Fiber, Preformed Pipe, Type I or II: 1 inch (25 mm) thick.

H. Hot Service Vents:

1. All Pipe Sizes: Insulation shall be one of the following:
  - a. Cellular Glass: 1-1/2 inches (38 mm) thick.
  - b. Mineral-Fiber, Preformed Pipe, Type I or II: 1 inch (25 mm) thick.

3.16 OUTDOOR, ABOVEGROUND PIPING INSULATION SCHEDULE

A. Domestic Water Piping:

1. All Pipe Sizes: Insulation shall be one of the following:
  - a. Cellular Glass: 2 inches (50 mm) thick.
  - b. Flexible Elastomeric: 2 inches (50 mm) thick.
  - c. Mineral-Fiber, Preformed Pipe Insulation, Type I: 2 inches (50 mm) thick.
  - d. Phenolic: 2 inches (50 mm) thick.
  - e. Polyolefin: 2 inches (50 mm) thick.

B. Domestic Hot and Recirculated Hot Water:

1. All Pipe Sizes: Insulation shall be one of the following:
  - a. Cellular Glass: 2 inches (50 mm) thick.
  - b. Flexible Elastomeric: 2 inches (50 mm) thick.

- c. Mineral-Fiber, Preformed Pipe Insulation, Type I: 2 inches (50 mm) thick.
- d. Phenolic: 2 inches (50 mm) thick.
- e. Polyolefin: 2 inches (50 mm) thick.

C. Sanitary Waste Piping Where Heat Tracing Is Installed:

- 1. All Pipe Sizes: Insulation shall be one of the following:
  - a. Cellular Glass: 2 inches (50 mm) thick.
  - b. Mineral-Fiber, Preformed Pipe Insulation, Type I: 2 inches (50 mm) thick.
  - c. Phenolic: 2 inches (50 mm) thick.

D. Hot Service Drains:

- 1. All Pipe Sizes: Insulation shall be one of the following:
  - a. Cellular Glass: 1-1/2 inches (38 mm) thick.
  - b. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1 inch (25 mm) thick.

E. Hot Service Vents:

- 1. All Pipe Sizes: Insulation shall be one of the following:
  - a. Cellular Glass: 1-1/2 inches (38 mm) thick.
  - b. Mineral-Fiber, Preformed Pipe Insulation, Type II: 1 inch (25 mm) thick.

3.17 OUTDOOR, UNDERGROUND PIPING INSULATION SCHEDULE

- A. Sanitary Waste Piping, All Sizes, Where Heat Tracing Is Installed: Cellular glass, 2 inches (50 mm) thick.
- B. Chilled Water, All Sizes: Cellular glass, 2 inches (50 mm) thick.

3.18 INDOOR, FIELD-APPLIED JACKET SCHEDULE

- A. Install jacket over insulation material. For insulation with factory-applied jacket, install the field-applied jacket over the factory-applied jacket.
- B. If more than one material is listed, selection from materials listed is Contractor's option.
- C. Piping, Concealed:
  - 1. None.
  - 2. PVC, Color-Coded by System: 30 mils (0.8 mm) thick.
  - 3. Aluminum, Smooth: 0.032 inch (0.81 mm) thick.
  - 4. Painted Aluminum, Smooth: 0.032 inch (0.81 mm) thick.
  - 5. Stainless Steel, Type 304 or Type 316, Smooth 2B Finish Corrugated: 0.020 inch (0.51 mm) thick.



D. Piping, Exposed:

1. None.
2. PVC, Color-Coded by System: 30 mils (0.8 mm) thick.
3. Aluminum, Smooth: 0.032 inch (0.81 mm) thick.
4. Painted Aluminum, Smooth: 0.024 inch (0.61 mm) thick.
5. Stainless Steel, Type 304 or Type 316, Smooth 2B Finish Corrugated: 0.020 inch (0.51 mm) thick.

3.19 OUTDOOR, FIELD-APPLIED JACKET SCHEDULE

A. Install jacket over insulation material. For insulation with factory-applied jacket, install the field-applied jacket over the factory-applied jacket.

B. If more than one material is listed, selection from materials listed is Contractor's option.

C. Piping, Concealed:

1. None.
2. PVC, Color-Coded by System: 30 mils (0.8 mm) thick.
3. Aluminum, Smooth: 0.032 inch (0.81 mm) thick.
4. Painted Aluminum, Smooth: 0.024 inch (0.61 mm) thick.
5. Stainless Steel, Type 304 or Type 316, Smooth 2B Finish Corrugated: 0.020 inch (0.51 mm) thick.

D. Piping, Exposed:

1. PVC: 30 mils (0.8 mm) thick.
2. Painted Aluminum, Smooth with Z-Shaped Locking Seam: 0.032 inch (0.81 mm) thick.
3. Stainless Steel, Type 304 or Type 316, Smooth 2B Finish Corrugated with Z-Shaped Locking Seam: 0.020 inch (0.51 mm) thick.

3.20 UNDERGROUND, FIELD-INSTALLED INSULATION JACKET

A. For underground direct-buried piping applications, install underground direct-buried jacket over insulation material.

END OF SECTION 220719

SECTION 221116 - DOMESTIC WATER PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

- 1. Under-building-slab and aboveground domestic water pipes, tubes, and fittings inside buildings.
- 2. Encasement for piping.

B. Related Requirements:

- 1. Section 221113 "Facility Water Distribution Piping" for water-service piping and water meters outside the building from source to the point where water-service piping enters the building.

1.3 ACTION SUBMITTALS

- A. Product Data: For transition fittings and dielectric fittings.

B. LEED Submittals:

- 1. Product Data for Credit IEQ 4.1: For solvent cements and adhesive primers, documentation including printed statement of VOC content.
- 2. Laboratory Test Reports for Credit IEQ 4: For solvent cements and adhesive primers, documentation indicating that products comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

1.4 INFORMATIONAL SUBMITTALS

- A. System purging and disinfecting activities report.
- B. Field quality-control reports.

1.5 FIELD CONDITIONS

- A. Interruption of Existing Water Service: Do not interrupt water service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary water service according to requirements indicated:
1. Notify Owner no fewer than two days in advance of proposed interruption of water service.
  2. Do not interrupt water service without Owner's written permission.

PART 2 - PRODUCTS

2.1 PIPING MATERIALS

- A. Comply with requirements in "Piping Schedule" Article for applications of pipe, tube, fitting materials, and joining methods for specific services, service locations, and pipe sizes.
- B. Potable-water piping and components shall comply with NSF 14 and NSF 61 Annex G. Plastic piping components shall be marked with "NSF-pw."

2.2 COPPER TUBE AND FITTINGS

- A. Hard Copper Tube: ASTM B 88, Type L (ASTM B 88M, Type B) and ASTM B 88, Type M (ASTM B 88M, Type C) water tube, drawn temper.
- B. Soft Copper Tube: ASTM B 88, Type K (ASTM B 88M, Type A) and ASTM B 88, Type L (ASTM B 88M, Type B) water tube, annealed temper.
- C. Cast-Copper, Solder-Joint Fittings: ASME B16.18, pressure fittings.
- D. Wrought-Copper, Solder-Joint Fittings: ASME B16.22, wrought-copper pressure fittings.
- E. Bronze Flanges: ASME B16.24, Class 150, with solder-joint ends.
- F. Copper Unions:
1. MSS SP-123.
  2. Cast-copper-alloy, hexagonal-stock body.
  3. Ball-and-socket, metal-to-metal seating surfaces.
  4. Solder-joint or threaded ends.
- G. Copper Pressure-Seal-Joint Fittings:
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- a. Elkhart Products Corporation.
    - b. NIBCO INC.
    - c. Viega LLC.
  2. Fittings for NPS 2 (DN 50) and Smaller: Wrought-copper fitting with EPDM-rubber, O-ring seal in each end.
  3. Fittings for NPS 2-1/2 to NPS 4 (DN 65 to DN 100): Cast-bronze or wrought-copper fitting with EPDM-rubber, O-ring seal in each end.
- H. Copper Push-on-Joint Fittings:
  1. Manufacturers: Subject to compliance with requirements, provide products by the following:
    - a. Victaulic Company.
  2. Description:
    - a. Cast-copper fitting complying with ASME B16.18 or wrought-copper fitting complying with ASME B 16.22.
    - b. Stainless-steel teeth and EPDM-rubber, O-ring seal in each end instead of solder-joint ends.
- I. Copper-Tube, Extruded-Tee Connections:
  1. Manufacturers: Subject to compliance with requirements, provide products by the following:
    - a. T-DRILL Industries Inc.
  2. Description: Tee formed in copper tube according to ASTM F 2014.
- J. Appurtenances for Grooved-End Copper Tubing:
  1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Anvil International.
    - b. Shurjoint Piping Products.
    - c. Victaulic Company.
  2. Bronze Fittings for Grooved-End, Copper Tubing: ASTM B 75 (ASTM B 75M) copper tube or ASTM B 584 bronze castings.
  3. Mechanical Couplings for Grooved-End Copper Tubing:
    - a. Copper-tube dimensions and design similar to AWWA C606.
    - b. Ferrous housing sections.
    - c. EPDM-rubber gaskets suitable for hot and cold water.
    - d. Bolts and nuts.
    - e. Minimum Pressure Rating: 300 psig (2070 kPa).

2.3 DUCTILE-IRON PIPE AND FITTINGS

A. Mechanical-Joint, Ductile-Iron Pipe:

1. AWWA C151/A21.51, with mechanical-joint bell and plain spigot end unless grooved or flanged ends are indicated.
2. Glands, Gaskets, and Bolts: AWWA C111/A21.11, ductile- or gray-iron glands, rubber gaskets, and steel bolts.

B. Standard-Pattern, Mechanical-Joint Fittings:

1. AWWA C110/A21.10, ductile or gray iron.
2. Glands, Gaskets, and Bolts: AWWA C111/A21.11, ductile- or gray-iron glands, rubber gaskets, and steel bolts.

C. Compact-Pattern, Mechanical-Joint Fittings:

1. AWWA C153/A21.53, ductile iron.
2. Glands, Gaskets, and Bolts: AWWA C111/A21.11, ductile- or gray-iron glands, rubber gaskets, and steel bolts.

D. Push-on-Joint, Ductile-Iron Pipe:

1. AWWA C151/A21.51.
2. Push-on-joint bell and plain spigot end unless grooved or flanged ends are indicated.

E. Standard-Pattern, Push-on-Joint Fittings:

1. AWWA C110/A21.10, ductile or gray iron.
2. Gaskets: AWWA C111/A21.11, rubber.

F. Compact-Pattern, Push-on-Joint Fittings:

1. AWWA C153/A21.53, ductile iron.
2. Gaskets: AWWA C111/A21.11, rubber.

G. Plain-End, Ductile-Iron Pipe: AWWA C151/A21.51.

H. Appurtenances for Grooved-End, Ductile-Iron Pipe:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Shurjoint Piping Products.
  - b. Smith-Cooper International.
  - c. Star Pipe Products.
  - d. Victaulic Company.
2. Fittings for Grooved-End, Ductile-Iron Pipe: ASTM A 47/A 47M, malleable-iron castings or ASTM A 536, ductile-iron castings with dimensions that match pipe.
3. Mechanical Couplings for Grooved-End, Ductile-Iron-Piping:

- a. AWWA C606 for ductile-iron-pipe dimensions.
- b. Ferrous housing sections.
- c. EPDM-rubber gaskets suitable for hot and cold water.
- d. Bolts and nuts.
- e. Minimum Pressure Rating:
  - 1) NPS 14 to NPS 18 (DN 350 to DN 450): 250 psig (1725 kPa).
  - 2) NPS 20 to NPS 46 (DN 500 to DN 900): 150 psig (1035 kPa).

## 2.4 GALVANIZED-STEEL PIPE AND FITTINGS

### A. Galvanized-Steel Pipe:

1. ASTM A 53/A 53M, Type E,, Standard Weight.
2. Include ends matching joining method.

### B. Galvanized-Steel Pipe Nipples: ASTM A 733, made of ASTM A 53/A 53M or ASTM A 106/A 106M, Standard Weight, seamless steel pipe with threaded ends.

### C. Galvanized, Gray-Iron Threaded Fittings: ASME B16.4, Class 125, standard pattern.

### D. Malleable-Iron Unions:

1. ASME B16.39, Class 150.
2. Hexagonal-stock body.
3. Ball-and-socket, metal-to-metal, bronze seating surface.
4. Threaded ends.

### E. Flanges: ASME B16.1, Class 125, cast iron.

### F. Appurtenances for Grooved-End, Galvanized-Steel Pipe:

1. <Double click here to find, evaluate, and insert list of manufacturers and products.>
2. Fittings for Grooved-End, Galvanized-Steel Pipe: Galvanized, ASTM A 47/A 47M, malleable-iron casting; ASTM A 106/A 106M, steel pipe; or ASTM A 536, ductile-iron casting; with dimensions matching steel pipe.
3. Fittings for Grooved-End, Galvanized-Steel Pipe:
  - a. AWWA C606 for steel-pipe dimensions.
  - b. Ferrous housing sections.
  - c. EPDM-rubber gaskets suitable for hot and cold water.
  - d. Bolts and nuts.
  - e. Minimum Pressure Rating:
    - 1) NPS 8 (DN 200) and Smaller: 600 psig (4137 kPa).
    - 2) NPS 10 and NPS 12 (DN 250 to DN 300): 400 psig (2758 kPa).
    - 3) NPS 14 to NPS 24 (DN 350 to DN 600): 250 psig (1725 kPa).

2.5 STAINLESS-STEEL PIPING

- A. Potable-water piping and components shall comply with NSF 61 Annex G.
- B. Stainless-Steel Pipe: ASTM A 312/A 312M, Schedule 10 and Schedule 40.
- C. Stainless-Steel Pipe Fittings: ASTM A 815/A 815M.
- D. Appurtenances for Grooved-End, Stainless-Steel Pipe:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Anvil International.
    - b. Grinnell Mechanical Products.
    - c. Victaulic Company.
  - 2. Fittings for Grooved-End, Stainless-Steel Pipe: Stainless-steel casting with dimensions matching stainless-steel pipe.
  - 3. Mechanical Couplings for Grooved-End, Stainless-Steel Pipe:
    - a. AWWA C606 for stainless-steel-pipe dimensions.
    - b. Stainless-steel housing sections.
    - c. Stainless-steel bolts and nuts.
    - d. EPDM-rubber gaskets suitable for hot and cold water.
    - e. Minimum Pressure Rating:
      - 1) NPS 8 (DN 200) and Smaller: 600 psig (4137 kPa).
      - 2) NPS 10 and NPS 12 (DN 250 to DN 300): 400 psig (2758 kPa).
      - 3) NPS 14 to NPS 24 (DN 350 to DN 600): 250 psig (1725 kPa).

2.6 CPVC PIPING

- A. CPVC Pipe: ASTM F 441/F 441M, Schedule 40 and Schedule 80.
  - 1. CPVC Socket Fittings: ASTM F 438 for Schedule 40 and ASTM F 439 for Schedule 80.
  - 2. CPVC Threaded Fittings: ASTM F 437, Schedule 80.
- B. CPVC Piping System: ASTM D 2846/D 2846M, SDR 11, pipe and socket fittings.
- C. CPVC Tubing System: ASTM D 2846/D 2846M, SDR 11, tube and socket fittings.

2.7 PEX TUBE AND FITTINGS

- A. PEX Distribution System: ASTM F 877, SDR 9 tubing.
- B. Fittings for PEX Tube: ASTM F 1807, metal-insert type with copper or stainless-steel crimp rings and matching PEX tube dimensions.

- C. Manifold: Multiple-outlet, plastic or corrosion-resistant-metal assembly complying with ASTM F 877; with plastic or corrosion-resistant-metal valve for each outlet.

## 2.8 PEX-AL-PEX TUBE AND FITTINGS

- A. PEX-AL-PEX Distribution System: ASTM F 1281 tubing.
- B. Fittings for PEX-AL-PEX Tube: ASTM F 1281, metal-insert type with copper or stainless-steel crimp rings and matching PEX-AL-PEX tube dimensions.

## 2.9 PEX-AL-HDPE TUBE AND FITTINGS

- A. PEX-AL-HPDE Distribution System: ASTM F 1986 tubing.
- B. Fittings for PEX-AL-HDPE Tube: ASTM F 1986, metal-insert type with copper or stainless-steel crimp ring and matching PEX-AL-HDPE tube dimensions

## 2.10 PVC PIPE AND FITTINGS

- A. PVC Pipe: ASTM D 1785, Schedule 40 and Schedule 80.
- B. PVC Socket Fittings: ASTM D 2466 for Schedule 40 and ASTM D 2467 for Schedule 80.
- C. PVC Schedule 80 Threaded Fittings: ASTM D 2464.

## 2.11 PP PIPE AND FITTINGS

- A. PP Pipe: ASTM F 2389, SDR 7.4 and SDR 11.
- B. PVC Socket Fittings: ASTM F 2389.

## 2.12 PIPING JOINING MATERIALS

- A. Pipe-Flange Gasket Materials:
  - 1. AWWA C110/A21.10, rubber, flat face, 1/8 inch (3.2 mm) thick or ASME B16.21, nonmetallic and asbestos free unless otherwise indicated.
  - 2. Full-face or ring type unless otherwise indicated.
- B. Metal, Pipe-Flange Bolts and Nuts: ASME B18.2.1, carbon steel unless otherwise indicated.
- C. Solder Filler Metals: ASTM B 32, lead-free alloys.
- D. Flux: ASTM B 813, water flushable.



- E. Brazing Filler Metals: AWS A5.8/A5.8M, BCuP Series, copper-phosphorus alloys for general-duty brazing unless otherwise indicated.
- F. Solvent Cements for Joining CPVC Piping and Tubing: ASTM F 493.
  - 1. CPVC solvent cement shall have a VOC content of 490 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 2. Adhesive primer shall have a VOC content of 550 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 3. Solvent cement and adhesive primer shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- G. Solvent Cements for Joining PVC Piping: ASTM D 2564. Include primer according to ASTM F 656.
  - 1. PVC solvent cement shall have a VOC content of 510 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 2. Adhesive primer shall have a VOC content of 550 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 3. Solvent cement and adhesive primer shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- H. Plastic, Pipe-Flange Gaskets, Bolts, and Nuts: Type and material recommended by piping system manufacturer unless otherwise indicated.

#### 2.13 ENCASEMENT FOR PIPING

- A. Standard: ASTM A 674 or AWWA C105/A21.5.
- B. Form: Sheet or tube.
- C. Color: Black or natural.

#### 2.14 TRANSITION FITTINGS

- A. General Requirements:
  - 1. Same size as pipes to be joined.
  - 2. Pressure rating at least equal to pipes to be joined.
  - 3. End connections compatible with pipes to be joined.
- B. Fitting-Type Transition Couplings: Manufactured piping coupling or specified piping system fitting.

C. Sleeve-Type Transition Coupling: AWWA C219.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Cascade Waterworks Mfg. Co.
  - b. Ford Meter Box Company, Inc. (The).
  - c. Smith, Jay R. Mfg. Co.
  - d. Viking Johnson.

D. Plastic-to-Metal Transition Fittings:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Charlotte Pipe and Foundry Company.
  - b. Harvel Plastics, Inc.
  - c. Spears Manufacturing Company.
2. Description:
  - a. CPVC or PVC one-piece fitting with manufacturer's Schedule 80 equivalent dimensions.
  - b. One end with threaded brass insert and one solvent-cement-socket end.

E. Plastic-to-Metal Transition Unions:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Colonial Engineering, Inc.
  - b. NIBCO INC.
  - c. Spears Manufacturing Company.
2. Description:
  - a. CPVC or PVC four-part union.
  - b. Brass threaded end.
  - c. Solvent-cement-joint plastic end.
  - d. Rubber O-ring.
  - e. Union nut.

2.15 DIELECTRIC FITTINGS

- A. General Requirements: Assembly of copper alloy and ferrous materials with separating nonconductive insulating material. Include end connections compatible with pipes to be joined.
- B. Dielectric Unions:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Central Plastics Company.
  - b. Watts; a Watts Water Technologies company.
  - c. Wilkins.
  - d. Zurn Industries, LLC.
2. Standard: ASSE 1079.
3. Pressure Rating: 125 psig (860 kPa) minimum at 180 deg F (82 deg C).
4. End Connections: Solder-joint copper alloy and threaded ferrous.

C. Dielectric Flanges:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Capitol Manufacturing Company.
  - b. Central Plastics Company.
  - c. Watts; a Watts Water Technologies company.
  - d. Zurn Industries, LLC.
2. Standard: ASSE 1079.
3. Factory-fabricated, bolted, companion-flange assembly.
4. Pressure Rating: 125 psig (860 kPa) minimum at 180 deg F (82 deg C).
5. End Connections: Solder-joint copper alloy and threaded ferrous; threaded solder-joint copper alloy and threaded ferrous.

D. Dielectric-Flange Insulating Kits:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Advance Products & Systems, Inc.
  - b. Calpico, Inc.
  - c. Central Plastics Company.
  - d. Pipeline Seal and Insulator, Inc.
2. Nonconducting materials for field assembly of companion flanges.
3. Pressure Rating: 150 psig (1035 kPa).
4. Gasket: Neoprene or phenolic.
5. Bolt Sleeves: Phenolic or polyethylene.
6. Washers: Phenolic with steel backing washers.

E. Dielectric Nipples:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Grinnell Mechanical Products.
  - b. Precision Plumbing Products.
  - c. Victaulic Company.

2. Standard: IAPMO PS 66.
3. Electroplated steel nipple complying with ASTM F 1545.
4. Pressure Rating and Temperature: 300 psig (2070 kPa) at 225 deg F (107 deg C).
5. End Connections: Male threaded or grooved.
6. Lining: Inert and noncorrosive, propylene.

### PART 3 - EXECUTION

#### 3.1 EARTHWORK

- A. Comply with requirements in Section 312000 "Earth Moving" for excavating, trenching, and backfilling.

#### 3.2 PIPING INSTALLATION

- A. Drawing plans, schematics, and diagrams indicate general location and arrangement of domestic water piping. Indicated locations and arrangements are used to size pipe and calculate friction loss, expansion, and other design considerations. Install piping as indicated unless deviations to layout are approved on coordination drawings.
- B. Install copper tubing under building slab according to CDA's "Copper Tube Handbook."
- C. Install ductile-iron piping under building slab with restrained joints according to AWWA C600 and AWWA M41.
- D. Install underground copper tube and ductile-iron pipe in PE encasement according to ASTM A 674 or AWWA C105/A21.5.
- E. Install shutoff valve, hose-end drain valve, strainer, pressure gage, and test tee with valve inside the building at each domestic water-service entrance. Comply with requirements for pressure gages in Section 220519 "Meters and Gages for Plumbing Piping" and with requirements for drain valves and strainers in Section 221119 "Domestic Water Piping Specialties."
- F. Install shutoff valve immediately upstream of each dielectric fitting.
- G. Install water-pressure-reducing valves downstream from shutoff valves. Comply with requirements for pressure-reducing valves in Section 221119 "Domestic Water Piping Specialties."
- H. Install domestic water piping level with 0.25 percent slope downward toward drain and plumb.
- I. Rough-in domestic water piping for water-meter installation according to utility company's requirements.

- J. Install seismic restraints on piping. Comply with requirements for seismic-restraint devices in Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment."
- K. Install piping concealed from view and protected from physical contact by building occupants unless otherwise indicated and except in equipment rooms and service areas.
- L. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- M. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal, and coordinate with other services occupying that space.
- N. Install piping to permit valve servicing.
- O. Install nipples, unions, special fittings, and valves with pressure ratings the same as or higher than the system pressure rating used in applications below unless otherwise indicated.
- P. Install piping free of sags and bends.
- Q. Install fittings for changes in direction and branch connections.
- R. Install PEX piping with loop at each change of direction of more than 90 degrees.
- S. Install unions in copper tubing at final connection to each piece of equipment, machine, and specialty.
- T. Install pressure gages on suction and discharge piping for each plumbing pump and packaged booster pump. Comply with requirements for pressure gages in Section 220519 "Meters and Gages for Plumbing Piping."
- U. Install thermostats in hot-water circulation piping. Comply with requirements for thermostats in Section 221123 "Domestic Water Pumps."
- V. Install thermometers on inlet and outlet piping from each water heater. Comply with requirements for thermometers in Section 220519 "Meters and Gages for Plumbing Piping."
- W. Install sleeves for piping penetrations of walls, ceilings, and floors. Comply with requirements for sleeves specified in Section 220517 "Sleeves and Sleeve Seals for Plumbing Piping."
- X. Install sleeve seals for piping penetrations of concrete walls and slabs. Comply with requirements for sleeve seals specified in Section 220517 "Sleeves and Sleeve Seals for Plumbing Piping."

- Y. Install escutcheons for piping penetrations of walls, ceilings, and floors. Comply with requirements for escutcheons specified in Section 220518 "Escutcheons for Plumbing Piping."

### 3.3 JOINT CONSTRUCTION

- A. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
- B. Remove scale, slag, dirt, and debris from inside and outside of pipes, tubes, and fittings before assembly.
- C. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1. Cut threads full and clean using sharp dies. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:
  - 1. Apply appropriate tape or thread compound to external pipe threads.
  - 2. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged.
- D. Brazed Joints for Copper Tubing: Comply with CDA's "Copper Tube Handbook," "Braze Joints" chapter.
- E. Soldered Joints for Copper Tubing: Apply ASTM B 813, water-flushable flux to end of tube. Join copper tube and fittings according to ASTM B 828 or CDA's "Copper Tube Handbook."
- F. Pressure-Sealed Joints for Copper Tubing: Join copper tube and pressure-seal fittings with tools recommended by fitting manufacturer.
- G. Push-on Joints for Copper Tubing: Clean end of tube. Measure insertion depth with manufacturer's depth gage. Join copper tube and push-on-joint fittings by inserting tube to measured depth.
- H. Extruded-Tee Connections: Form tee in copper tube according to ASTM F 2014. Use tool designed for copper tube; drill pilot hole, form collar for outlet, dimple tube to form seating stop, and braze branch tube into collar.
- I. Joint Construction for Grooved-End Copper Tubing: Make joints according to AWWA C606. Roll groove ends of tubes. Lubricate and install gasket over ends of tubes or tube and fitting. Install coupling housing sections over gasket with keys seated in tubing grooves. Install and tighten housing bolts.
- J. Joint Construction for Grooved-End, Ductile-Iron Piping: Make joints according to AWWA C606. Cut round-bottom grooves in ends of pipe at gasket-seat dimension required for specified (flexible or rigid) joint. Lubricate and install gasket over ends of pipes or pipe and fitting. Install coupling housing sections over gasket with keys seated in piping grooves. Install and tighten housing bolts.
- K. Joint Construction for Grooved-End Steel Piping: Make joints according to AWWA C606. Square cut groove ends of pipe as specified. Lubricate and install gasket over ends of pipes

or pipe and fitting. Install coupling housing sections over gasket with keys seated in piping grooves. Install and tighten housing bolts.

- L. Flanged Joints: Select appropriate asbestos-free, nonmetallic gasket material in size, type, and thickness suitable for domestic water service. Join flanges with gasket and bolts according to ASME B31.9.
- M. Joint Construction for Solvent-Cemented Plastic Piping: Clean and dry joining surfaces. Join pipe and fittings according to the following:
  - 1. Comply with ASTM F 402 for safe-handling practice of cleaners, primers, and solvent cements. Apply primer.
  - 2. CPVC Piping: Join according to ASTM D 2846/D 2846M Appendix.
  - 3. PVC Piping: Join according to ASTM D 2855.
- N. Joints for PEX Piping: Join according to ASTM F 1807.
- O. Joints for Dissimilar-Material Piping: Make joints using adapters compatible with materials of both piping systems.

### 3.4 TRANSITION FITTING INSTALLATION

- A. Install transition couplings at joints of dissimilar piping.
- B. Transition Fittings in Underground Domestic Water Piping:
  - 1. Fittings for NPS 1-1/2 (DN 40) and Smaller: Fitting-type coupling.
  - 2. Fittings for NPS 2 (DN 50) and Larger: Sleeve-type coupling.
- C. Transition Fittings in Aboveground Domestic Water Piping NPS 2 (DN 50) and Smaller: Plastic-to-metal transition fittings or unions.

### 3.5 DIELECTRIC FITTING INSTALLATION

- A. Install dielectric fittings in piping at connections of dissimilar metal piping and tubing.
- B. Dielectric Fittings for NPS 2 (DN 50) and Smaller: Use dielectric couplings.
- C. Dielectric Fittings for NPS 2-1/2 to NPS 4 (DN 65 to DN 100): Use dielectric flanges.
- D. Dielectric Fittings for NPS 5 (DN 125) and Larger: Use dielectric flange kits.

### 3.6 HANGER AND SUPPORT INSTALLATION

- A. Comply with requirements for seismic-restraint devices in Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment."

- B. Comply with requirements for pipe hanger, support products, and installation in Section 220529 "Hangers and Supports for Plumbing Piping and Equipment."
1. Vertical Piping: MSS Type 8 or 42, clamps.
  2. Individual, Straight, Horizontal Piping Runs:
    - a. 100 Feet (30 m) and Less: MSS Type 1, adjustable, steel clevis hangers.
    - b. Longer Than 100 Feet (30 m): MSS Type 43, adjustable roller hangers.
    - c. Longer Than 100 Feet (30 m) if Indicated: MSS Type 49, spring cushion rolls.
  3. Multiple, Straight, Horizontal Piping Runs 100 Feet (30 m) or Longer: MSS Type 44, pipe rolls. Support pipe rolls on trapeze.
  4. Base of Vertical Piping: MSS Type 52, spring hangers.
- C. Support vertical piping and tubing at base and at each floor.
- D. Rod diameter may be reduced one size for double-rod hangers, to a minimum of 3/8 inch (10 mm).
- E. Install hangers for copper tubing with the following maximum horizontal spacing and minimum rod diameters:
1. NPS 3/4 (DN 20) and Smaller: 60 inches (1500 mm) with 3/8-inch (10-mm) rod.
  2. NPS 1 and NPS 1-1/4 (DN 25 and DN 32): 72 inches (1800 mm) with 3/8-inch (10-mm) rod.
  3. NPS 1-1/2 and NPS 2 (DN 40 and DN 50): 96 inches (2400 mm) with 3/8-inch (10-mm) rod.
  4. NPS 2-1/2 (DN 65): 108 inches (2700 mm) with 1/2-inch (13-mm) rod.
  5. NPS 3 to NPS 5 (DN 80 to DN 125): 10 feet (3 m) with 1/2-inch (13-mm) rod.
  6. NPS 6 (DN 150): 10 feet (3 m) with 5/8-inch (16-mm) rod.
  7. NPS 8 (DN 200): 10 feet (3 m) with 3/4-inch (19-mm) rod.
- F. Install supports for vertical copper tubing every 10 feet (3 m).
- G. Install hangers for steel piping with the following maximum horizontal spacing and minimum rod diameters:
1. NPS 1-1/4 (DN 32) and Smaller: 84 inches (2100 mm) with 3/8-inch (10-mm) rod.
  2. NPS 1-1/2 (DN 40): 108 inches (2700 mm) with 3/8-inch (10-mm) rod.
  3. NPS 2 (DN 50): 10 feet (3 m) with 3/8-inch (10-mm) rod.
  4. NPS 2-1/2 (DN 65): 11 feet (3.4 m) with 1/2-inch (13-mm) rod.
  5. NPS 3 and NPS 3-1/2 (DN 80 and DN 90): 12 feet (3.7 m) with 1/2-inch (13-mm) rod.
  6. NPS 4 and NPS 5 (DN 100 and DN 125): 12 feet (3.7 m) with 5/8-inch (16-mm) rod.
  7. NPS 6 (DN 150): 12 feet (3.7 m) with 3/4-inch (19-mm) rod.
  8. NPS 8 to NPS 12 (DN 200 to DN 300): 12 feet (3.7 m) with 7/8-inch (22-mm) rod.
- H. Install supports for vertical steel piping every 15 feet (4.5 m).



- I. Install hangers for stainless-steel piping with the following maximum horizontal spacing and minimum rod diameters:
  - 1. NPS 1-1/4 (DN 32) and Smaller: 84 inches (2100 mm) with 3/8-inch (10-mm) rod.
  - 2. NPS 1-1/2 (DN 40): 108 inches (2700 mm) with 3/8-inch (10-mm) rod.
  - 3. NPS 2 (DN 50): 10 feet (3 m) with 3/8-inch (10-mm) rod.
  - 4. NPS 2-1/2 (DN 65): 11 feet (3.4 m) with 1/2-inch (13-mm) rod.
  - 5. NPS 3 and NPS 3-1/2 (DN 80 and DN 90): 12 feet (3.7 m) with 1/2-inch (13-mm) rod.
  - 6. NPS 4 and NPS 5 (DN 100 and DN 125): 12 feet (3.7 m) with 5/8-inch (16-mm) rod.
  - 7. NPS 6 (DN 150): 12 feet (3.7 m) with 3/4-inch (19-mm) rod.
  - 8. NPS 8 to NPS 12 (DN 200 to DN 300): 12 feet (3.7 m) with 7/8-inch (22-mm) rod.
- J. Install supports for vertical stainless-steel piping every 15 feet (4.5 m).
- K. Install vinyl-coated hangers for CPVC piping with the following maximum horizontal spacing and minimum rod diameters:
  - 1. NPS 1 (DN 25) and Smaller: 36 inches (900 mm) with 3/8-inch (10-mm) rod.
  - 2. NPS 1-1/4 to NPS 2 (DN 32 to DN 50): 48 inches (1200 mm) with 3/8-inch (10-mm) rod.
  - 3. NPS 2-1/2 to NPS 3-1/2 (DN 65 to DN 90): 48 inches (1200 mm) with 1/2-inch (13-mm) rod.
  - 4. NPS 4 and NPS 5 (DN 100 and DN 125): 48 inches (1200 mm) with 5/8-inch (16-mm) rod.
  - 5. NPS 6 (DN 150): 48 inches (1200 mm) with 3/4-inch (19-mm) rod.
  - 6. NPS 8 (DN 200): 48 inches (1200 mm) with 7/8-inch (22-mm) rod.
- L. Install supports for vertical CPVC piping every 60 inches (1500 mm) for NPS 1 (DN 25) and smaller, and every 72 inches (1800 mm) for NPS 1-1/4 (DN 32) and larger.
- M. Install vinyl-coated hangers for PEX piping with the following maximum horizontal spacing and minimum rod diameters:
  - 1. NPS 1 (DN 25) and Smaller: 32 inches (815 mm) with 3/8-inch (10-mm) rod.
- N. Install hangers for vertical PEX piping every 48 inches (1200 mm).
- O. Install vinyl-coated hangers for PVC piping with the following maximum horizontal spacing and minimum rod diameters:
  - 1. NPS 2 (DN 50) and Smaller: 48 inches (1200 mm) with 3/8-inch (10-mm) rod.
  - 2. NPS 2-1/2 to NPS 3-1/2 (DN 65 to DN 90): 48 inches (1200 mm) with 1/2-inch (13-mm) rod.
  - 3. NPS 4 and NPS 5 (DN 100 and DN 125): 48 inches (1200 mm) with 5/8-inch (16-mm) rod.
  - 4. NPS 6 (DN 150): 48 inches (1200 mm) with 3/4-inch (19-mm) rod.
  - 5. NPS 8 (DN 200): 48 inches (1200 mm) with 7/8-inch (22-mm) rod.

- P. Install supports for vertical PVC piping every 48 inches (1200 mm).
- Q. Install vinyl-coated hangers for PP piping with the following maximum horizontal spacing and minimum rod diameters:
  - 1. NPS 1 (DN 25) and Smaller: 36 inches (900 mm) with 3/8-inch (10-mm) rod.
  - 2. NPS 1-1/4 to NPS 2 (DN 32 to DN 50): 48 inches (1200 mm) with 3/8-inch (10-mm) rod.
  - 3. NPS 2-1/2 to NPS 3-1/2 (DN 65 to DN 90): 48 inches (1200 mm) with 1/2-inch (13-mm) rod.
  - 4. NPS 4 and NPS 5 (DN 100 and DN 125): 48 inches (1200 mm) with 5/8-inch (16-mm) rod.
  - 5. NPS 6 (DN 150): 48 inches (1200 mm) with 3/4-inch (19-mm) rod.
  - 6. NPS 8 (DN 200): 48 inches (1200 mm) with 7/8-inch (22-mm) rod.
- R. Install supports for vertical PP piping every 60 inches (1500 mm) for NPS 1 (DN 25) and smaller, and every 72 inches (1800 mm) for NPS 1-1/4 (DN 32) and larger.
- S. Support piping and tubing not listed in this article according to MSS SP-69 and manufacturer's written instructions.

### 3.7 CONNECTIONS

- A. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. When installing piping adjacent to equipment and machines, allow space for service and maintenance.
- C. Connect domestic water piping to exterior water-service piping. Use transition fitting to join dissimilar piping materials.
- D. Connect domestic water piping to water-service piping with shutoff valve; extend and connect to the following:
  - 1. Domestic Water Booster Pumps: Cold-water suction and discharge piping.
  - 2. Water Heaters: Cold-water inlet and hot-water outlet piping in sizes indicated, but not smaller than sizes of water heater connections.
  - 3. Plumbing Fixtures: Cold- and hot-water-supply piping in sizes indicated, but not smaller than that required by plumbing code.
  - 4. Equipment: Cold- and hot-water-supply piping as indicated, but not smaller than equipment connections. Provide shutoff valve and union for each connection. Use flanges instead of unions for NPS 2-1/2 (DN 65) and larger.

### 3.8 IDENTIFICATION

- A. Identify system components. Comply with requirements for identification materials and installation in Section 220553 "Identification for Plumbing Piping and Equipment."

- B. Label pressure piping with system operating pressure.

### 3.9 FIELD QUALITY CONTROL

- A. Perform the following tests and inspections:

- 1. Piping Inspections:

- a. Do not enclose, cover, or put piping into operation until it has been inspected and approved by authorities having jurisdiction.
- b. During installation, notify authorities having jurisdiction at least one day before inspection must be made. Perform tests specified below in presence of authorities having jurisdiction:
  - 1) Roughing-in Inspection: Arrange for inspection of piping before concealing or closing in after roughing in and before setting fixtures.
  - 2) Final Inspection: Arrange for authorities having jurisdiction to observe tests specified in "Piping Tests" Subparagraph below and to ensure compliance with requirements.
- c. Reinspection: If authorities having jurisdiction find that piping will not pass tests or inspections, make required corrections and arrange for reinspection.
- d. Reports: Prepare inspection reports and have them signed by authorities having jurisdiction.

- 2. Piping Tests:

- a. Fill domestic water piping. Check components to determine that they are not air bound and that piping is full of water.
- b. Test for leaks and defects in new piping and parts of existing piping that have been altered, extended, or repaired. If testing is performed in segments, submit a separate report for each test, complete with diagram of portion of piping tested.
- c. Leave new, altered, extended, or replaced domestic water piping uncovered and unconcealed until it has been tested and approved. Expose work that was covered or concealed before it was tested.
- d. Cap and subject piping to static water pressure of 50 psig (345 kPa) above operating pressure, without exceeding pressure rating of piping system materials. Isolate test source and allow it to stand for four hours. Leaks and loss in test pressure constitute defects that must be repaired.
- e. Repair leaks and defects with new materials, and retest piping or portion thereof until satisfactory results are obtained.
- f. Prepare reports for tests and for corrective action required.

- B. Domestic water piping will be considered defective if it does not pass tests and inspections.

- C. Prepare test and inspection reports.

### 3.10 ADJUSTING

#### A. Perform the following adjustments before operation:

1. Close drain valves, hydrants, and hose bibbs.
2. Open shutoff valves to fully open position.
3. Open throttling valves to proper setting.
4. Adjust balancing valves in hot-water-circulation return piping to provide adequate flow.
  - a. Manually adjust ball-type balancing valves in hot-water-circulation return piping to provide hot-water flow in each branch.
  - b. Adjust calibrated balancing valves to flows indicated.
5. Remove plugs used during testing of piping and for temporary sealing of piping during installation.
6. Remove and clean strainer screens. Close drain valves and replace drain plugs.
7. Remove filter cartridges from housings and verify that cartridges are as specified for application where used and are clean and ready for use.
8. Check plumbing specialties and verify proper settings, adjustments, and operation.

### 3.11 CLEANING

#### A. Clean and disinfect potable domestic water piping as follows:

1. Purge new piping and parts of existing piping that have been altered, extended, or repaired before using.
2. Use purging and disinfecting procedures prescribed by authorities having jurisdiction; if methods are not prescribed, use procedures described in either AWWA C651 or AWWA C652 or follow procedures described below:
  - a. Flush piping system with clean, potable water until dirty water does not appear at outlets.
  - b. Fill and isolate system according to either of the following:
    - 1) Fill system or part thereof with water/chlorine solution with at least 50 ppm (50 mg/L) of chlorine. Isolate with valves and allow to stand for 24 hours.
    - 2) Fill system or part thereof with water/chlorine solution with at least 200 ppm (200 mg/L) of chlorine. Isolate and allow to stand for three hours.
  - c. Flush system with clean, potable water until no chlorine is in water coming from system after the standing time.
  - d. Repeat procedures if biological examination shows contamination.
  - e. Submit water samples in sterile bottles to authorities having jurisdiction.

#### B. Clean non-potable domestic water piping as follows:

1. Purge new piping and parts of existing piping that have been altered, extended, or repaired before using.
2. Use purging procedures prescribed by authorities having jurisdiction or; if methods are not prescribed, follow procedures described below:
  - a. Flush piping system with clean, potable water until dirty water does not appear at outlets.
  - b. Submit water samples in sterile bottles to authorities having jurisdiction. Repeat procedures if biological examination shows contamination.
- C. Prepare and submit reports of purging and disinfecting activities. Include copies of water-sample approvals from authorities having jurisdiction.
- D. Clean interior of domestic water piping system. Remove dirt and debris as work progresses.

### 3.12 PIPING SCHEDULE

- A. Transition and special fittings with pressure ratings at least equal to piping rating may be used in applications below unless otherwise indicated.
- B. Flanges and unions may be used for aboveground piping joints unless otherwise indicated.
- C. Fitting Option: Extruded-tee connections and brazed joints may be used on aboveground copper tubing.
- D. Under-building-slab, domestic water, building-service piping, NPS 3 (DN 80) and smaller, shall be one of the following:
  1. Soft copper tube, ASTM B 88, Type K (ASTM B 88M, Type A); wrought-copper, solder-joint fittings; and brazed joints.
  2. PVC, Schedule 40; socket fittings; and solvent-cemented joints.
  3. PP, SDR 11 socket fittings; and fusion-welded joints.
- E. Under-building-slab, domestic water, building-service piping, NPS 4 to NPS 8 (DN 100 to DN 200) and larger, shall be one of the following:
  1. Soft copper tube, ASTM B 88, Type K (ASTM B 88M, Type A); wrought-copper, solder-joint fittings; and brazed joints.
  2. Mechanical-joint, ductile-iron pipe; standard- or compact-pattern, mechanical-joint fittings; and mechanical joints.
  3. Push-on-joint, ductile-iron pipe; standard- or compact-pattern, push-on-joint fittings; and gasketed joints.
  4. Plain-end, ductile-iron pipe; grooved-joint, ductile-iron-pipe appurtenances; and grooved joints.
  5. PVC, Schedule 40; socket fittings; and solvent-cemented joints.
  6. PP, SDR 11 socket fittings; and fusion-welded joints.

- F. Under-building-slab, combined domestic water, building-service, and fire-service-main piping, NPS 6 to NPS 12 (DN 150 to DN 300), shall be one of the following:
1. Mechanical-joint, ductile-iron pipe; standard- or compact-pattern, mechanical-joint fittings; and mechanical joints.
  2. Push-on-joint, ductile-iron pipe; standard- or compact-pattern, push-on-joint fittings; and gasketed joints.
  3. Plain-end, ductile-iron pipe; grooved-joint, ductile-iron-pipe appurtenances; and grooved joints.
- G. Under-building-slab, domestic water piping, NPS 2 (DN 50) and smaller, shall be one of the following:
1. Hard or soft copper tube, ASTM B 88, Type L (ASTM B 88M, Type B); wrought-copper, solder-joint fittings; and brazed joints.
  2. PVC, Schedule 40; socket fittings; and solvent-cemented joints.
  3. PP, SDR 11 socket fittings; and fusion-welded joints.
- H. Aboveground domestic water piping, NPS 2 (DN 50) and smaller, shall be one of the following:
1. Galvanized-steel pipe and nipples; galvanized, gray-iron threaded fittings; and threaded joints.
  2. Hard copper tube, ASTM B 88, Type L (ASTM B 88M, Type B); cast-copper, solder-joint fittings; and brazed joints.
  3. Hard copper tube, ASTM B 88, Type L (ASTM B 88M, Type B); copper pressure-seal-joint fittings; and pressure-sealed joints.
  4. Hard copper tube, ASTM B 88, Type L (ASTM B 88M, Type B); copper push-on-joint fittings; and push-on joints.
  5. CPVC, Schedule 40; socket fittings; and solvent-cemented joints.
  6. CPVC, Schedule 80 pipe; CPVC, Schedule 80 threaded fittings; and threaded joints.
  7. CPVC Tubing System: CPVC tube; CPVC socket fittings; and solvent-cemented joints. NPS 1-1/2 (DN 40) and NPS 2 (DN 50) CPVC pipe with CPVC socket fittings may be used instead of tubing.
  8. PEX tube, NPS 1 (DN 25) and smaller; fittings for PEX tube; and crimped joints.
  9. PE-AL-PE tube, NPS 1 (DN 25) and smaller; fittings for PE-AL-PE tube; and crimped joints
  10. PEX-AL-PEX tube, NPS 1 (DN 25) and smaller; fittings for PEX-AL-PEX tube; and crimped joints.
  11. PVC, Schedule 40; socket fittings; and solvent-cemented joints.
  12. PP, SDR 11 socket fittings; and fusion-welded joints.
- I. Aboveground domestic water piping, NPS 2-1/2 to NPS 4 (DN 65 to DN 100), shall be one of the following:
1. Hard copper tube, ASTM B 88, Type L (ASTM B 88M, Type B); cast-copper, solder-joint fittings; and brazed joints.
  2. Hard copper tube, ASTM B 88, Type L (ASTM B 88M, Type B); copper pressure-seal-joint fittings; and pressure-sealed joints.

3. Hard copper tube, ASTM B 88, Type L (ASTM B 88M, Type B); grooved-joint, copper-tube appurtenances; and grooved joints.
  4. Galvanized-steel pipe and nipples; galvanized, gray-iron threaded fittings; and threaded joints.
  5. Galvanized-steel pipe; grooved-joint, galvanized-steel-pipe appurtenances; and grooved joints.
  6. CPVC, Schedule 40; socket fittings; and solvent-cemented joints.
  7. CPVC, Schedule 80 pipe; CPVC, Schedule 80 threaded fittings; and threaded joints.
  8. PVC, Schedule 40; socket fittings; and solvent-cemented joints.
  9. PP, SDR 11 socket fittings; and fusion-welded joints.
- J. Aboveground domestic water piping, NPS 5 to NPS 8 (DN 125 to DN 200), shall be one of the following:
1. Hard copper tube, ASTM B 88, Type L (ASTM B 88M, Type B); cast-copper, solder-joint fittings; and brazed joints.
  2. Hard copper tube, ASTM B 88, Type L (ASTM B 88M, Type B); grooved-joint, copper-tube appurtenances; and grooved joints.
  3. Galvanized-steel pipe and nipples; galvanized, gray-iron threaded fittings; and threaded joints.
  4. Galvanized-steel pipe; grooved-joint, galvanized-steel-pipe appurtenances; and grooved joints.
  5. Stainless-steel Schedule 40 pipe, grooved-joint fittings, and grooved joints.
  6. CPVC, Schedule 40; socket fittings; and solvent-cemented joints.
  7. CPVC, Schedule 80 pipe; CPVC, Schedule 80 threaded fittings; and threaded joints.
  8. PVC, Schedule 40; socket fittings; and solvent-cemented joints.

### 3.13 VALVE SCHEDULE

- A. Drawings indicate valve types to be used. Where specific valve types are not indicated, the following requirements apply:
1. Shutoff Duty: Use ball or gate valves for piping NPS 2 (DN 50) and smaller. Use butterfly, ball, or gate valves with flanged ends for piping NPS 2-1/2 (DN 65) and larger.
  2. Throttling Duty: Use ball or globe valves for piping NPS 2 (DN 50) and smaller. Use butterfly or ball valves with flanged ends for piping NPS 2-1/2 (DN 65) and larger.
  3. Hot-Water Circulation Piping, Balancing Duty: Calibrated balancing valves.
  4. Drain Duty: Hose-end drain valves.
- B. Use check valves to maintain correct direction of domestic water flow to and from equipment.
- C. Iron grooved-end valves may be used with grooved-end piping.

END OF SECTION 221116

SECTION 221119 - DOMESTIC WATER PIPING SPECIALTIES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Vacuum breakers.
2. Backflow preventers.
3. Water pressure-reducing valves.
4. Balancing valves.
5. Temperature-actuated, water mixing valves.
6. Strainers.
7. Outlet boxes.
8. Hose stations.
9. Hose bibbs.
10. Wall hydrants.
11. Ground hydrants.
12. Post hydrants.
13. Drain valves.
14. Water-hammer arresters.
15. Air vents.
16. Trap-seal primer valves.
17. Trap-seal primer systems.
18. Specialty valves.
19. Flexible connectors.
20. Water meters.

B. Related Requirements:

1. Section 220519 "Meters and Gages for Plumbing Piping" for thermometers, pressure gages, and flow meters in domestic water piping.
2. Section 221116 "Domestic Water Piping" for water meters.
3. Section 223200 "Domestic Water Filtration Equipment" for water filters in domestic water piping.
4. Section 224300 "Medical Plumbing Fixtures" for thermostatic mixing valves for sitz baths, thermostatic mixing-valve assemblies for hydrotherapy equipment, and outlet boxes for dialysis equipment.
5. Section 224500 "Emergency Plumbing Fixtures" for water tempering equipment.
6. Section 224713 "Drinking Fountains" for water filters for water coolers.



7. Section 224716 "Pressure Water Coolers" for water filters for water coolers.
8. Section 224723 "Remote Water Coolers" for water filters for water coolers.

### 1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: For domestic water piping specialties.
  1. Include diagrams for power, signal, and control wiring.

### 1.4 INFORMATIONAL SUBMITTALS

- A. Field quality-control reports.

### 1.5 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For domestic water piping specialties to include in emergency, operation, and maintenance manuals.

## PART 2 - PRODUCTS

### 2.1 GENERAL REQUIREMENTS FOR PIPING SPECIALTIES

- A. Potable-water piping and components shall comply with NSF 61 Annex G and NSF 14. Mark "NSF-pw" on plastic piping components.

### 2.2 PERFORMANCE REQUIREMENTS

- A. Minimum Working Pressure for Domestic Water Piping Specialties: 125 psig (860 kPa) unless otherwise indicated.

### 2.3 VACUUM BREAKERS

- A. Pipe-Applied, Atmospheric-Type Vacuum Breakers:
  1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. FEBCO.
    - b. Watts; a Watts Water Technologies company.
    - c. Zurn Industries, LLC.
  2. Standard: ASSE 1001.

3. Size: NPS 1/4 to NPS 3 (DN 8 to DN 80), as required to match connected piping.
4. Body: Bronze.
5. Inlet and Outlet Connections: Threaded.
6. Finish: Rough bronze.

B. Hose-Connection Vacuum Breakers:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Watts; a Watts Water Technologies company.
  - b. Woodford Manufacturing Company.
  - c. Zurn Industries, LLC.
2. Standard: ASSE 1011.
3. Body: Bronze, nonremovable, with manual drain.
4. Outlet Connection: Garden-hose threaded complying with ASME B1.20.7.
5. Finish: Chrome or nickel plated Rough bronze.

C. Pressure Vacuum Breakers:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Conbraco Industries, Inc.
  - b. FEBCO.
  - c. Watts; a Watts Water Technologies company.
  - d. Zurn Industries, LLC.
  - e. Valves: Ball type, on inlet and outlet.

2.4 BACKFLOW PREVENTERS

A. Reduced-Pressure-Principle Backflow Preventers:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. FEBCO.
  - b. Watts; a Watts Water Technologies company.
2. Standard: ASSE 1013.
3. Operation: Continuous-pressure applications.
4. Pressure Loss: 12 psig (83 kPa) maximum, through middle third of flow range.
5. Size: See floor plans.
6. Design Flow Rate: See floor plans.
7. Pressure Loss at Design Flow Rate: See floor plans.

8. Body: Bronze for NPS 2 (DN 50) and smaller; cast iron with interior lining that complies with AWWA C550 or that is FDA approved for NPS 2-1/2 (DN 65) and larger.
9. End Connections: Threaded for NPS 2 (DN 50) and smaller; flanged for NPS 2-1/2 (DN 65) and larger.
10. Configuration: Designed for horizontal, straight-through flow.
11. Accessories:
  - a. Valves NPS 2 (DN 50) and Smaller: Ball type with threaded ends on inlet and outlet.
  - b. Valves NPS 2-1/2 (DN 65) and Larger: Outside-screw and yoke-gate type with flanged ends on inlet and outlet.
  - c. Air-Gap Fitting: ASME A112.1.2, matching backflow-preventer connection. Copy "Beverage-Dispensing-Equipment Backflow Preventers" Paragraph below and re-edit for each type of backflow preventer required. If only one type is required, drawing designation may be omitted. Copy "Hose-Connection Backflow Preventers" Paragraph below and re-edit for each type of backflow preventer required. If only one type is required, drawing designation may be omitted.

## 2.5 BALANCING VALVES

### A. Copper-Alloy Calibrated Balancing Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Griswold.
  - b. TACO Incorporated.
  - c. Watts; a Watts Water Technologies company.
2. Type: Ball or Y-pattern globe valve with two readout ports and memory-setting indicator.
3. Body: Brass or bronze.
4. Size: Same as connected piping, but not larger than NPS 2 (DN 50).
5. Accessories: Meter hoses, fittings, valves, differential pressure meter, and carrying case.

### B. Cast-Iron Calibrated Balancing Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Flo Fab inc.
  - b. Griswold.
  - c. NIBCO INC.
  - d. Watts; a Watts Water Technologies company.
2. Type: Adjustable with Y-pattern globe valve, two readout ports, and memory-setting indicator.

3. Size: Same as connected piping, but not smaller than NPS 2-1/2 (DN 65).

C. Accessories: Meter hoses, fittings, valves, differential pressure meter, and carrying case.

## 2.6 TEMPERATURE-ACTUATED, WATER MIXING VALVES

A. Primary, Thermostatic, Water Mixing Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- a. Lawler Manufacturing Company, Inc.
- b. Leonard Valve Company.
- c. Powers.

2. Standard: ASSE 1017.

3. Pressure Rating: 125 psig (860 kPa) minimum unless otherwise indicated.
4. Type: Exposed-mounted, thermostatically controlled, water mixing valve.
5. Material: Bronze body with corrosion-resistant interior components.
6. Connections: Threaded union inlets and outlet.
7. Accessories: Manual temperature control, check stops on hot- and cold-water supplies, and adjustable, temperature-control handle.
8. Tempered-Water Setting: See floor plans.
9. Tempered-Water Design Flow Rate: See floor plans.
10. Selected Valve Flow Rate at 45-psig (310-kPa) Pressure Drop: See cut sheet.
11. Pressure Drop at Design Flow Rate: See cut sheet.
12. Valve Finish: Rough bronze.
13. Piping Finish: Copper.
14. Cabinet: Factory fabricated, stainless steel, for surface mounting and with hinged, stainless-steel door.

B. Primary Water Tempering Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- a. Holby Valve Inc.
- b. Powers.
- c. Uponor.

2. Standard: ASSE 1017, thermostatically controlled, water tempering valve, listed as tempering valve.

3. Pressure Rating: 125 psig (860 kPa) minimum unless otherwise indicated.
4. Body: Bronze.
5. Temperature Control: Manual.
6. Inlets and Outlet: Threaded.
7. Selected Primary Water Tempering Valve Size: see floor plans.

8. Tempered-Water Setting: See floor plans.
9. Tempered-Water Design Flow Rate: See floor plans.
10. Pressure Drop at Design Flow Rate: See cut sheet.
11. Tempered-Water Outlet Size: See cut sheet.
12. Cold-Water Inlet Size: See floor plans.
13. Hot-Water Inlet Size: See floor plans.
14. Valve Finish: Rough bronze.

## 2.7 STRAINERS FOR DOMESTIC WATER PIPING

### A. Y-Pattern Strainers:

1. Pressure Rating: 125 psig (860 kPa) minimum unless otherwise indicated.
2. Body: Bronze for NPS 2 (DN 50) and smaller; cast iron with interior lining that complies with AWWA C550 or that is FDA approved, epoxy coated and for NPS 2-1/2 (DN 65) and larger.
3. End Connections: Threaded for NPS 2 (DN 50) and smaller; flanged for NPS 2-1/2 (DN 65) and larger.
4. Screen: Stainless steel with round perforations unless otherwise indicated.
5. Perforation Size:
  - a. Strainers NPS 2 (DN 50) and Smaller: 0.020 inch (0.51 mm) 0.033 inch (0.84 mm) 0.062 inch (1.57 mm).
  - b. Strainers NPS 2-1/2 to NPS 4 (DN 65 to DN 100): 0.045 inch (1.14 mm) 0.062 inch (1.57 mm) 0.125 inch (3.18 mm).
  - c. Strainers NPS 5 (DN 125) and Larger: 0.10 inch (2.54 mm) 0.125 inch (3.18 mm) 0.25 inch (6.35 mm).
6. Drain: Pipe plug Factory-installed, hose-end drain valve.

## 2.8 OUTLET BOXES

### A. Clothes Washer Outlet Boxes:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Acorn Engineering Company.
  - b. IPS Corporation.
  - c. LSP Products Group, Inc.
  - d. Symmons Industries, Inc.
  - e. Watts; a Watts Water Technologies company.
2. Mounting: Recessed.
3. Material and Finish: Enameled-steel or epoxy-painted-steel Enameled-steel, epoxy-painted-steel, or plastic box and faceplate.

4. Faucet: Combination valved fitting or separate hot- and cold-water valved fittings complying with ASME A112.18.1. Include garden-hose thread complying with ASME B1.20.7 on outlets.
5. Supply Shutoff Fittings: NPS 1/2 (DN 15) gate, globe, or ball valves and NPS 1/2 (DN 15) copper, water tubing.
6. Drain: NPS 1-1/2 (DN 40) NPS 2 (DN 50) standpipe and P-trap for direct waste connection to drainage piping.
7. Inlet Hoses: Two 60-inch- (1500-mm-) long, rubber household clothes washer inlet hoses with female, garden-hose-thread couplings. Include rubber washers.
8. Drain Hose: One 48-inch- (1200-mm-) long, rubber household clothes washer drain hose with hooked end.

B. Icemaker Outlet Boxes:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Acorn Engineering Company.
  - b. IPS Corporation.
  - c. LSP Products Group, Inc.
2. Mounting: Recessed.
3. Material and Finish: Enameled-steel, epoxy-painted-steel, or plastic box and faceplate.
4. Faucet: Valved fitting complying with ASME A112.18.1. Include NPS 1/2 (DN 15) or smaller copper tube outlet.
5. Supply Shutoff Fitting: NPS 1/2 (DN 15) gate, globe, or ball valve and NPS 1/2 (DN 15) copper, water tubing.

2.9 HOSE STATIONS

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. ARCHON Industries, Inc.
2. Armstrong International, Inc.
3. Strahman Valves, Inc.
4. T & S Brass and Bronze Works, Inc.

B. Single-Temperature-Water Hose Stations:

1. Standard: ASME A112.18.1.
2. Cabinet: Stainless-steel enclosure with exposed valve handle, hose connection, and hose rack. Include thermometer in front.
3. Hose-Rack Material: Stainless steel.
4. Body Material: Bronze with stainless-steel wetted parts.
5. Body Finish: Rough bronze, chrome plated.
6. Mounting: Wall, with reinforcement.

7. Supply Fittings: NPS 1/2 (DN 15) NPS 3/4 (DN 20) gate, globe, or ball valve and check valve and NPS 1/2 (DN 15) NPS 3/4 (DN 20) copper, water tubing. Omit check valve if check stop is included with fitting.
8. Hose: Manufacturer's standard, for service fluid, temperature, and pressure; **[25 feet (7.6 m)] [50 feet (15 m)]** <Insert dimension> long.
9. Nozzle: With hand-squeeze, on-off control.
10. Vacuum Breaker:
  - a. Integral or factory-installed, nonremovable, manual-drain-type, hose-connection vacuum breaker complying with ASSE 1011 or backflow preventer complying with ASSE 1052.
  - b. Garden-hose thread complying with ASME B1.20.7 on outlet.

C. Hot- and Cold-Water Hose Stations:

1. Standard: ASME A112.18.1.
2. Faucet Type: Blending valve.
3. Cabinet: Stainless-steel enclosure with exposed valve handles, hose connection, and hose rack. Include thermometer in front.
4. Hose-Rack Material: Stainless steel.
5. Body Material: Bronze with stainless-steel wetted parts.
6. Body Finish: Rough bronze or chrome plated.
7. Mounting: Wall, with reinforcement.
8. Supply Fittings: Two NPS 1/2 (DN 15) NPS 3/4 (DN 20) gate, globe, or ball valves and check valves and NPS 1/2 (DN 15) NPS 3/4 (DN 20) copper, water tubing. Omit check valves if check stops are included with fitting.
9. Hose: Manufacturer's standard, for service fluid, temperature, and pressure; 25 feet (7.6 m) 50 feet (15 m) long.
10. Nozzle: With hand-squeeze, on-off control.
11. Vacuum Breaker: Integral or factory-installed, nonremovable, manual-drain-type, hose-connection vacuum breaker complying with ASSE 1011 or backflow preventer complying with ASSE 1052; and garden-hose thread complying with ASME B1.20.7 on outlet.

2.10 HOSE BIBBS

A. Hose Bibbs:

1. Standard: ASME A112.18.1 for sediment faucets.
2. Body Material: Bronze.
3. Seat: Bronze, replaceable.
4. Supply Connections: NPS 1/2 or NPS 3/4 (DN 15 or DN 20) threaded or solder-joint inlet.
5. Outlet Connection: Garden-hose thread complying with ASME B1.20.7.
6. Pressure Rating: 125 psig (860 kPa).
7. Vacuum Breaker: Integral nonremovable, drainable, hose-connection vacuum breaker complying with ASSE 1011.
8. Finish for Equipment Rooms: Rough bronze, or chrome or nickel plated.
9. Finish for Service Areas: Rough bronze Chrome or nickel plated.

10. Finish for Finished Rooms: Chrome or nickel plated.
11. Operation for Equipment Rooms: Wheel handle or operating key.
12. Operation for Service Areas: Operating key.
13. Operation for Finished Rooms: Operating key.
14. Include operating key with each operating-key hose bibb.
15. Include integral wall flange with each chrome- or nickel-plated hose bibb.

## 2.11 WALL HYDRANTS

### A. Nonfreeze Wall Hydrants:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Watts; a Watts Water Technologies company.
  - b. Woodford Manufacturing Company.
  - c. Zurn Industries, LLC.
2. Standard: ASME A112.21.3M for concealed-outlet, self-draining wall hydrants.
3. Pressure Rating: 125 psig (860 kPa).
4. Operation: Loose key.
5. Casing and Operating Rod: Of length required to match wall thickness. Include wall clamp.
6. Inlet: NPS 3/4 or NPS 1 (DN 20 or DN 25).
7. Outlet: Concealed, with integral vacuum breaker and garden-hose thread complying with ASME B1.20.7.
8. Box: Deep, flush mounted with cover.
9. Box and Cover Finish: Polished nickel bronze Chrome plated.
10. Outlet: Exposed, with integral vacuum breaker and garden-hose thread complying with ASME B1.20.7.
11. Nozzle and Wall-Plate Finish: Polished nickel bronze Rough bronze.
12. Operating Keys(s): One with each wall hydrant.

### B. Moderate-Climate Wall Hydrants:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. MIFAB, Inc.
  - b. Watts; a Watts Water Technologies company.
  - c. Woodford Manufacturing Company.
  - d. Zurn Industries, LLC.
2. Standard: ASME A112.21.3M for concealed-outlet, self-draining wall hydrants.
3. Pressure Rating: 125 psig (860 kPa).
4. Operation: Loose key.
5. Inlet: NPS 3/4 or NPS 1 (DN 20 or DN 25).



6. Outlet:
  - a. Concealed, with integral vacuum breaker or nonremovable hose-connection vacuum breaker complying with ASSE 1011 or backflow preventer complying with ASSE 1052.
  - b. Garden-hose thread complying with ASME B1.20.7.
7. Box: Deep, flush mounted with cover.
8. Box and Cover Finish: Polished nickel bronze Chrome plated.
9. Outlet:
  - a. Concealed, with integral vacuum breaker or nonremovable hose-connection vacuum breaker complying with ASSE 1011 or backflow preventer complying with ASSE 1052.
  - b. Garden-hose thread complying with ASME B1.20.7.
10. Nozzle and Wall-Plate Finish: Polished nickel bronze Rough bronze.
11. Operating Keys(s): One with each wall hydrant.

C. Vacuum Breaker Wall Hydrants:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Arrowhead Brass Products.
  - b. Watts; a Watts Water Technologies company.
  - c. Woodford Manufacturing Company.
  - d. Zurn Industries, LLC.
2. Standard: ASSE 1019, Type A or Type B.
3. Type: Freeze-resistant, automatic draining with integral air-inlet valve.
4. Classification: Type A, for automatic draining with hose removed or Type B, for automatic draining with hose removed or with hose attached and nozzle closed.
5. Pressure Rating: 125 psig (860 kPa).
6. Operation: Loose key or wheel handle.
7. Casing and Operating Rod: Of length required to match wall thickness. Include wall clamp.
8. Inlet: NPS 1/2 or NPS 3/4 (DN 15 or DN 20).
9. Outlet: Exposed with garden-hose thread complying with ASME B1.20.7.

2.12 DRAIN VALVES

A. Ball-Valve-Type, Hose-End Drain Valves:

1. Standard: MSS SP-110 for standard-port, two-piece ball valves.
2. Pressure Rating: 400-psig (2760-kPa) minimum CWP.
3. Size: NPS 3/4 (DN 20).
4. Body: Copper alloy.

5. Ball: Chrome-plated brass.
6. Seats and Seals: Replaceable.
7. Handle: Vinyl-covered steel.
8. Inlet: Threaded or solder joint.
9. Outlet: Threaded, short nipple with garden-hose thread complying with ASME B1.20.7 and cap with brass chain.

B. Gate-Valve-Type, Hose-End Drain Valves:

1. Standard: MSS SP-80 for gate valves.
2. Pressure Rating: Class 125.
3. Size: NPS 3/4 (DN 20).
4. Body: ASTM B 62 bronze.
5. Inlet: NPS 3/4 (DN 20) threaded or solder joint.
6. Outlet: Garden-hose thread complying with ASME B1.20.7 and cap with brass chain.

C. Stop-and-Waste Drain Valves:

1. Standard: MSS SP-110 for ball valves or MSS SP-80 for gate valves.
2. Pressure Rating: 200-psig (1380-kPa) minimum CWP or Class 125.
3. Size: NPS 3/4 (DN 20).
4. Body: Copper alloy or ASTM B 62 bronze.
5. Drain: NPS 1/8 (DN 6) side outlet with cap.

## 2.13 WATER-HAMMER ARRESTERS

A. Water-Hammer Arresters:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. MIFAB, Inc.
  - b. Precision Plumbing Products.
  - c. Watts; a Watts Water Technologies company.
  - d. Zurn Industries, LLC.
2. Standard: ASSE 1010 or PDI-WH 201.
3. Type: Metal bellows Copper tube with piston.
4. Size: ASSE 1010, Sizes AA and A through F, or PDI-WH 201, Sizes A through F.

## 2.14 AIR VENTS

A. Bolted-Construction Automatic Air Vents:

1. Body: Bronze.
2. Pressure Rating and Temperature: 125-psig (860-kPa) minimum pressure rating at 140 deg F (60 deg C).

3. Float: Replaceable, corrosion-resistant metal.
4. Mechanism and Seat: Stainless steel.
5. Size: NPS 3/8 (DN 10) NPS 1/2 (DN 15) minimum inlet.
6. Inlet and Vent Outlet End Connections: Threaded.

B. Welded-Construction Automatic Air Vents:

1. Body: Stainless steel.
2. Pressure Rating: 150-psig (1035-kPa) minimum pressure rating.
3. Float: Replaceable, corrosion-resistant metal.
4. Mechanism and Seat: Stainless steel.
5. Size: NPS 3/8 (DN 10) minimum inlet.
6. Inlet and Vent Outlet End Connections: Threaded.

2.15 TRAP-SEAL PRIMER DEVICE

A. Supply-Type, Trap-Seal Primer Device:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Precision Plumbing Products.
  - b. Smith, Jay R. Mfg. Co.
  - c. Watts; a Watts Water Technologies company.
  - d. Zurn Industries, LLC.
2. Standard: ASSE 1018.
3. Pressure Rating: 125 psig (860 kPa) minimum.
4. Body: Bronze.
5. Inlet and Outlet Connections: NPS 1/2 (DN 15) threaded, union, or solder joint.
6. Gravity Drain Outlet Connection: NPS 1/2 (DN 15) threaded or solder joint.
7. Finish: Chrome plated, or rough bronze for units used with pipe or tube that is not chrome finished.

B. Drainage-Type, Trap-Seal Primer Device:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Mifab.
  - b. PPPINC.
  - c. Siouxchief.
  - d. Smith, Jay R. Mfg. Co.
2. Standard: ASSE 1044, lavatory P-trap with NPS 3/8 (DN 10) minimum, trap makeup connection.
3. Size: NPS 1-1/4 (DN 32) minimum.

4. Material: Chrome-plated, cast brass.

## 2.16 TRAP-SEAL PRIMER SYSTEMS

### A. Trap-Seal Primer Systems:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Mifab.
  - b. PPPINC.
  - c. Precision Plumbing Products.
  - d. Siouxchief.
  - e. Zurn Industries, LLC.
2. Standard: ASSE 1044.
3. Piping: NPS 3/4, ASTM B 88, Type L (DN 20, ASTM B 88M, Type B); copper, water tubing.
4. Cabinet: Recessed-mounted steel box with stainless-steel cover.
5. Electric Controls: 24-hour timer, solenoid valve, and manual switch for 120-V ac power.
  - a. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
6. Vacuum Breaker: ASSE 1001.
7. Number Outlets: Four.
8. Size Outlets: NPS 1/2 (DN 15) NPS 5/8 (DN 18).

## 2.17 SPECIALTY VALVES

- A. Comply with requirements for general-duty metal valves in Section 220523.12 "Ball Valves for Plumbing Piping," Section 220523.13 "Butterfly Valves for Plumbing Piping," Section 220523.14 "Check Valves for Plumbing Piping," and Section 220523.15 "Gate Valves for Plumbing Piping."

### B. CPVC Union Ball Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. American Valve, Inc.
  - b. Asahi/America.
  - c. Colonial Engineering, Inc.
  - d. Georg Fischer Inc.
  - e. Hayward Flow Control; a division of Hayward Industries, Inc.
  - f. IPEX USA LLC.

- g. NIBCO INC.
- h. Spears Manufacturing Company.
- i. Thermoplastic Valves, Inc.

2. Description:

- a. Standard: MSS SP-122.
- b. Pressure Rating and Temperature: 125 psig (860 kPa) at [73 deg F (23 deg C)].
- c. Body Material: CPVC.
- d. Body Design: Union type.
- e. End Connections for Valves NPS 2 (DN 50) and Smaller: Detachable, socket or threaded.
- f. End Connections for Valves NPS 2-1/2 to NPS 4 (DN 65 to DN 100): Detachable, socket socket or threaded threaded flanged.
- g. Ball: CPVC; full port.
- h. Seals: PTFE or EPDM-rubber O-rings.
- i. Handle: Tee shaped.

C. PVC Union Ball Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- a. American Valve, Inc.
- b. Jomar Valve.
- c. KBI (King Bros. Industries).
- d. Legend Valve & Fitting, Inc.
- e. NIBCO INC.
- f. Spears Manufacturing Company.

2. Description:

- a. Standard: MSS SP-122.
- b. Pressure Rating and Temperature: 125 psig (860 kPa) at 73 deg F (23 deg C).
- c. Body Material: PVC.
- d. Body Design: Union type.
- e. End Connections for Valves NPS 2 (DN 50) and Smaller: Detachable, socket or threaded.
- f. End Connections for Valves NPS 2-1/2 to NPS 4 (DN 65 to DN 100): Detachable, socket socket or threaded threaded flanged.
- g. Ball: PVC; full port.
- h. Seals: PTFE or EPDM-rubber O-rings.
- i. Handle: Tee shaped.

D. CPVC Non-Union Ball Valves:

1. <Double click here to find, evaluate, and insert list of manufacturers and products.>
2. Description:

- a. Standard: MSS SP-122.

- b. Pressure Rating and Temperature: 125 psig (860 kPa) at 73 deg F (23 deg C).
- c. Body Material: CPVC.
- d. Body Design: Non-union type.
- e. End Connections: Socket or threaded.
- f. Ball: CPVC; full or reduced port.
- g. Seals: PTFE or EPDM-rubber O-rings.
- h. Handle: Tee shaped.

E. PVC Non-Union Ball Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- a. American Valve, Inc.
- b. Asahi/America.
- c. Colonial Engineering, Inc.
- d. Georg Fischer Inc.
- e. Hayward Flow Control; a division of Hayward Industries, Inc.
- f. NIBCO INC.
- g. Spears Manufacturing Company.

2. Description:

- a. Standard: MSS SP-122.
- b. Pressure Rating and Temperature: 125 psig (860 kPa) at 73 deg F (23 deg C).
- c. Body Material: PVC.
- d. Body Design: Non-union type.
- e. End Connections: Socket or threaded.
- f. Ball: PVC; full or reduced port.
- g. Seals: PTFE or EPDM-rubber O-rings.
- h. Handle: Tee shaped.

F. CPVC Butterfly Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- a. Georg Fischer Inc.
- b. Hayward Flow Control; a division of Hayward Industries, Inc.
- c. NIBCO INC.
- d. Spears Manufacturing Company.

2. Description:

- a. Pressure Rating and Temperature: 125 psig (860 kPa) at 73 deg F (23 deg C).
- b. Body Material: CPVC.
- c. Body Design: Lug or wafer type.
- d. Seat: EPDM rubber.
- e. Seals: PTFE or EPDM-rubber O-rings.
- f. Disc: CPVC.

- g. Stem: Stainless steel.
- h. Handle: Lever.

G. PVC Butterfly Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. American Valve, Inc.
  - b. Colonial Engineering, Inc.
  - c. Georg Fischer Inc.
  - d. Hayward Flow Control; a division of Hayward Industries, Inc.
  - e. IPEX USA LLC.
  - f. NIBCO INC.
  - g. Spears Manufacturing Company.
2. Description:
  - a. Pressure Rating and Temperature: 125 psig (860 kPa) at [73 deg F (23 deg C)].
  - b. Body Material: PVC.
  - c. Body Design: Lug or wafer type.
  - d. Seat: EPDM rubber.
  - e. Seals: PTFE or EPDM-rubber O-rings.
  - f. Disc: PVC.
  - g. Stem: Stainless steel.
  - h. Handle: Lever.

H. CPVC Ball Check Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. American Valve, Inc.
  - b. Georg Fischer Inc.
  - c. Hayward Flow Control; a division of Hayward Industries, Inc.
  - d. IPEX USA LLC.
  - e. NIBCO INC.
  - f. Spears Manufacturing Company.
2. Description:
  - a. Pressure Rating and Temperature: 125 psig (860 kPa) at [73 deg F (23 deg C)].
  - b. Body Material: CPVC.
  - c. Body Design: Union-type ball check.
  - d. End Connections for Valves NPS 2 (DN 50) and Smaller: Detachable, socket or threaded.
  - e. End Connections for Valves NPS 2-1/2 to NPS 4 (DN 65 to DN 100): Detachable, socket socket or threaded threaded flanged.
  - f. Ball: CPVC.
  - g. Seals: EPDM- or FKM-rubber O-rings.

I. PVC Ball Check Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. American Valve, Inc.
  - b. Colonial Engineering, Inc.
  - c. Georg Fischer Inc.
  - d. Hayward Flow Control; a division of Hayward Industries, Inc.
  - e. IPEX USA LLC.
  - f. NIBCO INC.
  - g. Spears Manufacturing Company.
2. Description:
  - a. Pressure Rating and Temperature: 125 psig (860 kPa) at 73 deg F (23 deg C).
  - b. Body Material: PVC.
  - c. Body Design: Union-type ball check.
  - d. End Connections for Valves NPS 2 (DN 50) and Smaller: Detachable, socket or threaded.
  - e. End Connections for Valves NPS 2-1/2 to NPS 4 (DN 65 to DN 100): Detachable, socket socket or threaded threaded flanged.
  - f. Ball: PVC.
  - g. Seals: EPDM- or FKM-rubber O-rings.

J. CPVC Gate Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Georg Fischer Inc.
  - b. Spears Manufacturing Company.
2. Description:
  - a. Pressure Rating and Temperature: 125 psig (860 kPa) at 73 deg F (23 deg C).
  - b. Body Material: CPVC.
  - c. Body Design: Nonrising stem.
  - d. End Connections for Valves NPS 2 (DN 50) and Smaller: Socket or threaded.
  - e. End Connections for Valves NPS 2-1/2 to NPS 4 (DN 65 to DN 100): Socket Socket or threaded Threaded Flanged.
  - f. Gate and Stem: Plastic.
  - g. Seals: EPDM rubber.
  - h. Handle: Wheel.

K. PVC Gate Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:



- a. Asahi/America.
  - b. Georg Fischer Inc.
  - c. KBI (King Bros. Industries).
  - d. Spears Manufacturing Company.
2. Description:
- a. Pressure Rating and Temperature: 125 psig (860 kPa) at 73 deg F (23 deg C).
  - b. Body Material: PVC.
  - c. Body Design: Nonrising stem.
  - d. End Connections for Valves NPS 2 (DN 50) and Smaller: Socket or threaded.
  - e. End Connections for Valves NPS 2-1/2 to NPS 4 (DN 65 to DN 100): Socket Socket or threaded Threaded Flanged.
  - f. Gate and Stem: Plastic.
  - g. Seals: EPDM rubber.
  - h. Handle: Wheel.

## 2.18 FLEXIBLE CONNECTORS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
1. Flex Pression Ltd.
  2. Flex-Hose Co., Inc.
  3. Metraflex Company (The).
- B. Bronze-Hose Flexible Connectors: Corrugated-bronze tubing with bronze wire-braid covering and ends brazed to inner tubing.
1. Working-Pressure Rating: Minimum 200 psig (1380 kPa).
  2. End Connections NPS 2 (DN 50) and Smaller: Threaded copper pipe or plain-end copper tube.
  3. End Connections NPS 2-1/2 (DN 65) and Larger: Flanged copper alloy.
- C. Stainless-Steel-Hose Flexible Connectors: Corrugated-stainless-steel tubing with stainless-steel wire-braid covering and ends welded to inner tubing.
1. Working-Pressure Rating: Minimum 200 psig (1380 kPa).
  2. End Connections NPS 2 (DN 50) and Smaller: Threaded steel-pipe nipple.
  3. End Connections NPS 2-1/2 (DN 65) and Larger: Flanged steel nipple. Retain "Turbine-Type Water Meters" Paragraph below for water meters NPS 1-1/2 to NPS 10 (DN 40 to DN 250). Retain "Compound-Type Water Meters" Paragraph below for water meters NPS 3 (DN 80) and larger. NPS 2 (DN 50) meters are also available.
- D. Remote Registration System: Direct-reading type complying with AWWA C706; modified with signal-transmitting assembly, low-voltage connecting wiring, and remote register assembly as required by utility company.

- E. Remote Registration System: Encoder type complying with AWWA C707; modified with signal-transmitting assembly, low-voltage connecting wiring, and remote register assembly as required by utility company.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION

- A. Install backflow preventers in each water supply to mechanical equipment and systems and to other equipment and water systems that may be sources of contamination. Comply with authorities having jurisdiction.
  - 1. Locate backflow preventers in same room as connected equipment or system.
  - 2. Install drain for backflow preventers with atmospheric-vent drain connection with air-gap fitting, fixed air-gap fitting, or equivalent positive pipe separation of at least two pipe diameters in drain piping and pipe-to-floor drain. Locate air-gap device attached to or under backflow preventer. Simple air breaks are unacceptable for this application.
  - 3. Do not install bypass piping around backflow preventers.
- B. Install water regulators with inlet and outlet shutoff valves and bypass with memory-stop balancing valve. Install pressure gages on inlet and outlet.
- C. Install water-control valves with inlet and outlet shutoff valves and bypass with globe valve. Install pressure gages on inlet and outlet.
- D. Install balancing valves in locations where they can easily be adjusted.
- E. Install temperature-actuated, water mixing valves with check stops or shutoff valves on inlets and with shutoff valve on outlet.
  - 1. Install cabinet-type units recessed in or surface mounted on wall as specified.
- F. Install Y-pattern strainers for water on supply side of each control valve water pressure-reducing valve solenoid valve and pump.
- G. Install outlet boxes recessed in wall or surface mounted on wall. Install 2-by-4-inch (38-by-89-mm) fire-retardant-treated-wood blocking, wall reinforcement between studs. Comply with requirements for fire-retardant-treated-wood blocking in Section 061000 "Rough Carpentry."
- H. Install hose stations with check stops or shutoff valves on inlets and with thermometer on outlet.
  - 1. Install cabinet-type units recessed in or surface mounted on wall as specified. Install 2-by-4-inch (38-by-89-mm) fire-retardant-treated-wood blocking, wall reinforcement between studs. Comply with requirements for fire-retardant-treated-wood blocking in Section 061000 "Rough Carpentry."
- I. Install ground hydrants with 1 cu. yd. (0.75 cu. m) of crushed gravel around drain hole. Set ground hydrants with box flush with grade.

- J. Install draining-type post hydrants with 1 cu. yd. (0.75 cu. m) of crushed gravel around drain hole. Set post hydrants in concrete paving or in 1 cu. ft. (0.03 cu. m) of concrete block at grade.
- K. Set nonfreeze, nondraining-type post hydrants in concrete or pavement.
- L. Set freeze-resistant yard hydrants with riser pipe in concrete or pavement. Do not encase canister in concrete.
- M. Install water-hammer arresters in water piping according to PDI-WH 201.
- N. Install air vents at high points of water piping. Install drain piping and discharge onto floor drain.
- O. Install supply-type, trap-seal primer valves with outlet piping pitched down toward drain trap a minimum of 1 percent, and connect to floor-drain body, trap, or inlet fitting. Adjust valve for proper flow.
- P. Install drainage-type, trap-seal primer valves as lavatory trap with outlet piping pitched down toward drain trap a minimum of 1 percent, and connect to floor-drain body, trap, or inlet fitting.
- Q. Install trap-seal primer systems with outlet piping pitched down toward drain trap a minimum of 1 percent, and connect to floor-drain body, trap, or inlet fitting. Adjust system for proper flow.

### 3.2 CONNECTIONS

- A. Comply with requirements for ground equipment in Section 260526 "Grounding and Bonding for Electrical Systems."
- B. Fire-retardant-treated-wood blocking is specified in Section 260519 "Low-Voltage Electrical Power Conductors and Cables" for electrical connections.

### 3.3 LABELING AND IDENTIFYING

- A. Equipment Nameplates and Signs: Install engraved plastic-laminate equipment nameplate or sign on or near each of the following:
  - 1. Pressure vacuum breakers.
  - 2. Intermediate atmospheric-vent backflow preventers.
  - 3. Reduced-pressure-principle backflow preventers.
  - 4. Double-check, backflow-prevention assemblies.
  - 5. Carbonated-beverage-machine backflow preventers.
  - 6. Dual-check-valve backflow preventers.
  - 7. Reduced-pressure-detector, fire-protection, backflow-preventer assemblies.
  - 8. Double-check, detector-assembly backflow preventers.
  - 9. Water pressure-reducing valves.
  - 10. Calibrated balancing valves.
  - 11. Primary, thermostatic, water mixing valves.
  - 12. Manifold, thermostatic, water mixing-valve assemblies.

13. Photographic-process, thermostatic, water mixing-valve assemblies.
14. Primary water tempering valves.
15. Outlet boxes.
16. Hose stations.
17. Supply-type, trap-seal primer valves.
18. Trap-seal primer systems.

- B. Distinguish among multiple units, inform operator of operational requirements, indicate safety and emergency precautions, and warn of hazards and improper operations, in addition to identifying unit. Nameplates and signs are specified in Section 220553 "Identification for Plumbing Piping and Equipment."

### 3.4 FIELD QUALITY CONTROL

- A. Perform the following tests and inspections:
1. Test each pressure vacuum breaker reduced-pressure-principle backflow preventer double-check, backflow-prevention assembly and double-check, detector-assembly backflow preventer according to authorities having jurisdiction and the device's reference standard.
- B. Domestic water piping specialties will be considered defective if they do not pass tests and inspections.
- C. Prepare test and inspection reports.

### 3.5 ADJUSTING

- A. Set field-adjustable pressure set points of water pressure-reducing valves.
- B. Set field-adjustable flow set points of balancing valves.
- C. Set field-adjustable temperature set points of temperature-actuated, water mixing valves.

END OF SECTION 221119

## SECTION 221123 - DOMESTIC WATER PUMPS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. In-line, sealless centrifugal pumps.
- B. Related Sections include the following:
  - 1. Section 221123.13 "Domestic-Water Packaged Booster Pumps" for booster systems.
  - 2. Section 332100 "Water Supply Wells" for well pumps.

#### 1.3 DEFINITIONS

- A. Low Voltage: As defined in NFPA 70 for circuits and equipment operating at less than 50 V or for remote-control, signaling power-limited circuits.

#### 1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated. Include materials of construction, rated capacities, certified performance curves with operating points plotted on curves, operating characteristics, electrical characteristics, and furnished specialties and accessories.
- B. LEED Submittals:
  - 1. Product Data for Prerequisite EA 2: Documentation indicating that units comply with applicable requirements in ASHRAE/IESNA 90.1, without amendments, Section 7 - "Service Water Heating."

#### 1.5 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For domestic water pumps to include in operation and maintenance manuals.

1.6 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. UL Compliance: Comply with UL 778 for motor-operated water pumps.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Retain shipping flange protective covers and protective coatings during storage.
- B. Protect bearings and couplings against damage.
- C. Comply with pump manufacturer's written rigging instructions for handling.

1.8 COORDINATION

- A. Coordinate sizes and locations of concrete bases with actual equipment provided.

PART 2 - PRODUCTS

2.1 IN-LINE, SEALLESS CENTRIFUGAL PUMPS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Bell & Gossett; a Xylem brand.
  - 2. Grundfos Pumps Corp.
  - 3. TACO Incorporated.
- B. Description: Factory-assembled and -tested, in-line, close-coupled, canned-motor, sealless, overhung-impeller centrifugal pumps.
- C. Pump Construction:
  - 1. Pump and Motor Assembly: Hermetically sealed, replaceable-cartridge type with motor and impeller on common shaft and designed for installation with pump and motor shaft horizontal.
  - 2. Casing: Bronze, with threaded or companion-flange connections.
  - 3. Impeller: Plastic.
  - 4. Motor: Single speed, unless otherwise indicated.
- D. Capacities and Characteristics:
  - 1. Capacity: Per contract drawings.
  - 2. Total Dynamic Head: Per contract drawings.
  - 3. Minimum Working Pressure: 125 psig (860 kPa).

4. Maximum Continuous Operating Temperature: 220 deg F (104 deg C).
5. Inlet and Outlet Size: Per contract drawings.
6. Pump Speed: 2950 rpm.
7. Pump Control: Thermostat & Timer.
8. Electrical Characteristics:
  - a. Volts: 120.
  - b. Phases: Single.
  - c. Hertz: 60.
  - d. Full-Load Amperes: Per contract drawings.
  - e. Minimum Circuit Ampacity: Per contract drawings.
  - f. Maximum Overcurrent Protection: N/A

## 2.2 MOTORS

- A. Comply with NEMA designation, temperature rating, service factor, enclosure type, and efficiency requirements for motors specified in Section 220513 "Common Motor Requirements for Plumbing Equipment."
  1. Motor Sizes: Minimum size as indicated. If not indicated, large enough so driven load will not require motor to operate in service factor range above 1.0.

## 2.3 CONTROLS

- A. Thermostats: Electric; adjustable for control of hot-water circulation pump.
  1. Type: Water-immersion temperature sensor, for installation in piping.
  2. Range: Per contract drawings.
  3. Enclosure: NEMA 250, Type 4X.
  4. Operation of Pump: On or off.
  5. Transformer: Provide if required.
  6. Power Requirement: 120 V, ac.
  7. Settings: Per contract drawings.
- B. Timers: Electric, for control of hot-water circulation pump.
  1. Type: Programmable, seven-day clock with manual override on-off switch.
  2. Enclosure: NEMA 250, Type 1, suitable for wall mounting.
  3. Operation of Pump: On or off.
  4. Transformer: Provide if required.
  5. Power Requirement: 120-V ac.
  6. Programmable Sequence of Operation: Up to two on-off cycles each day for seven days.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine roughing-in of domestic-water-piping system to verify actual locations of connections before pump installation.

3.2 PUMP INSTALLATION

- A. Comply with HI 1.4.
- B. Install in-line, sealless centrifugal pumps with shaft horizontal unless otherwise indicated.
- C. Install horizontally mounted, in-line, close-coupled centrifugal pumps with shaft(s) horizontal.
- D. Install vertically mounted, in-line, close-coupled centrifugal pumps with shaft vertical.
- E. Pump Mounting: Install vertically mounted, in-line, close-coupled centrifugal pumps with cast-iron base mounted on concrete base using elastomeric mounts. Comply with requirements for concrete base specified in Section 033000 "Cast-in-Place Concrete." Section 033053 "Miscellaneous Cast-in-Place Concrete."
  - 1. Minimum Deflection: 1/4 inch (6 mm).
  - 2. Install dowel rods to connect concrete base to concrete floor. Unless otherwise indicated, install dowel rods on 18-inch (450-mm) centers around the full perimeter of concrete base.
  - 3. For supported equipment, install epoxy-coated anchor bolts that extend through concrete base and anchor into structural concrete floor.
  - 4. Place and secure anchorage devices. Use setting drawings, templates, diagrams, instructions, and directions furnished with items to be embedded.
  - 5. Install anchor bolts to elevations required for proper attachment to supported equipment.
- F. Install continuous-thread hanger rods and spring hangers of size required to support pump weight.
  - 1. Comply with requirements for vibration isolation devices specified in Section 220548.13 "Vibration Controls for Plumbing Piping and Equipment." Fabricate brackets or supports as required.
  - 2. Comply with requirements for hangers and supports specified in Section 220529 "Hangers and Supports for Plumbing Piping and Equipment."
- G. Install pressure switches in water supply piping.
- H. Install thermostats in hot-water return piping.
- I. Install timers on wall in engineer's office.
- J. Install time-delay relays in piping between water heaters and hot-water storage tanks.



### 3.3 CONNECTIONS

- A. Comply with requirements for piping specified in Section 221116 "Domestic Water Piping." Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Install piping adjacent to pumps to allow service and maintenance.
- C. Connect domestic water piping to pumps. Install suction and discharge piping equal to or greater than size of pump nozzles.
  - 1. Install flexible connectors adjacent to pumps in suction and discharge piping of the following pumps:
    - a. Horizontally mounted, in-line, separately coupled centrifugal pumps.
    - b. Horizontally mounted, in-line, close-coupled centrifugal pumps.
    - c. Vertically mounted, in-line, close-coupled centrifugal pumps.
    - d. Comply with requirements for flexible connectors specified in Section 221116 "Domestic Water Piping."
- D. Install shutoff valve and strainer on suction side of each pump, and check, shutoff, and throttling valves on discharge side of each pump. Install valves same size as connected piping. Comply with requirements for valves specified in Section 220523.12 "Ball Valves for Plumbing Piping," Section 220523.13 "Butterfly Valves for Plumbing Piping," Section 220523.14 "Check Valves for Plumbing Piping," and Section 220523.15 "Gate Valves for Plumbing Piping," and comply with requirements for strainers specified in Section 221119 "Domestic Water Piping Specialties."
- E. Connect thermostats, and timers to pumps that they control.
- F. Interlock pump between water heater and hot-water storage tank with water heater burner and time-delay relay.

### 3.4 IDENTIFICATION

- A. Comply with requirements for identification specified in Section 220553 "Identification for Plumbing Piping and Equipment" for identification of pumps.

### 3.5 STARTUP SERVICE

- A. Engage a factory-authorized service representative to perform startup service.
  - 1. Complete installation and startup checks according to manufacturer's written instructions.
  - 2. Check piping connections for tightness.
  - 3. Clean strainers on suction piping.
  - 4. Set thermostats, timers, for automatic starting and stopping operation of pumps.
  - 5. Perform the following startup checks for each pump before starting:
    - a. Verify bearing lubrication.

- b. Verify that pump is free to rotate by hand and that pump for handling hot liquid is free to rotate with pump hot and cold. If pump is bound or drags, do not operate until cause of trouble is determined and corrected.
  - c. Verify that pump is rotating in the correct direction.
- 6. Prime pump by opening suction valves and closing drains, and prepare pump for operation.
  - 7. Start motor.
  - 8. Open discharge valve slowly.
  - 9. Adjust temperature settings on thermostats.
  - 10. Adjust timer settings.

### 3.6 ADJUSTING

- A. Adjust domestic water pumps to function smoothly, and lubricate as recommended by manufacturer.
- B. Adjust initial temperature set points.
- C. Set field-adjustable switches and circuit-breaker trip ranges as indicated.

END OF SECTION 221123

SECTION 221316 - SANITARY WASTE AND VENT PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Pipe, tube, and fittings.
2. Specialty pipe fittings.
3. Encasement for underground metal piping.

B. Related Sections:

1. Section 221313 "Facility Sanitary Sewers" for sanitary sewerage piping and structures outside the building.
2. Section 221329 "Sanitary Sewerage Pumps" for effluent and sewage pumps.
3. Section 226600 "Chemical-Waste Systems for Laboratory and Healthcare Facilities" for chemical-waste and vent piping systems.

1.3 PERFORMANCE REQUIREMENTS

- A. Components and installation shall be capable of withstanding the following minimum working pressure unless otherwise indicated:

1. Soil, Waste, and Vent Piping: 10-foot head of water (30 kPa).
2. Waste, Force-Main Piping: 50 psig (345 kPa).

- B. Seismic Performance: Soil, waste, and vent piping and support and installation shall withstand the effects of earthquake motions determined according to ASCE/SEI 7.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.

- B. Shop Drawings: For sovent drainage system. Include plans, elevations, sections, and details.

1.5 INFORMATIONAL SUBMITTALS

- A. Seismic Qualification Certificates: For waste and vent piping, accessories, and components, from manufacturer.
  - 1. Basis for Certification: Indicate whether withstand certification is based on actual test of assembled components or on calculation.
  - 2. Detailed description of piping anchorage devices on which the certification is based and their installation requirements.
- B. Field quality-control reports.

1.6 QUALITY ASSURANCE

- A. Piping materials shall bear label, stamp, or other markings of specified testing agency.
- B. Comply with NSF/ANSI 14, "Plastics Piping Systems Components and Related Materials," for plastic piping components. Include marking with "NSF-dwv" for plastic drain, waste, and vent piping and "NSF-sewer" for plastic sewer piping.

1.7 PROJECT CONDITIONS

- A. Interruption of Existing Sanitary Waste Service: Do not interrupt service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary service according to requirements indicated:
  - 1. Notify Owner no fewer than two days in advance of proposed interruption of sanitary waste service.
  - 2. Do not proceed with interruption of sanitary waste service without Owner's written permission.

PART 2 - PRODUCTS

2.1 PIPING MATERIALS

- A. Comply with requirements in "Piping Schedule" Article for applications of pipe, tube, fitting materials, and joining methods for specific services, service locations, and pipe sizes.

2.2 HUB-AND-SPIGOT, CAST-IRON SOIL PIPE AND FITTINGS

- A. Pipe and Fittings: ASTM A 74, Service and Extra Heavy class(es).
- B. Gaskets: ASTM C 564, rubber.
- C. Calking Materials: ASTM B 29, pure lead and oakum or hemp fiber.

2.3 HUBLESS, CAST-IRON SOIL PIPE AND FITTINGS

- A. Pipe and Fittings: ASTM A 888 or CISPI 301.
- B. Sovent Stack Fittings: ASME B16.45 or ASSE 1043, hubless, cast-iron aerator and deaerator drainage fittings.
- C. CISPI, Hubless-Piping Couplings:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. ANACO-Husky.
    - b. MIFAB, Inc.
    - c. Tyler Pipe; a subsidiary of McWane Inc.
  - 2. Standards: ASTM C 1277 and CISPI 310.
  - 3. Description: Stainless-steel corrugated shield with stainless-steel bands and tightening devices; and ASTM C 564, rubber sleeve with integral, center pipe stop.
- D. Heavy-Duty, Hubless-Piping Couplings:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. ANACO-Husky.
    - b. MIFAB, Inc.
    - c. Tyler Pipe; a subsidiary of McWane Inc.
  - 2. Standards: ASTM C 1277 and ASTM C 1540.
  - 3. Description: Stainless-steel shield with stainless-steel bands and tightening devices; and ASTM C 564, rubber sleeve with integral, center pipe stop.
- E. Cast-Iron, Hubless-Piping Couplings:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by the following:
    - a. MG Piping Products Company.
  - 2. Standard: ASTM C 1277.
  - 3. Description: Two-piece ASTM A 48/A 48M, cast-iron housing; stainless-steel bolts and nuts; and ASTM C 564, rubber sleeve with integral, center pipe stop.

2.4 DUCTILE-IRON PIPE AND FITTINGS

- A. Ductile-Iron, Mechanical-Joint Piping:
  - 1. Ductile-Iron Pipe: AWWA C151/A21.51, with mechanical-joint bell and plain spigot end unless grooved or flanged ends are indicated.
  - 2. Ductile-Iron Fittings: AWWA C110/A21.10, mechanical-joint, ductile- or gray-iron standard pattern or AWWA C153/A21.53, ductile-iron compact pattern.

3. Glands, Gaskets, and Bolts: AWWA C111/A21.11, ductile- or gray-iron glands, rubber gaskets, and steel bolts.

B. Ductile-Iron, Push-on-Joint Piping:

1. Ductile-Iron Pipe: AWWA C151/A21.51, with push-on-joint bell and plain spigot end unless grooved or flanged ends are indicated.
2. Ductile-Iron Fittings: AWWA C110/A21.10, push-on-joint ductile- or gray-iron standard pattern or AWWA C153/A21.53, ductile-iron compact pattern.
3. Gaskets: AWWA C111/A21.11, rubber.

C. Ductile-Iron, Grooved-Joint Piping:

1. Ductile-Iron Pipe: AWWA C151/A21.51 with round-cut-grooved ends according to AWWA C606.
2. Ductile-Iron-Pipe Appurtenances:
  - a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - 1) Anvil International.
    - 2) Smith-Cooper International.
    - 3) Victaulic Company.
  - b. Grooved-End, Ductile-Iron Fittings: ASTM A 536 ductile-iron castings with dimensions matching AWWA C110/A 21.10 ductile-iron pipe or AWWA C153/A 21.53 ductile-iron fittings and complying with AWWA C606 for grooved ends.
  - c. Grooved Mechanical Couplings for Ductile-Iron Pipe: ASTM F 1476, Type I. Include ferrous housing sections with continuous curved keys; EPDM-rubber center-leg gasket suitable for hot and cold water; and bolts and nuts.

2.5 ABS PIPE AND FITTINGS

- A. Solid-Wall ABS Pipe: ASTM D 2661, Schedule 40.
- B. Cellular-Core ABS Pipe: ASTM F 628, Schedule 40.
- C. ABS Socket Fittings: ASTM D 2661, made to ASTM D 3311, drain, waste, and vent patterns.
- D. Solvent Cement: ASTM D 2235.
  1. ABS solvent cement shall have a VOC content of 325 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  2. Solvent cement shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

2.6 PVC PIPE AND FITTINGS

- A. Solid-Wall PVC Pipe: ASTM D 2665, drain, waste, and vent.
- B. Cellular-Core PVC Pipe: ASTM F 891, Schedule 40.
- C. PVC Socket Fittings: ASTM D 2665, made to ASTM D 3311, drain, waste, and vent patterns and to fit Schedule 40 pipe.
- D. Adhesive Primer: ASTM F 656.
  - 1. Adhesive primer shall have a VOC content of 550 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 2. Adhesive primer shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- E. Solvent Cement: ASTM D 2564.
  - 1. PVC solvent cement shall have a VOC content of 510 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 2. Solvent cement shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

2.7 SPECIALTY PIPE FITTINGS

- A. Transition Couplings:
  - 1. General Requirements: Fitting or device for joining piping with small differences in OD's or of different materials. Include end connections same size as and compatible with pipes to be joined.
  - 2. Fitting-Type Transition Couplings: Manufactured piping coupling or specified piping system fitting.
  - 3. Unshielded, Nonpressure Transition Couplings:
    - a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
      - 1) Dallas Specialty & Mfg. Co.
      - 2) Fernco Inc.
      - 3) Froet Industries LLC.
      - 4) Mission Rubber Company, LLC; a division of MCP Industries.
    - b. Standard: ASTM C 1173.
    - c. Description: Elastomeric, sleeve-type, reducing or transition pattern. Include shear ring and corrosion-resistant-metal tension band and tightening mechanism on each end.
    - d. Sleeve Materials:

- 1) For Cast-Iron Soil Pipes: ASTM C 564, rubber.
  - 2) For Plastic Pipes: ASTM F 477, elastomeric seal or ASTM D 5926, PVC.
  - 3) For Dissimilar Pipes: ASTM D 5926, PVC or other material compatible with pipe materials being joined.
4. Shielded, Nonpressure Transition Couplings:
- a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - 1) Cascade Waterworks Mfg. Co.
    - 2) Mission Rubber Company, LLC; a division of MCP Industries.
  - b. Standard: ASTM C 1460.
  - c. Description: Elastomeric or rubber sleeve with full-length, corrosion-resistant outer shield and corrosion-resistant-metal tension band and tightening mechanism on each end.
5. Pressure Transition Couplings:
- a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - 1) Cascade Waterworks Mfg. Co.
    - 2) Ford Meter Box Company, Inc. (The).
    - 3) JCM Industries, Inc.
    - 4) Smith, Jay R. Mfg. Co.
    - 5) Viking Johnson.
  - b. Standard: AWWA C219.
  - c. Description: Metal, sleeve-type same size as, with pressure rating at least equal to, and ends compatible with, pipes to be joined.
  - d. Center-Sleeve Material: Manufacturer's standard.
  - e. Gasket Material: Natural or synthetic rubber.
  - f. Metal Component Finish: Corrosion-resistant coating or material.

## 2.8 ENCASEMENT FOR UNDERGROUND METAL PIPING

- A. Standard: ASTM A 674 or AWWA C105/A 21.5.
- B. Material: Linear low-density polyethylene film of 0.008-inch (0.20-mm) or high-density, cross-laminated polyethylene film of 0.004-inch (0.10-mm) minimum thickness.
- C. Form: Sheet or tube.
- D. Color: Black or natural.



PART 3 - EXECUTION

3.1 EARTH MOVING

- A. Comply with requirements for excavating, trenching, and backfilling specified in Section 312000 "Earth Moving."

3.2 PIPING INSTALLATION

- A. Drawing plans, schematics, and diagrams indicate general location and arrangement of piping systems. Indicated locations and arrangements were used to size pipe and calculate friction loss, expansion, pump sizing, and other design considerations. Install piping as indicated unless deviations to layout are approved on coordination drawings.
- B. Install piping in concealed locations unless otherwise indicated and except in equipment rooms and service areas.
- C. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- D. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal.
- E. Install piping to permit valve servicing.
- F. Install piping at indicated slopes.
- G. Install piping free of sags and bends.
- H. Install fittings for changes in direction and branch connections.
- I. Install piping to allow application of insulation.
- J. Install seismic restraints on piping. Comply with requirements for seismic-restraint devices specified in Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment."
- K. Make changes in direction for soil and waste drainage and vent piping using appropriate branches, bends, and long-sweep bends. Sanitary tees and short-sweep 1/4 bends may be used on vertical stacks if change in direction of flow is from horizontal to vertical. Use long-turn, double Y-branch and 1/8-bend fittings if two fixtures are installed back to back or side by side with common drain pipe. Straight tees, elbows, and crosses may be used on vent lines. Do not change direction of flow more than 90 degrees. Use proper size of standard increasers and reducers if pipes of different sizes are connected. Reducing size of drainage piping in direction of flow is prohibited.
- L. Lay buried building drainage piping beginning at low point of each system. Install true to grades and alignment indicated, with unbroken continuity of invert. Place hub ends of piping upstream. Install required gaskets according to manufacturer's written instructions

for use of lubricants, cements, and other installation requirements. Maintain swab in piping and pull past each joint as completed.

- M. Install soil and waste drainage and vent piping at the following minimum slopes unless otherwise indicated:
  - 1. Building Sanitary Drain: 2 percent downward in direction of flow for piping NPS 3 (DN 80) and smaller; 2 percent downward in direction of flow for piping NPS 4 (DN 100) and larger.
  - 2. Horizontal Sanitary Drainage Piping: 2 percent downward in direction of flow.
  - 3. Vent Piping: 1 percent down toward vertical fixture vent or toward vent stack.
  
- N. Install cast-iron soil piping according to CISPI's "Cast Iron Soil Pipe and Fittings Handbook," Chapter IV, "Installation of Cast Iron Soil Pipe and Fittings."
  - 1. Install encasement on underground piping according to ASTM A 674 or AWWA C105/A 21.5.
  
- O. Install steel piping according to applicable plumbing code.
  
- P. Install stainless-steel piping according to ASME A112.3.1 and applicable plumbing code.
  
- Q. Install aboveground copper tubing according to CDA's "Copper Tube Handbook."
  
- R. Install aboveground ABS piping according to ASTM D 2661.
  
- S. Install aboveground PVC piping according to ASTM D 2665.
  
- T. Install underground ABS and PVC piping according to ASTM D 2321.
  
- U. Install engineered soil and waste drainage and vent piping systems as follows:
  - 1. Combination Waste and Vent: Comply with standards of authorities having jurisdiction.
  - 2. Solvent Drainage System: Comply with ASSE 1043 and solvent fitting manufacturer's written installation instructions.
  - 3. Reduced-Size Venting: Comply with standards of authorities having jurisdiction.
  
- V. Install underground, ductile-iron, force-main piping according to AWWA C600. Install buried piping inside building between wall and floor penetrations and connection to sanitary sewer piping outside building with restrained joints. Anchor pipe to wall or floor. Install thrust-block supports at vertical and horizontal offsets.
  - 1. Install encasement on piping according to ASTM A 674 or AWWA C105/A 21.5.
  
- W. Install underground, copper, force-main tubing according to CDA's "Copper Tube Handbook."
  - 1. Install encasement on piping according to ASTM A 674 or AWWA C105/A 21.5.
  
- X. Install force mains at elevations indicated.

Y. Plumbing Specialties:

1. Install backwater valves in sanitary waster gravity-flow piping. Comply with requirements for backwater valves specified in Section 221319 "Sanitary Waste Piping Specialties."
2. Install cleanouts at grade and extend to where building sanitary drains connect to building sanitary sewers in sanitary drainage gravity-flow piping. Install cleanout fitting with closure plug inside the building in sanitary drainage force-main piping. Comply with requirements for cleanouts specified in Section 221319 "Sanitary Waste Piping Specialties."
3. Install drains in sanitary drainage gravity-flow piping. Comply with requirements for drains specified in Section 221319 "Sanitary Waste Piping Specialties."

Z. Do not enclose, cover, or put piping into operation until it is inspected and approved by authorities having jurisdiction.

AA. Install sleeves for piping penetrations of walls, ceilings, and floors. Comply with requirements for sleeves specified in Section 220517 "Sleeves and Sleeve Seals for Plumbing Piping."

BB. Install sleeve seals for piping penetrations of concrete walls and slabs. Comply with requirements for sleeve seals specified in Section 220517 "Sleeves and Sleeve Seals for Plumbing Piping."

CC. Install escutcheons for piping penetrations of walls, ceilings, and floors. Comply with requirements for escutcheons specified in Section 220518 "Escutcheons for Plumbing Piping."

3.3 JOINT CONSTRUCTION

A. Join hub-and-spigot, cast-iron soil piping with gasket joints according to CISPI's "Cast Iron Soil Pipe and Fittings Handbook" for compression joints.

B. Join hub-and-spigot, cast-iron soil piping with calked joints according to CISPI's "Cast Iron Soil Pipe and Fittings Handbook" for lead-and-oakum calked joints.

C. Join hubless, cast-iron soil piping according to CISPI 310 and CISPI's "Cast Iron Soil Pipe and Fittings Handbook" for hubless-piping coupling joints.

D. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1. Cut threads full and clean using sharp dies. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:

1. Apply appropriate tape or thread compound to external pipe threads unless dry seal threading is specified.
2. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged. Do not use pipe sections that have cracked or open welds.

E. Join stainless-steel pipe and fittings with gaskets according to ASME A112.3.1.

- F. Join copper tube and fittings with soldered joints according to ASTM B 828. Use ASTM B 813, water-flushable, lead-free flux and ASTM B 32, lead-free-alloy solder.
- G. Grooved Joints: Cut groove ends of pipe according to AWWA C606. Lubricate and install gasket over ends of pipes or pipe and fitting. Install coupling housing sections, over gasket, with keys seated in piping grooves. Install and tighten housing bolts.
- H. Flanged Joints: Align bolt holes. Select appropriate gasket material, size, type, and thickness. Install gasket concentrically positioned. Use suitable lubricants on bolt threads. Torque bolts in cross pattern.
- I. Plastic, Nonpressure-Piping, Solvent-Cement Joints: Clean and dry joining surfaces. Join pipe and fittings according to the following:
  - 1. Comply with ASTM F 402 for safe-handling practice of cleaners, primers, and solvent cements.
  - 2. ABS Piping: Join according to ASTM D 2235 and ASTM D 2661 Appendixes.
  - 3. PVC Piping: Join according to ASTM D 2855 and ASTM D 2665 Appendixes.

### 3.4 SPECIALTY PIPE FITTING INSTALLATION

#### A. Transition Couplings:

- 1. Install transition couplings at joints of piping with small differences in OD's.
- 2. In Drainage Piping: Unshielded, nonpressure transition couplings.
- 3. In Aboveground Force Main Piping: Fitting-type transition couplings.
- 4. In Underground Force Main Piping:
  - a. NPS 1-1/2 (DN 40) and Smaller: Fitting-type transition couplings.
  - b. NPS 2 (DN 50) and Larger: Pressure transition couplings.

#### B. Dielectric Fittings:

- 1. Install dielectric fittings in piping at connections of dissimilar metal piping and tubing.
- 2. Dielectric Fittings for NPS 2 (DN 50) and Smaller: Use dielectric unions.
- 3. Dielectric Fittings for NPS 2-1/2 to NPS 4 (DN 65 to DN 100): Use dielectric flanges.
- 4. Dielectric Fittings for NPS 5 (DN 125) and Larger: Use dielectric flange kits.

### 3.5 HANGER AND SUPPORT INSTALLATION

- A. Comply with requirements for seismic-restraint devices specified in Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment."
- B. Comply with requirements for pipe hanger and support devices and installation specified in Section 220529 "Hangers and Supports for Plumbing Piping and Equipment."
  - 1. Install carbon-steel pipe hangers for horizontal piping in noncorrosive environments.

2. Install stainless-steel pipe hangers for horizontal piping in corrosive environments.
  3. Install carbon-steel pipe support clamps for vertical piping in noncorrosive environments.
  4. Install stainless-steel pipe support clamps for vertical piping in corrosive environments.
  5. Vertical Piping: MSS Type 8 or Type 42, clamps.
  6. Install individual, straight, horizontal piping runs:
    - a. 100 Feet (30 m) and Less: MSS Type 1, adjustable, steel clevis hangers.
    - b. Longer Than 100 Feet (30 m): MSS Type 43, adjustable roller hangers.
    - c. Longer Than 100 Feet (30 m) if Indicated: MSS Type 49, spring cushion rolls.
  7. Multiple, Straight, Horizontal Piping Runs 100 Feet (30 m) or Longer: MSS Type 44, pipe rolls. Support pipe rolls on trapeze.
  8. Base of Vertical Piping: MSS Type 52, spring hangers.
- C. Support horizontal piping and tubing within 12 inches (300 mm) of each fitting, valve, and coupling.
- D. Support vertical piping and tubing at base and at each floor.
- E. Rod diameter may be reduced one size for double-rod hangers, with 3/8-inch (10-mm) minimum rods.
- F. Install hangers for cast-iron soil piping with the following maximum horizontal spacing and minimum rod diameters:
1. NPS 1-1/2 and NPS 2 (DN 40 and DN 50): 60 inches (1500 mm) with 3/8-inch (10-mm) rod.
  2. NPS 3 (DN 80): 60 inches (1500 mm) with 1/2-inch (13-mm) rod.
  3. NPS 4 and NPS 5 (DN 100 and DN 125): 60 inches (1500 mm) with 5/8-inch (16-mm) rod.
  4. NPS 6 and NPS 8 (DN 150 and DN 200): 60 inches (1500 mm) with 3/4-inch (19-mm) rod.
  5. NPS 10 and NPS 12 (DN 250 and DN 300): 60 inches (1500 mm) with 7/8-inch (22-mm) rod.
  6. Spacing for 10-foot (3-m) lengths may be increased to 10 feet (3 m). Spacing for fittings is limited to 60 inches (1500 mm).
- G. Install supports for vertical cast-iron soil piping every 15 feet (4.5 m).
- H. Install hangers for steel piping with the following maximum horizontal spacing and minimum rod diameters:
1. NPS 1-1/4 (DN 32): 84 inches (2100 mm) with 3/8-inch (10-mm) rod.
  2. NPS 1-1/2 (DN 40): 108 inches (2700 mm) with 3/8-inch (10-mm) rod.
  3. NPS 2 (DN 50): 10 feet (3 m) with 3/8-inch (10-mm) rod.
  4. NPS 2-1/2 (DN 65): 11 feet (3.4 m) with 1/2-inch (13-mm) rod.
  5. NPS 3 (DN 80): 12 feet (3.7 m) with 1/2-inch (13-mm) rod.
  6. NPS 4 and NPS 5 (DN 100 and DN 125): 12 feet (3.7 m) with 5/8-inch (16-mm) rod.

7. NPS 6 and NPS 8 (DN 150 and DN 200): 12 feet (3.7 m) with 3/4-inch (19-mm) rod.
8. NPS 10 and NPS 12 (DN 250 and DN 300): 12 feet (3.7 m) with 7/8-inch (22-mm) rod.

I. Install supports for vertical steel piping every 15 feet (4.5 m).

J. Install hangers for stainless-steel piping with the following maximum horizontal spacing and minimum rod diameters:

1. NPS 2 (DN 50): 84 inches (2100 mm) with 3/8-inch (10-mm) rod.
2. NPS 3 (DN 80): 96 inches (2400 mm) with 1/2-inch (13-mm) rod.
3. NPS 4 (DN 100): 108 inches (2700 mm) with 1/2-inch (13-mm) rod.
4. NPS 6 (DN 150): 10 feet (3 m) with 5/8-inch (16-mm) rod.

K. Install supports for vertical stainless-steel piping every 10 feet (3 m).

L. Install hangers for copper tubing with the following maximum horizontal spacing and minimum rod diameters:

1. NPS 1-1/4 (DN 32): 72 inches (1800 mm) with 3/8-inch (10-mm) rod.
2. NPS 1-1/2 and NPS 2 (DN 40 and DN 50): 96 inches (2400 mm) with 3/8-inch (10-mm) rod.
3. NPS 2-1/2 (DN 65): 108 inches (2700 mm) with 1/2-inch (13-mm) rod.
4. NPS 3 and NPS 5 (DN 80 and DN 125): 10 feet (3 m) with 1/2-inch (13-mm) rod.
5. NPS 6 (DN 150): 10 feet (3 m) with 5/8-inch (16-mm) rod.
6. NPS 8 (DN 200): 10 feet (3 m) with 3/4-inch (19-mm) rod.

M. Install supports for vertical copper tubing every 10 feet (3 m).

N. Install hangers for ABS and PVC piping with the following maximum horizontal spacing and minimum rod diameters:

1. NPS 1-1/2 and NPS 2 (DN 40 and DN 50): 48 inches (1200 mm) with 3/8-inch (10-mm) rod.
2. NPS 3 (DN 80): 48 inches (1200 mm) with 1/2-inch (13-mm) rod.
3. NPS 4 and NPS 5 (DN 100 and DN 125): 48 inches (1200 mm) with 5/8-inch (16-mm) rod.
4. NPS 6 and NPS 8 (DN 150 and DN 200): 48 inches (1200 mm) with 3/4-inch (19-mm) rod.
5. NPS 10 and NPS 12 (DN 250 and DN 300): 48 inches (1200 mm) with 7/8-inch (22-mm) rod.

O. Install supports for vertical ABS and PVC piping every 48 inches (1200 mm).

P. Support piping and tubing not listed above according to MSS SP-69 and manufacturer's written instructions.

### 3.6 CONNECTIONS

A. Drawings indicate general arrangement of piping, fittings, and specialties.

- B. Connect soil and waste piping to exterior sanitary sewerage piping. Use transition fitting to join dissimilar piping materials.
- C. Connect drainage and vent piping to the following:
  - 1. Plumbing Fixtures: Connect drainage piping in sizes indicated, but not smaller than required by plumbing code.
  - 2. Plumbing Fixtures and Equipment: Connect atmospheric vent piping in sizes indicated, but not smaller than required by authorities having jurisdiction.
  - 3. Plumbing Specialties: Connect drainage and vent piping in sizes indicated, but not smaller than required by plumbing code.
  - 4. Install test tees (wall cleanouts) in conductors near floor and floor cleanouts with cover flush with floor.
  - 5. Install horizontal backwater valves with cleanout cover flush with floor.
  - 6. Comply with requirements for backwater valves cleanouts and drains specified in Section 221319 "Sanitary Waste Piping Specialties."
  - 7. Equipment: Connect drainage piping as indicated. Provide shutoff valve if indicated and union for each connection. Use flanges instead of unions for connections NPS 2-1/2 (DN 65) and larger.
- D. Connect force-main piping to the following:
  - 1. Sanitary Sewer: To exterior force main.
  - 2. Sewage Pump: To sewage pump discharge.
- E. Where installing piping adjacent to equipment, allow space for service and maintenance of equipment.
- F. Make connections according to the following unless otherwise indicated:
  - 1. Install unions, in piping NPS 2 (DN 50) and smaller, adjacent to each valve and at final connection to each piece of equipment.
  - 2. Install flanges, in piping NPS 2-1/2 (DN 65) and larger, adjacent to flanged valves and at final connection to each piece of equipment.

### 3.7 IDENTIFICATION

- A. Identify exposed sanitary waste and vent piping. Comply with requirements for identification specified in Section 220553 "Identification for Plumbing Piping and Equipment."

### 3.8 FIELD QUALITY CONTROL

- A. During installation, notify authorities having jurisdiction at least 24 hours before inspection must be made. Perform tests specified below in presence of authorities having jurisdiction.
  - 1. Roughing-in Inspection: Arrange for inspection of piping before concealing or closing-in after roughing-in and before setting fixtures.

2. Final Inspection: Arrange for final inspection by authorities having jurisdiction to observe tests specified below and to ensure compliance with requirements.
- B. Reinspection: If authorities having jurisdiction find that piping will not pass test or inspection, make required corrections and arrange for reinspection.
- C. Reports: Prepare inspection reports and have them signed by authorities having jurisdiction.
- D. Test sanitary drainage and vent piping according to procedures of authorities having jurisdiction or, in absence of published procedures, as follows:
1. Test for leaks and defects in new piping and parts of existing piping that have been altered, extended, or repaired. If testing is performed in segments, submit separate report for each test, complete with diagram of portion of piping tested.
  2. Leave uncovered and unconcealed new, altered, extended, or replaced drainage and vent piping until it has been tested and approved. Expose work that was covered or concealed before it was tested.
  3. Roughing-in Plumbing Test Procedure: Test drainage and vent piping except outside leaders on completion of roughing-in. Close openings in piping system and fill with water to point of overflow, but not less than 10-foot head of water (30 kPa). From 15 minutes before inspection starts to completion of inspection, water level must not drop. Inspect joints for leaks.
  4. Finished Plumbing Test Procedure: After plumbing fixtures have been set and traps filled with water, test connections and prove they are gastight and watertight. Plug vent-stack openings on roof and building drains where they leave building. Introduce air into piping system equal to pressure of 1-inch wg (250 Pa). Use U-tube or manometer inserted in trap of water closet to measure this pressure. Air pressure must remain constant without introducing additional air throughout period of inspection. Inspect plumbing fixture connections for gas and water leaks.
  5. Repair leaks and defects with new materials and retest piping, or portion thereof, until satisfactory results are obtained.
  6. Prepare reports for tests and required corrective action.
- E. Test force-main piping according to procedures of authorities having jurisdiction or, in absence of published procedures, as follows:
1. Leave uncovered and unconcealed new, altered, extended, or replaced force-main piping until it has been tested and approved. Expose work that was covered or concealed before it was tested.
  2. Cap and subject piping to static-water pressure of 50 psig (345 kPa) above operating pressure, without exceeding pressure rating of piping system materials. Isolate test source and allow to stand for four hours. Leaks and loss in test pressure constitute defects that must be repaired.
  3. Repair leaks and defects with new materials and retest piping, or portion thereof, until satisfactory results are obtained.
  4. Prepare reports for tests and required corrective action.



3.9 CLEANING AND PROTECTION

- A. Clean interior of piping. Remove dirt and debris as work progresses.
- B. Protect drains during remainder of construction period to avoid clogging with dirt and debris and to prevent damage from traffic and construction work.
- C. Place plugs in ends of uncompleted piping at end of day and when work stops.
- D. Exposed ABS and PVC Piping: Protect plumbing vents exposed to sunlight with two coats of water-based latex paint.

3.10 PIPING SCHEDULE

- A. Flanges and unions may be used on aboveground pressure piping unless otherwise indicated.
- B. Aboveground, soil and waste piping NPS 4 (DN 100) and smaller shall be any of the following:
  - 1. Service class, cast-iron soil pipe and fittings; gaskets; and gasketed joints.
  - 2. Hubless, cast-iron soil pipe and fittings and solvent stack fittings; CISPI heavy-duty hubless-piping couplings; and coupled joints.
  - 3. Galvanized-steel pipe, drainage fittings, and threaded joints.
  - 4. Stainless-steel pipe and fittings, sealing rings, and gasketed joints.
  - 5. Copper DWV tube, copper drainage fittings, and soldered joints.
  - 6. Solid-wall ABS pipe, ABS socket fittings, and solvent-cemented joints.
  - 7. Solid-wall PVC pipe, PVC socket fittings, and solvent-cemented joints.
  - 8. Dissimilar Pipe-Material Couplings: Unshielded, nonpressure transition couplings.
- C. Aboveground, soil and waste piping NPS 5 (DN 125) and larger shall be any of the following:
  - 1. Service class, cast-iron soil pipe and fittings; gaskets; and gasketed joints.
  - 2. Hubless, cast-iron soil pipe and fittings and solvent stack fittings; CISPI heavy-duty hubless-piping couplings; and coupled joints.
  - 3. Galvanized-steel pipe, drainage fittings, and threaded joints.
  - 4. Stainless-steel pipe and fittings, sealing rings, and gasketed joints.
  - 5. Solid-wall PVC pipe, PVC socket fittings, and solvent-cemented joints.
  - 6. Dissimilar Pipe-Material Couplings: Unshielded, nonpressure transition couplings.
- D. Aboveground, vent piping NPS 4 (DN 100) and smaller shall be any of the following:
  - 1. Service class, cast-iron soil pipe and fittings; gaskets; and gasketed joints.
  - 2. Hubless, cast-iron soil pipe and fittings; CISPI heavy-duty hubless-piping couplings; and coupled joints.
  - 3. Galvanized-steel pipe, drainage fittings, and threaded joints.
  - 4. Stainless-steel pipe and fittings gaskets, and gasketed joints.
  - 5. Copper DWV tube, copper drainage fittings, and soldered joints.

- a. Option for Vent Piping, NPS 2-1/2 and NPS 3-1/2 (DN 65 and DN 90): Hard copper tube, Type M (Type C); copper pressure fittings; and soldered joints.
  6. Solid-wall ABS pipe, ABS socket fittings, and solvent-cemented joints.
  7. Solid-wall PVC pipe, PVC socket fittings, and solvent-cemented joints.
  8. Dissimilar Pipe-Material Couplings: Unshielded, nonpressure transition couplings.
- E. Underground, soil, waste, and vent piping NPS 4 (DN 100) and smaller shall be any of] the following:
1. Extra Heavy Service class, cast-iron soil piping; gaskets; and gasketed joints.
  2. Hubless, cast-iron soil pipe and fittings; CISPI heavy-duty cast-iron hubless-piping couplings; and coupled joints.
  3. Stainless-steel pipe and fittings, gaskets, and gasketed joints.
  4. Solid wall ABS pipe, ABS socket fittings, and solvent-cemented joints.
  5. Solid wall PVC pipe, PVC socket fittings, and solvent-cemented joints.
  6. Dissimilar Pipe-Material Couplings: Unshielded, nonpressure transition couplings.
- F. Underground, soil and waste piping NPS 5 (DN 125) and larger shall be any of the following:
1. Extra Heavy Service class, cast-iron soil piping; gaskets; and gasketed joints.
  2. Hubless, cast-iron soil pipe and fittings; CISPI heavy-duty cast-iron hubless-piping couplings; coupled joints.
  3. Solid-wall PVC pipe; PVC socket fittings; and solvent-cemented joints.
  4. Dissimilar Pipe-Material Couplings: Unshielded, nonpressure transition couplings.
- G. Aboveground sanitary-sewage force mains NPS 2-1/2 to NPS 6 (DN 65 to DN 150) shall be any of the following:
1. Hard copper tube, Type L (Type B); copper pressure fittings; and soldered joints.
  2. Galvanized-steel pipe, pressure fittings, and threaded joints.
  3. Grooved-end, galvanized-steel pipe; grooved-joint, galvanized-steel-pipe appurtenances; and grooved joints.
- H. Underground sanitary-sewage force mains NPS 5 (DN 125) and larger shall be any of the following:
1. Hard copper tube, Type L (Type B); wrought-copper pressure fittings; and soldered joints.
  2. Ductile-iron, mechanical-joint piping and mechanical joints.
  3. Ductile-iron, push-on-joint piping and push-on joints.
  4. Ductile-iron, grooved-joint piping and grooved joints.
  5. Pressure transition couplings if dissimilar pipe materials.

END OF SECTION 221316

SECTION 221319 - SANITARY WASTE PIPING SPECIALTIES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Cleanouts.
2. Floor drains.
3. Trench drains.
4. Channel drainage systems.
5. Air-admittance valves.
6. Roof flashing assemblies.
7. Through-penetration firestop assemblies.
8. Miscellaneous sanitary drainage piping specialties.
9. Flashing materials.
10. Grease interceptors.
11. Oil interceptors.
12. Solids interceptors.

B. Related Requirements:

1. Section 221423 "Storm Drainage Piping Specialties" for storm drainage piping inside the building, drainage piping specialties, and drains.
2. Section 224300 "Medical Plumbing Fixtures" for plaster sink interceptors.
3. Section 334100 "Storm Utility Drainage Piping" for storm draining piping and piping specialties outside the building.

1.3 DEFINITIONS

- A. ABS: Acrylonitrile-butadiene-styrene plastic.
- B. FOG: Fats, oils, and greases.
- C. FRP: Fiberglass-reinforced plastic.
- D. HDPE: High-density polyethylene plastic.
- E. PE: Polyethylene plastic.
- F. PP: Polypropylene plastic.

- G. PVC: Polyvinyl chloride plastic.

#### 1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated. Include rated capacities, operating characteristics, and accessories for the following:
  - 1. FOG disposal systems.
  - 2. Grease interceptors.
  - 3. Grease removal devices.
  - 4. Oil interceptors.
- B. Shop Drawings: Show fabrication and installation details for frost-resistant vent terminals.
  - 1. Wiring Diagrams: Power, signal, and control wiring.

#### 1.5 INFORMATIONAL SUBMITTALS

- A. Manufacturer Seismic Qualification Certification: Submit certification that grease interceptors, accessories, and components will withstand seismic forces defined in Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment." Include the following:
  - 1. Basis for Certification: Indicate whether withstand certification is based on actual test of assembled components or on calculation.
    - a. The term "withstand" means "the unit will remain in place without separation of any parts from the device when subjected to the seismic forces specified."
    - b. The term "withstand" means "the unit will remain in place without separation of any parts from the device when subjected to the seismic forces specified and the unit will be fully operational after the seismic event."
  - 2. Dimensioned Outline Drawings of Equipment Unit: Identify center of gravity and locate and describe mounting and anchorage provisions.
  - 3. Detailed description of equipment anchorage devices on which the certification is based and their installation requirements.
- B. Field quality-control reports.

#### 1.6 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For drainage piping specialties to include in emergency, operation, and maintenance manuals.

#### 1.7 QUALITY ASSURANCE

- A. Drainage piping specialties shall bear label, stamp, or other markings of specified testing agency.

- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- C. Comply with NSF 14, "Plastics Piping Components and Related Materials," for plastic sanitary piping specialty components.

#### 1.8 COORDINATION

- A. Coordinate size and location of concrete bases. Cast anchor-bolt inserts into bases. Concrete, reinforcement, and formwork requirements are specified in Section 033000 "Cast-in-Place Concrete."
- B. Coordinate size and location of roof penetrations.

#### 1.9 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials described below that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Cultures: Provide 1-gal. (3.8-L) bottles of bacteria culture recommended by manufacturer of FOG disposal systems equal to 200 percent of amount installed, but no fewer than 2 1-gal. (3.8-L) bottles.

### PART 2 - PRODUCTS

#### 2.1 CLEANOUTS

- A. Exposed Metal Cleanouts:
  - 1. ASME A112.36.2M, Cast-Iron Cleanouts:
    - a. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:
      - 1) Josam Company.
      - 2) Smith, Jay R. Mfg. Co.
      - 3) Watts; a Watts Water Technologies company.
      - 4) Zurn Industries, LLC.
  - 2. ASME A112.3.1, Stainless-Steel Cleanouts:
    - a. Manufacturers: Subject to compliance with requirements, provide products by the following:
      - 1) Josam Company.

3. Standard: ASME A112.36.2M for cast iron ASME A112.3.1 for stainless steel for cleanout test tee.
4. Size: Same as connected drainage piping
5. Body Material: Hub-and-spigot, cast-iron soil pipe T-branch Hubless, cast-iron soil pipe test tee as required to match connected piping.
6. Closure: Countersunk Countersunk or raised-head Raised-head, brass cast-iron plug.
7. Closure Plug Size: Same as or not more than one size smaller than cleanout size.
8. Closure: Stainless-steel plug with seal.

B. Metal Floor Cleanouts:

1. ASME A112.36.2M, Cast-Iron Cleanouts:
  - a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - 1) Josam Company.
    - 2) Smith, Jay R. Mfg. Co.
    - 3) Watts; a Watts Water Technologies company.
    - 4) Zurn Industries, LLC.
2. ASME A112.36.2M, Stainless-Steel Cleanouts:
  - a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - 1) Josam Company.
    - 2) Smith, Jay R. Mfg. Co.
    - 3) Zurn Industries, LLC.
3. ASME A112.3.1, Stainless-Steel Cleanouts:
  - a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - 1) Josam Company.
    - 2) Zurn Industries, LLC.
4. Standard: ASME A112.36.2M for adjustable housing cast-iron soil pipe with cast-iron ferrule heavy-duty, adjustable housing threaded, adjustable housing cleanout.
5. Size: Same as connected branch.
6. Type: Adjustable housing Cast-iron soil pipe with cast-iron ferrule Heavy-duty, adjustable housing Threaded, adjustable housing.
7. Body or Ferrule: Cast iron Stainless steel.
8. Clamping Device: Required.
9. Outlet Connection: Inside callk Spigot Threaded.
10. Closure: Brass plug with straight threads and gasket Brass plug with tapered threads Cast-iron plug.
11. Adjustable Housing Material: Cast iron with threads set-screws or other device.

12. Frame and Cover Material and Finish: Nickel-bronze, copper alloy Painted cast iron  
Polished bronze Stainless steel.
13. Frame and Cover Shape: Round.
14. Top Loading Classification: Heavy Medium Duty.
15. Riser: ASTM A 74, Service class, cast-iron drainage pipe fitting and riser to cleanout.
16. Standard: ASME A112.3.1.
17. Size: Same as connected branch.
18. Housing: Stainless steel.
19. Closure: Stainless steel with seal.
20. Riser: Stainless-steel drainage pipe fitting to cleanout.

C. Cast-Iron Wall Cleanouts:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Josam Company.
  - b. Smith, Jay R. Mfg. Co.
  - c. Watts; a Watts Water Technologies company.
  - d. Zurn Industries, LLC.
2. Standard: ASME A112.36.2M. Include wall access.
3. Size: Same as connected drainage piping.
4. Body: Hub-and-spigot, cast-iron soil pipe T-branch Hubless, cast-iron soil pipe test tee as required to match connected piping.
5. Closure: Countersunk Countersunk or raised-head Raised-head, drilled-and-threaded brass cast-iron plug.
6. Closure Plug Size: Same as or not more than one size smaller than cleanout size.
7. Wall Access: Round, deep, chrome-plated bronze flat, chrome-plated brass or stainless-steel cover plate with screw.
8. Wall Access: Round, nickel-bronze, copper-alloy, or stainless-steel wall-installation frame and cover.

2.2 FLOOR DRAINS

A. Cast-Iron Floor Drains:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Smith, Jay R. Mfg. Co.
  - b. Watts; a Watts Water Technologies company.
  - c. Zurn Industries, LLC.
2. Standard: ASME A112.6.3.
3. Pattern: Floor Sanitary drain.
4. Body Material: Gray iron.

5. Seepage Flange: Required.
6. Anchor Flange: Required.
7. Clamping Device: Required.
8. Outlet: Bottom.
9. Backwater Valve: Drain-outlet type Integral, ASME A112.14.1, swing-check type.
10. Coating on Interior and Exposed Exterior Surfaces: Not required.
11. Top or Strainer Material: Bronze.
12. Top of Body and Strainer Finish: Polished bronze.
13. Top Shape: Round Square.
14. Dimensions of Top or Strainer: See floor plans.
15. Top Loading Classification: Medium Duty.
16. Funnel: Not required.
17. Inlet Fitting: Gray iron, with threaded inlet and threaded or spigot outlet, and trap-seal primer valve connection.
18. Trap Material: Cast iron.
19. Trap Pattern: Standard P-trap.
20. Trap Features: Not required.

B. Stainless-Steel Floor Drains:

1. ASME A112.3.1, Stainless-Steel Floor Drains:
  - a. Manufacturers: Subject to compliance with requirements, provide products by the following:
    - 1) Josam Company.
    - 2) JR Smith.
2. ASME A112.6.3, Stainless-Steel Floor Drains:
  - a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - 1) Josam Company.
    - 2) Smith, Jay R. Mfg. Co.
    - 3) Zurn Industries, LLC.
3. Standard: ASME A112.3.1.
4. Outlet: Bottom.
5. Top or Strainer Material: Stainless steel.
6. Top Shape: Square.
7. Dimensions of Top or Strainer: **See floor plans.**
8. Seepage Flange: Required.
9. Anchor Flange: Required.
10. Clamping Device: Required.
11. Trap-Primer Connection: Required.
12. Trap Material: Cast iron.
13. Trap Pattern: Standard P-trap.



## 2.3 TRENCH DRAINS

### A. Trench Drains:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Josam Company.
  - b. Smith, Jay R. Mfg. Co.
  - c. Zurn Industries, LLC.
2. Standard: ASME A112.6.3 for trench drains.
3. Material: Ductile or gray iron.
4. Flange: Anchor.
5. Clamping Device: Required.
6. Outlet: Bottom.
7. Grate Material: Ductile iron or gray iron.
8. Grate Finish: Not required.
9. Dimensions of Frame and Grate: See floor plans.
10. Top Loading Classification: Medium Duty.
11. Trap Material: Cast iron.
12. Trap Pattern: Standard P-trap.

## 2.4 ROOF FLASHING ASSEMBLIES

### A. Roof Flashing Assemblies:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Acorn Engineering Company.
  - b. Zurn Industries, LLC.
2. Description: Manufactured assembly made of 4.0-lb/sq. ft. (20-kg/sq. m), 0.0625-inch- (1.6-mm-) thick, lead flashing collar and skirt extending at least 6 inches (150 mm) from pipe, with galvanized-steel boot reinforcement and counterflashing fitting.
  - a. Open-Top Vent Cap: Without cap.
  - b. Low-Silhouette Vent Cap: With vandal-proof vent cap.
  - c. Extended Vent Cap: With field-installed, vandal-proof vent cap.

## 2.5 THROUGH-PENETRATION FIRESTOP ASSEMBLIES

### A. Through-Penetration Firestop Assemblies:

1. **<Double click here to find, evaluate, and insert list of manufacturers and products.>**
2. Standard: UL 1479 assembly of sleeve and stack fitting with firestopping plug.

3. Size: Same as connected soil, waste, or vent stack.
4. Sleeve: Molded PVC plastic, of length to match slab thickness and with integral nailing flange on one end for installation in cast-in-place concrete slabs.
5. Stack Fitting: ASTM A 48/A 48M, gray-iron, hubless-pattern, wye branch with neoprene O-ring at base and gray-iron plug in thermal-release harness. Include PVC protective cap for plug.
6. Special Coating: Corrosion resistant on interior of fittings.

## 2.6 MISCELLANEOUS SANITARY DRAINAGE PIPING SPECIALTIES

### A. Floor-Drain, Trap-Seal Primer Fittings:

1. Description: Cast iron, with threaded inlet and threaded or spigot outlet, and trap-seal primer valve connection.
2. Size: Same as floor drain outlet with NPS 1/2 (DN 15) side inlet.

### B. Air-Gap Fittings:

1. Standard: ASME A112.1.2, for fitting designed to ensure fixed, positive air gap between installed inlet and outlet piping.
2. Body: Bronze or cast iron.
3. Inlet: Opening in top of body.
4. Outlet: Larger than inlet.
5. Size: Same as connected waste piping and with inlet large enough for associated indirect waste piping.

### C. Sleeve Flashing Device:

1. Description: Manufactured, cast-iron fitting, with clamping device, that forms sleeve for pipe floor penetrations of floor membrane. Include galvanized-steel pipe extension in top of fitting that will extend 1 inch (25 mm) above finished floor and galvanized-steel pipe extension in bottom of fitting that will extend through floor slab.
2. Size: As required for close fit to riser or stack piping.

### D. Vent Caps:

1. Description: Cast-iron body with threaded or hub inlet and vandal-proof design. Include vented hood and setscrews to secure to vent pipe.
2. Size: Same as connected stack vent or vent stack.

### E. Frost-Resistant Vent Terminals:

1. Description: Manufactured or shop-fabricated assembly constructed of copper, lead-coated copper, or galvanized steel.
2. Design: To provide 1-inch (25-mm) enclosed air space between outside of pipe and inside of flashing collar extension, with counterflashing.

### F. Expansion Joints:

1. Standard: ASME A112.21.2M.
2. Body: Cast iron with bronze sleeve, packing, and gland.
3. End Connections: Matching connected piping.
4. Size: Same as connected soil, waste, or vent piping.

## 2.7 FLASHING MATERIALS

- A. Lead Sheet: ASTM B 749, Type L51121, copper bearing, with the following minimum weights and thicknesses, unless otherwise indicated:
  1. General Use: 4.0-lb/sq. ft. (20-kg/sq. m), 0.0625-inch (1.6-mm) thickness.
  2. Vent Pipe Flashing: 3.0-lb/sq. ft. (15-kg/sq. m), 0.0469-inch (1.2-mm) thickness.
  3. Burning: 6-lb/sq. ft. (30-kg/sq. m), 0.0938-inch (2.4-mm) thickness.
- B. Copper Sheet: ASTM B 152/B 152M, of the following minimum weights and thicknesses, unless otherwise indicated:
  1. General Applications: 12 oz./sq. ft. (3.7 kg/sq. m or 0.41-mm thickness).
  2. Vent Pipe Flashing: 8 oz./sq. ft. (2.5 kg/sq. m or 0.27-mm thickness).
- C. Zinc-Coated Steel Sheet: ASTM A 653/A 653M, with 0.20 percent copper content and 0.04-inch (1.01-mm) minimum thickness, unless otherwise indicated. Include G90 (Z275) hot-dip galvanized, mill-phosphatized finish for painting if indicated.
- D. Elastic Membrane Sheet: ASTM D 4068, flexible, chlorinated polyethylene, 40-mil (1.01-mm) minimum thickness.
- E. Fasteners: Metal compatible with material and substrate being fastened.
- F. Metal Accessories: Sheet metal strips, clamps, anchoring devices, and similar accessory units required for installation; matching or compatible with material being installed.
- G. Solder: ASTM B 32, lead-free alloy.
- H. Bituminous Coating: SSPC-Paint 12, solvent-type, bituminous mastic.

## 2.8 GREASE INTERCEPTORS

- A. Grease Interceptors:
  1. Cast-Iron or Steel Grease Interceptors:
    - a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
      - 1) Jensen Precast.
      - 2) Rockford Sanitary Systems, Inc.
      - 3) Watts; a Watts Water Technologies company.

4) Zurn Industries, LLC.

2.9 MOTORS

- A. General requirements for motors are specified in Section 220513 "Common Motor Requirements for Plumbing Equipment."
1. Motor Sizes: Minimum size as indicated. If not indicated, large enough so driven load will not require motor to operate in service factor range above 1.0.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Equipment Mounting:
1. Install grease interceptors on cast-in-place concrete equipment base(s). Comply with requirements for equipment bases and foundations specified in Section 033000 "Cast-in-Place Concrete."
  2. Comply with requirements for vibration isolation and seismic control devices specified in Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment."
  3. Comply with requirements for vibration isolation devices specified in Section 220548.13 "Vibration Controls for Plumbing Piping and Equipment."
- B. Install backwater valves in building drain piping. For interior installation, provide cleanout deck plate flush with floor and centered over backwater valve cover, and of adequate size to remove valve cover for servicing.
- C. Install cleanouts in aboveground piping and building drain piping according to the following, unless otherwise indicated:
1. Size same as drainage piping up to NPS 4 (DN 100). Use NPS 4 (DN 100) for larger drainage piping unless larger cleanout is indicated.
  2. Locate at each change in direction of piping greater than 45 degrees.
  3. Locate at minimum intervals of 50 feet (15 m) for piping NPS 4 (DN 100) and smaller and 100 feet (30 m) for larger piping.
  4. Locate at base of each vertical soil and waste stack.
- D. For floor cleanouts for piping below floors, install cleanout deck plates with top flush with finished floor.
- E. For cleanouts located in concealed piping, install cleanout wall access covers, of types indicated, with frame and cover flush with finished wall.
- F. Install floor drains at low points of surface areas to be drained. Set grates of drains flush with finished floor, unless otherwise indicated.

1. Position floor drains for easy access and maintenance.
  2. Set floor drains below elevation of surrounding finished floor to allow floor drainage. Set with grates depressed according to the following drainage area radii:
    - a. Radius, 30 Inches (750 mm) or Less: Equivalent to 1 percent slope, but not less than 1/4-inch (6.35-mm) total depression.
    - b. Radius, 30 to 60 Inches (750 to 1500 mm): Equivalent to 1 percent slope.
    - c. Radius, 60 Inches (1500 mm) or Larger: Equivalent to 1 percent slope, but not greater than 1-inch (25-mm) total depression.
  3. Install floor-drain flashing collar or flange so no leakage occurs between drain and adjoining flooring. Maintain integrity of waterproof membranes where penetrated.
  4. Install individual traps for floor drains connected to sanitary building drain, unless otherwise indicated.
- G. Install trench drains at low points of surface areas to be drained. Set grates of drains flush with finished surface, unless otherwise indicated.
- H. Assemble and install ASME A112.3.1, stainless-steel channel drainage systems according to ASME A112.3.1. Install on support devices so that top will be flush with surface.
- I. Assemble non-ASME A112.3.1, stainless-steel channel drainage system components according to manufacturer's written instructions. Install on support devices so that top will be flush with adjacent surface.
- J. Assemble FRP channel drainage system components according to manufacturer's written instructions. Install on support devices so that top will be flush with adjacent surface.
- K. Assemble plastic channel drainage system components according to manufacturer's written instructions. Install on support devices so that top will be flush with adjacent surface.
- L. Install fixture air-admittance valves on fixture drain piping.
- M. Install stack air-admittance valves at top of stack vent and vent stack piping.
- N. Install air-admittance-valve wall boxes recessed in wall.
- O. Install roof flashing assemblies on sanitary stack vents and vent stacks that extend through roof.
- P. Install flashing fittings on sanitary stack vents and vent stacks that extend through roof.
- Q. Install through-penetration firestop assemblies in plastic conductors and stacks at floor penetrations.
- R. Assemble open drain fittings and install with top of hub 1 inch (25 mm) above floor.
- S. Install deep-seal traps on floor drains and other waste outlets, if indicated.
- T. Install floor-drain, trap-seal primer fittings on inlet to floor drains that require trap-seal primer connection.

1. Exception: Fitting may be omitted if trap has trap-seal primer connection.
  2. Size: Same as floor drain inlet.
- U. Install air-gap fittings on draining-type backflow preventers and on indirect-waste piping discharge into sanitary drainage system.
- V. Install sleeve flashing device with each riser and stack passing through floors with waterproof membrane.
- W. Install vent caps on each vent pipe passing through roof.
- X. Install frost-resistant vent terminals on each vent pipe passing through roof. Maintain 1-inch (25-mm) clearance between vent pipe and roof substrate.
- Y. Install expansion joints on vertical stacks and conductors. Position expansion joints for easy access and maintenance.
- Z. Install frost-proof vent caps on each vent pipe passing through roof. Maintain 1-inch (25-mm) clearance between vent pipe and roof substrate.
- AA. Assemble components of FOG disposal systems and install on floor. Install trap, vent, fresh-air inlet, and flow-control fitting according to authorities having jurisdiction. Install shelf fastened to reinforcement in wall construction and adjacent to unit, unless otherwise indicated. Install culture bottle, culture metering pump, timer, and control on shelf. Install tubing between culture bottle, metering pump, and chamber.
- BB. Install grease interceptors, including trapping, venting, and flow-control fitting, according to authorities having jurisdiction and with clear space for servicing.
1. Above-Floor Installation: Set unit with bottom resting on floor, unless otherwise indicated.
  2. Flush with Floor Installation: Set unit and extension, if required, with cover flush with finished floor.
  3. Recessed Floor Installation: Set unit in receiver housing having bottom or cradle supports, with receiver housing cover flush with finished floor.
  4. Install cleanout immediately downstream from interceptors not having integral cleanout on outlet.
- CC. Install grease removal devices on floor. Install trap, vent, and flow-control fitting according to authorities having jurisdiction. Install control panel adjacent to unit, unless otherwise indicated.
- DD. Install oil interceptors, including trapping, venting, and flow-control fitting, according to authorities having jurisdiction and with clear space for servicing. Coordinate oil-interceptor storage tank and gravity drain with Section 231113 "Facility Fuel-Oil Piping."
- EE. Install solids interceptors with cleanout immediately downstream from interceptors that do not have integral cleanout on outlet. Install trap on interceptors that do not have integral trap and are connected to sanitary drainage and vent systems.
- FF. Install wood-blocking reinforcement for wall-mounting-type specialties.

- GG. Install traps on plumbing specialty drain outlets. Omit traps on indirect wastes unless trap is indicated.

### 3.2 CONNECTIONS

- A. Comply with requirements in Section 221316 "Sanitary Waste and Vent Piping" for piping installation requirements. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Install piping adjacent to equipment to allow service and maintenance.
- C. FOG Disposal Systems: Connect inlet and outlet to unit, connect flow-control fitting and fresh-air inlet piping to unit inlet piping, and connect vent piping between trap and media chamber. Connect electrical power.
- D. Grease Interceptors: Connect inlet and outlet to unit, and connect flow-control fitting and vent to unit inlet piping. Install valve on outlet of automatic drawoff-type unit.
- E. Grease Removal Devices: Connect controls, electrical power, factory-furnished accessories, and inlet, outlet, and vent piping to unit.
- F. Oil Interceptors: Connect inlet, outlet, vent, and gravity drawoff piping to unit; flow-control fitting and vent to unit inlet piping; and gravity drawoff and suction piping to oil storage tank.
- G. Ground equipment according to Section 260526 "Grounding and Bonding for Electrical Systems."
- H. Connect wiring according to Section 260519 "Low-Voltage Electrical Power Conductors and Cables."

### 3.3 FLASHING INSTALLATION

- A. Fabricate flashing from single piece unless large pans, sumps, or other drainage shapes are required. Join flashing according to the following if required:
  - 1. Lead Sheets: Burn joints of lead sheets 6.0-lb/sq. ft. (30-kg/sq. m), 0.0938-inch (2.4-mm) thickness or thicker. Solder joints of lead sheets 4.0-lb/sq. ft. (20-kg/sq. m), 0.0625-inch (1.6-mm) thickness or thinner.
  - 2. Copper Sheets: Solder joints of copper sheets.
- B. Install sheet flashing on pipes, sleeves, and specialties passing through or embedded in floors and roofs with waterproof membrane.
  - 1. Pipe Flashing: Sleeve type, matching pipe size, with minimum length of 10 inches (250 mm), and skirt or flange extending at least 8 inches (200 mm) around pipe.
  - 2. Sleeve Flashing: Flat sheet, with skirt or flange extending at least 8 inches (200 mm) around sleeve.

3. Embedded Specialty Flashing: Flat sheet, with skirt or flange extending at least 8 inches (200 mm) around specialty.
- C. Set flashing on floors and roofs in solid coating of bituminous cement.
- D. Secure flashing into sleeve and specialty clamping ring or device.
- E. Install flashing for piping passing through roofs with counterflashing or commercially made flashing fittings, according to Section 076200 "Sheet Metal Flashing and Trim."
- F. Extend flashing up vent pipe passing through roofs and turn down into pipe, or secure flashing into cast-iron sleeve having calking recess.
- G. Fabricate and install flashing and pans, sumps, and other drainage shapes.

### 3.4 LABELING AND IDENTIFYING

- A. Equipment Nameplates and Signs: Install engraved plastic-laminate equipment nameplate or sign on or near each of the following:
  1. FOG disposal systems.
  2. Grease interceptors.
  3. Grease removal devices.
  4. Oil interceptors.
  5. Solids interceptors.
- B. Distinguish among multiple units, inform operator of operational requirements, indicate safety and emergency precautions, and warn of hazards and improper operations, in addition to identifying unit. Nameplates and signs are specified in Section 220553 "Identification for Plumbing Piping and Equipment."

### 3.5 FIELD QUALITY CONTROL

- A. Perform tests and inspections and prepare test reports.
  1. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect field-assembled and their installation, including piping and electrical connections, and to assist in testing.
- B. Tests and Inspections:
  1. Leak Test: After installation, charge system and test for leaks. Repair leaks and retest until no leaks exist.
  2. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.



3.6 PROTECTION

- A. Protect drains during remainder of construction period to avoid clogging with dirt or debris and to prevent damage from traffic or construction work.
- B. Place plugs in ends of uncompleted piping at end of each day or when work stops.

3.7 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain. Refer to Section 017900 "Demonstration and Training."

END OF SECTION 221319

SECTION 221423 - STORM DRAINAGE PIPING SPECIALTIES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Roof drains.
  - 2. Miscellaneous storm drainage piping specialties.
  - 3. Cleanouts.
  - 4. Backwater valves.
  - 5. Trench drains.
  - 6. Channel drainage systems.
  - 7. Through-penetration firestop assemblies.
  - 8. Flashing materials.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.

1.4 QUALITY ASSURANCE

- A. Drainage piping specialties shall bear label, stamp, or other markings of specified testing agency.

PART 2 - PRODUCTS

2.1 METAL ROOF DRAINS

- A. Cast-Iron, Medium-Sump, General-Purpose Roof Drains:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. MIFAB, Inc.
    - b. Smith, Jay R. Mfg. Co.
    - c. Tyler Pipe; a subsidiary of McWane Inc.

- d. Watts; a Watts Water Technologies company.
- e. Zurn Industries, LLC.
- 2. Standard: ASME A112.6.4, for general-purpose roof drains.
- 3. Body Material: Cast iron.
- 4. Dimension of Body: 8- to 12-inch (203- to 305-mm) diameter.
- 5. Combination Flashing Ring and Gravel Stop: Required.
- 6. Flow-Control Weirs: Not required.
- 7. Outlet: Bottom.
- 8. Extension Collars: Not required.
- 9. Underdeck Clamp: Required.
- 10. Expansion Joint: Required.
- 11. Sump Receiver Plate: Not required.
- 12. Dome Material: Aluminum.
- 13. Wire Mesh: Stainless steel or brass over dome.
- 14. Perforated Gravel Guard: Stainless steel.
- 15. Vandal-Proof Dome: Required.
- 16. Water Dam: 2 inches (51 mm) high.

B. Metal, MISCELLANEOUS STORM DRAINAGE PIPING SPECIALTIES

C. Downspout Adaptors:

- 1. Description: Manufactured, gray-iron casting, for attaching to horizontal-outlet, parapet roof drain and to exterior, sheet metal downspout.
- 2. Size: Inlet size to match parapet drain outlet.

D. Downspout Boots:

- 1. Description: Manufactured, ASTM A 48/A 48M, gray-iron casting, with strap or ears for attaching to building; NPS 4 (DN 100) outlet; and shop-applied bituminous coating.
- 2. Size: Inlet size to match downspout and NPS 4 (DN 100) outlet.

E. Conductor Nozzles:

- 1. Description: Bronze body with threaded inlet and bronze wall flange with mounting holes.
- 2. Size: Same as connected conductor.

2.2 CLEANOUTS

A. Floor Cleanouts:

- 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Smith, Jay R. Mfg. Co.
  - b. Tyler Pipe; a subsidiary of McWane Inc.
  - c. Watts; a Watts Water Technologies company.

- d. Zurn Industries, LLC.
2. Standard: ASME A112.36.2M, for adjustable housing cleanouts.
3. Size: Same as connected branch.
4. Type: Adjustable housing.
5. Body or Ferrule Material: Cast iron.
6. Clamping Device: Not required.
7. Outlet Connection: Inside calk.
8. Closure: Brass plug with straight threads and gasket.
9. Adjustable Housing Material: Cast iron with threads.
10. Frame and Cover Material and Finish: Nickel-bronze, copper alloy.
11. Frame and Cover Shape: Round.
12. Top-Loading Classification: Extra-Heavy Duty.
13. Riser: ASTM A 74, Extra-Heavy class, cast-iron drainage pipe fitting and riser to cleanout.

B. Test Tees:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. MIFAB, Inc.
  - b. Smith, Jay R. Mfg. Co.
  - c. Tyler Pipe; a subsidiary of McWane Inc.
  - d. Watts; a Watts Water Technologies company.
  - e. Zurn Industries, LLC.
2. Standard: ASME A112.36.2M and ASTM A 74, ASTM A 888, or CISPI 301, for cleanout test tees.
3. Size: Same as connected drainage piping.
4. Body Material: Hub-and-spigot, cast-iron soil-pipe T-branch or hubless, cast-iron soil-pipe test tee as required to match connected piping.
5. Closure Plug: Countersunk, brass.
6. Closure Plug Size: Same as or not more than one size smaller than cleanout size.

C. Wall Cleanouts:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. MIFAB, Inc.
  - b. Smith, Jay R. Mfg. Co.
  - c. Tyler Pipe; a subsidiary of McWane Inc.
  - d. Watts; a Watts Water Technologies company.
  - e. Zurn Industries, LLC.
2. Standard: ASME A112.36.2M, for cleanouts. Include wall access.
3. Size: Same as connected drainage piping.
4. Body Material: Hubless, cast-iron soil-pipe test tee as required to match connected piping.
5. Closure: Countersunk, brass plug.
6. Closure Plug Size: Same as or not more than one size smaller than cleanout size.
7. Wall Access: Round, deep, chrome-plated bronze cover plate with screw.

8. Wall Access: Round, nickel-bronze, copper-alloy, or stainless-steel wall-installation frame and cover.

D. Plastic Floor Cleanouts:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. IPS Corporation.
  - b. Zurn Industries, LLC.
2. Size: Same as connected branch.
3. Body Material: PVC.
4. Closure Plug: PVC.
5. Riser: Drainage pipe fitting and riser to cleanout of same material as drainage piping.

2.3 BACKWATER VALVES

A. Cast-Iron, Horizontal Backwater Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. MIFAB, Inc.
  - b. Smith, Jay R. Mfg. Co.
  - c. Tyler Pipe; a subsidiary of McWane Inc.
  - d. Watts; a Watts Water Technologies company.
  - e. Zurn Industries, LLC.
2. Standard: ASME A112.14.1, for backwater valves.
3. Size: Same as connected piping.
4. Body Material: Cast iron.
5. Cover: Cast iron with bolted or threaded access check valve.
6. End Connections: hubless.
7. Check Valve: Removable, bronze, swing check, factory assembled or field modified to hang closed.
8. Extension: ASTM A 74, Service class; full-size, cast-iron soil-pipe extension to field-installed cleanout at floor; replaces backwater valve cover.

B. Cast-Iron, Drain-Outlet Backwater Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Smith, Jay R. Mfg. Co.
  - b. Watts; a Watts Water Technologies company.
  - c. Zurn Industries, LLC.
2. Size: Same as floor drain outlet.
3. Body Material: Cast iron or bronze made for vertical installation in bottom outlet of floor drain.

4. Check Valve: Removable ball float.
5. Inlet: Threaded.
6. Outlet: Threaded or spigot.

C. Plastic, Horizontal Backwater Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. IPS Corporation.
  - b. Oatey.
  - c. Zurn Industries, LLC.
2. Standard: ASME A112.14.1, for backwater valves.
3. Size: Same as connected piping.
4. Body Material: ABS.
5. Cover: Same material as body with threaded access to check valve.
6. Check Valve: Removable swing check.
7. End Connections: Socket type.

2.4 TRENCH DRAINS

A. Trench Drains:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. MIFAB, Inc.
  - b. Smith, Jay R. Mfg. Co.
  - c. Tyler Pipe; a subsidiary of McWane Inc.
  - d. Watts; a Watts Water Technologies company.
  - e. Zurn Industries, LLC.
2. Standard: ASME A112.6.3, for trench drains.
3. Body Material: Cast iron.
4. Flange: Anchor.
5. Clamping Device: Not required.
6. Outlet: Bottom.
7. Grate Material: Ductile iron.
8. Grate Finish: Painted.
9. Dimensions of Frame and Grate: .
10. Top-Loading Classification: Extra-Heavy Duty.

2.5 FLASHING MATERIALS

- A. Copper Sheet: ASTM B 152/B 152M, 12 oz./sq. ft. (3.7 kg/sq. m or 0.41-mm thickness).
- B. Zinc-Coated Steel Sheet: ASTM A 653/A 653M, with 0.20 percent copper content and 0.04-inch (1.01-mm) minimum thickness unless otherwise indicated. Include G90 (Z275) hot-dip galvanized, mill-phosphatized finish for painting if indicated.

- C. Elastic Membrane Sheet: ASTM D 4068, flexible, chlorinated polyethylene, 40-mil (1.01-mm) minimum thickness.
- D. Fasteners: Metal compatible with material and substrate being fastened.
- E. Metal Accessories: Sheet metal strips, clamps, anchoring devices, and similar accessory units required for installation; matching or compatible with material being installed.
- F. Solder: ASTM B 32, lead-free alloy.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION

- A. Install roof drains at low points of roof areas according to roof membrane manufacturer's written installation instructions.
  - 1. Install flashing collar or flange of roof drain to prevent leakage between drain and adjoining roofing. Maintain integrity of waterproof membranes where penetrated.
  - 2. Install expansion joints, if indicated, in roof drain outlets.
  - 3. Position roof drains for easy access and maintenance.
- B. Install downspout adapters on outlet of back-outlet parapet roof drains and connect to sheet metal downspouts.
- C. Install downspout boots at grade with top 6 inches (152 mm) above grade. Secure to building wall.
- D. Install conductor nozzles at exposed bottom of conductors where they spill onto grade.
- E. Install cleanouts in aboveground piping and building drain piping according to the following instructions unless otherwise indicated:
  - 1. Use cleanouts the same size as drainage piping up to NPS 4 (DN 100). Use NPS 4 (DN 100) for larger drainage piping unless larger cleanout is indicated.
  - 2. Locate cleanouts at each change in direction of piping greater than 45 degrees.
  - 3. Locate cleanouts at minimum intervals of 50 feet (15 m) for piping NPS 4 (DN 100) and smaller and 100 feet (30 m) for larger piping.
  - 4. Locate cleanouts at base of each vertical soil and waste stack.
- F. For floor cleanouts for piping below floors, install cleanout deck plates with top flush with finished floor.
- G. For cleanouts located in concealed piping, install cleanout wall access covers, of types indicated, with frame and cover flush with finished wall.
- H. Install horizontal backwater valves in floor with cover flush with floor.
- I. Install drain-outlet backwater valves in outlet of drains.

- J. Install test tees in vertical conductors and near floor.
- K. Install wall cleanouts in vertical conductors. Install access door in wall if indicated.
- L. Install trench drains at low points of surface areas to be drained. Set grates of drains flush with finished surface unless otherwise indicated.
- M. Assemble channel drainage system components according to manufacturer's written instructions. Install on support devices so that top will be flush with adjacent surface.
- N. Install through-penetration firestop assemblies in plastic conductors at concrete floor penetrations.
- O. Install sleeve flashing device with each conductor passing through floors with waterproof membrane.

### 3.2 CONNECTIONS

- A. Comply with requirements for piping specified in Section 221413 "Facility Storm Drainage Piping." Drawings indicate general arrangement of piping, fittings, and specialties.

### 3.3 FLASHING INSTALLATION

- A. Fabricate flashing from single piece of metal unless large pans, sumps, or other drainage shapes are required. Join flashing according to the following if required:
  - 1. Lead Sheets: Burn joints of 6.0-lb/sq. ft. (30-kg/sq. m) lead sheets, 0.0938-inch (2.4-mm) thickness or thicker. Solder joints of 4.0-lb/sq. ft. (20-kg/sq. m) lead sheets, 0.0625-inch (1.6-mm) thickness or thinner.
  - 2. Copper Sheets: Solder joints of copper sheets.
- B. Install sheet flashing on pipes, sleeves, and specialties passing through or embedded in floors and roofs with waterproof membrane.
  - 1. Pipe Flashing: Sleeve type, matching the pipe size, with a minimum length of 10 inches (250 mm) and with skirt or flange extending at least 8 inches (200 mm) around pipe.
  - 2. Sleeve Flashing: Flat sheet, with skirt or flange extending at least 8 inches (200 mm) around sleeve.
  - 3. Embedded Specialty Flashing: Flat sheet, with skirt or flange extending at least 8 inches (200 mm) around specialty.
- C. Set flashing on floors and roofs in solid coating of bituminous cement.
- D. Secure flashing into sleeve and specialty clamping ring or device.
- E. Fabricate and install flashing and pans, sumps, and other drainage shapes.



3.4 PROTECTION

- A. Protect drains during remainder of construction period to avoid clogging with dirt or debris and to prevent damage from traffic or construction work.
- B. Place plugs in ends of uncompleted piping at end of each day or when work stops.

END OF SECTION 221423

## SECTION 223100 - DOMESTIC WATER SOFTENERS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Commercial water softeners.
  - 2. Chemicals.
  - 3. Water-testing sets.

#### 1.3 PERFORMANCE REQUIREMENTS

- A. Seismic Performance: Water softeners shall withstand the effects of earthquake motions determined according to ASCE/SEI 7.
  - 1. The term "withstand" means "the unit will remain in place without separation of any parts from the device when subjected to the seismic forces specified and the unit will be fully operational after the seismic event."

#### 1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.
  - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for water softeners.
  - 2. Include rated capacities, operating characteristics, electrical characteristics, and furnished specialties and accessories.
  - 3. Wiring Diagrams: For power, signal, and control wiring.

#### 1.5 INFORMATIONAL SUBMITTALS

- A. Seismic Qualification Certificates: For water softeners, accessories, and components, from manufacturer.
  - 1. Basis for Certification: Indicate whether withstand certification is based on actual test of assembled components or on calculation.
  - 2. Dimensioned Outline Drawings of Equipment Unit: Identify center of gravity and locate and describe mounting and anchorage provisions.

3. Detailed description of equipment anchorage devices on which the certification is based and their installation requirements.

- B. Source quality-control reports.
- C. Field quality-control reports.
- D. Warranty: Sample of special warranty.

#### 1.6 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For water softeners to include in emergency, operation, and maintenance manuals.

#### 1.7 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  1. Salt for Brine Tanks: Furnish in same form as and at least four times original load, but not less than 200 lb (90.7 kg). Deliver on pallets according to the following:
    - a. Food-Grade Pellet Salt: In 40- or 50-lb (18.1- or 22.7-kg) 80-lb (36.3-kg) packages.
    - b. Plain Pellet Salt: In 40- or 50-lb (18.1- or 22.7-kg) 80-lb (36.3-kg) packages.
    - c. Crystallized Solar Salt: In 40- or 50-lb (18.1- or 22.7-kg) 80-lb (36.3-kg) packages.
    - d. Plain, Brine Block Salt: In 50-lb (22.7-kg) or as applicable blocks.
  2. Store salt on raised platform where directed by Owner. Do not store in contact with concrete floor.

#### 1.8 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended application.
- B. ASME Compliance for Steel Tanks: Fabricate and label mineral tanks to comply with ASME Boiler and Pressure Vessel Code: Section VIII, Division 1, where indicated.
- C. ASME Compliance for FRP Tanks: Fabricate and label mineral tanks to comply with ASME Boiler and Pressure Vessel Code: Section X, where indicated.
- D. UL Compliance: Fabricate and label water softeners to comply with UL 979, "Water Treatment Appliances."

1.9 COORDINATION

- A. Coordinate sizes and locations of concrete bases with actual equipment provided.

1.10 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of water softeners that fail in materials or workmanship within specified warranty period.

- 1. Failures include, but are not limited to, the following:

- a. Structural failures of mineral and brine tanks.
    - b. Faulty operation of controls.
    - c. Deterioration of metals, metal finishes, and other materials beyond normal use.
    - d. Attrition loss of resin exceeding 3 percent per year.
    - e. Mineral washed out of system during service run or backwashing period.
    - f. Effluent turbidity greater and color darker than incoming water.
    - g. Fouling of underdrain system, gravel, and resin with turbidity or by dirt, rust, or scale from water softener or soft water, while operating according to manufacturer's written operating instructions.

- 2. Commercial Water Softeners, Warranty Period: From date of Substantial Completion.

- a. Mineral Tanks: Five years.
    - b. Brine Tanks: 10 years.
    - c. Control Valve: 2 year(s).

1.11 MAINTENANCE SERVICE

- A. Initial Maintenance Service: Beginning at Substantial Completion, provide six months' full maintenance by skilled employees of water softener Installer. Include quarterly preventive maintenance, repair or replacement of worn or defective components, cleaning, and adjusting as required for proper water softener operation at rated capacity. Provide parts and supplies the same as those used in the manufacture and installation of original equipment.
- B. Continuing Maintenance Proposal: From Installer to Owner, in the form of a standard yearly (or other period) maintenance agreement, starting on date initial maintenance service is concluded. State services, obligations, conditions, and terms for agreement period and for future renewal options.

PART 2 - PRODUCTS

2.1 COMMERCIAL WATER SOFTENERS

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Aquion Water Treatment Products.
2. Diamond Water Systems, Inc.
3. Environmentak System Product inc.
4. Springsoft International, Inc.
5. Water King.
6. WaterSoft.

B. Description: Factory-assembled, pressure-type water softener.

1. Standard: Comply with NSF 61 Annex, "Drinking Water System Components - Health Effects."
2. Configuration: Single unit with one mineral tank and one brine tank.
3. Mounting: On skids.
4. Wetted Components: Suitable for water temperatures from 40 to at least 100 deg F (5 to at least 38 deg C).
5. Mineral Tanks: FRP, pressure-vessel quality.
  - a. Construction: Non-ASME code. Fabricated and stamped to comply with ASME Boiler and Pressure Vessel Code: Section X, "Fiber-Reinforced Plastic Pressure Vessels."
  - b. Pressure Rating: 100 psig (690 kPa) minimum.
  - c. Freeboard: 50 percent minimum for backwash expansion above normal resin bed level.
  - d. Support Legs or Skirt: Constructed of structural steel, welded to tank before testing and labeling.
  - e. Upper Distribution System: Single, point type, fabricated from galvanized-steel pipe and fittings.
  - f. Lower Distribution System: Hub and radial-arm or header-lateral type; fabricated from nonmetallic pipe and fittings with individual, fine-slotted, nonclogging plastic strainers, and arranged for even flow distribution through resin bed.
  - g. Liner: PE, ABS, or other material suitable for potable water.
6. Mineral Tanks: Steel, electric welded; pressure-vessel quality.
  - a. Seismic Requirements: Fabricate supports and attachments to tank with reinforcement strong enough to resist tank movement during seismic event when tank supports are anchored to building structure.
  - b. Construction: Non-ASME code. Fabricated and stamped to comply with ASME Boiler and Pressure Vessel Code: Section VIII, "Pressure Vessels," Division 1.
  - c. Pressure Rating: 100 psig (690 kPa) minimum.

- d. Freeboard: 50 percent minimum for backwash expansion above normal resin bed level.
  - e. Handholes: 4 inches (102 mm) round or 4 by 6 inches (102 by 152 mm) elliptical, in top head and lower sidewall of tanks 30 inches (762 mm) and smaller in diameter.
  - f. Manhole: 11 by 15 inches (280 by 380 mm) in top head of tanks larger than 30 inches (762 mm) in diameter.
  - g. Support Legs or Skirt: Constructed of structural steel, welded to tank before testing and labeling.
  - h. Finish: Hot-dip galvanized on exterior and interior of tank after fabrication unless tank is stainless steel.
  - i. Finish: Exterior of tank spray-painted with rust-resistant prime coat, 2- to 3-mil (0.051- to 0.076-mm) dry film thickness. Interior sandblasted and lined with epoxy-polyamide coating, 8- to 10-mil (0.203- to 0.254-mm) dry film thickness.
  - j. Upper Distribution System: Single, point type, fabricated from galvanized-steel pipe and fittings.
  - k. Lower Distribution System: Hub and radial-arm or header-lateral type; fabricated from PVC pipe and fittings with individual, fine-slotted, nonclogging PE strainers, and arranged for even flow distribution through resin bed.
  - l. Liner: PE, ABS, or other material suitable for potable water.
7. Controls: Automatic; factory wired and factory mounted on unit.
- a. Adjustable duration of various regeneration steps.
  - b. Push-button start and complete manual operation.
  - c. Electric time clock and switch for automatic operation except for manual return to service.
  - d. Sequence of Operation: Multiport pilot-control valve automatically pressure-actuates main operating valve through steps of regeneration.
  - e. Pointer on pilot-control valve shall indicate cycle of operation.
  - f. Includes means of manual operation of pilot-control valve if power fails.
8. Controls: Fully automatic; factory wired and factory mounted on unit.
- a. Adjustable duration of various regeneration steps.
  - b. Push-button start and complete manual operation.
  - c. Electric time clock and switch for fully automatic operation, adjustable to initiate regeneration at any hour of day and any day of week or at fixed intervals.
  - d. Sequence of Operation: Multiport pilot-control valve automatically pressure-actuates main operating valve through steps of regeneration and return to service.
  - e. Pointer on pilot-control valve shall indicate cycle of operation.
  - f. Includes means of manual operation of pilot-control valve if power fails.
9. Main Operating Valves: Industrial, automatic, multiport, diaphragm type with the following features:
- a. Slow opening and closing, nonslam operation.
  - b. Diaphragm guiding on full perimeter from fully open to fully closed.
  - c. Isolated, dissimilar metals within valve.

- d. Self-adjusting, internal, automatic brine injector that draws brine and rinses at constant rate independent of pressure.
  - e. Valve for single mineral-tank unit with internal automatic bypass of raw water during regeneration.
  - f. Sampling cocks for soft water.
  - g. Special tools are not required for service.
10. Flow Control: Automatic, to control backwash and flush rates over wide variations in operating pressure; does not require field adjustments.
- a. Meter Control: Each mineral tank is equipped with signal-register-head water meter that produces electrical signal indicating need for regeneration on reaching hand-set total in gallons (liters). Signal will continue until reset.
  - b. Demand-Initiated Control: Single mineral tank is equipped with automatic-reset-head water meter that electrically activates cycle controller to initiate regeneration at preset total in gallons (liters). Head automatically resets to preset total in gallons (liters) for next service run.
  - c. Demand-Initiated Control: Each mineral tank of twin mineral-tank unit is equipped with automatic-reset-head water meter that electrically activates cycle controllers to initiate regeneration at preset total in gallons (liters). Head automatically resets to preset total in gallons (liters) for next service run. Electrical lockout prevents simultaneous regeneration of both tanks.
  - d. Demand-Initiated Control: Each twin mineral-tank unit is equipped with automatic-reset-head water meter, in common outlet header, that electrically activates cycle controller to automatically regenerate one mineral tank at preset total in gallons (liters) and divert flow to other tank. Automatically repeats with other tank. Electrical lockout prevents simultaneous regeneration of both tanks.
  - e. Demand-Initiated Control: Each mineral tank of multiple mineral-tank unit is equipped with automatic-reset-head water meter that electrically activates cycle controllers to automatically regenerate at preset total in gallons (liters). Head automatically resets to preset total in gallons (liters) for next service run. Electrical lockout prevents simultaneous regeneration of more than one tank.
  - f. Demand-Initiated Control: Each multiple mineral-tank unit is equipped with automatic-reset-head water meter, in common outlet header, that electrically activates cycle controller to automatically regenerate one mineral tank at preset total in gallons (liters) and divert flow to other tanks. Automatically repeats with other tanks. Electrical lockout prevents simultaneous regeneration of more than one tank.
11. Brine Tank: Combination measuring and wet-salt storing system.
- a. Tank and Cover Material: Fiberglass, 3/16 inch (4.8 mm) thick; or molded PE, 3/8 inch (9.5 mm) thick.
  - b. Brine Valve: Float operated and plastic fitted for automatic control of brine withdrawal and freshwater refill.
  - c. Size: Large enough for at least four regenerations at full salting.
12. Factory-Installed Accessories:
- a. Piping, valves, tubing, and drains.

- b. Sampling cocks.
- c. Main-operating-valve position indicators.
- d. Water meters.

C. Capacities and Characteristics:

1. Water Analysis:

- a. Hardness: 308 ppm (mg/L).
- b. Iron: 6 ppb.
- c. Dissolved Solids: 552 ppm.
- d. Inlet Water Pressure: 40 psi.
- e. Water Temperature: 50 **deg F (deg C)**>.

- 2. Continuous Service Flow Rate: 12 gpm at 10-psig ( L/s at 104-kPa) pressure drop.
- 3. Peak Service Flow Rate: 12 gpm at 10-psig ( L/s at 173-kPa) pressure drop.
- 4. Manifold Pipe Size: 1.5".
- 5. Backwash-to-Drain Pipe Size: ¾".
- 6. Number of Mineral Tanks: One.
- 7. Mineral Quantity, Each Tank: Not available.
- 8. Mineral Exchange Capacity: Not available.
- 9. Electrical Characteristics:

- a. Volts: 120.
- b. Phases: 1.
- c. Hertz: 60.
- d. Full-Load Amperes: Not available.
- e. Minimum Circuit Ampacity: Not available.
- f. Maximum Overcurrent Protection: Not available.

- 10. Salt Capacity: Not available.
- 11. Minimum Number of Regenerations per Refill: Not available.
- 12. Floor Area Required: Not available.
- 13. Height Required: 62 **inches (mm)**>.

2.2 CHEMICALS

A. Mineral: High-capacity, sulfonated-polystyrene, ion-exchange resin that is stable over entire pH range with good resistance to bead fracture from attrition or shock.

- 1. Exchange Capacity: 30,000 grains/cu. ft. (69 kg/cu. m) of calcium carbonate of resin when regenerated with 15 lb (6.8 kg) of salt.

B. Salt for Brine Tanks: High-purity sodium chloride, free of dirt and foreign material. Rock and granulated forms are unacceptable.

- 1. Form: Processed, food-grade salt pellets, plain salt pellets, crystallized solar salt collected from shallow ponds and milled into irregular particles.



2.3 WATER-TESTING SETS

- A. Description: Manufacturer's standard water-hardness testing apparatus and chemicals with testing procedure instructions. Include metal container suitable for wall mounting.

2.4 SOURCE QUALITY CONTROL

- A. Hydrostatically test mineral tanks before shipment to a minimum of one and one-half times the pressure rating.
- B. Prepare test and inspection reports.

PART 3 - EXECUTION

3.1 WATER SOFTENER INSTALLATION

- A. Equipment Mounting:
  - 1. Install commercial water softeners on cast-in-place concrete equipment base(s). Comply with requirements for equipment bases and foundations specified in Section 033000 "Cast-in-Place Concrete."
  - 2. Comply with requirements for vibration isolation and seismic control devices specified in Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment"
  - 3. Comply with requirements for vibration isolation devices specified in Section 220548.13 "Vibration Controls for Plumbing Piping and Equipment."
- B. Install seismic restraints for tanks and floor-mounting accessories and anchor to building structure.
- C. Install brine lines and fittings furnished by equipment manufacturer but not specified to be factory installed.
- D. Prepare mineral-tank distribution system and underbed for minerals and place specified mineral into mineral tanks.
- E. Install water-testing sets mounted on wall, unless otherwise indicated, and near water softeners.

3.2 CONNECTIONS

- A. Comply with requirements for piping specified in Section 221116 "Domestic Water Piping." Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Where piping is installed adjacent to equipment, allow space for service and maintenance of equipment.
- C. Install shutoff valves on raw-water inlet and soft-water outlet piping of each mineral tank, and on inlet and outlet headers.

1. Metal general-duty valves are specified in Section 220523.12 "Ball Valves for Plumbing Piping," Section 220523.13 "Butterfly Valves for Plumbing Piping," Section 220523.14 " and Section 220523.15 "Gate Valves for Plumbing Piping."
  2. Plastic valves are specified in Section 221116 "Domestic Water Piping."
  3. Exception: Water softeners with factory-installed shutoff valves at locations indicated.
- D. Install pressure gages on raw-water inlet and soft-water outlet piping of each mineral tank. Pressure gages are specified in Section 220519 "Meters and Gages for Plumbing Piping."
1. Exception: Water softeners with factory-installed pressure gages at locations indicated.
  2. Exception: Household water softeners.
  3. Exception: Water softeners in hot-water service.
- E. Install valved bypass in water piping around water softeners.
1. Metal general-duty valves are specified in Section 220523.12 "Ball Valves for Plumbing Piping," Section 220523.13 "Butterfly Valves for Plumbing Piping," Section 220523.14 "Check Valves for Plumbing Piping," and Section 220523.15 "Gate Valves for Plumbing Piping."
  2. Plastic valves are specified in Section 221116 "Domestic Water Piping."
  3. Water piping is specified in Section 221116 "Domestic Water Piping."
  4. Exception: Household water softeners.
  5. Exception: Water softeners in hot-water service.
- F. Install drains as indirect wastes to spill into open drains or over floor drains.

### 3.3 IDENTIFICATION

- A. Identify system components. Comply with requirements for identification specified in Section 220553 "Identification for Plumbing Piping and Equipment."

### 3.4 FIELD QUALITY CONTROL

- A. Tests and Inspections:
1. Leak Test: After installation, charge system and test for leaks. Repair leaks and retest until no leaks exist.
  2. Operational Test: After electrical circuitry has been energized, start units to confirm proper unit operation.
  3. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- B. Water softeners will be considered defective if they do not pass tests and inspections.
- C. Prepare test and inspection reports.

### 3.5 STARTUP SERVICE

- A. Engage a factory-authorized service representative to perform startup service.
  - 1. Complete installation and startup checks according to manufacturer's written instructions.
- B. Add water to brine tanks and fill with the following form of salt:
  - 1. Commercial Water Softeners: Processed, plain salt pellets, crystallized solar salt collected from shallow ponds and milled into irregular particles plain, brine block salt.
- C. Sample water softener effluent after startup and at three consecutive seven-day intervals (total of four samples), and prepare certified test reports for required water performance characteristics. Comply with the following:
  - 1. ASTM D 859, "Test Method for Silica in Water."
  - 2. ASTM D 1067, "Test Methods for Acidity or Alkalinity of Water."
  - 3. ASTM D 1068, "Test Methods for Iron in Water."
  - 4. ASTM D 1126, "Test Method for Hardness in Water."
  - 5. ASTM D 1129, "Terminology Relating to Water."
  - 6. ASTM D 3370, "Practices for Sampling Water from Closed Conduits."

### 3.6 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain water softeners.

END OF SECTION 223100

SECTION 223400 - FUEL-FIRED, DOMESTIC-WATER HEATERS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Commercial, atmospheric, gas-fired, storage, domestic-water heaters.
  - 2. Commercial, gas-fired, high-efficiency, storage, domestic-water heaters.
  - 3. Domestic-water heater accessories.

1.3 PERFORMANCE REQUIREMENTS

- A. Seismic Performance: Commercial domestic-water heaters shall withstand the effects of earthquake motions determined according to ASCE/SEI 7.
  - 1. The term "withstand" means "the unit will remain in place without separation of any parts from the device when subjected to the seismic forces specified and the unit will be fully operational after the seismic event."

1.4 ACTION SUBMITTALS

- A. Product Data: For each type and size of domestic-water heater indicated. Include rated capacities, operating characteristics, electrical characteristics, and furnished specialties and accessories.
- B. LEED Submittals:
  - 1. Product Data for Prerequisite EA 2: Documentation indicating that units comply with applicable requirements in ASHRAE/IESNA 90.1, Section 7, "Service Water Heating."
- C. Shop Drawings:
  - 1. Wiring Diagrams: For power, signal, and control wiring.

### 1.5 INFORMATIONAL SUBMITTALS

- A. Seismic Qualification Certificates: For fuel-fired, domestic-water heaters, accessories, and components, from manufacturer.
  - 1. Basis for Certification: Indicate whether withstand certification is based on actual test of assembled components or on calculation.
  - 2. Dimensioned Outline Drawings of Equipment Unit: Identify center of gravity and locate and describe mounting and anchorage provisions.
  - 3. Detailed description of equipment anchorage devices on which the certification is based and their installation requirements.
- B. Product Certificates: For each type of commercial, gas-fired, and commercial, gas- and oil-fired, domestic-water heater, from manufacturer.
- C. Domestic-Water Heater Labeling: Certified and labeled by testing agency acceptable to authorities having jurisdiction.
- D. Source quality-control reports.
- E. Field quality-control reports.
- F. Warranty: Sample of special warranty.

### 1.6 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For fuel-fired, domestic-water heaters to include in emergency, operation, and maintenance manuals.

### 1.7 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. ASHRAE/IESNA Compliance: Fabricate and label fuel-fired, domestic-water heaters to comply with ASHRAE/IESNA 90.1.
- C. ASME Compliance:
  - 1. Where ASME-code construction is indicated, fabricate and label commercial, domestic-water heater storage tanks to comply with ASME Boiler and Pressure Vessel Code: Section VIII, Division 1.
  - 2. Where ASME-code construction is indicated, fabricate and label commercial, finned-tube, domestic-water heaters to comply with ASME Boiler and Pressure Vessel Code: Section IV.

- D. NSF Compliance: Fabricate and label equipment components that will be in contact with potable water to comply with NSF 61 Annex G, "Drinking Water System Components - Health Effects."

## 1.8 COORDINATION

- A. Coordinate sizes and locations of concrete bases with actual equipment provided.

## 1.9 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of fuel-fired, domestic-water heaters that fail in materials or workmanship within specified warranty period.

- 1. Failures include, but are not limited to, the following:
  - a. Structural failures including storage tank and supports.
  - b. Faulty operation of controls.
  - c. Deterioration of metals, metal finishes, and other materials beyond normal use.
- 2. Warranty Periods: From date of Substantial Completion.
  - a. Commercial, Gas-Fired, Storage, Domestic-Water Heaters:
    - 1) Storage Tank: Three years.
    - 2) Controls and Other Components: One year(s).
  - b. Compression Tanks: Five years.

## PART 2 - PRODUCTS

### 2.1 COMMERCIAL, GAS-FIRED, STORAGE, DOMESTIC-WATER HEATERS

- A. Commercial, Atmospheric, Gas-Fired, Storage, Domestic-Water Heaters:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Bradford White Corporation.
    - b. Lochinvar, LLC.
    - c. PVI Industries, LLC.
    - d. Rheem Manufacturing Company.
    - e. Smith, A. O. Corporation.
  - 2. Standard: ANSI Z21.10.3/CSA 4.3.

3. Storage-Tank Construction: ASME-code steel with 150-psig (1035-kPa) working-pressure rating.
  - a. Tappings: Factory fabricated of materials compatible with tank. Attach tappings to tank before testing.
    - 1) NPS 2 (DN 50) and Smaller: Threaded ends according to ASME B1.20.1.
    - 2) NPS 2-1/2 (DN 65) and Larger: Flanged ends according to ASME B16.5 for steel and stainless-steel flanges, and according to ASME B16.24 for copper and copper-alloy flanges.
  - b. Interior Finish: Comply with NSF 61 Annex G barrier materials for potable-water tank linings, including extending finish into and through tank fittings and outlets.
4. Factory-Installed Storage-Tank Appurtenances:
  - a. Anode Rod: Replaceable magnesium.
  - b. Dip Tube: Required unless cold-water inlet is near bottom of tank.
  - c. Drain Valve: Corrosion-resistant metal complying with ASSE 1005.
  - d. Insulation: Comply with ASHRAE/IESNA 90.1. Surround entire storage tank except connections and controls.
  - e. Jacket: Steel with enameled finish.
  - f. Burner: For use with atmospheric, gas-fired, domestic-water heaters and natural-gas fuel.
  - g. Automatic Ignition: ANSI Z21.20/CSA C22.2 No. 199, electric, automatic, gas-ignition system.
  - h. Temperature Control: Adjustable thermostat.
  - i. Safety Controls: Automatic, high-temperature-limit and low-water cutoff devices or systems.
  - j. Combination Temperature-and-Pressure Relief Valves: ANSI Z21.22/CSA 4.4-M. Include one or more relief valves with total relieving capacity at least as great as heat input, and include pressure setting less than domestic-water heater working-pressure rating. Select one relief valve with sensing element that extends into storage tank.
5. Special Requirements: NSF 5 construction.
6. Draft Hood: Draft diverter, complying with ANSI Z21.12.
7. Factory-Installed Storage-Tank Appurtenances:
  - a. Anode Rod: Replaceable magnesium.
  - b. Dip Tube: Required unless cold-water inlet is near bottom of tank.
  - c. Drain Valve: Corrosion-resistant metal complying with ASSE 1005.
  - d. Insulation: Comply with ASHRAE/IESNA 90.1. Surround entire storage tank except connections and controls.
  - e. Jacket: Steel with enameled finish.
  - f. Burner or Heat Exchanger: Comply with UL 795 or approved testing agency requirements for gas-fired, high-efficiency, domestic-water heaters and natural-gas fuel.
  - g. Temperature Control: Adjustable thermostat.



- h. Safety Controls: Automatic, high-temperature-limit and low-water cutoff devices or systems.
    - i. Combination Temperature-and-Pressure Relief Valves: ANSI Z21.22/CSA 4.4-M. Include one or more relief valves with total relieving capacity at least as great as heat input, and include pressure setting less than domestic-water heater working-pressure rating. Select one relief valve with sensing element that extends into storage tank.
  - 8. Draft Hood: Draft diverter, complying with ANSI Z21.12.
- B. Capacity and Characteristics:
  - 1. Capacity: See schedules.
  - 2. Recovery: See schedules.
  - 3. Temperature Setting: [120 deg .
  - 4. Fuel Gas Demand: See schedules.
  - 5. Fuel Gas Input: See schedules.
  - 6. Gas Pressure Regulator:
    - a. Capacity: See schedules.
    - b. Inlet Pressure: See schedules.
    - c. Gas Pressure Required at Burner: 8" water column.
  - 7. Electrical Characteristics:
    - a. Volts: 120.
    - b. Phase: Single.
    - c. Hertz: 60.
    - d. Full-Load Amperes: 13.
  - 8. Minimum Vent Diameter: See cut sheet.

## 2.2 DOMESTIC-WATER HEATER ACCESSORIES

### A. Domestic-Water Compression Tanks:

- 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. AMTROL, Inc.
  - b. Flexcon Industries.
  - c. Taco, Inc.
- 2. Description: Steel, pressure-rated tank constructed with welded joints and factory-installed butyl-rubber diaphragm. Include air precharge to minimum system-operating pressure at tank.
- 3. Construction:

- a. Tappings: Factory-fabricated steel, welded to tank before testing and labeling. Include ASME B1.20.1 pipe thread.
  - b. Interior Finish: Comply with NSF 61 Annex G barrier materials for potable-water tank linings, including extending finish into and through tank fittings and outlets.
  - c. Air-Charging Valve: Factory installed.
4. Capacity and Characteristics:
- a. Working-Pressure Rating: 150 psig (1035 kPa).
  - b. Capacity Acceptable: **6.4 gal. (26.5 L)** minimum.
  - c. Air Precharge Pressure: 55 PSIG.
- B. Drain Pans: Corrosion-resistant metal with raised edge. Comply with ANSI/CSA LC 3. Include dimensions not less than base of domestic-water heater, and include drain outlet not less than NPS 3/4 (DN 20) with ASME B1.20.1 pipe threads or with ASME B1.20.7 garden-hose threads.
- C. Piping-Type Heat Traps: Field-fabricated piping arrangement according to ASHRAE/IESNA 90.1 or ASHRAE 90.2.
- D. Heat-Trap Fittings: ASHRAE 90.2.
- E. Manifold Kits: Domestic-water heater manufacturer's factory-fabricated inlet and outlet piping for field installation, for multiple domestic-water heater installation. Include ball-, butterfly-, or gate-type shutoff valves to isolate each domestic-water heater and calibrated memory-stop balancing valves to provide balanced flow through each domestic-water heater.
- F. Comply with requirements for ball-, butterfly-, or gate-type shutoff valves specified in Section 220523.12 "Ball Valves for Plumbing Piping," Section 220523.13 "Butterfly Valves for Plumbing Piping," and Section 220523.15 "Gate Valves for Plumbing Piping."
1. Comply with requirements for balancing valves specified in Section 221119 "Domestic Water Piping Specialties."
- G. Gas Shutoff Valves: ANSI Z21.15/CSA 9.1-M, manually operated. Furnish for installation in piping.
- H. Gas Pressure Regulators: ANSI Z21.18/CSA 6.3, appliance type. Include 1/2-psig (3.5-kPa) 2-psig (13.8-kPa) pressure rating as required to match gas supply.
- I. Automatic Gas Valves: ANSI Z21.21/CSA 6.5, appliance, electrically operated, on-off automatic valve.
- J. Combination Temperature-and-Pressure Relief Valves: Include relieving capacity at least as great as heat input, and include pressure setting less than domestic-water heater working-pressure rating. Select relief valves with sensing element that extends into storage tank.
1. Gas-Fired, Domestic-Water Heaters: ANSI Z21.22/CSA 4.4-M.
  2. Oil-Fired, Domestic-Water Heaters: ASME rated and stamped.

- K. Pressure Relief Valves: Include pressure setting less than domestic-water heater working-pressure rating.
  - 1. Gas-Fired, Domestic-Water Heaters: ANSI Z21.22/CSA 4.4-M.
  - 2. Oil-Fired, Domestic-Water Heaters: ASME rated and stamped.
- L. Vacuum Relief Valves: ANSI Z21.22/CSA 4.4-M.
- M. Domestic-Water Heater Stands: Manufacturer's factory-fabricated steel stand for floor mounting, capable of supporting domestic-water heater and water. Provide dimension that will support bottom of domestic-water heater a minimum of 18 inches (457 mm) above the floor.
- N. Domestic-Water Heater Mounting Brackets: Manufacturer's factory-fabricated steel bracket for wall mounting, capable of supporting domestic-water heater and water.

### 2.3 SOURCE QUALITY CONTROL

- A. Factory Tests: Test and inspect assembled domestic-water heaters and storage tanks specified to be ASME-code construction, according to ASME Boiler and Pressure Vessel Code.
- B. Hydrostatically test commercial domestic-water heaters and storage tanks to minimum of one and one-half times pressure rating before shipment.
- C. Domestic-water heaters will be considered defective if they do not pass tests and inspections. Comply with requirements in Section 014000 "Quality Requirements" for retesting and reinspecting requirements and Section 017300 "Execution" for requirements for correcting the Work.
- D. Prepare test and inspection reports.

## PART 3 - EXECUTION

### 3.1 DOMESTIC-WATER HEATER INSTALLATION

- A. Commercial, Domestic-Water Heater Mounting: Install commercial domestic-water heaters on concrete base. Comply with requirements for concrete base specified in Section 033000 "Cast-in-Place Concrete." Section 033053 "Miscellaneous Cast-in-Place Concrete."
  - 1. Exception: Omit concrete bases for commercial domestic-water heaters if installation on stand, bracket, suspended platform, or directly on floor is indicated.
  - 2. Maintain manufacturer's recommended clearances.
  - 3. Arrange units so controls and devices that require servicing are accessible.
  - 4. Install dowel rods to connect concrete base to concrete floor. Unless otherwise indicated, install dowel rods on 18-inch (450-mm) centers around the full perimeter of concrete base.
  - 5. For supported equipment, install epoxy-coated anchor bolts that extend through concrete base and anchor into structural concrete floor.

6. Place and secure anchorage devices. Use setting drawings, templates, diagrams, instructions, and directions furnished with items to be embedded.
  7. Install anchor bolts to elevations required for proper attachment to supported equipment.
  8. Anchor domestic-water heaters to substrate.
- B. Residential, Domestic-Water Heater Mounting: Install residential domestic-water heaters on floor water-heater stand on floor domestic-water heater mounting bracket.
1. Maintain manufacturer's recommended clearances.
  2. Arrange units so controls and devices that require servicing are accessible.
  3. Place and secure anchorage devices. Use setting drawings, templates, diagrams, instructions, and directions furnished with items to be embedded.
  4. Install anchor bolts to elevations required for proper attachment to supported equipment.
  5. Anchor domestic-water heaters to substrate.
- C. Tankless, Domestic-Water Heater Mounting: Install tankless, domestic-water heaters at least 18 inches (457 mm) above floor on wall bracket.
1. Maintain manufacturer's recommended clearances.
  2. Arrange units so controls and devices that require servicing are accessible.
  3. Place and secure anchorage devices. Use setting drawings, templates, diagrams, instructions, and directions furnished with items to be embedded.
  4. Install anchor bolts to elevations required for proper attachment to supported equipment.
  5. Anchor domestic-water heaters to substrate.
- D. Install domestic-water heaters level and plumb, according to layout drawings, original design, and referenced standards. Maintain manufacturer's recommended clearances. Arrange units so controls and devices needing service are accessible.
1. Install shutoff valves on domestic-water-supply piping to domestic-water heaters and on domestic-hot-water outlet piping. Comply with requirements for shutoff valves specified in Section 220523.12 "Ball Valves for Plumbing Piping," Section 220523.13 "Butterfly Valves for Plumbing Piping," and Section 220523.15 "Gate Valves for Plumbing Piping."
- E. Install gas-fired, domestic-water heaters according to NFPA 54.
1. Install gas shutoff valves on gas supply piping to gas-fired, domestic-water heaters without shutoff valves.
  2. Install gas pressure regulators on gas supplies to gas-fired, domestic-water heaters without gas pressure regulators if gas pressure regulators are required to reduce gas pressure at burner.
  3. Install automatic gas valves on gas supplies to gas-fired, domestic-water heaters if required for operation of safety control.
  4. Comply with requirements for gas shutoff valves, gas pressure regulators, and automatic gas valves specified in Section 231123 "Facility Natural-Gas Piping." Section 231126 "Facility Liquefied-Petroleum Gas Piping."
- F. Install oil-fired, domestic-water heaters according to NFPA 31.

1. Install shutoff valves on fuel-oil supply piping to oil-fired water-heater burners without shutoff valves. Comply with requirements for shutoff valves specified in Section 231113 "Facility Fuel-Oil Piping."
- G. Install commercial domestic-water heaters with seismic-restraint devices. Comply with requirements for seismic-restraint devices specified in Section 220548 "Vibration and Seismic Controls for Plumbing Piping and Equipment."
- H. Install combination temperature-and-pressure relief valves in top portion of storage tanks. Use relief valves with sensing elements that extend into tanks. Extend commercial-water-heater relief-valve outlet, with drain piping same as domestic-water piping in continuous downward pitch, and discharge by positive air gap onto closest floor drain.
- I. Install combination temperature-and-pressure relief valves in water piping for domestic-water heaters without storage. Extend commercial-water-heater relief-valve outlet, with drain piping same as domestic-water piping in continuous downward pitch, and discharge by positive air gap onto closest floor drain.
- J. Install water-heater drain piping as indirect waste to spill by positive air gap into open drains or over floor drains. Install hose-end drain valves at low points in water piping for domestic-water heaters that do not have tank drains. Comply with requirements for hose-end drain valves specified in Section 221119 "Domestic Water Piping Specialties."
- K. Install thermometer on outlet piping of domestic-water heaters. Comply with requirements for thermometers specified in Section 220519 "Meters and Gages for Plumbing Piping."
- L. Assemble and install inlet and outlet piping manifold kits for multiple domestic-water heaters. Fabricate, modify, or arrange manifolds for balanced water flow through each domestic-water heater. Include shutoff valve and thermometer in each domestic-water heater inlet and outlet, and throttling valve in each domestic-water heater outlet. Comply with requirements for valves specified in Section 220523.12 "Ball Valves for Plumbing Piping," Section 220523.13 "Butterfly Valves for Plumbing Piping," and Section 220523.15 "Gate Valves for Plumbing Piping," and comply with requirements for thermometers specified in Section 220519 "Meters and Gages for Plumbing Piping."
- M. Install piping-type heat traps on inlet and outlet piping of domestic-water heater storage tanks without integral or fitting-type heat traps.
- N. Fill domestic-water heaters with water.
- O. Charge domestic-water compression tanks with air.

### 3.2 CONNECTIONS

- A. Comply with requirements for domestic-water piping specified in Section 221116 "Domestic Water Piping."
- B. Comply with requirements for fuel-oil piping specified in Section 231113 "Facility Fuel-Oil Piping."

- C. Comply with requirements for gas piping specified in Section 231123 "Facility Natural-Gas Piping." Section 231126 "Facility Liquefied-Petroleum Gas Piping."
- D. Drawings indicate general arrangement of piping, fittings, and specialties.
- E. Where installing piping adjacent to fuel-fired, domestic-water heaters, allow space for service and maintenance of water heaters. Arrange piping for easy removal of domestic-water heaters.

### 3.3 IDENTIFICATION

- A. Identify system components. Comply with requirements for identification specified in Section 220553 "Identification for Plumbing Piping and Equipment."

### 3.4 FIELD QUALITY CONTROL

- A. Perform tests and inspections.
  - 1. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect components, assemblies, and equipment installations, including connections, and to assist in testing.
  - 2. Leak Test: After installation, charge system and test for leaks. Repair leaks and retest until no leaks exist.
  - 3. Operational Test: After electrical circuitry has been energized, start units to confirm proper operation.
  - 4. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- B. Domestic-water heaters will be considered defective if they do not pass tests and inspections. Comply with requirements in Section 014000 "Quality Requirements" for retesting and reinspecting requirements and Section 017300 "Execution" for requirements for correcting the Work.
- C. Prepare test and inspection reports.

### 3.5 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Train Owner's maintenance personnel to adjust, operate, and maintain commercial, gas-fired, storage, commercial, gas- and oil-fired, domestic-water heaters.

END OF SECTION 223400

SECTION 224213.13 - COMMERCIAL WATER CLOSETS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Water closets.
2. Flushometer valves.
3. Toilet seats.
4. Supports.

B. Related Requirements:

1. Section 224100 "Residential Plumbing Fixtures" for residential water closets.
2. Section 224300 "Medical Plumbing Fixtures" for healthcare water closets.
3. Section 224600 "Security Plumbing Fixtures" for security water closets.

1.3 ACTION SUBMITTALS

A. Product Data: For each type of product.

1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for water closets.
2. Include rated capacities, operating characteristics, electrical characteristics, and furnished specialties and accessories.

B. LEED Submittals:

1. Product Data for Prerequisite WE 1 and Credit WE 3, Credit WE 2, and Credit WE 3: Documentation indicating flow and water consumption requirements.
2. Product Data for Prerequisite WE 1: Documentation indicating flow and water consumption requirements.
3. Product Data for Prerequisite WE 1 and Credit WE 2: Documentation indicating flow and water consumption requirements.

C. Shop Drawings: Include diagrams for power, signal, and control wiring.



1.4 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For flushometer valves and electronic sensors to include in operation and maintenance manuals.

1.5 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that are packaged with protective covering for storage and identified with labels describing contents.
1. Flushometer-Valve Repair Kits: Equal to 10 percent of amount of each type installed, but no fewer than one of each type.

PART 2 - PRODUCTS

2.1 FLOOR-MOUNTED, BOTTOM-OUTLET WATER CLOSETS

- A. Water Closets: Floor mounted, bottom outlet, top spud.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. American Standard America.
    - b. Crane Plumbing, L.L.C.
    - c. Kohler Co.
  2. Bowl:
    - a. Standards: ASME A112.19.2/CSA B45.1 and ASME A112.19.5.
    - b. Material: Vitreous china.
    - c. Type: Siphon jet.
    - d. Style: Flushometer valve.
    - e. Height: Standard Handicapped/elderly, complying with ICC/ANSI A117.1.
    - f. Rim Contour: Elongated.
    - g. Water Consumption: 1.28 gal. (4.8 L) per flush.
    - h. Spud Size and Location: NPS 1-1/2 (DN 40); top.
    - i. Color: White.
  3. Bowl-to-Drain Connecting Fitting: ASTM A 1045 or ASME A112.4.3.
  4. Flushometer Valve:
  5. Toilet Seat:

## 2.2 FLUSHOMETER VALVES

### A. Solenoid-Actuator, Diaphragm Flushometer Valves:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:
  - a. Sloan Valve Company.
  - b. Zurn Industries, LLC.
2. Standard: ASSE 1037.
3. Minimum Pressure Rating: 125 psig (860 kPa).
4. Features: Include integral check stop and backflow-prevention device.
5. Material: Brass body with corrosion-resistant components.
6. Exposed Flushometer-Valve Finish: Chrome plated.
7. Panel Finish: Chrome plated or stainless steel.
8. Style: Exposed.
9. Actuator: Solenoid complying with UL 1951, and listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
10. Trip Mechanism: Hard-wired electronic sensor complying with UL 1951, and listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
11. Consumption: 1.28 gal. (4.8 L) per flush.
12. Minimum Inlet: NPS 1 (DN 25).
13. Minimum Outlet: NPS 1-1/4 (DN 32).
- 14.

## 2.3 TOILET SEATS

### A. Toilet Seats:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. American Standard America.
  - b. Bemis Manufacturing Company.
  - c. Kohler Co.
  - d. Olsonite Seat Co.
2. Standard: IAPMO/ANSI Z124.5.
3. Material: Plastic.
4. Type: Commercial (Standard).
5. Shape: Elongated rim, open front.
6. Hinge: Check Self-sustaining, check.

7. Hinge Material: Noncorroding metal.
8. Seat Cover: [**Required**] [**Not required**].
9. Color: [**White**] [**Black**] <Insert color>.

## 2.4 SUPPORTS

### A. Water Closet Carrier:

1. Manufacturers: Subject to compliance with requirements, provide products by the following:
  - a. JR Smith.
  - b. Zurn Industries, LLC.
2. Standard: ASME A112.6.1M.
3. Description: Waste-fitting assembly, as required to match drainage piping material and arrangement with faceplates, couplings gaskets, and feet; bolts and hardware matching fixture. Include additional extension coupling, faceplate, and feet for installation in wide pipe space.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine roughing-in of water supply and sanitary drainage and vent piping systems to verify actual locations of piping connections before water-closet installation.
- B. Examine walls and floors for suitable conditions where water closets will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

#### A. Water-Closet Installation:

1. Install level and plumb according to roughing-in drawings.
2. Install floor-mounted water closets on bowl-to-drain connecting fitting attachments to piping or building substrate.
3. Install accessible, wall-mounted water closets at mounting height for handicapped/elderly, according to ICC/ANSI A117.1.

#### B. Support Installation:

1. Install supports, affixed to building substrate, for floor-mounted, back-outlet water closets.
2. Use carrier supports with waste-fitting assembly and seal.

3. Install floor-mounted, back-outlet water closets attached to building floor substrate, onto waste-fitting seals; and attach to support.
4. Install wall-mounted, back-outlet water-closet supports with waste-fitting assembly and waste-fitting seals; and affix to building substrate.

C. Flushometer-Valve Installation:

1. Install flushometer-valve, water-supply fitting on each supply to each water closet.
2. Attach supply piping to supports or substrate within pipe spaces behind fixtures.
3. Install lever-handle flushometer valves for accessible water closets with handle mounted on open side of water closet.
4. Install actuators in locations that are easy for people with disabilities to reach.
5. Install fresh batteries in battery-powered, electronic-sensor mechanisms.

D. Install toilet seats on water closets.

E. Wall Flange and Escutcheon Installation:

1. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations and within cabinets and millwork.
2. Install deep-pattern escutcheons if required to conceal protruding fittings.
3. Comply with escutcheon requirements specified in Section 220518 "Escutcheons for Plumbing Piping."

F. Joint Sealing:

1. Seal joints between water closets and walls and floors using sanitary-type, one-part, mildew-resistant silicone sealant.
2. Match sealant color to water-closet color.
3. Comply with sealant requirements specified in Section 079200 "Joint Sealants."

### 3.3 CONNECTIONS

- A. Connect water closets with water supplies and soil, waste, and vent piping. Use size fittings required to match water closets.
- B. Comply with water piping requirements specified in Section 221116 "Domestic Water Piping."
- C. Comply with soil and waste piping requirements specified in Section 221316 "Sanitary Waste and Vent Piping."
- D. Where installing piping adjacent to water closets, allow space for service and maintenance.

### 3.4 ADJUSTING

- A. Operate and adjust water closets and controls. Replace damaged and malfunctioning water closets, fittings, and controls.

- B. Adjust water pressure at flushometer valves to produce proper flow.
- C. Install fresh batteries in battery-powered, electronic-sensor mechanisms.

3.5 CLEANING AND PROTECTION

- A. Clean water closets and fittings with manufacturers' recommended cleaning methods and materials.
- B. Install protective covering for installed water closets and fittings.
- C. Do not allow use of water closets for temporary facilities unless approved in writing by Owner.

END OF SECTION 224213.13

SECTION 224213.16 - COMMERCIAL URINALS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

- 1. Urinals.
- 2. Flushometer valves.

B. Related Requirements:

- 1. Section 224600 "Security Plumbing Fixtures" for security urinals.

1.3 ACTION SUBMITTALS

A. Product Data: For each type of product.

- 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for urinals.
- 2. Include rated capacities, operating characteristics, electrical characteristics, and furnished specialties and accessories.

B. LEED Submittals:

- 1. Product Data for Prerequisite WE 1 and Credit WE 3, Credit WE 2, and Credit WE 3: Documentation indicating flow and water consumption requirements.
- 2. Product Data for Prerequisite WE 1: Documentation indicating flow and water consumption requirements.
- 3. Product Data for Prerequisite WE 1 and Credit WE 2: Documentation indicating flow and water consumption requirements.

C. Shop Drawings: Include diagrams for power, signal, and control wiring.

1.4 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For flushometer valves and electronic sensors to include in operation and maintenance manuals.

## 1.5 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that are packaged with protective covering for storage and identified with labels describing contents.
1. Flushometer-Valve Repair Kits: Equal to 10 percent of amount of each type installed, but no fewer than one of each type.
  2. Waterless Urinal Trap-Seal Cartridges: Equal to 200 percent of amount of each type installed, but no fewer than 12 of each type.
  3. Waterless Urinal Trap-Seal Liquid: Equal to 1 gal. (3.8 L) for each urinal installed.

## PART 2 - PRODUCTS

### 2.1 WALL-HUNG URINALS

- A. Urinals: Wall hung, back outlet, washout, accessible.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. American Standard America.
    - b. Kohler Co.
    - c. Zurn Industries, LLC.
  2. Fixture:
    - a. Standards: ASME A112.19.2/CSA B45.1 and ASME A112.19.5.
    - b. Material: Vitreous china.
    - c. Type: Washout with extended shields.
    - d. Strainer or Trapway: Manufacturer's standard strainer with integral trap.
    - e. Water Consumption: Water saving.
    - f. Spud Size and Location: NPS 3/4 (DN 20), top.
    - g. Outlet Size and Location: NPS 2 (DN 50), back.
    - h. Color: White.
  3. Flushometer Valve:
  4. Waste Fitting:
    - a. Standard: ASME A112.18.2/CSA B125.2 for coupling.
    - b. Size: NPS 2 (DN 50).
  5. Support: ASME A112.6.1M, Type I, urinal carrier with fixture support plates and coupling with seal and fixture bolts and hardware matching fixture. Include rectangular, steel uprights.

### 2.2 URINAL FLUSHOMETER VALVES



A. Solenoid-Actuator, Diaphragm Flushometer Valves:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:
  - a. Sloan Valve Company.
  - b. Zurn Industries, LLC.
2. Standard: ASSE 1037.
3. Minimum Pressure Rating: 125 psig (860 kPa).
4. Features: Include integral check stop and backflow-prevention device.
5. Material: Brass body with corrosion-resistant components.
6. Exposed Flushometer-Valve Finish: Chrome plated.
7. Panel Finish: Chrome plated or stainless steel.
8. Style: Exposed.
9. Actuator: Solenoid complying with UL 1951; listed and labeled as defined in NFPA 70, by a qualified testing agency; and marked for intended location and application.
10. Trip Mechanism: Hard-wired electronic sensor complying with UL 1951; listed and labeled as defined in NFPA 70, by a qualified testing agency; and marked for intended location and application.
11. Consumption: 0.125gal per flush.
12. Minimum Inlet: NPS 3/4 (DN 20).
13. Minimum Outlet: NPS 3/4 (DN 20).

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine roughing-in of water supply and sanitary drainage and vent piping systems to verify actual locations of piping connections before urinal installation.
- B. Examine walls and floors for suitable conditions where urinals will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

A. Urinal Installation:

1. Install urinals level and plumb according to roughing-in drawings.
2. Install wall-hung, back-outlet urinals onto waste fitting seals and attached to supports.
3. Install wall-hung, bottom-outlet urinals with tubular waste piping attached to supports.
4. Install accessible, wall-mounted urinals at mounting height for the handicapped/elderly, according to ICC/ANSI A117.1.

5. Install trap-seal liquid in waterless urinals.

B. Support Installation:

1. Install supports, affixed to building substrate, for wall-hung urinals.
2. Use off-floor carriers with waste fitting and seal for back-outlet urinals.
3. Use carriers without waste fitting for urinals with tubular waste piping.
4. Use chair-type carrier supports with rectangular steel uprights for accessible urinals.

C. Flushometer-Valve Installation:

1. Install flushometer-valve water-supply fitting on each supply to each urinal.
2. Attach supply piping to supports or substrate within pipe spaces behind fixtures.
3. Install lever-handle flushometer valves for accessible urinals with handle mounted on open side of compartment.
4. Install fresh batteries in battery-powered, electronic-sensor mechanisms.

D. Wall Flange and Escutcheon Installation:

1. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations.
2. Install deep-pattern escutcheons if required to conceal protruding fittings.
3. Comply with escutcheon requirements specified in Section 220518 "Escutcheons for Plumbing Piping."

E. Joint Sealing:

1. Seal joints between urinals and walls and floors using sanitary-type, one-part, mildew-resistant silicone sealant.
2. Match sealant color to urinal color.
3. Comply with sealant requirements specified in Section 079200 "Joint Sealants."

### 3.3 CONNECTIONS

- A. Connect urinals with water supplies and soil, waste, and vent piping. Use size fittings required to match urinals.
- B. Comply with water piping requirements specified in Section 221116 "Domestic Water Piping."
- C. Comply with soil and waste piping requirements specified in Section 221316 "Sanitary Waste and Vent Piping."
- D. Where installing piping adjacent to urinals, allow space for service and maintenance.

### 3.4 ADJUSTING

- A. Operate and adjust urinals and controls. Replace damaged and malfunctioning urinals, fittings, and controls.

- B. Adjust water pressure at flushometer valves to produce proper flow.
- C. Install fresh batteries in battery-powered, electronic-sensor mechanisms.

3.5 CLEANING AND PROTECTION

- A. Clean urinals and fittings with manufacturers' recommended cleaning methods and materials.
- B. Install protective covering for installed urinals and fittings.
- C. Do not allow use of urinals for temporary facilities unless approved in writing by Owner.

END OF SECTION 224213.16

SECTION 224216.13 - COMMERCIAL LAVATORIES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Lavatories.
2. Shampoo bowls.
3. Faucets.

B. Related Requirements:

1. Section 224100 "Residential Plumbing Fixtures" for residential lavatories.
2. Section 224300 "Medical Plumbing Fixtures" for healthcare lavatories.
3. Section 224600 "Security Plumbing Fixtures" for security lavatories.

1.3 ACTION SUBMITTALS

A. Product Data: For each type of product.

1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for lavatories.
2. Include rated capacities, operating characteristics, electrical characteristics, and furnished specialties and accessories.

B. LEED Submittals:

1. Product Data for Prerequisite WE 1 and Credit WE 3, Credit WE 2, and Credit WE 3: Documentation indicating flow and water consumption requirements.
2. Product Data for Prerequisite WE 1: Documentation indicating flow and water consumption requirements.
3. Product Data for Prerequisite WE 1 and Credit WE 2: Documentation indicating flow and water consumption requirements.

C. Shop Drawings: Include diagrams for power, signal, and control wiring of automatic faucets.

1.4 INFORMATIONAL SUBMITTALS

- A. Coordination Drawings: Counter cutout templates for mounting of counter-mounted lavatories.

1.5 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For lavatories and faucets to include in operation and maintenance manuals.

1. In addition to items specified in Section 017823 "Operation and Maintenance Data," include the following:
  - a. Servicing and adjustments of automatic faucets.

1.6 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.

1. Faucet Washers and O-Rings: Equal to 10 percent of amount of each type and size installed.
2. Faucet Cartridges and O-Rings: Equal to 5 percent of amount of each type and size installed.

PART 2 - PRODUCTS

2.1 VITREOUS-CHINA, COUNTER-MOUNTED LAVATORIES

- A. Lavatory: Oval, vitreous china, undercounter mounted.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. American Standard America.
    - b. Kohler Co.
  2. Fixture:
    - a. Standard: ASME A112.19.2/CSA B45.1.
    - b. Type: For undercounter mounting.
    - c. Nominal Size: Oval, 21-15/16" x 19-3/4".
    - d. Faucet-Hole Punching: One hole.
    - e. Faucet-Hole Location: On countertop.
    - f. Color: White.
    - g. Mounting Material: Sealant and undercounter mounting kit.
  3. Faucet: Solid-Brass, Automatically Operated Lavatory Faucets.

2.2 VITREOUS-CHINA, WALL-MOUNTED LAVATORIES

A. Lavatory: Ledge back, vitreous china, wall mounted.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. American Standard America.
  - b. Kohler Co.
2. Fixture:
  - a. Standard: ASME A112.19.2/CSA B45.1.
  - b. Type: For wall hanging.
  - c. Nominal Size: Oval, 21-15/16" x 19-3/4".
  - d. Faucet-Hole Punching: One hole.
  - e. Faucet-Hole Location: Top.
  - f. Color: White.
  - g. Mounting Material: Chair carrier.
3. Faucet: Solid-Brass, Automatically Operated Lavatory Faucets.
4. Support: ASME A112.6.1M, Type I, exposed-arm lavatory carrier, Type II, concealed-arm lavatory carrier, Type II, concealed-arm lavatory carrier with escutcheons.

B. Lavatory: Wheelchair, vitreous china, wall mounted.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. American Standard America.
  - b. Kohler Co.
2. Fixture:
  - a. Standard: ASME A112.19.2/CSA B45.1.
  - b. Type: Slab or wheelchair.
  - c. Nominal Size: Oval, 21-15/16" x 19-3/4".
  - d. Faucet-Hole Punching: One hole .
  - e. Faucet-Hole Location: Top.
  - f. Color: White.
  - g. Mounting: For concealed-arm carrier.
3. Faucet: Solid-Brass, Automatically Operated Lavatory Faucets.
4. Support: ASME A112.6.1M, Type II, concealed-arm lavatory carrier with rectangular, steel uprights.

2.3 SOLID-BRASS, AUTOMATICALLY OPERATED LAVATORY FAUCETS

- A. NSF Standard: Comply with NSF/ANSI 61 Annex G, "Drinking Water System Components - Health Effects," for faucet materials that will be in contact with potable water.
- B. Lavatory Faucets: Automatic-type, hard-wired, electronic-sensor-operated, mixing, solid-brass valve.
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Chicago Faucets; Geberit Company.
    - b. Kohler Co.
    - c. Sloan Valve Company.
  - 2. Standards: ASME A112.18.1/CSA B125.1 and UL 1951.
  - 3. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
  - 4. General: Include hot- and cold-water indicators; coordinate faucet inlets with supplies and fixture hole punchings; coordinate outlet with spout and fixture receptor.
  - 5. Body Type: Single hole.
  - 6. Body Material: Commercial, solid brass.
  - 7. Finish: Polished chrome plate.
  - 8. Maximum Flow Rate: 0.5 gpm (1.5 L/min.).
  - 9. Mounting Type: Deck, concealed.
  - 10. Spout: Rigid type.
  - 11. Spout Outlet: Aerator.
  - 12. Drain: Not part of faucet.

2.4 SUPPLY FITTINGS

- A. NSF Standard: Comply with NSF/ANSI 61 Annex G, "Drinking Water System Components - Health Effects," for supply-fitting materials that will be in contact with potable water.
- B. Standard: ASME A112.18.1/CSA B125.1.
- C. Supply Piping: Chrome-plated-brass pipe or chrome-plated copper tube matching water-supply piping size. Include chrome-plated-brass or stainless-steel wall flange.
- D. Supply Stops: Chrome-plated-brass, one-quarter-turn, ball-type or compression valve with inlet connection matching supply piping.
- E. Operation: Loose key.
- F. Risers:
  - 1. NPS 3/8 (DN 10).

2. Chrome-plated, rigid-copper-pipe and brass straight or offset tailpieces ASME A112.18.6, braided- or corrugated-stainless-steel, flexible hose riser.

## 2.5 WASTE FITTINGS

- A. Standard: ASME A112.18.2/CSA B125.2.
- B. Drain: Grid type with NPS 1-1/4 (DN 32) offset and straight tailpiece.
- C. Trap:
  1. Size: NPS 1-1/2 by NPS 1-1/4 (DN 40 by DN 32).
  2. Material: Chrome-plated, two-piece, cast-brass trap and swivel elbow with 0.032-inch- (0.83-mm-) thick brass tube to wall two-piece, cast-brass trap and ground-joint swivel elbow with 0.032-inch- (0.83-mm-) thick brass tube to wall one-piece, cast-brass trap with swivel 0.029-inch- (73-mm-) thick tubular brass wall bend; and chrome-plated, brass or steel wall flange.
  3. Material: Stainless-steel, two-piece trap and swivel elbow with 0.012-inch- (0.30-mm-) thick stainless-steel tube to wall; and stainless-steel wall flange.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine roughing-in of water supply and sanitary drainage and vent piping systems to verify actual locations of piping connections before lavatory installation.
- B. Examine counters and walls for suitable conditions where lavatories will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. Install lavatories level and plumb according to roughing-in drawings.
- B. Install supports, affixed to building substrate, for wall-mounted lavatories.
- C. Install accessible wall-mounted lavatories at handicapped/elderly mounting height for people with disabilities or the elderly, according to ICC/ANSI A117.1.
- D. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations. Use deep-pattern escutcheons if required to conceal protruding fittings. Comply with escutcheon requirements specified in Section 220518 "Escutcheons for Plumbing Piping."
- E. Seal joints between lavatories, counters, and walls using sanitary-type, one-part, mildew-resistant silicone sealant. Match sealant color to fixture color. Comply with sealant requirements specified in Section 079200 "Joint Sealants."



- F. Install protective shielding pipe covers and enclosures on exposed supplies and waste piping of accessible lavatories. Comply with requirements in Section 220719 "Plumbing Piping Insulation."

### 3.3 CONNECTIONS

- A. Connect fixtures with water supplies, stops, and risers, and with traps, soil, waste, and vent piping. Use size fittings required to match fixtures.
- B. Comply with water piping requirements specified in Section 221116 "Domestic Water Piping."
- C. Comply with soil and waste piping requirements specified in Section 221316 "Sanitary Waste and Vent Piping."

### 3.4 ADJUSTING

- A. Operate and adjust lavatories and controls. Replace damaged and malfunctioning lavatories, fittings, and controls.
- B. Adjust water pressure at faucets to produce proper flow.
- C. Install fresh batteries in battery-powered, electronic-sensor mechanisms.

### 3.5 CLEANING AND PROTECTION

- A. After completing installation of lavatories, inspect and repair damaged finishes.
- B. Clean lavatories, faucets, and other fittings with manufacturers' recommended cleaning methods and materials.
- C. Provide protective covering for installed lavatories and fittings.
- D. Do not allow use of lavatories for temporary facilities unless approved in writing by Owner.

END OF SECTION 224216.13

## SECTION 224216.16 - COMMERCIAL SINKS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:

1. Service basins.
2. Service sinks.
3. Utility sinks.
4. Handwash sinks.
5. Sacristy sinks.
6. Sink faucets.
7. Laminar-flow, faucet-spout outlets.
8. Supply fittings.
9. Waste fittings.

- B. Related Requirements:

1. Section 224100 "Residential Plumbing Fixtures" for residential sinks.

#### 1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.

1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for sinks.
2. Include rated capacities, operating characteristics and furnished specialties and accessories.

- B. LEED Submittals:

1. Product Data for Prerequisite WE 1 and Credit WE 3, Credit WE 2, and Credit WE 3: Documentation indicating flow and water consumption requirements.
2. Product Data for Prerequisite WE 1: Documentation indicating flow and water consumption requirements.
3. Product Data for Prerequisite WE 1 and Credit WE 2: Documentation indicating flow and water consumption requirements.

1.4 INFORMATIONAL SUBMITTALS

- A. Coordination Drawings: Counter cutout templates for mounting of counter-mounted lavatories.

1.5 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For sinks to include in maintenance manuals.

1.6 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
1. Faucet Washers and O-Rings: Equal to 10 percent of amount of each type and size installed.
  2. Faucet Cartridges and O-Rings: Equal to 5 percent of amount of each type and size installed.

PART 2 - PRODUCTS

2.1 SERVICE BASINS

- A. Service Basins: Terrazzo, floor mounted.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Fiat Products.
    - b. Florestone Products Co., Inc.
  2. Fixture:
    - a. Standard: IAPMO PS 99.
    - b. Shape: Square.
    - c. Nominal Size: 24 by 24 inches (610 by 610 mm).
    - d. Height: [**10 inches (255 mm)**].
    - e. Tiling Flange: On two or **three sides**.
    - f. Rim Guard: On all top surfaces.
    - g. Color: **White**.
    - h. Drain: Grid with NPS 3 (DN 80) outlet.
  3. Mounting: On floor and flush to wall.
  4. Faucet: **Wall mounted, two lever handle, with vacuum breaker and pail hook.**

## 2.2 UTILITY SINKS

### A. Utility Sinks: Stainless steel, counter mounted.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Advance Tabco.
  - b. Just Manufacturing.
2. Fixture:
  - a. Standard: ASME A112.19.3/CSA B45.4.
  - b. Type: Ledge back.
  - c. Number of Compartments: One.
  - d. Overall Dimensions: **20" x 17"**.
  - e. Metal Thickness: 18 Gauge.
  - f. Compartment:
    - 1) Drain: Grid with NPS 1-1/2 (DN 40) tailpiece and twist drain.
    - 2) Drain Location: Centered in compartment.
3. Faucet(s): **Deck mounted, Rigid/Swing plain end Gooseneck Spout**.
  - a. Number Required: One.
  - b. Mounting: On ledge.
4. Supply Fittings:
  - a. Standard: ASME A112.18.1/CSA B125.1.
  - b. Supplies: Chrome-plated brass compression stop with inlet connection matching water-supply piping type and size.
    - 1) Operation: Loose key.
    - 2) Risers: NPS 1/2 (DN 15), chrome-plated, rigid-copper pipe ASME A112.18.6, braided or corrugated stainless-steel flexible hose.
5. Waste Fittings:
  - a. Standard: ASME A112.18.2/CSA B125.2.
  - b. Trap(s):
    - 1) Size: NPS 1-1/2 (DN 40).
    - 2) Material: Chrome-plated, two-piece, cast-brass trap and swivel elbow with 0.032-inch- (0.83-mm-) thick brass tube to wall; and chrome-plated brass or steel wall flange.
    - 3) Material: Stainless-steel, two-piece trap and swivel elbow with 0.012-inch- (0.30-mm-) thick stainless-steel tube to wall; and stainless-steel wall flange.

c. Continuous Waste:

- 1) Size: NPS 1-1/2 (DN 40).
- 2) Material: Chrome-plated, 0.032-inch- (0.83-mm-) thick brass tube.

6. Mounting: On counter with sealant.

2.3 SINK FAUCETS

A. NSF Standard: Comply with NSF/ANSI 61 Annex G, "Drinking Water System Components - Health Effects," for faucet-spout materials that will be in contact with potable water.

B. Sink Faucets: Manual type, two-lever-handle mixing valve.

1. Commercial, Solid-Brass Faucets.

a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- 1) Chicago Faucets; Geberit Company.
- 2) Delta Faucet Company.
- 3) Moen Incorporated.

2. General-Duty, Solid-Brass Faucets.

a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- 1) Chicago Faucets; Geberit Company.
- 2) Delta Faucet Company.
- 3) Moen Incorporated.

2.4 SUPPLY FITTINGS

A. NSF Standard: Comply with NSF/ANSI 61 Annex G, "Drinking Water System Components - Health Effects," for supply-fitting materials that will be in contact with potable water.

B. Standard: ASME A112.18.1/CSA B125.1.

C. Supply Piping: Chrome-plated brass pipe or chrome-plated copper tube matching water-supply piping size. Include chrome-plated brass or stainless-steel wall flange.

D. Supply Stops: Chrome-plated brass, one-quarter-turn, ball-type or compression valve with inlet connection matching supply piping.

E. Operation: Loose key.

F. Risers:

1. NPS 3/8 (DN 10)
2. Chrome-plated, soft-copper flexible tube ASME A112.18.6, braided or corrugated stainless-steel flexible hose.

## 2.5 WASTE FITTINGS

- A. Standard: ASME A112.18.2/CSA B125.2.
- B. Drain: Grid type with NPS 1-1/2 (DN 40) offset and straight tailpiece.
- C. Trap:
  1. Size: NPS 1-1/2 (DN 40).
  2. Material: Chrome-plated, two-piece, cast-brass trap and swivel elbow with 0.032-inch- (0.83-mm-) thick brass tube to wall one-piece, cast-brass trap with swivel 0.029-inch- (73-mm-) thick tubular brass wall bend; and chrome-plated brass or steel wall flange.
  3. Material: Stainless-steel, two-piece trap and swivel elbow with 0.012-inch- (0.30-mm-) thick stainless-steel tube to wall; and stainless-steel wall flange.

## 2.6 GROUT

- A. Standard: ASTM C 1107/C 1107M, Grade B, post-hardening and volume-adjusting, dry, hydraulic-cement grout.
- B. Characteristics: Nonshrink; recommended for interior and exterior applications.
- C. Design Mix: 5000-psi (34.5-MPa), 28-day compressive strength.
- D. Packaging: Premixed and factory packaged.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine roughing-in of water supply and sanitary drainage and vent piping systems to verify actual locations of piping connections before sink installation.
- B. Examine walls, floors, and counters for suitable conditions where sinks will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. Install sinks level and plumb according to roughing-in drawings.
- B. Install supports, affixed to building substrate, for wall-hung sinks.

- C. Install accessible wall-mounted sinks at handicapped/elderly mounting height according to ICC/ANSI A117.1.
- D. Set floor-mounted sinks in leveling bed of cement grout.
- E. Install water-supply piping with stop on each supply to each sink faucet.
  - 1. Exception: Use ball or gate valves if supply stops are not specified with sink. Comply with valve requirements specified in Section 220523.12 "Ball Valves for Plumbing Piping" and Section 220523.15 "Gate Valves for Plumbing Piping."
  - 2. Install stops in locations where they can be easily reached for operation.
- F. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations. Use deep-pattern escutcheons if required to conceal protruding fittings. Comply with escutcheon requirements specified in Section 220518 "Escutcheons for Plumbing Piping."
- G. Seal joints between sinks and counters, floors, and walls using sanitary-type, one-part, mildew-resistant silicone sealant. Match sealant color to fixture color. Comply with sealant requirements specified in Section 079200 "Joint Sealants."
- H. Install protective shielding pipe covers and enclosures on exposed supplies and waste piping of accessible sinks. Comply with requirements in Section 220719 "Plumbing Piping Insulation."

### 3.3 CONNECTIONS

- A. Connect sinks with water supplies, stops, and risers, and with traps, soil, waste, and vent piping. Use size fittings required to match fixtures.
- B. Comply with water piping requirements specified in Section 221116 "Domestic Water Piping."
- C. Comply with soil and waste piping requirements specified in Section 221316 "Sanitary Waste and Vent Piping."

### 3.4 ADJUSTING

- A. Operate and adjust sinks and controls. Replace damaged and malfunctioning sinks, fittings, and controls.
- B. Adjust water pressure at faucets to produce proper flow.

### 3.5 CLEANING AND PROTECTION

- A. After completing installation of sinks, inspect and repair damaged finishes.
- B. Clean sinks, faucets, and other fittings with manufacturers' recommended cleaning methods and materials.
- C. Provide protective covering for installed sinks and fittings.



D. Do not allow use of sinks for temporary facilities unless approved in writing by Owner.

END OF SECTION 224216.16

## SECTION 224223 - COMMERCIAL SHOWERS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Shower faucets.
  - 2. Grout.
- B. Related Requirements:
  - 1. Section 224100 "Residential Plumbing Fixtures" for residential showers.
  - 2. Section 224300 "Medical Plumbing Fixtures" for healthcare showers.
  - 3. Section 224500 "Emergency Plumbing Fixtures" for emergency showers.
  - 4. Section 224600 "Security Plumbing Fixtures" for security showers.

#### 1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for showers and basins.
  - 2. Include rated capacities, operating characteristics, and furnished specialties and accessories.
- B. LEED Submittals:
  - 1. Product Data for Prerequisite WE 1 and Credit WE 3, Credit WE 2, and Credit WE 3: Documentation indicating flow and water consumption requirements.
  - 2. Product Data for Prerequisite WE 1: Documentation indicating flow and water consumption requirements.
  - 3. Product Data for Prerequisite WE 1 and Credit WE 2: Documentation indicating flow and water consumption requirements.

#### 1.4 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For shower faucets to include in maintenance manuals.

1.5 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Faucet Washers and O-Rings: Equal to 10 percent of amount of each type and size installed.
  - 2. Faucet Cartridges and O-Rings: Equal to 5 percent of amount of each type and size installed.

PART 2 - PRODUCTS

2.1 SHOWER FAUCETS

- A. NSF Standard: Comply with NSF 61 Annex G, "Drinking Water System Components - Health Effects," for shower materials that will be in contact with potable water.
- B. Shower Faucets:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. American Standard America.
    - b. Kohler Co.
    - c. Moen Incorporated.
    - d. Symmons.
  - 2. Description: Single-handle, pressure-balance mixing valve with hot- and cold-water indicators; check stops; and shower head.
  - 3. Faucet:
    - a. Standards: ASME A112.18.1/CSA B125.1 and ASSE 1016.
    - b. Body Material: Solid brass.
    - c. Finish: Polished chrome plate.
    - d. Maximum Flow Rate: 2.5 gpm (9.5 L/min.) unless otherwise indicated.
    - e. Mounting: Exposed.
    - f. Operation: Single-handle, twist or rotate control.
    - g. Antiscald Device: Not required.
    - h. Check Stops: Check-valve type, integral with or attached to body; on hot- and cold-water supply connections.
  - 4. Supply Connections: NPS 1/2 (DN 15).
  - 5. Shower Head:
    - a. Standard: ASME A112.18.1/CSA B125.1.
    - b. Type: Ball joint with arm and flange, Ball joint and head integral with mounting flange.

- c. Shower Head Material: Metallic with chrome-plated finish.
- d. Spray Pattern: Adjustable.
- e. Integral Volume Control: Required.
- f. Shower-Arm, Flow-Control Fitting: Not required.
- g. Temperature Indicator: Not required.

## 2.2 GROUT

- A. Standard: ASTM C 1107/C 1107M, Grade B, post-hardening and volume-adjusting, dry, hydraulic-cement grout.
- B. Characteristics: Nonshrink; recommended for interior and exterior applications.
- C. Design Mix: 5000-psi (34.5-MPa), 28-day compressive strength.
- D. Packaging: Premixed and factory packaged.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine roughing-in of water-supply and sanitary drainage and vent piping systems to verify actual locations of piping connections before shower installation.
- B. Examine walls and floors for suitable conditions where showers will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. Assemble shower components according to manufacturers' written instructions.
- B. Install showers level and plumb according to roughing-in drawings.
- C. Install water-supply piping with stop on each supply to each shower faucet.
  - 1. Exception: Use ball or gate valves if supply stops are not specified with shower. Comply with valve requirements specified in Section 220523.12 "Ball Valves for Plumbing Piping" and Section 220523.15 "Gate Valves for Plumbing Piping."
  - 2. Install stops in locations where they can be easily reached for operation.
- D. Install shower flow-control fittings with specified maximum flow rates in shower arms.
- E. Set shower receptors and shower basins in leveling bed of cement grout.

- F. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations. Use deep-pattern escutcheons if required to conceal protruding fittings. Comply with escutcheons requirements specified in Section 220518 "Escutcheons for Plumbing Piping."
- G. Seal joints between showers and floors and walls using sanitary-type, one-part, mildew-resistant silicone sealant. Match sealant color to fixture color. Comply with sealant requirements specified in Section 079200 "Joint Sealants."

### 3.3 CONNECTIONS

- A. Connect fixtures with water supplies, stops, and risers, and with traps, soil, waste, and vent piping. Use size fittings required to match fixtures.
- B. Comply with water piping requirements specified in Section 221116 "Domestic Water Piping."
- C. Comply with traps and soil and waste piping requirements specified in Section 221316 "Sanitary Waste and Vent Piping."

### 3.4 ADJUSTING

- A. Operate and adjust showers and controls. Replace damaged and malfunctioning showers, fittings, and controls.
- B. Adjust water pressure at faucets to produce proper flow.

### 3.5 CLEANING AND PROTECTION

- A. After completing installation of showers and basins, inspect and repair damaged finishes.
- B. Clean showers and basins, faucets, and other fittings with manufacturers' recommended cleaning methods and materials.
- C. Provide protective covering for installed fixtures and fittings.
- D. Do not allow use of showers and basins for temporary facilities unless approved in writing by Owner.

END OF SECTION 224223

SECTION 224500 - EMERGENCY PLUMBING FIXTURES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
  - 1. Eyewash equipment.
  - 2. Eye/face wash equipment.
  - 3. Supplemental equipment.

1.3 DEFINITIONS

- A. Accessible Fixture: Emergency plumbing fixture that can be approached, entered, and used by people with disabilities.
- B. Plumbed Emergency Plumbing Fixture: Fixture with fixed, potable-water supply.
- C. Self-Contained Emergency Plumbing Fixture: Fixture with flushing-fluid-solution supply.
- D. Tepid: Moderately warm.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated. Include flow rates and capacities, furnished specialties, and accessories.
- B. Shop Drawings: Diagram power, signal, and control wiring.

1.5 INFORMATIONAL SUBMITTALS

- A. Product Certificates: Submit certificates of performance testing specified in "Source Quality Control" Article.
- B. Field quality-control test reports.

1.6 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For emergency plumbing fixtures to include in operation and maintenance manuals.

1.7 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. ANSI Standard: Comply with ANSI Z358.1, "Emergency Eyewash and Shower Equipment."
- C. NSF Standard: Comply with NSF 61 Annex G, "Drinking Water System Components - Health Effects," for fixture materials that will be in contact with potable water.
- D. Regulatory Requirements: Comply with requirements in ICC/ANSI A117.1, "Accessible and Usable Buildings and Facilities"; Public Law 90-480, "Architectural Barriers Act"; and Public Law 101-336, "Americans with Disabilities Act"; for plumbing fixtures for people with disabilities.

PART 2 - PRODUCTS

- A. Accessible, Wall-Mounted, Plumbed, Eye/Face Wash Units:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Bradley Corporation.
    - b. Guardian Equipment Co.
    - c. Haws Corporation.
  - 2. Capacity: Not less than 3.0 gpm (11.4 L/min.) for at least 15 minutes.
  - 3. Supply Piping: NPS 1/2 (DN 15) chrome-plated brass or stainless steel with flow regulator and stay-open control valve.
  - 4. Control-Valve Actuator: Paddle.
  - 5. Spray-Head Assembly: Two or four receptor-mounted spray heads.
  - 6. Receptor: Chrome-plated brass or stainless-steel bowl.
  - 7. Mounting: Wall bracket.
  - 8. Special Construction: Comply with ICC/ANSI A117.1.

2.2 SOURCE QUALITY CONTROL

- A. Certify performance of emergency plumbing fixtures by independent testing organization acceptable to authorities having jurisdiction.



PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine roughing-in for water and waste piping systems to verify actual locations of piping connections before plumbed emergency plumbing fixture installation.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 EMERGENCY PLUMBING FIXTURE INSTALLATION

- A. Assemble emergency plumbing fixture piping, fittings, control valves, and other components.
- B. Install fixtures level and plumb.
- C. Fasten fixtures to substrate.
- D. Install shutoff valves in water-supply piping to fixtures. Use ball or gate valve if specific type valve is not indicated. Install valves chained or locked in open position if permitted. Install valves in locations where they can easily be reached for operation. Comply with requirements for valves specified in Section 220523.12 "Ball Valves for Plumbing Piping" and Section 220523.15 "Gate Valves for Plumbing Piping."
  - 1. Exception: Omit shutoff valve on supply to group of plumbing fixtures that includes emergency equipment.
  - 2. Exception: Omit shutoff valve on supply to emergency equipment if prohibited by authorities having jurisdiction.
- E. Install shutoff valve and strainer in steam piping and shutoff valve in condensate return piping. Comply with requirements for steam and condensate piping specified in Section 232213 "Steam and Condensate Heating Piping" and Section 232216 "Steam and Condensate Piping Specialties."
- F. Install dielectric fitting in supply piping to emergency equipment if piping and equipment connections are made of different metals. Comply with requirements for dielectric fittings specified in Section 221116 "Domestic Water Piping."
- G. Install thermometers in supply and outlet piping connections to water-tempering equipment. Comply with requirements for thermometers specified in Section 220519 "Meters and Gages for Plumbing Piping."
- H. Install trap and waste piping on drain outlet of emergency equipment receptors that are indicated to be directly connected to drainage system. Comply with requirements for waste piping specified in Section 221316 "Sanitary Waste and Vent Piping."
- I. Install indirect waste piping on drain outlet of emergency equipment receptors that are indicated to be indirectly connected to drainage system. Comply with requirements for waste piping specified in Section 221316 "Sanitary Waste and Vent Piping."

- J. Install escutcheons on piping wall and ceiling penetrations in exposed, finished locations. Comply with requirements for escutcheons specified in Section 220518 "Escutcheons for Plumbing Piping."
- K. Fill self-contained fixtures with flushing fluid.

### 3.3 CONNECTIONS

- A. Connect cold-water-supply piping to plumbed emergency plumbing fixtures not having water-tempering equipment. Comply with requirements for cold-water piping specified in Section 221116 "Domestic Water Piping."
- B. Connect hot- and cold-water-supply piping to hot- and cold-water, water-tempering equipment. Connect output from water-tempering equipment to emergency plumbing fixtures. Comply with requirements for hot- and cold-water piping specified in Section 221116 "Domestic Water Piping."
- C. Connect steam and cold-water-supply and condensate return piping to steam and cold water-tempering equipment. Connect output from water-tempering equipment to emergency plumbing fixtures. Comply with requirements for cold-water piping specified in Section 221116 "Domestic Water Piping" and comply with requirements for steam and condensate piping specified in Section 232213 "Steam and Condensate Heating Piping" and Section 232216 "Steam and Condensate Piping Specialties."
- D. Connect cold water and electrical power to electric heating water-tempering equipment. Comply with requirements for cold-water piping specified in Section 221116 "Domestic Water Piping."
- E. Directly connect emergency plumbing fixture receptors with trapped drain outlet to sanitary waste and vent piping. Comply with requirements for waste piping specified in Section 221316 "Sanitary Waste and Vent Piping."
- F. Indirectly connect emergency plumbing fixture receptors without trapped drain outlet to sanitary waste or storm drainage piping.
- G. Where installing piping adjacent to emergency plumbing fixtures, allow space for service and maintenance of fixtures.

### 3.4 IDENTIFICATION

- A. Install equipment nameplates or equipment markers on emergency plumbing fixtures and equipment and equipment signs on water-tempering equipment. Comply with requirements for identification materials specified in Section 220553 "Identification for Plumbing Piping and Equipment."

3.5 FIELD QUALITY CONTROL

- A. Mechanical-Component Testing: After plumbing connections have been made, test for compliance with requirements. Verify ability to achieve indicated capacities.
- B. Tests and Inspections:
  - 1. Perform each visual and mechanical inspection.
  - 2. Leak Test: After installation, charge system and test for leaks. Repair leaks and retest until no leaks exist.
  - 3. Operational Test: After electrical circuitry has been energized, start units to confirm proper unit operation.
  - 4. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- C. Emergency plumbing fixtures and water-tempering equipment will be considered defective if they do not pass tests and inspections.
- D. Prepare test and inspection reports.

3.6 ADJUSTING

- A. Adjust or replace fixture flow regulators for proper flow.
- B. Adjust equipment temperature settings.

END OF SECTION 224500

## SECTION 224600 - SECURITY PLUMBING FIXTURES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:

1. Combination units.
2. Water closets.
3. Urinals.
4. Lavatories.
5. Drinking fountains.
6. Showers.
7. Service sinks.
8. Supports.

- B. Related Requirements:

1. Section 224213.13 "Commercial Water Closets."
2. Section 224213.16 "Commercial Urinals."
3. Section 224216.13 "Commercial Lavatories."
4. Section 224216.16 "Commercial Sinks."
5. Section 224223 "Commercial Showers."
6. Section 224233 "Wash Fountains."
7. Section 224300 "Healthcare Plumbing Fixtures."
8. Section 224500 "Emergency Plumbing Fixtures" for emergency showers.
9. Section 224713 "Drinking Fountains" for standard drinking fountains.

#### 1.3 DEFINITIONS

- A. Accessible Service Space: Service area in secure space behind wall-mounted fixtures.
- B. Back-Access Fixture: Security plumbing fixture designed to mount on wall sleeve built into wall or on wall, so installation and removal of fixture, piping, and other components are accessible only from service space behind wall.
- C. Front-Access Fixture: Security plumbing fixture designed to mount on wall with installation and removal from fixture side of wall, and with piping and other components accessible only from access panel in fixture.

#### 1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for security plumbing fixtures.
  - 2. Include rated capacities, operating characteristics, and furnished specialties and accessories.
- B. LEED Submittals:
  - 1. Product Data for Prerequisite WE 1 and Credit WE 3, Credit WE 2, and Credit WE 3: Documentation indicating flow and water consumption requirements.
  - 2. Product Data for Prerequisite WE 1 and Credit WE 1: Documentation indicating flow and water consumption requirements.
  - 3. Product Data for Prerequisite WE 1 and Credit WE 2: Documentation indicating flow and water consumption requirements.

#### 1.5 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For security plumbing fixtures and components to include in maintenance manuals.

#### 1.6 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Flushometer-Valve Repair Kits: Equal to 10 percent of quantity of each type installed, but no fewer than 5 of each type.
  - 2. Toilet Seats: Equal to five percent of quantity of each type installed.

### PART 2 - PRODUCTS

#### 2.1 COMBINATION UNITS

- A. Combination Units: Back access, on floor, cabinet, with water closet and lavatory.
  - 1. Manufacturers: Subject to compliance with requirements, provide products by the following:
    - a. Acorn Engineering Company.
  - 2. Material: 0.078-inch- (2.0-mm-) minimum-thick stainless steel; corrosion-resistant metal for internal piping and bracing.
  - 3. Finish: ASTM A 480/A 480M, No. 4 polished finish on exposed surfaces.

4. Cabinet: Multi-sided apron with backsplash.
  - a. Water-Closet Bowl Location: Per contract drawings.
  - b. Toilet-Paper Holder: Recessed; stainless steel located left of center in front of apron.
5. Accessories:
  - a. Toothbrush Holders: None.
  - b. Towel Hooks: None.
  - c. Bubbler: On deck.
6. Mounting: Bolts through wall sleeve into accessible service space.
7. Water Closet:
  - a. Standard: IAPMO PS 61.
  - b. Bowl:
    - 1) Type: Elongated, with back inlet, integral trap, and blowout design with back outlet and contoured seat.
    - 2) Seat Surface: ASTM A 480/A 480M, No. 7 polished finish.
    - 3) Punching: Two holes for installation of separate toilet seat.
    - 4) Outlet Connection: NPS 4 (DN 100), horizontal with cleanout and slip joint.
8. Flushometer Valve: Concealed high efficiency.
9. Toilet Seat: High polished seat.
10. Lavatory:
  - a. Standard: ASME A 112.19.3/CSA B45.4.
  - b. Location: In top of cabinet.
  - c. Receptor: Oval bowl with integral soap depression.
  - d. Hot- and Cold-Water and Bubbler Supply Valves: Mechanical-metering type with push-button actuation and individual check stops complying with ASME A112.18.1/CSA B125.1.
  - e. Filler Spout: **deck** mounted.
  - f. Drain: Integral punched grid with NPS 1-1/4 (DN 32) minimum waste and trap complying with ASME A112.18.2/CSA B125.2.
11. Wall Sleeve: Galvanized-steel frame of dimensions required to match fixture. Include steel bars or other design to prevent escape if fixture is removed.
- 12.

## 2.2 STAINLESS-STEEL WATER CLOSETS

- A. Water Closets: Back access, on floor, back outlet, cabinet.

1. Manufacturers: Subject to compliance with requirements, provide products by the following:
  - a. Acorn Engineering Company.
2. Material: 0.078-inch- (2.0-mm-) minimum-thick stainless steel; corrosion-resistant metal for internal piping and bracing.
3. Finish: ASTM A 480/A 480M, No. 4 polished finish on exposed surfaces.
4. Cabinet Per contract drawings with backsplash.
  - a. Water-Closet Bowl Location: Centered on front of apron.
  - b. Toilet-Paper Holder: Per contract drawings.
  - c. Toilet seat: Per contract drawings.
5. Mounting: Bolts through wall sleeve into accessible service space.
6. Water Closet:
  - a. Standard: IAPMO PS 61.
  - b. Bowl:
    - 1) Type: Elongated, with back inlet, integral trap, and blowout design with back outlet and contoured seat.
    - 2) Type: Elongated, with back inlet, integral trap, and siphon-jet design with bottom outlet and contoured seat.
    - 3) Back-Outlet Connection: NPS 4 (DN 100), horizontal with cleanout and slip joint.
    - 4) Bottom-Outlet Connection: NPS 4 (DN 100), vertical.
    - 5) Seat Surface: ASTM A 480/A 480M, No. 7 polished finish.
    - 6) Punching: Two holes for installation of separate toilet seat.
7. Flushometer Valve: Concealed high efficiency.
8. Toilet Seat: High polished seat.
9. Wall Sleeve: Galvanized-steel frame of dimensions required to match fixture. Include steel bars or other design to prevent escape if fixture is removed.
  - a. Configuration: Modify wall sleeve for water-closet mounting height according to ICC A117.1.

### 2.3 FLUSHOMETER VALVES

#### A. Flushometer Valves: Concealed diaphragm with Push button.

1. Manufacturers: Subject to compliance with requirements, provide products by the following:
  - a. Sloan Valve Company.
2. Standard: ASSE 1037.

3. Minimum Pressure Rating: 125 psig (860 kPa).
4. Features: Integral check stops and backflow-prevention device.
5. Material: Brass body with corrosion-resistant components.
6. Panel Finish: Chrome plated or stainless steel.
7. Style: Concealed.
8. Consumption: 1.28 gpf for water closets and 0.125 gpf for urinals.
9. Minimum Inlet: NPS 1 (DN 25).
10. Minimum Outlet: NPS 1-1/4 (DN 32).

## 2.4 URINALS

### A. Urinals: Back access, back outlet, single.

1. Manufacturers: Subject to compliance with requirements, provide products by the following:
  - a. Acorn Engineering Company.
2. Fixture:
  - a. Standard: IAPMO PS 61.
  - b. Material: 0.078-inch- (2.0-mm-) minimum-thick stainless steel; corrosion-resistant metal for internal piping and bracing.
  - c. Finish: ASTM A 480/A 480M, No. 4 polished finish on exposed surfaces.
  - d. Type and Configuration: Blowout or Washout, with back inlet.
  - e. Drain: Strainer with NPS 2 (DN 50) tailpiece and trap.
3. Mounting: Bolts through wall sleeve into accessible service space.
4. Flushometer Valve: Concealed diaphragm with Push button.
5. Wall Sleeve: Galvanized-steel frame of dimensions required to match fixture.

## 2.5 STAINLESS-STEEL LAVATORIES

### A.

1. Manufacturers: Subject to compliance with requirements, provide products by the following:
  - a. Acorn Engineering Company.
2. Fixture:
  - a. Standard: IAPMO PS 61.
  - b. Material: 0.078-inch- (2.0-mm-) minimum-thick stainless steel; corrosion-resistant metal for internal piping and bracing.
  - c. Finish: ASTM A 480/A 480M, No. 4 polished finish on exposed surfaces.
  - d. Receptor: rectangular bowl with integral soap depression, backsplash, and access panel.



- e. Hot- and Cold-Water and Bubbler Supply Valves: Mechanical-metering type with push-button actuation, individual check stops, and backsplash-mounted filler spouts complying with ASME A112.18.1/CSA B125.1.
  - f. Drain: Integral punched grid with NPS 1-1/4 (DN 32) minimum horizontal waste and trap complying with ASME A112.18.2/CSA B125.2.
3. Mounting: Bolts from fixture-mounted flanges into wall.
  4. Faucet: Integral, H & C metering, 4" centered.

## 2.6 SHOWERS

### A. Showers: Front access, recessed.

1. Manufacturers: Subject to compliance with requirements, provide products by the following:
  - a. Acorn Engineering Company.
2. Fixture:
  - a. Standard: ASME A112.19.3/CSA B45.4.
  - b. Material: 0.078-inch- (2.0-mm-) minimum-thick stainless steel; corrosion-resistant metal for internal piping and bracing.
  - c. Finish: ASTM A 480/A 480M, No. 4 polished finish on exposed surfaces.
  - d. Type and Configuration: Wall, with showerhead and soap dish.
  - e. Hot- and Cold-Water Supply Valves: Mechanical-metering type with individual check stops complying with ASME A112.18.1/CSA B125.1.
  - f. Shower: Hose with vandal-resistant, hand-held Vandal-resistant, fixed-type head.
  - g. Soap Dish: Recessed, stainless steel.
  - h. Access to Internal Components: Vandal-resistant access panels.
3. Mounting: Bolts from fixture-mounted flanges into wall.

## 2.7 SUPPORTS

### A. Type III Lavatory Carrier:

1. Manufacturers: Subject to compliance with requirements, provide products by the following:
  - a. Zurn Industries, LLC.
2. ASME A112.6.1M.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine roughing-in for water supply and sanitary drainage and vent piping systems to verify actual locations of piping connections before fixture installation.
- B. Examine walls and floors for suitable conditions where fixtures will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Install security plumbing fixtures level and plumb according to roughing-in drawings.
- B. Install back-access, stainless-steel fixtures as follows:
  - 1. Install wall sleeve in wall if indicated.
  - 2. Install fixture on wall sleeve or wall, as indicated, with access from accessible service space.
  - 3. Extend supply piping from service space to fixture.
  - 4. Install soil and waste piping from fixture and extend into service space.
  - 5. Install fixture trap in service space instead of below fixture drain.
- C. Install front-access, stainless-steel fixtures as follows:
  - 1. Install fixture support or mounting bracket.
  - 2. Install fixture on support; mount components inside of or attached to fixture.
  - 3. Extend supply piping from pipe space to fixture.
  - 4. Install trap below fixture and extend soil and waste piping into pipe space.
- D. Install vitreous-china fixture service space as follows:
  - 1. Install fixture support in service space.
    - a. Use combination support and waste fitting assembly for water closet.
    - b. Use chair carrier for lavatory.
  - 2. Install fixture on support.
  - 3. Install components in service space.
- E. Install fixture outlets with gasket seals.
- F. Install fixtures designated "accessible" according to ICC A117.1 for heights, dimensions, and clearances.
- G. Install toilet seats on water closets and combination units if seats are indicated.

- H. Install protective shielding pipe covers and enclosures on exposed supplies and waste piping of accessible fixtures. Comply with requirements in Section 220719 "Plumbing Piping Insulation."
- I. Seal joints between fixtures, floors, and walls using sanitary-type, one-part, mildew-resistant silicone sealant. Match sealant color to fixture color. Comply with sealant requirements specified in Section 079200 "Joint Sealants."
- J. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations. Use deep-pattern escutcheons if required to conceal protruding fittings. Comply with escutcheon requirements specified in Section 220518 "Escutcheons for Plumbing Piping."

### 3.3 CONNECTIONS

- A. Connect fixtures with water supplies, stops, and risers, and with traps, soil, waste, and vent piping. Use size fittings required to match fixtures.
- B. Comply with requirements for water piping specified in Section 221116 "Domestic Water Piping."
- C. Comply with requirements for soil and waste drainage piping specified in Section 221316 "Sanitary Waste and Vent Piping."

### 3.4 ADJUSTING

- A. Operate and adjust flushometer valves and flow-control valves on fixtures.

### 3.5 CLEANING AND PROTECTION

- A. After installing fixtures, inspect and repair damaged finishes.
- B. Clean fixtures, faucets, and other fittings with manufacturers' recommended cleaning methods and materials.
- C. Provide protective covering for installed fixtures and fittings.
- D. Do not allow use of fixtures for temporary facilities unless approved in writing by Owner.

END OF SECTION 224600

## SECTION 224713 - DRINKING FOUNTAINS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes drinking fountains and related components.

#### 1.3 ACTION SUBMITTALS

- A. Product Data: For each type of drinking fountain.
  - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes.
  - 2. Include operating characteristics, and furnished specialties and accessories.
- B. LEED Submittals:
  - 1. Product Data for Prerequisite WE 1 and Credit WE 3, Credit WE 2, and Credit WE 3: Documentation indicating flow and water consumption requirements.

#### 1.4 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For drinking fountains to include in maintenance manuals.

### PART 2 - PRODUCTS

#### 2.1 DRINKING FOUNTAINS

- 1.
- B. Drinking Fountains: Stainless steel, two level, wall mounted.
  - 1. Stainless-Steel Drinking Fountains:
    - a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- 1) Elkay Manufacturing Co.
  - 2) Haws Corporation.
2. Standards:
- a. Comply with ASME A112.19.3/CSA B45.4.
  - b. Comply with NSF 61 Annex G.
3. Type Receptor: With back.
  4. Receptor Shape: Rectangular.
  5. Back Panel: Stainless-steel wall plate behind drinking fountain.
  6. Bubblers: Two, with adjustable stream regulator, located on deck.
  7. Control: Push button.
  8. Drain: Grid type with NPS 1-1/4 (DN 32) tailpiece.
  9. Supply: NPS 3/8 (DN 10) with shutoff valve.
  10. Waste Fitting: ASME A112.18.2/CSA B125.2, NPS 1-1/4 (DN 32) chrome-plated brass P-trap and waste.
  11. Support: ASME A112.6.1M, Type III lavatory carrier.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine roughing-in for water-supply and sanitary drainage and vent piping systems to verify actual locations of piping connections before fixture installation.
- B. Examine walls and floors for suitable conditions where fixtures will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 INSTALLATION

- A. Install fixtures level and plumb according to roughing-in drawings. For fixtures indicated for children, install at height required by authorities having jurisdiction.
- B. Set pedestal drinking fountains on floor.
- C. Install recessed drinking fountains secured to wood blocking in wall construction.
- D. Install off-the-floor carrier supports, affixed to building substrate, for wall-mounted fixtures.
- E. Install water-supply piping with shutoff valve on supply to each fixture to be connected to domestic-water distribution piping. Use ball or gate valve. Install valves in locations where they can be easily reached for operation. Valves are specified in Section 220523.12 "Ball Valves for Plumbing Piping" and Section 220523.15 "Gate Valves for Plumbing Piping."

- F. Install trap and waste piping on drain outlet of each fixture to be connected to sanitary drainage system.
- G. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations. Use deep-pattern escutcheons where required to conceal protruding fittings. Comply with escutcheon requirements specified in Section 220518 "Escutcheons for Plumbing Piping."
- H. Seal joints between fixtures and walls using sanitary-type, one-part, mildew-resistant, silicone sealant. Match sealant color to fixture color. Comply with sealant requirements specified in Section 079200 "Joint Sealants."

### 3.3 CONNECTIONS

- A. Connect fixtures with water supplies, stops, and risers, and with traps, soil, waste, and vent piping. Use size fittings required to match fixtures.
- B. Comply with water piping requirements specified in Section 221116 "Domestic Water Piping."
- C. Install ball or gate shutoff valve on water supply to each fixture. Comply with valve requirements specified in Section 220523.12 "Ball Valves for Plumbing Piping" and Section 220523.15 "Gate Valves for Plumbing Piping."
- D. Comply with soil and waste piping requirements specified in Section 221316 "Sanitary Waste and Vent Piping."

### 3.4 ADJUSTING

- A. Adjust fixture flow regulators for proper flow and stream height.

### 3.5 CLEANING

- A. After installing fixtures, inspect unit. Remove paint splatters and other spots, dirt, and debris. Repair damaged finish to match original finish.
- B. Clean fixtures, on completion of installation, according to manufacturer's written instructions.
- C. Provide protective covering for installed fixtures.
- D. Do not allow use of fixtures for temporary facilities unless approved in writing by Owner.

END OF SECTION 224713