

State of California
Well Completion Report
 WCR Form Submitted 11/09/2016
 WCR2016-007759

Owner's Well Number D00234 Date Work Began 05/23/2016 Date Work Ended 10/14/2016
 Local Permit Agency Environmental Health Services of Monterey County
 Secondary Permit Agency _____ Permit Number 15-12608 Permit Date 02/25/2015

Well Owner (must remain confidential pursuant to Water Code 13752)

Name NADER DALIRI
 Mailing Address 12173 SADDLE ROAD
 City CARMEL VALLEY State CA Zip 93924

Planned Use and Activity

Activity New Well
 Planned Use Water Supply Domestic

Well Location

Address 12173 SADDLE RD. APN 416-122-036-000
 City CARMEL VALLEY Zip 93924 County Monterey Township 16 S
 Range 02 E
 Section 09
 Latitude _____ N Longitude _____ W
 Deg. Min. Sec. Deg. Min. Sec.
 Baseline Meridian Mount Diablo
 Dec. Lat. 38.5482810 Dec. Long. -121.7565447
 Ground Surface Elevation _____
 Vertical Datum _____ Horizontal Datum WGS84 Elevation Accuracy _____
 Location Accuracy _____ Location Determination Method _____ Elevation Determination Method _____

Borehole Information

Orientation Vertical Specify _____
 Drilling Method Direct Rotary Drilling Fluid Bentonite
 Total Depth of Boring 1260 Feet
 Total Depth of Completed Well 1180 Feet

Water Level and Yield of Completed Well

Depth to first water 840 (Feet below surface)
 Depth to Static _____
 Water Level 879 (Feet) Date Measured 10/11/2016
 Estimated Yield* 3 Test Type Pump
 Test Length 72 Total Drawdown 42 (Feet)
 *May not be representative of a well's long term yield.

Geologic Log - Free Form

Depth from Surface Feet to Feet	Description
0 - 10	Top soil
10 - 130	Sandstone
130 - 990	Shale
990 - 1030	Decomposed granite & shale
1030 - 1260	Decomposed granite

Casings

Casing #	Depth from Surface Feet to Feet	Casing Type	Material	Casings Specifications	Well Thickness (Inches)	Outside Diameter (Inches)	Screen Type	Slot Size if any (Inches)	Description
1	0 - 800	Blank	Low Carbon Steel	Grade: ASTM A53	0.188	6.563			
1	800 - 1180	Screen	Low Carbon Steel	Grade: ASTM A53	0.188	5.563	Milled Slots	0.25	

Annular Material

Depth from Surface Feet to Feet	Fill	Fill Type Details	Filter Pack Size	Description
0 - 80	Cement	10.3 Sack Mix		
90 - 1260	Filter Pack	8 x 16		

Other Observations:

