

State of California
Well Completion Report
 Form DWR 188 Submitted 2/8/2024
 WCR2024-001190

Owner's Well Number DA-1 Date Work Began _____ Date Work Ended 11/10/2023
 Local Permit Agency Environmental Health Services of Monterey County
 Secondary Permit Agency _____ Permit Number 23-SEA24-000037 Permit Date 09/10/2023

Well Owner (must remain confidential pursuant to Water Code 13752)	Planned Use and Activity
Name <u>SALINAS VALLEY BASIN GROUNDWATER SUSTAINABILITY AGENCY,</u>	Activity <u>New Well</u>
Mailing Address <u>1441 Schilling Pl</u>	Planned Use <u>Monitoring</u>
City <u>Salinas</u> State <u>CA</u> Zip <u>93901</u>	

Well Location	
Address _____	APN <u>207201001000</u>
City _____ Zip _____ County <u>Monterey</u>	Township <u>15 S</u>
Latitude <u>36 38 51.248</u> N Longitude <u>-121 42 6.6117</u> W	Range <u>02 E</u>
Deg. Min. Sec. Deg. Min. Sec.	Section <u>12</u>
Dec. Lat. <u>36.6475689</u> Dec. Long. <u>-121.7018366</u>	Baseline Meridian <u>Mount Diablo</u>
Vertical Datum _____ Horizontal Datum <u>WGS84</u>	Ground Surface Elevation _____
Location Accuracy _____ Location Determination Method _____	Elevation Accuracy _____
	Elevation Determination Method _____

Borehole Information	
Orientation <u>Vertical</u> Specify _____	
Drilling Method <u>Direct Rotary</u> Drilling Fluid <u>Bentonite</u>	
Total Depth of Boring <u>1400</u> Feet	
Total Depth of Completed Well <u>1010</u> Feet	

Water Level and Yield of Completed Well	
Depth to first water _____ (Feet below surface)	
Depth to Static _____	
Water Level _____ (Feet) Date Measured _____	
Estimated Yield* _____ (GPM) Test Type _____	
Test Length _____ (Hours) Total Drawdown _____ (feet)	
*May not be representative of a well's long term yield.	

Geologic Log - Free Form		
Depth from Surface	Feet to Feet	Description
0	10	Sand; redish brown sand, loose, moist
10	60	Sand; brown, vf-fgr, loose, wet, subangular-subrounded grs
60	170	Sand; grey, vf gr, loose, wet, subrounded grs
170	520	Sand; tan, loose, wet
520	760	Clayey sand; tan, loose, wet, sun-angular-rounded
760	1050	Sandy clay; tan, vf-coarse gr sand, loose, moist
1050	1210	Silty sandy clay to sandy clay; tan, loose, wet
1210	1260	Silt; brown, fine grain, loose, no plasticity
1260	1320	Sandy Clay; brown, vf-fgr sand, loose
1320	1400	Sandy silt; tan, vfgr, loose, v well sorted, no plasticity

Casings										
Casing #	Depth from Surface Feet to Feet		Casing Type	Material	Casings Specificatons	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	900	Blank	PVC	OD: 4.500 in. Thickness: 0.337 in.	0.337	4.5			
1	900	1000	Screen	PVC	OD: 4.500 in. Thickness: 0.337 in.	0.337	4.5	Saw Cut	0,04	
1	1000	1010	Other: Well Cellar	PVC	OD: 4.500 in. Thickness: 0.337 in.	0.337	4.5			

Annular Material					
Depth from Surface Feet to Feet		Fill	Fill Type Details	Filter Pack Size	Description
0	50	Cement	10.3 Sack Mix		
50	935	Bentonite	High Solids		Hydrated Bentonite
935	940	Other Fill	See description.		#60 Plaster Sand Transition
940	1015	Filter Pack	8 x 20		
1015	1400	Bentonite	High Solids		Hydrated Bentonite

Other Observations:

Borehole Specifications		
Depth from Surface Feet to Feet		Borehole Diameter (inches)
0	1400	10.625

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief			
Name	GREGG DRILLING LLC, Tim Boyd		
	Person, Firm or Corporation		
	2726 WALNUT AVE	SIGNAL HILL	CA 90755
	Address	City	State Zip
Signed	<i>electronic signature received</i>	02/08/2024	1044456
	C-57 Licensed Water Well Contractor	Date Signed	C-57 License Number

Attachments	
DA-1_lithology.xlsx - Geologic Log	
da-1_for_construction_10082023.pdf - Well Construction Diagram	

DWR Use Only			
CSG #	State Well Number	Site Code	Local Well Number
		N	W
Latitude Deg/Min/Sec		Longitude Deg/Min/Sec	
TRS:			
APN:			

State of California
Well Completion Report
 Form DWR 188 Submitted 2/8/2024
 WCR2024-001194

Owner's Well Number DA-3 Date Work Began _____ Date Work Ended 10/20/2023
 Local Permit Agency Environmental Health Services of Monterey County
 Secondary Permit Agency _____ Permit Number 23-SEA24-000035 Permit Date 09/10/2023

Well Owner (must remain confidential pursuant to Water Code 13752)	Planned Use and Activity
Name <u>SALINAS VALLEY BASIN GROUNDWATER SUSTAINABILITY AGENCY,</u>	Activity <u>New Well</u>
Mailing Address <u>1441 Schilling Pl</u>	Planned Use <u>Monitoring</u>
City <u>Salinas</u> State <u>CA</u> Zip <u>93901</u>	

Well Location	
Address <u>14665 Blackie RD</u>	APN _____
City <u>Salinas</u> Zip <u>93907</u> County <u>Monterey</u>	Township <u>13 S</u>
Latitude <u>36 46 20.9855 N</u> Longitude <u>-121 43 6.3443 W</u>	Range <u>02 E</u>
Deg. Min. Sec. Deg. Min. Sec.	Section <u>26</u>
Dec. Lat. <u>36.772496</u> Dec. Long. <u>-121.718429</u>	Baseline Meridian <u>Mount Diablo</u>
Vertical Datum _____ Horizontal Datum <u>WGS84</u>	Ground Surface Elevation _____
Location Accuracy _____ Location Determination Method _____	Elevation Accuracy _____
	Elevation Determination Method _____

Borehole Information	
Orientation <u>Vertical</u> Specify _____	
Drilling Method <u>Direct Rotary</u> Drilling Fluid <u>Bentonite</u>	
Total Depth of Boring <u>1300</u> Feet	
Total Depth of Completed Well <u>1210</u> Feet	

Water Level and Yield of Completed Well	
Depth to first water _____ (Feet below surface)	
Depth to Static _____	
Water Level _____ (Feet) Date Measured _____	
Estimated Yield* _____ (GPM) Test Type _____	
Test Length _____ (Hours) Total Drawdown _____ (feet)	
*May not be representative of a well's long term yield.	

Geologic Log - Free Form		
Depth from Surface	Feet to Feet	Description
0	20	Sandy Clay: Redish brown, loose, fine grained sand, sub rounded- rounded grains, very well sorted with moderate plasticity clay
20	30	Sandy Silt: Redish brown, loose, very fine grained sand, subrounded - rounded grains, very well sorted with silt
30	300	Sand; redish brown to tan, loose, fine grained
300	420	Silt and Sand layers; tan and brown, very fine grained, loose
420	690	Sandy Clay; tan, loose, very fine grained
690	840	Sandy Clay; redish brown, loose, very fine grained, very well sorted
840	990	Sand; brown, loose, very fine grained, well sorted
990	1110	Silt: Tan, loose, extremely fine grained, soft, no plasticity and Sand: Brown, loose, very fine grained, subrounded - rounded, very well sorted
1110	1290	Sandy Silt: tan, soft, very fine grained, angular - rounded grains, well sorted with silt
1290	1300	Silt: Tan, loose, extremely fine grained, soft, no plasticity

Casings										
Casing #	Depth from Surface Feet to Feet		Casing Type	Material	Casings Specificatons	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	1150	Blank	PVC	OD: 4.500 in. Thickness: 0.337 in.	0.337	4.5			
1	1150	1200	Screen	PVC	OD: 4.500 in. Thickness: 0.337 in.	0.337	4.5	Saw Cut	0,04	
1	1200	1210	Other: Well Cellar	PVC	OD: 4.500 in. Thickness: 0.337 in.	0.337	4.5			

Annular Material					
Depth from Surface Feet to Feet		Fill	Fill Type Details	Filter Pack Size	Description
0	50	Cement	10.3 Sack Mix		
50	1130	Bentonite	High Solids		Hydrated Bentonite
1130	1135	Other Fill	See description.		#60 Plaster Sand Transition
1135	1215	Filter Pack	8 x 20		
1215	1300	Bentonite	High Solids		Hydrated Bentonite

Other Observations:

Borehole Specifications		
Depth from Surface Feet to Feet		Borehole Diameter (inches)
0	1300	10.625

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief			
Name	GREGG DRILLING LLC, Tim Boyd		
	Person, Firm or Corporation		
	2726 WALNUT AVE	SIGNAL HILL	CA 90755
	Address	City	State Zip
Signed	<i>electronic signature received</i>	02/08/2024	1044456
	C-57 Licensed Water Well Contractor	Date Signed	C-57 License Number

Attachments	
DA-3 lithology.xlsx - Geologic Log	
da-3_final_design_10302023.pdf - Well Construction Diagram	

DWR Use Only			
CSG #	State Well Number	Site Code	Local Well Number
		N	W
Latitude Deg/Min/Sec		Longitude Deg/Min/Sec	
TRS:			
APN:			

State of California
Well Completion Report
 Form DWR 188 Submitted 2/8/2024
 WCR2024-001186

Owner's Well Number ISW-1 Date Work Began _____ Date Work Ended 11/10/2023
 Local Permit Agency Environmental Health Services of Monterey County
 Secondary Permit Agency _____ Permit Number 23-SEA24-000032 Permit Date 09/10/2023

Well Owner (must remain confidential pursuant to Water Code 13752)	Planned Use and Activity
Name <u>SALINAS VALLEY BASIN GROUNDWATER SUSTAINABILITY AGENCY,</u>	Activity <u>New Well</u>
Mailing Address <u>1411 Schilling Pl</u>	Planned Use <u>Monitoring</u>
City <u>Salinas</u> State <u>CA</u> Zip <u>93901</u>	

Well Location	
Address <u>0 Laguna RD</u>	APN _____
City <u>Salinas</u> Zip <u>93908</u> County <u>Monterey</u>	Township <u>15 S</u>
Latitude <u>36 35 57.1632 N</u> Longitude <u>-121 37 0.9731 W</u>	Range <u>03 E</u>
Deg. Min. Sec. Deg. Min. Sec.	Section <u>26</u>
Dec. Lat. <u>36.599212</u> Dec. Long. <u>-121.616937</u>	Baseline Meridian <u>Mount Diablo</u>
Vertical Datum _____ Horizontal Datum <u>WGS84</u>	Ground Surface Elevation _____
Location Accuracy _____ Location Determination Method _____	Elevation Accuracy _____
	Elevation Determination Method _____

Borehole Information	
Orientation <u>Vertical</u> Specify _____	
Drilling Method <u>Direct Rotary</u> Drilling Fluid <u>Bentonite</u>	
Total Depth of Boring <u>200</u> Feet	
Total Depth of Completed Well <u>95</u> Feet	

Water Level and Yield of Completed Well	
Depth to first water _____ (Feet below surface)	
Depth to Static _____	
Water Level _____ (Feet) Date Measured _____	
Estimated Yield* _____ (GPM) Test Type _____	
Test Length _____ (Hours) Total Drawdown _____ (feet)	
*May not be representative of a well's long term yield.	

Geologic Log - Free Form		
Depth from Surface	Feet to Feet	Description
0	90	Sand; brown, very fine grained, subrounded-rounded grains, very well sorted, loose
90	180	Gravelly sand; brown, fine-coarse grained, angular-rounded grains, poor-moderately sorted, loose, w/ gravel
180	200	Clayey sand; tan, vf-medium grained, angular-rounded grains, poor-moderately sorted, loose, w/ moderate plasticity clay

Casings										
Casing #	Depth from Surface Feet to Feet		Casing Type	Material	Casings Specificatons	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	35	Blank	PVC	OD: 4.500 in. Thickness: 0.337 in.	0.337	4.5			
1	35	85	Screen	PVC	OD: 4.500 in. Thickness: 0.337 in.	0.337	4.5	Saw Cut	0,04	
1	85	95	Other: Well Cellar	PVC	OD: 4.500 in. Thickness: 0.337 in.	0.337	4.5			

Annular Material					
Depth from Surface Feet to Feet		Fill	Fill Type Details	Filter Pack Size	Description
0	20	Cement	10.3 Sack Mix		
20	25	Bentonite	High Solids		Hydrated Bentonite
25	100	Filter Pack	8 x 20		
100	200	Bentonite	High Solids		Hydrated Bentonite

Other Observations:

Borehole Specifications		
Depth from Surface Feet to Feet		Borehole Diameter (inches)
0	200	10.625

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief			
Name	GREGG DRILLING LLC, Tim Boyd		
	Person, Firm or Corporation		
2726 WALNUT AVE	SIGNAL HILL	CA	90755
Address	City	State	Zip
Signed	<i>electronic signature received</i>	02/08/2024	1044456
	C-57 Licensed Water Well Contractor	Date Signed	C-57 License Number

Attachments
ISW-1 lithology.xlsx - Geologic Log
isw-1_final_design_11132023.pdf - Well Construction Diagram

DWR Use Only			
CSG #	State Well Number	Site Code	Local Well Number
		N	W
Latitude Deg/Min/Sec		Longitude Deg/Min/Sec	
TRS:			
APN:			