



# County of Monterey

Board of Supervisors  
Chambers  
168 W. Alisal St., 1st Floor  
Salinas, CA 93901

## Board Report

---

**File #:** A 13-193, **Version:** 1

---

Authorize the Purchasing Manager for Natividad Medical Center (NMC) to execute Renewal and Amendment No. 4 to the Agreement (A-12060) with Certified Medical Testing for Repair, Maintenance and Testing of Medical Gas System Services at NMC, extending the Agreement to June 30, 2014 and adding \$20,000 for a revised total Agreement amount not to exceed \$150,000 in the aggregate.

RECOMMENDATION:

It is recommended the Board of Supervisors authorize the Purchasing Manager for Natividad Medical Center (NMC) to execute Renewal and Amendment No. 4 to the Agreement (A-12060) with Certified Medical Testing for Repair, Maintenance and Testing of Medical Gas System Services at NMC, extending the Agreement to June 30, 2014 and adding \$20,000 for a revised total Agreement amount not to exceed \$150,000 in the aggregate.

SUMMARY/DISCUSSION:

Certified Medical Testing possesses the certification and expertise for fume hood and chemotherapy hood certification, waste anesthesia gas and glutaraldehyde monitoring, radiation badge monitoring, anesthetizing location air change measurement, and maintenance and testing on medical oxygen, medical air, nitrous oxide, nitrogen, and medical vacuum systems. Maintenance, testing, and repairs are required by the Joint Commission and the National Fire Protection Association.

OTHER AGENCY INVOLVEMENT:

County Counsel has reviewed and approved this Renewal and Amendment No. 4 as to legal form and risk provisions. Auditor-Controller has reviewed and approved this Renewal and Amendment No. 4 as to fiscal provisions. The Renewal and Amendment No. 4 has also been reviewed and approved by Natividad Medical Center's Board of Trustees.

FINANCING:

The cost for this Renewal and Amendment No. 4 is \$20,000 and is included in the Fiscal Year 2013/2014 Adopted Budget. There is no impact to the General Fund.

Prepared by: James Kari, Hospital Director of Engineering and Safety, 783-2602

Approved by: Harry Weis, Chief Executive Officer, 783-2553

Attachments: Renewal and Amendment No. 4, Original Agreement, Amendments 1, 2, and 3, Spend Sheet  
Attachments on file with the Clerk to the Boards Office