

Exhibit H

This page intentionally left blank.



511 Forest Lodge Road
Suite 100
Pacific Grove, CA 93950
www.amwater.com

P: 831.646.3241
C: 831.277.2405

April 25, 2022

Coastal Investment Enterprise LLC
c/o Eric Ellis, Paul Parker & Will Tucker
385 Dante Lane
Templeton, California 93465

Owner: Eric Ellis, Paul Parker & Will Tucker
Service Address: End of Center Street, Carmel Valley, California 93923
(Property is Undeveloped)
Assessor's Parcel Number: 169-131-024

To Whom It May Concern:

This letter serves as notification that the above-referenced property (the "Service Address") is in California-American Water Company's ("California American Water") water service area. California American Water will provide private fire protection service to the Service Address pursuant to the rules, regulations and tariffs of the California Public Utilities Commission ("CPUC") and in accordance with all applicable federal, state and local laws, regulation, rules, ordinances, orders, and restrictions, including those of the Monterey Peninsula Water Management District ("MPWMD") and the California State Water Resources Control Board ("SWRCB").

If you wish to initiate private fire protection service (the "Applicant"), you must comply with all California America Water Tariff Schedules on file with the CPUC and as they may be amended from time to time. Among other things, the Tariff Schedules require you submit an application to California American Water, obtain all required permits (which may include a water permit from MPWMD), and pay all required fees as a condition of initiation of service. California American Water's Tariff Schedules are available on its website, www.amwater.com/caaw/. Availability of private fire protection service to the Service Address is subject to change before applicants apply for private fire protection service and receive all required permits, approvals, and pay all applicable fees required to initiate such service

Sincerely,

Chris Cook, PE
Director of Operations
Central Division
P: 831-646-3241
C: 831-277-2405
E: Christopher.Cook@amwater.com

Will Tucker (williamtuckerinc@gmail.com) Paul Parker (paul@parkerandsander.com)
Rick Riedl (rickr@wallacegroup.us)



FIRE HYDRANT FLOW INFORMATION

Date Flowed: 2/14/2022

Flowed By: Paul Rappa

Flow Hydrant No.: HCR-1479
Location: 9500 Center Street & Berwick Dr, Carmel

Static Pressure	102	psi
Pito Pressure	51	psi
Outlet Size	2.5	inches

Qob = 1198.3 gpm

$$Q_{ob} = (29.83 \times .9) \times (\text{Outlet Diameter}^2) \times (\sqrt{P_{ito}})$$

Residual Hydrant No.: HCR-1277
Location: Berwick Drive & Dorris Drive

Static Pressure	102	psi
Residual Pressure	45	psi

Q20 = 1437.2 gpm

$$Q_{20} = Q_{ob} \sqrt{\frac{\text{Sta} - 20}{\text{Sta} - \text{Res}}}$$

Note: All numbers are approximate.

FIRE HYDRANT FLOW INFORMATION

<input checked="" type="checkbox"/> Q @ X
<input type="checkbox"/> Q @ 20

Note: All numbers are approximate.

This page intentionally left blank