

GENERAL NOTES - FLOOR PLAN

- A. ALL INTERIOR PARTITIONS SHALL BE "A3_" UNLESS NOTED OTHERWISE. B. PLAN DIMENSIONS ARE FROM FACE OF PARTITION TYPE AND DO NOT INCLUDE APPLIED FINISHES, UNLESS NOTED OTHERWISE. PLAN DIMENSIONS INDICATED AS "HOLD" OR "CLEAR" DIMENSIONS ARE FROM FACE OF APPLIED FINISH.
- C. INSTALL WORK STRAIGHT, PLUMB, LEVEL, SQUARE, AND TRUE, IN PROPER ALIGNMENT D. FLATNESS: LEVEL FLOORS TO TRUE PLANE WITHIN 1/4 INCH (6 MM) IN 10'-0" (3 M) WHEN TESTED BY TEN FOOT (3 M) STRAIGHTEDGE PLACED ANYWHERE ON FLOOR IN ANY
- E. BEFORE PROCEEDING WITH PARTITION FRAMING, PROVIDE LAYOUT MARKINGS OF PARTITIONS AND ASSOCIATED IN-WALL ELECTRICAL DEVICES ON SUBFLOOR FOR REVIEW BY ARCHITECT. BEFORE PROCEEDING WITH PARTITION FRAMING, PROVIDE LAYOUT MARKINGS OF PARTITIONS AND ASSOCIATED IN-WALL ELECTRICAL DEVICES ON SUBFLOOR FOR REVIEW BY ARCHITECT.
- F. COORDINATE FURNITURE-RELATED ELECTRICAL LAYOUT WITH FURNITURE VENDOR. G. WHERE HANDRAILS, GRAB BARS, CABINETS, WALL-MOUNTED DOOR STOPS, OR OTHER WALL-HUNG ITEMS ARE ATTACHED TO PARTITIONS, INSTALL BACKER PLATES [OR WOOD BLOCKING | ACCURATELY POSITIONED AND FIRMLY SECURED TO METAL STUDS, WHETHER OR NOT SUCH BACKER PLATES OR BLOCKING ARE INDICATED ON DRAWINGS.
- H. WHERE NEW WORK ABUTS, ALIGNS OR ADJOINS EXISITING MATERIALS, MAKE SMOOTH AND EVEN TRANSITION AND ELIMINATE EVIDENCE OF PATCHING AND REFINISHING. FINISH NEW WORK TO MATCH ADJACENT UNDISTURBED SURFACES, UNLESS NOTED
- OTHERWISE I. CLOSE AND PATCH HOLES AND OPENINGS IN EXISTING FLOOR, WALL AND CEILING WHICH EXIST OR RESULT FROM DEMOLITION OR ALTERATION WORK TO MATCH ADJACENT
- UNDISTURBED SURFACES. J. PRIOR TO CONCEALMENT OF FIRE RESISTIVE MATERIALS BY OTHER WORK, PATCH AND REPAIR AREAS OF REMOVED OR DAMAGED APPLIED FIREPROOFING. COMPLETE PATCHING AND REPAIR TO MAINTAIN EXISTING FIRE-RESISTANCE DESIGN IN ACCORDANCE WITH FIREPROOFING MANUFACTURER'S WRITTEN INSTRUCTIONS FOR CONDITIONS OF EXPOSURE AND INTENDED USE. COORDINATE TESTING AND INSPECTION
- OF ASSEMBLIES AS REQUIRED BY AUTHORITIES HAVING JURISDICTION. K. PROVIDE FIRESTOPPING OF PENETRATIONS AND VOIDS THROUGH FIRE-RATED WALL, FLOOR AND PARTITION ASSEMBLIES [AND ROOF] INCLUDING EMPTY OPENINGS AND OPENINGS CONTAINING CABLES, PIPES, DUCTS, CONDUIT AND OTHER ELEMENTS.
- L. AT SOUND-RATED PARTITION WALLS, PROVIDE CONTINUOUS BEAD OF ACOUSTICAL SEALANT AT AT JUNCTURE OF BOTH FACES OF RUNNERS OR PLATES WITH FLOOR AND CEILING CONSTRUCTION, AND WHEREVER GYPSUM BOARD ABUTS DISSIMILAR
 - AT OPENINGS AND CUTOUTS, FILL OPEN SPACES BETWEEN GYPSUM BOARD AND FIXTURES, CABINETS, DUCTS AND OTHER FLUSH OR PENETRATING ITEMS, WITH CONTINUOUS BEAD OF SEALANT.
 - SEAL SIDES AND BACKS OF ELECTRICAL BOXES TO COMPLETELY CLOSE OFF OPENINGS AND JOINTS.

~~~~~~		~~~~~
PATIENT	ROOM & BED C	OUNT
EXISTING ROOM & BED COUNT		
ROOM TYPE	# OF ROOMS	# OF BEDS
PRIVATE	20	20
SEMI-PRIVATE	8	16
TOTAL	28	36
(ACCESSIBLE ROOMS: 5)		
PROPOSED ROOM & BED COUN	<u>T</u>	
ROOM TYPE	# OF ROOMS	# OF BEDS
PRIVATE	13	13
SEMI-PRIVATE	15	30
TOTAL	28	43
(ACCESSIBLE ROOMS: 8)		

munumunum manum ma



222 Sutter Street, Suite 500 San Francisco, California 94108 Telephone 415.814.6910

> STRUCTURAL ENGINEER **BUEHLER ENGINEERING** 180 MONTGOMERY STREET. SUITE 1500,

## SAN FRANCISCO, CA 94104. 415.495.1635

MECHANICAL/PLUMBING

**ENGINEER** GLUMAC 100 MONTGOMERY STREET, SUITE 2050, SAN FRANCISCO, CA 94104 415.398.7667

**ELECTRICAL ENGINEER** INT-ELECT ENGINEERING 1487 FINCH LANE, GILROY, CA 408.846.7171

**INTERIOR DESIGNER** 

1900 GRANT STREET, SUITE 750,

**M** Natividad

**GALLUN SNOW** 

## DENVER, CO. 80203 303.433.9500


MEDICAL CENTER

**NATIVIDAD MEDICAL** 

**MEDICAL SURGERY DEPARTMENT** 


LEVEL 3 1441 CONSTITUTION BOULEVARD

SALINAS, CA 93906 HCAI RECORD NUMBER:





**HCAI APPROVAL** 



 $\triangle$ NO DESCRIPTION DATE BC1 BACKCHECK#1 12/13/2024 BC2 BACKCHECK#2 03/14/2025 ISSUANCE HISTORY - THIS SHEET

**OVERALL** FLOOR PLAN -LEVEL 03

DATE: APRIL 16, 2024 CONSTRUCTION

© COPYRIGHT HGA ARCHITECTS AND ENGINEERS, Inc.